

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 23/May/2016 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 133.753        | 2933.736        | 1) Gujrat                      | -1.429         | -84.374         |
| 2) Hydro            | 6.258          | 224.618         | 2) Madhya Pradesh              | 14.035         | 291.947         |
| 3) Gas              | 10.112         | 236.503         | 3) Chattisgarh                 | 7.310          | 148.890         |
| <b>Total MSPGCL</b> | <b>150.123</b> | <b>3394.857</b> | 4) Maharashtra Net             | 90.503         | 2291.465        |
| B) 1) APMIL         | 12.703         | 708.541         | 5) Goa (Amona)                 | -1.190         | -16.076         |
| 2) JSWEL            | 26.982         | 620.836         | 6) TAPS 1&2 Injection          | 3.427          | 47.958          |
| 3) VIPL             | 10.109         | 281.997         | 7) RGPPL Injection             | 11.649         | 266.479         |
| 4) RPL(AMT)         | 14.091         | 377.600         | 8) Pench (MS)                  | 0.015          | 0.737           |
| 5) WPCL             | 2.756          | 66.328          | 9) Pench (Excess)              | -0.015         | -0.737          |
| 6) Other IPP        | 5.239          | 120.607         | <b>Total</b>                   | <b>124.290</b> | <b>2945.552</b> |
| C) 1) TPCL Thermal  | 15.653         | 357.840         | a) Mumbai Schedule             | 24.829         | 565.025         |
| 2) TPCL Hydro       | 2.684          | 62.309          | b) Mumbai Drawl                | 35.421         | 711.784         |
| 3) TPCL Gas         | 4.418          | 90.720          | c) MSEDCL Bilateral *          | 38.669         | 757.737         |
| 4) R-INFRA Thermal  | 11.183         | 254.146         | Include PX                     | 0.000          | -4.914          |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 24.829         | 565.025         |
| 1) Thermal          | 232.469        | 5721.631        | Include PX                     | 3.647          | 60.273          |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.000          | 0.000           |
| 2) Hydro            | 8.942          | 286.927         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas              | 14.530         | 327.223         | 1) MSEDCL                      | 356.668        | 8282.646        |
| 4) Wind             | 44.397         | 447.553         | 2) Mumbai Discoms              | 69.359         | 1476.769        |
| 6) SOLAR            | 1.399          | 30.559          | <b>TOTAL STATE</b>             | <b>426.027</b> | <b>9759.415</b> |
| <b>TOTAL STATE</b>  | <b>301.737</b> | <b>6813.893</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 5 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5644                      | 6100                  | 5622                      | 5198                      |
| MSPGCL Hydro             | 803                       | 323                   | 221                       | 72                        |
| MSPGCL Gas               | 422                       | 422                   | 425                       | 439                       |
| MSPGCL Total Generation  | 6869                      | 6845                  | 6268                      | 5709                      |
| Central Sector Receipt   | 5557                      | 5884                  | 5342                      | 4697                      |
| WIND                     | 1584                      | 1539                  | 2190                      | 1807                      |
| CPP / IPP                | 3052                      | 3046                  | 2893                      | 2957                      |
| SOLAR                    | 183                       | 129                   | 0                         | 0                         |
| Exchange with Mumbai     | -1540                     | -1722                 | -1513                     | -1143                     |
| <b>MSEDCL DEMAND MET</b> | <b>15705</b>              | <b>15721</b>          | <b>15180</b>              | <b>14027</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15705                     | 15721                 | 15180                     | 14027                     |
| TPCL GENERATION          | 1319                      | 1226                  | 1022                      | 703                       |
| R-INFRA GENERATION       | 498                       | 498                   | 511                       | 403                       |
| <b>MUMBAI DEMAND</b>     | <b>3357</b>               | <b>3446</b>           | <b>3046</b>               | <b>2249</b>               |
| STATE DEMAND MET         | 19062                     | 19167                 | 18226                     | 16276                     |
| <b>STATE DEMAND</b>      | <b>19062</b>              | <b>19167</b>          | <b>18226</b>              | <b>16276</b>              |
| Frequency (Hz)           | 49.97                     | 50.05                 | 49.96                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.3 Hz at 18.03 Hrs | 49.79 Hz at 19.41 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 23/May/2016

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 3.30         | 22.34         | 147      | 125      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.59         | 35.95         | 170      | 135      |
| Unit 8             | 12.16        | 230.49        | 512      | 494      |
| <b>Total</b>       | <b>19.05</b> | <b>288.78</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 43.32         | 0        | 0        |
| Unit 3             | 3.81         | 90.44         | 165      | 140      |
| Unit 4             | 8.63         | 233.22        | 370      | 355      |
| Unit 5             | 8.69         | 230.31        | 375      | 350      |
| <b>Total</b>       | <b>21.13</b> | <b>597.29</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.18         | 99.23         | 200      | 163      |
| Unit 4             | 4.01         | 98.31         | 190      | 152      |
| Unit 5             | 9.25         | 175.86        | 455      | 355      |
| Unit 6             | 9.16         | 233.78        | 450      | 350      |
| Unit 7             | 9.19         | 170.30        | 447      | 360      |
| <b>Total</b>       | <b>35.78</b> | <b>777.48</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 3.38         | 107.92        | 244      | 0        |
| Unit 4             | 5.14         | 127.54        | 255      | 190      |
| <b>Total</b>       | <b>8.52</b>  | <b>235.46</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.78         | 81.00         | 165      | 145      |
| Unit 2             | 1.92         | 86.20         | 160      | 0        |
| Unit 3             | 3.92         | 92.53         | 172      | 157      |
| Unit 4             | 4.28         | 81.28         | 191      | 167      |
| Unit 5             | 9.86         | 224.38        | 500      | 370      |
| <b>Total</b>       | <b>23.75</b> | <b>565.39</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.99         | 96.25         | 170      | 160      |
| Unit 4             | 4.00         | 88.70         | 172      | 162      |
| Unit 5             | 4.01         | 96.26         | 178      | 164      |
| <b>Total</b>       | <b>12.00</b> | <b>281.21</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.11        | 236.50        | 439      | 410      |
| <b>Total</b>       | <b>10.11</b> | <b>236.50</b> |          |          |

| Generating unit   | Generation   |                |          |          |
|-------------------|--------------|----------------|----------|----------|
|                   | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |              |                |          |          |
| Pench (MS)        | 0.02         | 0.74           | 11       | 0        |
| <b>Total</b>      | <b>0.02</b>  | <b>0.74</b>    |          |          |
| <b>Koyna</b>      |              |                |          |          |
| Stage 1-2         | 2.16         | 73.18          | 215      | 40       |
| Stage 4           | 0.55         | 65.26          | 185      | 0        |
| Stage 3           | 0.56         | 31.43          | 160      | 0        |
| <b>Total</b>      | <b>3.27</b>  | <b>169.86</b>  |          |          |
| <b>Hydro</b>      |              |                |          |          |
| KDPH              | 0.48         | 11.57          | 20       | 20       |
| VTRNA             | 0.00         | 0.29           | 0        | 0        |
| TILLARI           | 0.42         | 7.25           | 62       | 0        |
| BHTGR/VEER        | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.08         | 3.64           | 70       | 0        |
| RNGR+BHTSA        | 0.21         | 3.71           | 9        | 8        |
| BHANDARDRA        | 0.10         | 3.17           | 34       | 0        |
| ELDARY            | 0.00         | 0.00           | 0        | 0        |
| SMLHY_PTN         | 0.09         | 4.00           | 4        | 3        |
| GHATGHAR          | 1.60         | 21.13          | 250      | 0        |
| <b>Total</b>      | <b>2.99</b>  | <b>54.76</b>   |          |          |
| <b>Wind</b>       |              |                |          |          |
| Total             | 44.40        | 447.55         | 0        | 0        |
| <b>Total</b>      | <b>44.40</b> | <b>447.55</b>  |          |          |
| <b>CPP</b>        |              |                |          |          |
| APML(Mus)         | 12.70        | 708.54         | 0        | 0        |
| JSWEL(Mus)        | 26.98        | 620.84         | 0        | 0        |
| VIPL(Mus)         | 10.11        | 282.00         | 0        | 0        |
| RPLAMT(Mus)       | 14.09        | 377.60         | 0        | 0        |
| WPCL(Mus)         | 2.76         | 66.33          | 0        | 0        |
| Other(Mus)        | 5.24         | 120.61         | 0        | 0        |
| <b>Total</b>      | <b>71.88</b> | <b>2175.91</b> |          |          |
| <b>SOLAR</b>      |              |                |          |          |
| Total             | 1.40         | 30.56          | 0        | 0        |
| <b>Total</b>      | <b>1.40</b>  | <b>30.56</b>   |          |          |
| <b>Tata</b>       |              |                |          |          |
| Trombay 5         | 10.10        | 226.39         | 497      | 319      |
| Trombay 6         | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A        | 2.83         | 58.16          | 124      | 114      |
| Trombay 7B        | 1.59         | 32.56          | 69       | 65       |
| Trombay 8         | 5.55         | 131.45         | 250      | 203      |
| TATA Hydro        | 2.68         | 62.31          | 383      | 0        |
| <b>Total</b>      | <b>22.76</b> | <b>510.87</b>  |          |          |
| <b>R-INFRA</b>    |              |                |          |          |
| 1-2               | 11.18        | 254.15         | 513      | 401      |
| <b>Total</b>      | <b>11.18</b> | <b>254.15</b>  |          |          |

| * Infirm Power |             |         |
|----------------|-------------|---------|
| Particulars    | Daily (Mus) | Monthly |
| Chandrapur 8   | 0.50        | 0.50    |
| Chandrapur 9   | 0.00        | 1.92    |
| Koradi 9       | 13.03       | 185.71  |
| Parli 8        | 0.00        | 0.00    |

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 133.75      | 2933.74       |
| MSPGCL Thml+Gas | 143.86      | 3170.24       |
| MSPGCL Hydro    | 6.26        | 224.62        |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| MSPGCL Total        | 150.12      | 3394.86       |
| Koyna 1,2 & 4 Total | 2.71        | 138.43        |
| State Total         | 301.74      | 6813.89       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 23/May/2016

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |       | TOTAL  | WIND  | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|-------|--------|-------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS   |        |       |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5195        | 191  | 423   | 5809   | 2143  | 2880         | 0     | 4862        | 5277        | -1634                | 14475                 | 0                    | 14475                     | 2769             | 17244           | 49.96         |
| 2                  | 5203        | 211  | 415   | 5829   | 2184  | 2958         | 0     | 4687        | 4855        | -1474                | 14352                 | 0                    | 14352                     | 2578             | 16930           | 49.98         |
| 3                  | 5209        | 77   | 426   | 5712   | 2017  | 2958         | 0     | 4570        | 4664        | -1315                | 14036                 | 0                    | 14036                     | 2423             | 16459           | 49.99         |
| 4                  | 5210        | 72   | 423   | 5705   | 1856  | 2959         | 0     | 4488        | 4792        | -1208                | 14104                 | 0                    | 14104                     | 2314             | 16418           | 50.00         |
| 5                  | 5198        | 72   | 439   | 5709   | 1807  | 2957         | 0     | 4474        | 4697        | -1143                | 14027                 | 0                    | 14027                     | 2249             | 16276           | 49.98         |
| 6                  | 5342        | 153  | 417   | 5912   | 1618  | 2985         | 0     | 4906        | 5124        | -1154                | 14485                 | 0                    | 14485                     | 2259             | 16744           | 50.00         |
| 7                  | 5487        | 198  | 427   | 6112   | 1433  | 3055         | 8     | 5097        | 5051        | -1078                | 14581                 | 0                    | 14581                     | 2187             | 16768           | 50.02         |
| 8                  | 5640        | 93   | 427   | 6160   | 1730  | 3063         | 39    | 5177        | 4996        | -1228                | 14760                 | 0                    | 14760                     | 2336             | 17096           | 50.05         |
| 9                  | 5609        | 214  | 435   | 6258   | 1646  | 3041         | 90    | 5380        | 5248        | -1487                | 14796                 | 0                    | 14796                     | 2603             | 17399           | 50.07         |
| 10                 | 5377        | 387  | 415   | 6179   | 1594  | 3056         | 136   | 5249        | 5825        | -1637                | 15153                 | 0                    | 15153                     | 2906             | 18059           | 49.97         |
| 11                 | 5498        | 914  | 416   | 6828   | 1608  | 3054         | 166   | 5231        | 5581        | -1589                | 15648                 | 0                    | 15648                     | 3308             | 18956           | 49.94         |
| 12                 | 5644        | 803  | 422   | 6869   | 1584  | 3052         | 183   | 5382        | 5557        | -1540                | 15705                 | 0                    | 15705                     | 3357             | 19062           | 49.97         |
| 13                 | 5645        | 492  | 412   | 6549   | 1607  | 3022         | 188   | 5389        | 5306        | -1639                | 15033                 | 0                    | 15033                     | 3423             | 18456           | 49.98         |
| 14                 | 5633        | 222  | 422   | 6277   | 1627  | 3038         | 180   | 5357        | 5833        | -1654                | 15301                 | 0                    | 15301                     | 3364             | 18665           | 50.01         |
| 15                 | 5866        | 394  | 412   | 6672   | 1462  | 3036         | 156   | 5371        | 5629        | -1712                | 15243                 | 0                    | 15243                     | 3437             | 18680           | 50.01         |
| 16                 | 6100        | 323  | 422   | 6845   | 1539  | 3046         | 129   | 5409        | 5884        | -1722                | 15721                 | 0                    | 15721                     | 3446             | 19167           | 50.05         |
| 17                 | 5982        | 160  | 418   | 6560   | 1953  | 3037         | 83    | 5174        | 5295        | -1682                | 15246                 | 0                    | 15246                     | 3402             | 18648           | 50.03         |
| 18                 | 5678        | 78   | 410   | 6166   | 2179  | 2940         | 34    | 4791        | 4925        | -1604                | 14640                 | 0                    | 14640                     | 3221             | 17861           | 50.13         |
| 19                 | 5602        | 73   | 415   | 6090   | 2177  | 2879         | 7     | 4803        | 4381        | -1494                | 14040                 | 0                    | 14040                     | 3060             | 17100           | 50.11         |
| 20                 | 5622        | 221  | 425   | 6268   | 2190  | 2893         | 0     | 5045        | 5342        | -1513                | 15180                 | 0                    | 15180                     | 3046             | 18226           | 49.96         |
| 21                 | 5675        | 236  | 425   | 6336   | 2201  | 3004         | 0     | 4853        | 5224        | -1517                | 15248                 | 0                    | 15248                     | 2978             | 18226           | 50.05         |
| 22                 | 5639        | 78   | 425   | 6142   | 2144  | 2991         | 0     | 4864        | 4920        | -1395                | 14802                 | 0                    | 14802                     | 2828             | 17630           | 50.03         |
| 23                 | 5644        | 260  | 415   | 6319   | 2148  | 2966         | 0     | 5059        | 5044        | -1476                | 15001                 | 0                    | 15001                     | 2906             | 17907           | 49.80         |
| 24                 | 6055        | 336  | 426   | 6817   | 1950  | 3009         | 0     | 5221        | 4840        | -1526                | 15090                 | 0                    | 15090                     | 2959             | 18049           | 49.96         |
| MUs                | 133.75      | 6.26 | 10.11 | 150.12 | 44.40 | 71.88        | 1.40  | 120.84      | 124.29      | -35.42               | 356.67                | 0.00                 | 356.67                    | 69.36            | 426.03          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 23/May/2016**

**Position as on 6.30 Hrs of 24/May/2016**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                  | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                   |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 10/09/2015   | 12.55        |            | Continued. | Refuelling work                                                                                                   |               |
| MSPGCL                | Koyna Unit 10           | 80       | 29/12/2015   | 08:00        |            | Continued. | Annual Overhaul                                                                                                   |               |
| CENT.SECTOR           | TARAPUR-3               | 540      | 23/05/2016   | 20.30        |            | Continued. | Maintenance work                                                                                                  |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                   |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                                                                     |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                                                                      |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                                                                      |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                                                                                                       |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                                                                                                |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown                                                                                                 |               |
| MSPGCL                | Parli Unit 3            | 210      | 14/06/2015   | 12.58        |            | Continued. | Water Shortage                                                                                                    |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                                                                                                    |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                                                                                                    |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.                                                                                                   |               |
| MSPGCL                | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage                                                                                                    |               |
| RGPL                  | Dabhol 3B               | 230      | 07/01/2016   | 17:51        |            | Continued. | Change Over.                                                                                                      |               |
| MSPGCL                | Chandrapur Unit 2       | 210      | 12/01/2016   | 04.47        |            | Continued. | Boiler Tube Leakage                                                                                               |               |
| CPP                   | WPCL U-1                | 135      | 16/02/2016   | 17.09        |            | Continued. | No Schedule                                                                                                       |               |
| IPP                   | WPCL U-2                | 135      | 29/02/2016   | 21.46        |            | Continued. | Change over against Unit III                                                                                      |               |
| MSPGCL                | Koyna Unit 11           | 80       | 11/03/2016   | 13.53        |            | Continued. | stator earth fault                                                                                                |               |
| IPP                   | Adani U-3               | 660      | 20/04/2016   | 03.33        |            | Continued. | Furnace Pressure High                                                                                             |               |
| MSPGCL                | Uran Unit 8             | 108      | 02/05/2016   | 14.47        |            | Continued. | Gas shortage                                                                                                      |               |
| CPP                   | WPCL U-4                | 135      | 03/05/2016   | 00.00        |            | Continued. | ESP Back Filter DP High                                                                                           |               |
| IPP                   | Adani U-5               | 660      | 05/05/2016   | 23.09        |            | Continued. | Due to Unavailblity of Water.                                                                                     |               |
| RGPL                  | Dabhol 3X               | 290      | 07/05/2016   | 18.40        |            | Continued. | Low Vaccum                                                                                                        |               |
| RGPL                  | Dabhol 3A               | 230      | 07/05/2016   | 18.44        |            | Continued. | Low Vaccum                                                                                                        |               |
| IPP                   | Adani U-1               | 660      | 13/05/2016   | 22.53        |            | Continued. | Water Shortage                                                                                                    |               |
| IPP                   | Adani U-2               | 660      | 15/05/2016   | 00.58        |            | Continued. | Water Shortage                                                                                                    |               |
| MSPGCL                | Paras Unit 3            | 250      | 19/05/2016   | 16.24        | 23/05/2016 | 06.58      | BTL.                                                                                                              |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 20/05/2016   | 00.05        | 24/05/2016 | 02.18      | Boiler Tube Leakage & zero schedule 22.05.2016 continue                                                           |               |
| IPP                   | RPL(AMT) U-4            | 270      | 21/05/2016   | 16.15        |            | Continued. | Zero Schedule                                                                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 23/May/2016**

**Position as on 6.30 Hrs of 24/May/2016**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage          | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------|---------------|
| IPP                | RPL(AMT) U-3            | 270      | 21/05/2016   | 18.10        |            | Continued. | Zero Schedule             |               |
| MSPGCL             | Uran Unit 5             | 108      | 22/05/2016   | 18.05        |            | Continued. | Gas shortage              |               |
| MSPGCL             | Khaparkheda Unit 2      | 210      | 22/05/2016   | 21.32        | 23/05/2016 | 10.22      | ID Fan Problem            |               |
| MSPGCL             | Chandrapur Unit-8       | 500      | 23/05/2016   | 05.10        | 23/05/2016 | 11.13      | Flame Failure             |               |
| MSPGCL             | Chandrapur Unit-8       | 500      | 23/05/2016   | 11.31        |            | Continued. | Reheater Prot.operated    |               |
| IPP                | RPL(AMT) U-1            | 270      | 24/05/2016   | 00.00        |            | Continued. | Zero Schedule From MSEDCL |               |
| MSPGCL             | Koradi Unit 5           | 200      | 24/05/2016   | 00.05        |            | Continued. | Zero Schedule From MSEDCL |               |
| IPP                | RPL(AMT) U-5            | 270      | 24/05/2016   | 00.05        |            | Continued. | Zero Schedule From MSEDCL |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 23/May/2016**

**Statement-VII**

Position as on 6.30 Hrs of 24/May/2016

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                     |
| Dhule Sar'Sarovar I                      | InterState                | 22/05/2016   | 16.32        | 24/05/2016 | 06.43      | HT          | Over Voltage                                                                                                        |
| Dabhol New koyna I                       | InterState                | 22/05/2016   | 23.40        | 23/05/2016 | 21.40      | T           | Distance Protection                                                                                                 |
| Kolhapur Solapur(PG) I                   | InterState                | 23/05/2016   | 18.01        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Akola II - Taptitanda ckt-I              | IntraState                | 27/04/2016   | 11.41        |            | Continued. | PO          | Dismantalling of Conductor Reorientation.                                                                           |
| Ektuni-Bableshtar ckt II                 | IntraState                | 19/05/2016   | 09.44        |            | Continued. | HT          | To Control BBLR Padghe Loading.                                                                                     |
| Karad - Jaigad - II                      | IntraState                | 21/05/2016   | 13.00        | 23/05/2016 | 09.15      | PO          | Insulator Replacement Work                                                                                          |
| karad -kolhapur-I                        | IntraState                | 21/05/2016   | 17.10        | 23/05/2016 | 08.58      | HT          | Over Voltage                                                                                                        |
| Bhusawal-Aurangabad                      | IntraState                | 21/05/2016   | 20.07        | 23/05/2016 | 07.42      | HT          | Over Voltage                                                                                                        |
| Bus Coupler @ Chandrapur                 | IntraState                | 23/05/2016   | 08.24        | 23/05/2016 | 20.52      | PO          | Hot spot and R.M.Work                                                                                               |
| karad -kolhapur-I                        | IntraState                | 23/05/2016   | 16.07        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                      | IntraState                | 23/05/2016   | 16.43        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Bhusawal-Aurangabad                      | IntraState                | 23/05/2016   | 17.07        | 24/05/2016 | 06.32      | HT          | Over Voltage                                                                                                        |
| <b>400 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                     |
| 400/220 KV 500 MVA ICT- I @Warora        | IntraState                | 06/05/2016   | 14.37        |            | Continued. | PO          | To Dismantle & Transport To Babhaleshtar.                                                                           |
| 400/220 KV 500 MVA ICT- II @Warora       | IntraState                | 13/05/2016   | 14.39        |            | Continued. | PO          | For Dismantling Of ICT-I                                                                                            |
| 400/220 Kv 315 Mva Ict -2 @New Koyna     | IntraState                | 23/05/2016   | 08.06        | 23/05/2016 | 18.32      | PO          | Quarterly Maintenance Work                                                                                          |
| <b>220 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                     |
| Nasik Navsari I                          | InterState                | 16/05/2016   | 18.32        |            | Continued. | HT          | O/L of Interconnector betn. Nsk OCR & GCR                                                                           |
| Chandrapur GCR - Warora - I              | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                    | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| GIS Bhandup - Borivali                   | IntraState                | 11/01/2016   | 07.42        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| Padghe - Vasai                           | IntraState                | 24/01/2016   | 08.32        |            | Continued. | PO          | For Formation of Temp. Padgha-Borivali (Charge upto 51/1).                                                          |
| Bableshtar- Ranjangaon                   | IntraState                | 03/02/2016   | 07.12        |            | Continued. | HT          | To Control BBLSR ICT O/L                                                                                            |
| Bableshtar- Alephata                     | IntraState                | 19/03/2016   | 19.44        |            | Continued. | HT          | To control BBLSR ICT Loading                                                                                        |
| Butibori - VIPL Ckt I                    | IntraState                | 23/05/2016   | 08.46        | 23/05/2016 | 13.52      | EO          | To attend Hot Spot                                                                                                  |
| Kolhapur-Birdi                           | IntraState                | 23/05/2016   | 09.40        | 23/05/2016 | 19.18      | PO          | Quarterly Maintenance Work                                                                                          |
| Tilawani-Talandge-I                      | IntraState                | 23/05/2016   | 10.24        | 23/05/2016 | 13.33      | PO          | Quarterly Maintenance Work                                                                                          |
| Hamidwada-Mumewadi                       | IntraState                | 23/05/2016   | 14.29        | 23/05/2016 | 16.44      | PO          | Quarterly Maintenance Work                                                                                          |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali     | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |
| 220/132kv 150MVA ICT-II @ Satana         | IntraState                | 20/05/2016   | 15.40        |            | Continued. | PO          | R-PH Bushing Replacement work.                                                                                      |
| 220/132 Kv 200 Mva Vijay Ict 2 @Malegaon | IntraState                | 23/05/2016   | 08.45        | 23/05/2016 | 13.33      | PO          | Tan Delta Measurment of CTs                                                                                         |
| 220/132-110kv 100mva Imp Ptr 1 @Wathar   | IntraState                | 23/05/2016   | 09.32        | 23/05/2016 | 12.10      | PO          | Routine Maintenance Work                                                                                            |
| 220/132-110kv 100mva Imp Ptr 2 @Wathar   | IntraState                | 23/05/2016   | 13.30        | 23/05/2016 | 16.25      | PO          | Routine Maintenance Work                                                                                            |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage