

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 23/May/2019 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 155.478        | 3540.782        | 1) Gujrat                      | 0.793          | 20.742           |
| 2) Hydro            | 32.902         | 834.984         | 2) Madhya Pradesh              | 8.467          | 239.894          |
| 3) Gas              | 6.783          | 154.888         | 3) Chattisgarh                 | 3.250          | 90.600           |
| <b>Total MSPGCL</b> | <b>195.163</b> | <b>4530.654</b> | 4) Maharashtra                 | 110.083        | 2657.976         |
| B) 1) APLM          | 77.115         | 1598.602        | 5) Goa (Amona)                 | -0.154         | -10.582          |
| 2) JSWEL            | 23.348         | 542.440         | <b>Total</b>                   | <b>122.439</b> | <b>2998.630</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 30.670         | 647.899          |
| 4) RPL(AMT)         | 27.571         | 60.242          | b) Mumbai Drawl                | 33.496         | 742.173          |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 9.855          | 296.971          |
| 6) Other IPP        | 7.912          | 180.440         | Include PX                     | -8.944         | -147.209         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 30.670         | 647.899          |
| C) 1) TPCL Thermal  | 15.925         | 309.795         | Include PX                     | 16.257         | 367.432          |
| 2) TPCL Hydro       | 4.799          | 105.681         | Standby                        | 0.000          | 0.000            |
| 3) TPCL Gas         | 4.356          | 99.320          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 10.985         | 227.998         | 1) MSEDCL                      | 452.555        | 9887.248         |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 69.561         | 1484.966         |
| 1) Thermal          | 318.334        | 6460.299        | <b>TOTAL STATE</b>             | <b>522.116</b> | <b>11372.214</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 37.701         | 940.665         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 11.139         | 254.208         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 25.538         | 555.610         |                                |                |                  |
| 6) SOLAR            | 6.965          | 162.803         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>399.677</b> | <b>8373.585</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 5 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6687                      | 6625                  | 6555                      | 6360                      |
| MSPGCL Hydro             | 1639                      | 1538                  | 689                       | 1323                      |
| MSPGCL Gas               | 279                       | 278                   | 285                       | 287                       |
| MSPGCL Total Generation  | 8605                      | 8441                  | 7529                      | 7970                      |
| Central Sector Receipt   | 5818                      | 6050                  | 4610                      | 4322                      |
| WIND                     | 510                       | 839                   | 1974                      | 1055                      |
| CPP / IPP Thermal        | 5711                      | 5869                  | 5584                      | 5633                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 880                       | 635                   | 0                         | 0                         |
| Exchange with Mumbai     | -1700                     | -1700                 | -1480                     | -878                      |
| <b>MSEDCL DEMAND MET</b> | <b>19824</b>              | <b>20134</b>          | <b>18217</b>              | <b>18102</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 19824                     | 20134                 | 18217                     | 18102                     |
| TPCL GENERATION          | 1216                      | 1282                  | 1112                      | 879                       |
| AEML GENERATION          | 496                       | 497                   | 375                       | 498                       |
| <b>MUMBAI DEMAND</b>     | <b>3412</b>               | <b>3479</b>           | <b>2967</b>               | <b>2255</b>               |
| STATE DEMAND MET         | 23236                     | 23613                 | 21184                     | 20357                     |
| <b>STATE DEMAND</b>      | <b>23236</b>              | <b>23613</b>          | <b>21184</b>              | <b>20357</b>              |
| Frequency (Hz)           | 50.03                     | 49.99                 | 50.01                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.28 Hz at 18.28 Hrs | 49.85 Hz at 06.49 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 23/May/2019

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.66         | 47.97          | 165      | 135      |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 7.84         | 234.03         | 430      | 158      |
| Unit 9             | 10.30        | 212.70         | 490      | 338      |
| Unit 10            | 10.20        | 244.88         | 551      | 285      |
| <b>Total</b>       | <b>32.00</b> | <b>739.58</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 203.83         | 0        | 0        |
| Unit 5             | 11.98        | 242.71         | 505      | 495      |
| <b>Total</b>       | <b>11.98</b> | <b>446.54</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.57         | 86.01          | 193      | 170      |
| Unit 4             | 4.05         | 94.93          | 174      | 155      |
| Unit 5             | 10.10        | 160.07         | 425      | 415      |
| Unit 6             | 10.96        | 239.12         | 465      | 450      |
| Unit 7             | 9.53         | 224.95         | 415      | 385      |
| Unit 8             | 11.50        | 248.05         | 485      | 470      |
| Unit 9             | 11.14        | 234.04         | 470      | 455      |
| <b>Total</b>       | <b>61.87</b> | <b>1287.17</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 6.10         | 133.25         | 258      | 252      |
| Unit 4             | 6.05         | 133.42         | 255      | 250      |
| <b>Total</b>       | <b>12.15</b> | <b>266.67</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.10         | 64.78          | 135      | 115      |
| Unit 2             | 3.04         | 77.16          | 130      | 100      |
| Unit 3             | 3.33         | 82.57          | 148      | 130      |
| Unit 4             | 3.22         | 82.85          | 145      | 127      |
| Unit 5             | 11.08        | 252.66         | 480      | 445      |
| <b>Total</b>       | <b>23.78</b> | <b>560.02</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 4.54         | 43.12          | 203      | 163      |
| Unit 4             | 4.72         | 100.00         | 210      | 160      |
| Unit 5             | 4.45         | 97.69          | 197      | 160      |
| <b>Total</b>       | <b>13.70</b> | <b>240.81</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 6.78         | 154.89         | 299      | 268      |
| <b>Total</b>       | <b>6.78</b>  | <b>154.89</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.00         | 1.20           | 0        | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>   | <b>1.20</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 6.44          | 158.00         | 525      | 40       |
| Stage 4         | 18.76         | 463.85         | 1000     | 70       |
| Stage 3         | 5.47          | 136.47         | 320      | 72       |
| <b>Total</b>    | <b>30.66</b>  | <b>758.32</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.52          | 15.01          | 22       | 21       |
| VTRNA           | 0.90          | 18.99          | 61       | 0        |
| TILLARI         | 0.00          | 6.60           | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.24          | 5.51           | 40       | 0        |
| RNGR+BHTSA      | 0.22          | 5.65           | 9        | 9        |
| BHANDARDRA      | 0.00          | 2.36           | 0        | 0        |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.20          | 7.13           | 9        | 8        |
| GHATGHAR        | 0.16          | 15.41          | 90       | 0        |
| <b>Total</b>    | <b>2.24</b>   | <b>76.66</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 25.54         | 555.61         | 0        | 0        |
| <b>Total</b>    | <b>25.54</b>  | <b>555.61</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 77.12         | 1598.60        | 0        | 0        |
| JSWEL(Mus)      | 23.35         | 542.44         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 27.57         | 60.24          | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 7.91          | 180.44         | 0        | 0        |
| <b>Total</b>    | <b>135.95</b> | <b>2381.72</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 6.96          | 162.80         | 0        | 0        |
| <b>Total</b>    | <b>6.96</b>   | <b>162.80</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 10.67         | 205.94         | 486      | 314      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.78          | 63.32          | 116      | 115      |
| Trombay 7B      | 1.57          | 36.00          | 66       | 65       |
| Trombay 8       | 5.26          | 103.86         | 229      | 199      |
| TATA Hydro      | 4.80          | 105.68         | 417      | 3        |
| <b>Total</b>    | <b>25.08</b>  | <b>514.80</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 10.98         | 228.00         | 499      | 374      |
| <b>Total</b>    | <b>10.98</b>  | <b>228.00</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 155.48      | 3540.78       | MSPGCL Total        | 195.16      | 4530.65       |
|                |             |         | MSPGCL Thml+Gas | 162.26      | 3695.67       | Koyna 1,2 & 4 Total | 25.19       | 621.85        |
|                |             |         | MSPGCL Hydro    | 32.90       | 834.98        | State Total         | 399.68      | 8373.58       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 23/May/2019

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6417        | 1802  | 285  | 8504   | 1069  | 5601      | 0    | 0     | 4620        | 4898        | -1325                | 18747                 | 0                    | 18747                     | 2806             | 21553           | 49.96         |
| 2                  | 6345        | 1600  | 287  | 8232   | 998   | 5604      | 0    | 0     | 4569        | 4758        | -1164                | 18428                 | 0                    | 18428                     | 2601             | 21029           | 49.99         |
| 3                  | 6353        | 1802  | 287  | 8442   | 1003  | 5624      | 0    | 0     | 4334        | 4291        | -1058                | 18302                 | 0                    | 18302                     | 2432             | 20734           | 50.00         |
| 4                  | 6320        | 1643  | 287  | 8250   | 963   | 5618      | 0    | 0     | 4251        | 4164        | -917                 | 18078                 | 0                    | 18078                     | 2305             | 20383           | 50.00         |
| 5                  | 6360        | 1323  | 287  | 7970   | 1055  | 5633      | 0    | 0     | 4293        | 4322        | -878                 | 18102                 | 0                    | 18102                     | 2255             | 20357           | 50.02         |
| 6                  | 6221        | 1433  | 289  | 7943   | 899   | 5600      | 0    | 0     | 4783        | 4943        | -898                 | 18487                 | 0                    | 18487                     | 2287             | 20774           | 50.01         |
| 7                  | 6190        | 1763  | 299  | 8252   | 813   | 5673      | 0    | 47    | 5144        | 4880        | -847                 | 18818                 | 0                    | 18818                     | 2235             | 21053           | 49.92         |
| 8                  | 6262        | 1238  | 285  | 7785   | 723   | 5645      | 0    | 231   | 5163        | 5179        | -963                 | 18600                 | 0                    | 18600                     | 2361             | 20961           | 49.97         |
| 9                  | 6370        | 1203  | 274  | 7847   | 702   | 5607      | 0    | 497   | 5257        | 5330        | -1271                | 18712                 | 0                    | 18712                     | 2696             | 21408           | 50.01         |
| 10                 | 6477        | 1343  | 281  | 8101   | 717   | 5573      | 0    | 686   | 5464        | 5573        | -1575                | 19075                 | 0                    | 19075                     | 3031             | 22106           | 49.93         |
| 11                 | 6644        | 1734  | 280  | 8658   | 432   | 5605      | 0    | 840   | 5689        | 5319        | -1655                | 19199                 | 0                    | 19199                     | 3295             | 22494           | 50.00         |
| 12                 | 6687        | 1639  | 279  | 8605   | 510   | 5711      | 0    | 880   | 5881        | 5818        | -1700                | 19824                 | 0                    | 19824                     | 3412             | 23236           | 50.03         |
| 13                 | 6690        | 1673  | 268  | 8631   | 587   | 5758      | 0    | 907   | 5950        | 5780        | -1706                | 19957                 | 0                    | 19957                     | 3410             | 23367           | 49.99         |
| 14                 | 6698        | 1167  | 278  | 8143   | 690   | 5560      | 0    | 904   | 5962        | 6080        | -1737                | 19640                 | 0                    | 19640                     | 3336             | 22976           | 50.02         |
| 15                 | 6619        | 1738  | 279  | 8636   | 713   | 5773      | 0    | 748   | 6026        | 6018        | -1768                | 20120                 | 0                    | 20120                     | 3440             | 23560           | 50.03         |
| 16                 | 6625        | 1538  | 278  | 8441   | 839   | 5869      | 0    | 635   | 6123        | 6050        | -1700                | 20134                 | 0                    | 20134                     | 3479             | 23613           | 49.99         |
| 17                 | 6613        | 1299  | 271  | 8183   | 1043  | 5882      | 0    | 398   | 5880        | 5737        | -1589                | 19654                 | 0                    | 19654                     | 3391             | 23045           | 49.96         |
| 18                 | 6616        | 1003  | 281  | 7900   | 1443  | 5763      | 0    | 171   | 5405        | 5230        | -1474                | 19033                 | 0                    | 19033                     | 3244             | 22277           | 50.06         |
| 19                 | 6510        | 325   | 283  | 7118   | 1951  | 5616      | 0    | 21    | 4869        | 4689        | -1480                | 17915                 | 0                    | 17915                     | 3029             | 20944           | 50.14         |
| 20                 | 6555        | 689   | 285  | 7529   | 1974  | 5584      | 0    | 0     | 4561        | 4610        | -1480                | 18217                 | 0                    | 18217                     | 2967             | 21184           | 50.01         |
| 21                 | 6480        | 1013  | 285  | 7778   | 1689  | 5676      | 0    | 0     | 4496        | 4479        | -1494                | 18128                 | 0                    | 18128                     | 2910             | 21038           | 50.03         |
| 22                 | 6485        | 1361  | 284  | 8130   | 1562  | 5676      | 0    | 0     | 4409        | 4412        | -1475                | 18305                 | 0                    | 18305                     | 2850             | 21155           | 49.98         |
| 23                 | 6478        | 1261  | 284  | 8023   | 1612  | 5679      | 0    | 0     | 4793        | 4898        | -1625                | 18587                 | 0                    | 18587                     | 2879             | 21466           | 49.96         |
| 24                 | 6463        | 1312  | 287  | 8062   | 1551  | 5616      | 0    | 0     | 5030        | 4981        | -1717                | 18493                 | 0                    | 18493                     | 2910             | 21403           | 50.05         |
| MUs                | 155.48      | 32.90 | 6.78 | 195.16 | 25.54 | 135.95    | 0.00 | 6.97  | 122.95      | 122.44      | -33.50               | 452.56                | 0.00                 | 452.56                    | 69.56            | 522.12          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 23/May/2019**

**Position as on 6.30 Hrs of 24/May/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                            |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                                                                                            |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL) |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                                                                          |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                    |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                          |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                          |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.                                                                                        |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                                                                                                          |               |
| MSPGCL                | Uran Unit B0            | 120      | 08/09/2018   | 12.19        |            | Continued. | T/F Shifting Work.                                                                                                         |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                                                                                               |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.                                                                                                             |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 14/12/2018   | 03.00        |            | Continued. | Zero Schedule.                                                                                                             |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                                                                                                |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                                                              |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                                                              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 19/01/2019   | 18.21        |            | Continued. | Poor Coal Receipt                                                                                                          |               |
| IPP                   | RPL(AMT) U-2            | 270      | 24/04/2019   | 00.00        | 23/05/2019 | 02.43      | Zero Schedule                                                                                                              |               |
| MSPGCL                | Parli Unit 8            | 250      | 01/05/2019   | 00.00        |            | Continued. | Zero Schedule                                                                                                              |               |
| MSPGCL                | Uran Unit 8             | 108      | 20/05/2019   | 16.01        |            | Continued. | Gas shortage                                                                                                               |               |
| IPP                   | JSW (J) U4              | 300      | 22/05/2019   | 14.51        | 23/05/2019 | 12.47      | ACW Leakage                                                                                                                |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 22/05/2019   | 16.42        |            | Continued. | Steam Leakage                                                                                                              |               |
| MSPGCL                | Koyna Unit 10           | 80       | 23/05/2019   | 01.00        | 23/05/2019 | 02.00      | Auxiliary supply failure                                                                                                   |               |
| MSPGCL                | Koyna Unit 12           | 80       | 23/05/2019   | 01.00        | 23/05/2019 | 01.25      | Auxiliary supply failure                                                                                                   |               |
| MSPGCL                | Koyna Unit 9            | 80       | 23/05/2019   | 01.00        | 23/05/2019 | 01.40      | Auxiliary supply failure                                                                                                   |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 23/May/2019**

**Statement-VII**

**Position as on 6.30 Hrs of 24/May/2019**

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                         | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                               |
| Dhule Sar'Sarovar I                        | InterState                | 17/05/2019   | 13.39        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Kalwa - Talegaon(PG)                       | IntraState                | 22/05/2019   | 01.36        |            | Continued. | T           | Distance Protection,Zone 1 32.4km R PH 06.07KA                                                                                         |
| Main Bus A @Kharghar                       | IntraState                | 22/05/2019   | 16.16        | 23/05/2019 | 01.43      | PO          | R Phase damaged PG isolator                                                                                                            |
| Kalwa - Kharghar                           | IntraState                | 22/05/2019   | 16.16        | 23/05/2019 | 02.10      | HT          | Shifting from A Bus to B Bus (due to A Bus outage at Kharghar)                                                                         |
| Khadka-Aurangabad (Waluj)                  | IntraState                | 22/05/2019   | 19.18        | 23/05/2019 | 06.34      | HT          | Over Voltage                                                                                                                           |
| Deepnagar - Aurangabad                     | IntraState                | 23/05/2019   | 06.39        | 23/05/2019 | 16.03      | PO          | Replacement of Dead End And Mid Span Joint.                                                                                            |
| New Koyna - Dabhol - II                    | IntraState                | 23/05/2019   | 10.33        | 23/05/2019 | 16.07      | PO          | Replacement of Defective Insulator String.                                                                                             |
| Bhusawal-Aurangabad                        | IntraState                | 23/05/2019   | 18.17        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe        | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                                                                                              |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2 | IntraState                | 12/04/2019   | 17.10        |            | Continued. | HT          | Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.                                                                                 |
| 400/220/33 Kv 315 Mva Ict- 2 @Kharghar     | IntraState                | 22/05/2019   | 15.08        | 23/05/2019 | 02.32      | PO          | Shifting from A Bus to B Bus (due to A Bus outage at Kharghar)                                                                         |
| <b>220 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                        | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                        | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Chandrapur GCR - Warora - I                | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.                   |
| Chandrapur GCR - Wani                      | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                            | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading.                                                                                                               |
| Nashik-Padgha                              | IntraState                | 23/05/2019   | 10.48        | 23/05/2019 | 21.03      | HT          | Due To Increase Loading On Bus Coupler.                                                                                                |
| <b>220 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                        |
| 220/100 Kv 200 MVA ICT-II @Trombay         | IntraState                | 28/03/2019   | 22.48        |            | Continued. | T           | Buccholz Trip.                                                                                                                         |
| 220/132Kv 200MVA ICT-I @ Chikhali          | IntraState                | 20/05/2019   | 08.08        |            | Continued. | PO          | Pre Mponsoon Maint.and Testing work                                                                                                    |
| 220/33kV 100 MVA Transformer 1 @Aarey R/S  | IntraState                | 22/05/2019   | 08.59        | 23/05/2019 | 00.05      | PO          | Pre Monsoon Maint.work                                                                                                                 |
| 220/33 Kv 100 Mva Alstom Ptr 1 @Valve      | IntraState                | 22/05/2019   | 10.00        |            | Continued. | PO          | OLTC Overhauling work                                                                                                                  |
| <b>132 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                        |
| Kanhan Pench                               | InterState                | 23/05/2019   | 09.15        |            | Continued. | T           | R PH LA Replacement.                                                                                                                   |
| Pusad-Umarkhed                             | IntraState                | 23/05/2019   | 06.10        | 23/05/2019 | 06.34      | T           | Monkey Fault On CC At Umarkhed S/S Pusad- R Ph, Z2, 50.02KM, 1.64KA, Umhed- R Ph, Z1, 1.3KA.                                           |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage