

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Aug/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	101.708	2353.619	1) Gujrat	10.839	205.237
2) Hydro	16.138	304.556	2) Madhya Pradesh	8.099	128.771
3) Gas	5.455	115.584	3) Chattisgarh	2.800	66.860
Total MSPGCL	123.301	2773.759	4) Maharashtra	147.055	3259.785
B) 1) APLM	62.806	1155.682	5) Goa (Amona)	-1.859	-37.231
2) JSWEL	11.796	321.811	Total	166.934	3623.422
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.313	700.468
4) RPL(AMT)	19.082	459.625	b) Mumbai Drawl	35.466	765.260
5) SWPGPL	5.612	140.990	c) MSEDCL Bilateral *	70.596	1745.961
6) Other IPP	4.819	133.739	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.313	700.244
C) 1) TPCL Thermal	9.698	234.603	Include PX	0.000	0.000
2) TPCL Hydro	7.579	136.615	Standby	0.000	0.224
3) TPCL Gas	2.013	44.147	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.942	195.065	1) MSEDCL	408.428	8781.672
D) STATE			2) Mumbai Discoms	61.698	1375.690
1) Thermal	222.463	4995.134	3) Other Discoms	8.784	199.492
(A1+C1+C4+(B1-B6))			TOTAL STATE	478.910	10356.854
2) Hydro	23.717	441.171			
(A2+C2)					
3) Gas	7.468	159.731			
(A3+B7+C3)					
4) Wind	49.793	957.057			
6) SOLAR	8.535	180.339			
TOTAL STATE	311.976	6733.432			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4264	4032	4508	4117
MSPGCL Hydro	611	493	1957	340
MSPGCL Gas	229	225	223	232
MSPGCL Total Generation	5104	4750	6688	4689
Central Sector Receipt	7703	7599	7842	5267
WIND	2243	2605	1452	2399
CPP / IPP Thermal	4929	3662	4637	4227
CPP / IPP Gas	0	0	0	0
SOLAR	594	1018	0	0
Exchange with Mumbai	-1597	-1944	-1470	-1029
MSEDCL DEMAND MET	18568	17340	18753	15272
Load Shedding	0	0	0	0
MSEDCL DEMAND	18568	17340	18753	15272
TPCL GENERATION	819	774	905	703
AEML GENERATION	235	238	465	182
MUMBAI DEMAND	2651	2956	2840	1914
OTHER DISCOM DEMAND	408	349	396	280
STATE DEMAND MET	21627	20646	21989	17467
STATE DEMAND	21627	20646	21989	17467
Frequency (Hz)	49.98	50.00	49.94	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 13.06 Hrs	49.75 Hz at 11.52 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.19	57.40	155	95
Unit 7	0.00	0.00	0	0
Unit 8	0.00	102.62	0	0
Unit 9	0.00	46.51	0	0
Unit 10	10.74	236.39	500	395
Total	13.93	442.91		
Bhusawal				
Unit 3	0.00	7.23	0	0
Unit 4	7.77	185.34	350	290
Unit 5	0.00	55.81	0	0
Total	7.77	248.38		
Parli				
Unit 6	4.29	94.11	204	146
Unit 7	4.24	84.01	194	147
Unit 8	3.71	81.19	166	144
Total	12.24	259.31		
Chandrapur				
Unit 3	0.00	32.41	0	0
Unit 4	0.00	12.42	0	0
Unit 5	5.96	118.89	270	197
Unit 6	6.56	115.33	325	210
Unit 7	5.32	38.08	234	207
Unit 8	10.15	202.56	460	390
Unit 9	9.86	211.37	448	364
Total	37.86	731.06		
Paras				
Unit 3	4.73	79.89	225	154
Unit 4	4.51	84.55	195	168
Total	9.23	164.44		
Khaparkheda				
Unit 1	0.00	37.40	0	0
Unit 2	0.00	44.16	0	0
Unit 3	3.45	77.30	167	130
Unit 4	3.93	51.82	197	135
Unit 5	8.70	164.23	420	270
Total	16.08	374.92		
Nasik				
Unit 3	1.66	66.63	132	0
Unit 4	0.00	0.00	0	0
Unit 5	2.94	65.96	141	110
Total	4.60	132.59		
Uran				
All Units	5.46	115.58	234	213
Total	5.46	115.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	13.71	25	24
Total	0.60	13.71		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.03	53.36	430	35
Stage 4	2.89	42.62	856	0
Stage 3	1.41	32.75	160	0
Total	6.32	128.73		
Hydro				
KDPH	0.86	10.68	36	36
VTRNA	0.79	13.98	61	0
TILLARI	0.58	12.13	58	0
BHIRA T.R.	0.49	10.75	80	0
SMLHY_PTN	6.04	110.49	274	240
GHATGHAR	0.46	4.09	125	0
Total	9.22	162.11		
Wind				
Total	49.79	957.06	0	0
Total	49.79	957.06		
CPP				
APML(Mus)	62.81	1155.68	0	0
JSWEL(Mus)	11.80	321.81	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.08	459.62	0	0
SWPGPL-Mus	5.61	140.99	0	0
Other(Mus)	4.82	133.74	0	0
Total	104.12	2211.85		
SOLAR				
Total	8.54	180.34	0	0
Total	8.54	180.34		
Tata				
Trombay 5	6.48	156.58	275	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.08	25.50	55	40
Trombay 7B	0.93	18.65	47	35
TATA Hydro	7.58	136.62	407	196
Trombay 8	3.21	78.02	148	132
Total	19.29	415.36		
AEML				
DTPS U-1&2	6.94	195.06	483	159
Total	6.94	195.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	101.71	2353.62	MSPGCL Total	123.30	2773.76
			MSPGCL Thml+Gas	107.16	2469.20	Koyna 1,2 & 4 Total	4.92	95.98
			MSPGCL Hydro	16.14	304.56	State Total	311.98	6733.43

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 23/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4256	340	232	4828	2238	4566	0	0	5312	5286	-1149	15432	0	15432	2170	337	17939	50.01
2	4238	346	232	4816	2266	4311	0	0	5226	5255	-1086	15259	0	15259	2023	303	17585	50.01
3	4117	340	232	4689	2399	4227	0	0	5276	5267	-1029	15272	0	15272	1914	280	17467	50.04
4	4040	339	232	4611	2512	4180	0	0	5212	5675	-958	15740	0	15740	1851	281	17871	50.06
5	4208	344	232	4784	2321	4435	0	0	5290	5271	-943	15578	0	15578	1838	290	17706	49.96
6	4269	365	232	4866	2289	4613	0	0	6219	6389	-1005	16821	0	16821	1957	331	19109	49.96
7	4152	1028	234	5414	2110	4841	0	60	6996	6879	-1141	17801	0	17801	2118	363	20281	49.96
8	4187	967	230	5384	1985	4960	0	291	7674	7251	-1341	18144	0	18144	2331	386	20861	49.97
9	4264	611	229	5104	2243	4929	0	594	7693	7703	-1597	18568	0	18568	2651	408	21627	49.98
10	4209	531	232	4972	2480	4415	0	807	7633	7913	-1943	18240	0	18240	2943	403	21587	50.04
11	4217	531	233	4981	2600	4245	0	1012	7642	7465	-2085	17806	0	17806	3114	412	21332	50.05
12	3947	575	230	4752	2694	3808	0	997	7773	7778	-2191	17416	0	17416	3134	422	20972	49.95
13	3951	554	230	4735	2361	3523	0	1049	7738	8028	-2165	17126	0	17126	3079	404	20610	49.95
14	4017	543	233	4793	2503	3485	0	1026	7375	7574	-2038	16978	0	16978	2962	366	20305	50.01
15	4032	493	225	4750	2605	3662	0	1018	7730	7599	-1944	17340	0	17340	2956	349	20646	50.00
16	3993	456	218	4667	2132	3716	0	831	7852	7799	-1847	16939	0	16939	2973	359	20271	50.02
17	4230	456	224	4910	1821	3921	0	578	7832	7924	-1745	17033	0	17033	2950	376	20359	50.03
18	4380	592	225	5197	1488	4417	0	245	7594	7669	-1599	17031	0	17031	2917	386	20334	49.99
19	4478	1145	215	5838	1425	4579	0	27	7656	7650	-1512	17590	0	17590	2888	416	20895	50.01
20	4508	1957	223	6688	1452	4637	0	0	7780	7842	-1470	18753	0	18753	2840	396	21989	49.94
21	4524	1264	222	6010	1468	4617	0	0	7491	7317	-1370	17653	0	17653	2719	389	20761	49.97
22	4509	1108	223	5840	1433	4649	0	0	7030	7065	-1208	17387	0	17387	2569	392	20348	50.01
23	4515	758	213	5486	1453	4715	0	0	6593	6192	-1082	16384	0	16384	2451	380	19215	49.98
24	4467	495	224	5186	1515	4666	0	0	6252	6143	-1018	16136	0	16136	2350	355	18842	49.99
MUs	101.71	16.14	5.46	123.30	49.79	104.12	0.00	8.53	166.87	166.93	-35.47	408.43	0.00	408.43	61.70	8.78	478.91	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Aug/2022

Position as on 6.30 Hrs of 24/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Koyna STG-IV Unit-4	250	13/08/2022	10:06	23/08/2022	17:30	Commissioning and installation of new TSLG Governor	22/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	24/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 4	210	09/08/2022	20:25		Continued.	FURNACE DRAFT VERY HIGH/ poor coal receipt & wet coal.	
MSPGCL	Chandrapur Unit 3	210	15/08/2022	12:50		Continued.	Poor Coal Receipt	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	16/08/2022	03:44		Continued.	Wet coal problem.	
MSPGCL	Khaparkheda Unit 1	210	16/08/2022	04:28		Continued.	DUE TO WET STEAM PROTECTION/ poor coal	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Aug/2022

Position as on 6.30 Hrs of 24/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							receipt & wet coal.	
AEML	AEML Unit 1	250	18/08/2022	10:04	23/08/2022	15:06	UAT T/F Buchholz relay tripped	22/08/2022
MSPGCL	Khaparkheda Unit 2	210	19/08/2022	02:18		Continued.	Furnace Pressure High/poor coal receipt & wet coal.	
IPP	RPL(AMT) U-5	270	19/08/2022	11:00		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 8	660	21/08/2022	14:10		Continued.	SUSPECTED BOILER TUBE LEAKAGE	27/08/2022
MSPGCL	Uran Unit 6	108	22/08/2022	02:50	23/08/2022	23:53	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	22/08/2022	18:25	23/08/2022	19:20	Excitation Problem	
MSPGCL	Nasik Unit 3	210	23/08/2022	06:06	23/08/2022	15:21	Bus Bar Protection operated	
IPP	JSW (J) U3	300	23/08/2022	11:44	23/08/2022	17:09	turbine governing valve problem rectification work.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 24/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
Tie bay (705) of Ektuni ckt - 1 & Koradi - 3 ckt - 1 @ Akola - 2	IntraState	23/08/2022	10:16	23/08/2022	13:18	PO	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
500 KV LR Outages/Trippings							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/08/2022	15:11			HT	This breaker put in lock out at 15:06hrs dt.15.08.2022 and this filter is under breakdown and expert service are required for
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	23/08/2022	08:10	23/08/2022	10:55	EO	For attending hevy sparking at plc filter
400 KV TBC Outages/Trippings							
BUS COUPLER @ CHAKAN	IntraState	23/08/2022	12:34	23/08/2022	15:56	EO	For attending Hotspots at Y phase 89 A PG Isolators Hanger Rod of 400 KV Bus coupler bay.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	IntraState	23/08/2022	12:18	23/08/2022	15:16	PO	400 KV CB Overhauling work
400 KV LINE Outages/Trippings							
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	22/08/2022	09:31	23/08/2022	02:06	PO	400kv TBC B bus isolator repair work
JAIGAD - KARAD CKT - 2	IntraState	22/08/2022	00:24			HT	To control OV
KARAD - TALANDGE CKT - 2	IntraState	22/08/2022	09:44	23/08/2022	00:38	PO	400kv TBC B bus isolator repair work
KHADKA-AURANGABAD (WALUJ)	IntraState	23/08/2022	20:45	24/08/2022	06:09	HT	H/T DUE TO O/V
MAIN BUS - A @ CHAKAN	IntraState	23/08/2022	21:32	24/08/2022	00:51	EO	For attending Hot Spot at 89A PG Isolators Y phase hanger rod of 400kv Bus Coupler bay
DEEPNAGAR - THAPTI TANDA	IntraState	24/08/2022	05:56			T	Distance Protection
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	23/08/2022	11:08	24/08/2022	02:55	EO	Replacement of 2 Nos. of radiators of B ph unit of ICT 2
95 MVA STN TF - II @ KORADI 2	IntraState	23/08/2022	12:26			PO	1)Transformer testing and oil filtration 2)Transformer bus duct inspection 3) Station switch gear checking , breaker and relay testing
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	23/08/2022	21:15	24/08/2022	01:22	HT	H/T FOR A -BUS OUTAGE
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	24/08/2022	04:51			EO	29D isolator alignment work
220 KV MAINBAY Outages/Trippings							
MAIN BUS @ SAWANTWADI	IntraState	23/08/2022	08:50	23/08/2022	10:21	PO	220kv main Bus & allied equipment's maintenance work.
220 KV LINE Outages/Trippings							
MALHARPETH SATARA MIDC	IntraState	23/08/2022	01:57	23/08/2022	16:10	T	DP
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	23/08/2022	06:06	23/08/2022	07:48	T	R-ph CT busrt
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	23/08/2022	06:06	23/08/2022	07:43	T	Tripped on Overload
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	23/08/2022	06:06	23/08/2022	07:49	T	Tripped due to same Bus as BBLR Nashik 2
MAIN BUS SECTION - 1 @ EKLAHARE (GCR)	IntraState	23/08/2022	06:06	23/08/2022	07:50	T	Tripped due to CT burst of BBLR Nashik 2
MAIN BUS SECTION - 2 @ EKLAHARE (GCR)	IntraState	23/08/2022	06:06	23/08/2022	07:40	T	Tripped due to CT burst of BBLR Nashik 2

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 24/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHAKAN (400KV) - VOLKSWAGEN	IntraState	23/08/2022	10:16	23/08/2022	14:29	PO	For replacement of Faulty conductor Jump at R Ph Wave Trap.
VANKUSWADE - AJINKYATARA	IntraState	23/08/2022	12:02	23/08/2022	16:50	EO	Replacement of Faulty Polymer insulator at Loc No-97 R ph of 220KV Satara MIDC-Malharpeth line
HINJAWADI I- CHINCHWAD	IntraState	23/08/2022	12:06	23/08/2022	16:19	HT	To control loading
BABLESHWAR- BABLESHWAR(400KV)-I	IntraState	23/08/2022	12:50	23/08/2022	17:38	PO	CB Timing DCRM
MAIN BUS SECTION - 1 @ PEDAMBE	IntraState	23/08/2022	13:40	23/08/2022	19:37	EO	220KV New Koyna line R phase Main Bus to Isolator & B phase M. B. side isolator to Breaker Jumpers replacement work.
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	23/08/2022	15:04	23/08/2022	17:22	EO	Y-ph line isolator towards line side
RANJANGAON - U TECH SUGAR CKT	IntraState	24/08/2022	01:12	24/08/2022	06:58	T	Distance Protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	23/08/2022	06:06	23/08/2022	07:55	T	Tripped due to same Bus as BBLR Nashik 2
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	23/08/2022	06:06	23/08/2022	07:55	T	Tripped due to same Bus as BBLR Nashik 2
220/132KV 200MVA ICT 6 @ EKLAHARE (GCR)	IntraState	23/08/2022	06:06	23/08/2022	07:58	T	Tripped due to same Bus as BBLR Nashik 2
220/33KV 50MVA PTR 1 @ MIRAJ	IntraState	23/08/2022	10:26	23/08/2022	14:22	EO	Quarterly maintenance, isolator alignment work and hot spot attending work
220/22KV 50MVA PTR 1 @ KONDHWA	IntraState	23/08/2022	11:40	23/08/2022	16:58	PO	For half yearly maintenance & annual relay testing
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	24/08/2022	06:24			PO	Routine Maintenance work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage