

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Aug/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	128.243	2942.595	1) Gujrat	17.181	289.972
2) Hydro	17.626	384.011	2) Madhya Pradesh	12.730	175.765
3) Gas	3.872	32.009	3) Chattisgarh	0.820	38.940
Total MSPGCL	149.741	3358.615	4) Maharashtra	180.061	3772.917
B) 1) APLM	58.143	1262.012	5) Goa (Amona)	-1.536	-36.462
2) JSWEL	21.486	369.288	Total	209.256	4241.132
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.874	716.678
4) RPL(AMT)	25.478	624.316	b) Mumbai Drawl	39.979	801.111
5) SWPGPL	12.200	221.147	c) MSEDCL Bilateral *	97.598	2110.720
6) Other IPP	6.425	139.793	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.874	716.667
C) 1) TPCL Thermal	12.095	282.553	Include PX	0.000	0.000
2) TPCL Hydro	6.418	133.203	Standby	0.000	0.011
3) TPCL Gas	2.292	65.423	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.421	213.066	1) MSEDCL	477.709	10401.985
D) STATE			2) Mumbai Discoms	66.205	1495.352
1) Thermal	269.491	6054.770	3) Other Discoms	10.271	230.653
(A1+C1+C4+(B1-B6))			TOTAL STATE	554.185	12127.990
2) Hydro (A2+C2)	24.044	517.214			
3) Gas (A3+B7+C3)	6.164	97.432			
4) Wind	32.674	963.887			
6) SOLAR	12.556	253.559			
TOTAL STATE	344.929	7886.862			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5241	5515	5508	5297
MSPGCL Hydro	632	463	1713	270
MSPGCL Gas	179	168	169	107
MSPGCL Total Generation	6052	6146	7390	5674
Central Sector Receipt	10534	9512	8374	7263
WIND	1112	1325	1911	1275
CPP / IPP Thermal	4536	5356	5103	5180
CPP / IPP Gas	0	0	0	0
SOLAR	1515	1173	0	0
Exchange with Mumbai	-2206	-2213	-1646	-1040
MSEDCL DEMAND MET	21082	20836	20664	18012
Load Shedding	0	0	658	0
MSEDCL DEMAND	21082	20836	21322	18012
TPCL GENERATION	825	737	1141	786
AEML GENERATION	234	246	247	169
MUMBAI DEMAND	3265	3196	3034	1995
OTHER DISCOM DEMAND	461	463	468	340
STATE DEMAND MET	24808	24495	24166	20347
STATE DEMAND	24808	24495	24824	20347
Frequency (Hz)	50.03	50.02	50.06	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.28 Hz at 13.03 Hrs	49.8 Hz at 17.39 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.51	70.72	175	125
Unit 8	0.00	218.98	0	0
Unit 9	10.98	282.08	518	386
Unit 10	0.00	0.00	0	0
Total	14.50	571.77		
Bhusawal				
Unit 3	2.86	70.09	145	110
Unit 4	9.68	182.31	440	360
Unit 5	10.12	209.21	440	390
Total	22.66	461.61		
Parli				
Unit 6	5.17	72.97	238	160
Unit 7	4.63	73.44	248	97
Unit 8	4.71	68.40	222	154
Total	14.51	214.81		
Chandrapur				
Unit 3	3.16	67.30	160	109
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	6.81	129.04	319	250
Unit 7	6.86	162.26	309	262
Unit 8	9.53	234.30	440	356
Unit 9	8.54	233.62	417	211
Total	34.91	826.52		
Paras				
Unit 3	4.93	92.67	223	183
Unit 4	5.22	105.79	232	201
Total	10.15	198.45		
Khaparkheda				
Unit 1	2.92	53.94	140	110
Unit 2	2.85	61.75	126	103
Unit 3	4.15	81.03	184	164
Unit 4	4.18	90.21	182	149
Unit 5	10.59	223.25	450	420
Total	24.70	510.18		
Nasik				
Unit 3	0.00	46.24	0	0
Unit 4	3.54	67.47	161	132
Unit 5	3.29	45.54	148	120
Total	6.83	159.26		
Uran				
All Units	3.87	32.01	188	89
Total	3.87	32.01		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.40	18.51	44	0
Total	0.40	18.51		
Koyna				
Stage 1-2	3.02	71.88	355	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	7.67	126.26	750	0
Stage 3	2.39	47.51	240	0
Total	13.08	245.64		
Hydro				
KDPH	0.00	7.15	0	0
VTRNA	0.00	0.61	0	0
TILLARI	0.00	1.86	0	0
BHIRA T.R.	0.45	10.27	80	0
SMLHY_PTN	3.30	93.07	142	132
GHATGHAR	0.40	6.90	125	0
Total	4.14	119.86		
Wind				
Total	32.67	963.89	0	0
Total	32.67	963.89		
CPP				
APML(Mus)	58.14	1262.01	0	0
JSWEL(Mus)	21.49	369.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.48	624.32	0	0
SWPGPL-Mus	12.20	221.15	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.39	116.32	265	0
Other(Mus)	1.04	23.47	0	0
Total	123.73	2616.56		
SOLAR				
Total	12.56	253.56	0	0
Total	12.56	253.56		
Tata				
Trombay 5	7.98	187.08	458	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.33	38.94	109	36
Trombay 7B	0.96	26.48	64	32
TATA Hydro	6.42	133.20	428	175
Trombay 8	4.12	95.47	225	128
Total	20.80	481.18		
AEML				
DTPS U-1&2	5.42	213.07	250	161
Total	5.42	213.07		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	128.24	2942.60	MSPGCL Total	149.74	3358.62
			MSPGCL Thml+Gas	132.12	2974.60	Koyna 1,2 & 4 Total	10.69	198.13
			MSPGCL Hydro	17.63	384.01	State Total	344.93	7886.86

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 23/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5305	910	89	6304	1178	5231	0	0	6602	6719	-1061	17979	0	0	17979	2394	392	20765	50.05
2	5295	851	90	6236	1267	5225	0	0	6589	6906	-883	18395	0	0	18395	2218	356	20969	50.05
3	5303	756	90	6149	1284	5236	0	0	7242	7477	-999	18795	0	0	18795	2077	352	21224	50.05
4	5297	270	107	5674	1275	5180	0	0	7777	7263	-1040	18012	0	0	18012	1995	340	20347	49.99
5	5229	247	178	5654	1330	5308	0	0	8051	7715	-1025	18631	0	0	18631	1991	351	20973	49.98
6	5227	799	188	6214	1249	5302	0	0	8578	9037	-1183	20243	0	0	20243	2112	376	22731	50.02
7	5228	1441	186	6855	1078	5298	0	57	8611	8752	-1224	20414	706	0	21120	2298	402	23820	50.01
8	5288	1137	186	6611	878	5318	0	355	9365	9023	-1253	20505	107	0	20612	2506	427	23545	50.08
9	5315	665	183	6163	976	5315	0	863	10139	10177	-1726	21317	0	0	21317	2827	451	24595	50.03
10	5216	712	181	6109	1044	4911	0	1183	10575	10545	-2134	21203	0	0	21203	3115	455	24773	50.02
11	5241	632	179	6052	1112	4536	0	1515	11000	10534	-2206	21082	0	0	21082	3265	461	24808	50.03
12	5212	602	173	5987	1163	4533	0	1557	10544	10404	-2154	21055	0	0	21055	3304	435	24794	50.01
13	5262	672	172	6106	936	4758	0	1657	9756	9933	-2298	20667	0	0	20667	3248	425	24340	50.05
14	5257	472	169	5898	1061	5132	0	1605	9530	9454	-2169	20533	0	0	20533	3107	448	24088	50.03
15	5316	615	168	6099	1234	5208	0	1421	9474	9556	-2208	20851	0	0	20851	3163	459	24473	50.02
16	5515	463	168	6146	1325	5356	0	1173	9776	9512	-2213	20836	0	0	20836	3196	463	24495	50.02
17	5332	550	170	6052	1637	5345	0	796	9714	9167	-2221	20311	0	0	20311	3191	465	23967	49.95
18	5441	373	169	5983	1942	5278	0	331	9289	9049	-2091	20026	0	0	20026	3144	466	23636	49.93
19	5536	921	169	6626	1992	5064	0	43	8925	8632	-1934	19943	0	0	19943	3061	480	23484	50.03
20	5508	1713	169	7390	1911	5103	0	0	8166	8374	-1646	20664	658	0	21322	3034	468	24824	50.06
21	5539	1222	170	6931	1898	5208	0	0	7848	7810	-1514	19874	227	0	20101	2920	459	23480	50.03
22	5497	539	171	6207	1794	5219	0	0	8079	8103	-1562	19296	0	0	19296	2775	465	22536	50.02
23	5508	678	173	6359	1580	5334	0	0	7548	7592	-1671	18745	0	0	18745	2680	449	21874	50.02
24	5376	386	174	5936	1530	5334	0	0	7627	7522	-1564	18332	0	0	18332	2584	426	21342	50.02
MUs	128.24	17.63	3.87	149.74	32.67	123.73	0.00	12.56	210.81	209.26	-39.98	477.71	1.70	0.00	479.41	66.21	10.27	555.88	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 23/Aug/2023

Position as on 6.30 Hrs of 24/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	27/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	31/08/2023
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	25/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	COH (Hot spot on Stator).	13/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/08/2023
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	29/08/2023
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	02/09/2023
MSPGCL	Nasik Unit 3	210	13/08/2023	16:00		Continued.	Boiler Tube Leakage (Tolling from 15:00 hrs on Dt 14.08.2023.)	
MSPGCL	Koradi Unit 8	660	17/08/2023	16:20		Continued.	Boiler Tube Leakage	24/08/2023
MSPGCL	Uran Unit 7	108	21/08/2023	15:18	23/08/2023	03:11	GT Unit changeover done from GT 7 to GT 8.	
AEML	AEML Unit 1	250	22/08/2023	01:29	24/08/2023	02:33	Boiler Tube Leakage	24/08/2023
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	28/08/2023
MSPGCL	Uran Unit 8	108	22/08/2023	23:23		Continued.	Generator protection	24/08/2023
IPP	IEPL Unit 1	270	23/08/2023	17:48	23/08/2023	20:19	Boiler furnace pressure very low.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 24/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TBC Outages/Trippings							
TBC @ NAGOTHANE	IntraState	18/08/2023	11:02			PO	CB replacement work
400 KV MAINBAY Outages/Trippings							
MAIN BAY (410) OF 765/400KV 1500 MVA ICT-1 @ EKTUNI	IntraState	23/08/2023	12:37	23/08/2023	18:19	PO	Diagnostic Testing
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ɛYɛ phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07	23/08/2023	11:01	HT	TO CONTROL LINE LOADING OF PUNE GIS
KHADKA-AURANGABAD (WALUJ)	IntraState	22/08/2023	19:45	23/08/2023	08:36	HT	H/T for voltage management.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	23/08/2023	10:32	23/08/2023	18:06	HT	AMP work at PG end
KHADKA-AURANGABAD (WALUJ)	IntraState	23/08/2023	18:24	24/08/2023	07:40	HT	H/T for voltage management
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	24/08/2023	06:20			HT	H/T to control loading
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	24/08/2023	09:04			PO	Point to point testing of all protection signals, I/O Signals, Analog signals etc for visibility at LD centre
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	21/08/2023	13:18			PO	1. CB Pole Overhauling Work. 2. Replacement of Rusted Aluminum Cabinet of CB Mechanism. 3.Reactor can be taken on TBC if required.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
AAREY - AEML BORIVALI	IntraState	06/08/2023	18:20			PO	Shifting of 220kV AIS Bay No 9 to New GIS Bay No 18.
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
TALANDGE - BIDRI	IntraState	23/08/2023	09:32	23/08/2023	14:44	PO	Diagnostic Testing of CB

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 24/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY DHARAVI - 6	IntraState	23/08/2023	10:00	23/08/2023	19:49	PO	For 220KV TD-6 breaker LBBU testing, 220KV TD-6 Protection trial 220KV TD-6 Carrier Trials, 220KV TD-6 A/B/C Phase CVT Testing, 220KV TD-6 A/B/C Phase LA counter replacement at Trombay generating station.
PANDHARPUR - BHALVANI	IntraState	23/08/2023	10:09	23/08/2023	20:59	PO	Outage is required for Quarterly Maintenance
PANDHARPUR - BHALVANI	IntraState	23/08/2023	10:09	23/08/2023	20:59	PO	Outage is required for Quarterly Maintenance
KARAD -MUDSHINGI CKT- 4	IntraState	23/08/2023	10:18	23/08/2023	20:42	PO	For stringing of earth wire at tower loc no. 178 to 183 on dt. 23.08.2023.
WATHAR - MUDSHINGI 3 LINE	IntraState	23/08/2023	10:36	23/08/2023	20:40	PO	Replacement of LMU unit in presence of company representative & Quarterly maint. Work & diagnostic testing work
WATHAR - MUDSHINGI 3 LINE	IntraState	23/08/2023	10:36	23/08/2023	20:40	PO	For stringing of earth wire at tower loc no. 178 to 183 on dt. 23.08.2023.
LAMBOTI - TULJAPUR CKT - 2	IntraState	23/08/2023	10:50	23/08/2023	12:55	PO	For Bay Maintenance work
ONGC PANVEL - TSS PANVEL	IntraState	23/08/2023	11:28	23/08/2023	15:52	PO	For 220 kV TSS Line Y phase Line Side Isolator Jumper Replacement Work.
BIDRI - SAWANTWADI	IntraState	23/08/2023	15:16	23/08/2023	17:55	PO	Diagnostic Testing of CB
VAIRAG - AVAADA SOLAPR (PANGAON)	IntraState	23/08/2023	18:00	23/08/2023	19:05	PO	Outage is required for Quarterly Maintenance
PEDHAMBE ONI LINE	IntraState	23/08/2023	18:31			T	Tripped on Distance Protection.
MAIN BUS - 1 @ AAREY	IntraState	24/08/2023	07:48	24/08/2023	08:32	PO	CHARGING OF 220KV AAREY-AEML BORIVALI BAY NO 18 UNDER AIS TO GIS PROJECT WORK
HINJAWADI I- CHINCHWAD	IntraState	24/08/2023	08:25			PO	On. 24.08.23 Thursday a) Conductor paying out & Final sag (Location 160 to 161) & Top Ckt b) Installation of Missing parts & final checking of Monopole (160 & 161) On. 25.08.23 Friday a) Conductor paying out & Final Sag (Location 161 a to 162) & Top Ckt b) Installation of Missing parts & final checking of Monopole (161A&162) On. 26.08.23 Saturday Conductor paying out & Final sag(Location 161 to 161 A) & Circuit I & Top circuit On. 27.08.23 Sunday Conductor paying out & Final sag (Location 161 to 161 A) & circuit & II & Top Circuit On. 28.08.23 Monday Conductor paying out & Final sag (Location 161 to 161 A) & Circuit I & Bottom Circuit On. 29.08.23 Tuesday Conductor paying out & Final sag (Location 161 to 161 A) & circuit & II & Bottom Circuit
KHADKI- CENTURY ENKA	IntraState	24/08/2023	10:15			PO	Wave Trap Jump Replacement Work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 24/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - DHARAVI 9	IntraState	24/08/2023	10:28			PO	FOR R/M AND TESTING AT TROMBAY
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	23/08/2023	09:53	23/08/2023	11:14	PO	diagnostic testing work (CT Tan Delta) .
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	23/08/2023	10:06	23/08/2023	14:51	PO	Outage is required for Quarterly Maintenance
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	23/08/2023	11:24	23/08/2023	12:30	PO	diagnostic testing work (CT Tan Delta) .
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	IntraState	23/08/2023	12:35	23/08/2023	14:24	PO	diagnostic testing work (CT Tan Delta) .
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	24/08/2023	09:31			PO	Diagnostic testing work.
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	24/08/2023	10:28			PO	For CTR Maintenance Works & Trials
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage