

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Sep/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	115.835	2592.056	1) Gujrat	12.179	216.232
2) Hydro	8.484	271.078	2) Madhya Pradesh	9.486	82.294
3) Gas	2.164	61.538	3) Chattisgarh	3.510	82.400
Total MSPGCL	126.483	2924.672	4) Maharashtra	138.609	3457.707
B) 1) APLM	57.039	1447.052	5) Goa (Amona)	-1.299	-27.631
2) JSWEL	16.510	415.322	Total	162.485	3811.002
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.526	750.415
4) RPL(AMT)	16.428	376.008	b) Mumbai Drawl	36.503	828.373
5) SWPGPL	5.104	103.101	c) MSEDCL Bilateral *	73.977	1302.459
6) Other IPP	4.981	129.226	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.526	750.205
C) 1) TPCL Thermal	9.596	258.908	Include PX	0.000	0.000
2) TPCL Hydro	4.313	122.202	Standby	0.000	0.210
3) TPCL Gas	0.000	13.433	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.002	205.730	1) MSEDCL	384.241	8885.471
D) STATE			2) Mumbai Discoms	58.414	1428.647
1) Thermal	233.495	5527.403	3) Other Discoms	8.857	206.980
(A1+C1+C4+(B1-B6))			TOTAL STATE	451.512	10521.098
2) Hydro	12.797	393.280			
(A2+C2)					
3) Gas	2.164	74.971			
(A3+B7+C3)					
4) Wind	31.236	515.651			
6) SOLAR	9.335	198.790			
TOTAL STATE	289.027	6710.095			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5077	4463	5480	4343
MSPGCL Hydro	230	275	1108	163
MSPGCL Gas	90	88	89	94
MSPGCL Total Generation	5397	4826	6677	4600
Central Sector Receipt	7845	7117	6858	5411
WIND	1256	1061	1341	1544
CPP / IPP Thermal	4348	4069	5065	3800
CPP / IPP Gas	0	0	0	0
SOLAR	1123	1328	0	0
Exchange with Mumbai	-2014	-2220	-1459	-893
MSEDCL DEMAND MET	17551	15796	18076	14156
Load Shedding	0	0	0	0
MSEDCL DEMAND	17551	15796	18076	14156
TPCL GENERATION	477	477	767	563
AEML GENERATION	314	320	469	308
MUMBAI DEMAND	2805	3017	2695	1764
OTHER DISCOM DEMAND	404	385	406	306
STATE DEMAND MET	20760	19198	21177	16226
STATE DEMAND	20760	19198	21177	16226
Frequency (Hz)	50.05	50.02	50.04	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13.04 Hrs	49.68 Hz at 17.47 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.67	227.88	463	362
Unit 9	9.94	21.91	470	365
Unit 10	10.06	232.21	472	375
Total	29.67	521.36		
Bhusawal				
Unit 3	2.82	50.44	130	115
Unit 4	8.98	189.62	445	285
Unit 5	1.38	38.79	345	0
Total	13.19	278.85		
Parli				
Unit 6	4.13	97.89	225	147
Unit 7	3.92	79.96	202	144
Unit 8	3.59	84.66	168	140
Total	11.64	262.51		
Chandrapur				
Unit 3	3.05	66.30	150	120
Unit 4	2.98	68.64	142	117
Unit 5	6.35	121.59	310	230
Unit 6	6.85	127.04	335	236
Unit 7	7.26	129.99	350	274
Unit 8	0.00	49.00	0	0
Unit 9	8.29	213.60	426	274
Total	34.78	776.15		
Paras				
Unit 3	4.64	100.09	232	144
Unit 4	0.00	86.15	0	0
Total	4.64	186.24		
Khaparkheda				
Unit 1	2.74	59.77	125	100
Unit 2	0.00	38.82	0	0
Unit 3	2.98	76.36	142	0
Unit 4	3.35	67.92	173	125
Unit 5	7.25	184.54	400	265
Total	16.31	427.41		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	2.85	42.38	132	102
Unit 5	2.76	64.59	128	101
Total	5.61	139.54		
Uran				
All Units	2.16	61.54	94	85
Total	2.16	61.54		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	11.93	0	0
Total	0.00	11.93		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.42	50.90	205	35
Stage 4	1.53	42.86	447	0
Stage 3	0.91	24.90	240	0
Total	3.87	118.66		
Hydro				
KDPH	0.43	5.26	18	18
VTRNA	0.71	17.47	60	0
TILLARI	0.49	10.60	58	0
BHIRA T.R.	0.33	9.41	60	0
SMLHY_PTN	2.49	92.77	107	100
GHATGHAR	0.17	4.98	90	0
Total	4.62	140.49		
Wind				
Total	31.24	515.65	0	0
Total	31.24	515.65		
CPP				
APML(Mus)	57.04	1447.05	0	0
JSWEL(Mus)	16.51	415.32	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	16.43	376.01	0	0
SWPGPL-Mus	5.10	103.10	0	0
Other(Mus)	4.98	129.23	0	0
Total	100.06	2470.71		
SOLAR				
Total	9.34	198.79	0	0
Total	9.34	198.79		
Tata				
Trombay 5	6.38	174.17	270	260
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	8.68	0	0
Trombay 7B	0.00	4.76	0	0
TATA Hydro	4.31	122.20	370	56
Trombay 8	3.22	84.74	135	130
Total	13.91	394.54		
AEML				
DTPS U-1&2	8.00	205.73	469	292
Total	8.00	205.73		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	115.84	2592.06	MSPGCL Total	126.48	2924.67
			MSPGCL Thml+Gas	118.00	2653.59	Koyna 1,2 & 4 Total	2.96	93.76
			MSPGCL Hydro	8.48	271.08	State Total	289.03	6710.10

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 23/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4330	164	93	4587	1471	4038	0	0	5617	5855	-962	14658	0	14658	1895	331	16884	49.99
2	4343	163	94	4600	1544	3800	0	0	5316	5411	-893	14156	0	14156	1764	306	16226	49.98
3	4330	158	94	4582	1657	3968	0	0	5200	5406	-899	14444	0	14444	1676	270	16390	50.01
4	4318	158	94	4570	1617	3890	0	0	5161	5578	-874	14507	0	14507	1631	274	16412	50.04
5	4438	166	94	4698	1592	3967	0	0	5386	5883	-874	14984	0	14984	1639	282	16905	50.00
6	4637	261	94	4992	1464	4163	0	0	6244	6639	-958	15980	0	15980	1779	320	18079	49.97
7	5198	365	93	5656	1328	4537	0	38	7186	7562	-1150	17611	0	17611	1967	360	19938	49.99
8	5290	274	93	5657	1247	4392	0	241	7795	7931	-1363	17732	0	17732	2188	373	20293	50.01
9	5273	364	92	5729	1285	4410	0	655	7513	7840	-1718	17815	0	17815	2500	386	20701	50.05
10	5077	230	90	5397	1256	4348	0	1123	7901	7845	-2014	17551	0	17551	2805	404	20760	50.05
11	4486	237	89	4812	1214	4198	0	1337	8110	7827	-2195	16785	0	16785	3008	408	20201	50.04
12	4456	245	87	4788	1126	3906	0	1337	8070	7858	-2226	16396	0	16396	3049	393	19838	50.02
13	4463	275	88	4826	1061	4069	0	1328	7489	7117	-2220	15796	0	15796	3017	385	19198	50.02
14	4475	274	87	4836	1131	3592	0	1223	7492	7128	-2114	15391	0	15391	2870	405	18666	50.04
15	4609	280	86	4975	1256	3640	0	907	7077	7294	-2106	15563	0	15563	2881	403	18847	49.97
16	4456	278	85	4819	1273	4144	0	621	7439	7409	-2008	15851	0	15851	2910	407	19168	50.00
17	4726	275	87	5088	1327	3941	0	399	7416	7250	-1687	15906	0	15906	2751	412	19069	49.98
18	5051	288	87	5426	1278	4209	0	124	7331	6930	-1704	15855	0	15855	2862	408	19125	49.88
19	5366	1019	87	6472	1250	4635	0	2	7132	6590	-1752	16787	0	16787	2948	410	20145	49.98
20	5480	1108	89	6677	1341	5065	0	0	6950	6858	-1459	18076	0	18076	2695	406	21177	50.04
21	5332	894	90	6316	1310	4302	0	0	6749	6419	-1427	16518	0	16518	2556	402	19476	50.02
22	5408	569	90	6067	1174	4284	0	0	6435	6103	-1446	15786	0	15786	2491	396	18673	50.00
23	5106	262	90	5458	1014	4279	0	0	6017	6187	-1288	15275	0	15275	2338	375	17988	50.00
24	5187	177	91	5455	1020	4285	0	0	5764	5565	-1166	14817	0	14817	2194	342	17353	49.99
MUs	115.83	8.48	2.16	126.48	31.24	100.06	0.00	9.34	162.79	162.48	-36.50	384.24	0.00	384.24	58.41	8.86	451.51	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 23/Sep/2022

Position as on 6.30 Hrs of 24/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	24/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	14/09/2022	05:36		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	14/09/2022	05:50		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	14/09/2022	21:39	24/09/2022	12:57	ID Fan Problem	25/09/2022
MSPGCL	Khaparkheda Unit 2	210	17/09/2022	13:00		Continued.	wet coal	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	24/09/2022

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Sep/2022

Position as on 6.30 Hrs of 24/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 5	500	19/09/2022	22:30	23/09/2022	17:18	Boiler Tube Leakage	24/09/2022
MSPGCL	Khaparkheda Unit 3	210	23/09/2022	22:04		Continued.	Boiler Tube Leakage	
MSPGCL	Koyna STG-IV Unit-2	250	24/09/2022	18:23	24/09/2022	21:00	Generator Elect. Fault	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 24/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	13/09/2022	21:00			T	Reason awaited
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KORADI 2-WARDHA (PG)	InterState	21/09/2022	08:55			PO	Connecting 400 kv Koradi 2-Wardha PGCIL Deoli through new towers.
KORADI 2-WARDHA (PG)	InterState	21/09/2022	08:55			PO	Diversion of 400 kv Koradi-Wardha Line through 6 nos of Newly constructed tower of POWERGRID. Configuration of 400 kv Koradi Bays at Wardha shall remain the same. MSETCL 400 kv IEPL-Warora Line shall be in non- A/R Mode for safety precautions
KHADKA-AURANGABAD (WALUJ)	IntraState	22/09/2022	19:39	23/09/2022	08:50	HT	HT for Overvoltage Control
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	23/09/2022	09:15	23/09/2022	18:53	PO	Cold Line Washing work to be carried out in view of frequent tripping of line.
CHANDRAPUR-PARLI CKT-3	IntraState	23/09/2022	10:27	23/09/2022	18:36	PO	Hardware Tightening & Fitting Work
LONIKAND I -JEJURI	IntraState	23/09/2022	18:46	23/09/2022	21:45	EO	For Attending hot spot on R-ph 29C PGI of 400kv Jejuri Bay (Temp � 107 ˚C)
KHADKA-AURANGABAD (WALUJ)	IntraState	23/09/2022	20:16	24/09/2022	08:53	HT	HT for Overvoltage Control
CHANDRAPUR-PARLI CKT-3	IntraState	24/09/2022	08:53	24/09/2022	19:01	PO	for replacement of polymer insulator with log rod porcelain insulator strings
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/09/2022	09:14	24/09/2022	18:57	PO	Cold Line Washing work to be carried out in view of frequent tripping of line.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/09/2022	19:52		Continued.	T	TRIPPED ON DISTANCE PROTECTION
400 KV ICT Outages/Trippings							
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	23/09/2022	09:45	23/09/2022	17:22	PO	For attending hot spot at R ph BPI clamp of spare ICT which is now in service through RRS for ICT-I .Temp-150 degree, Also Tan delta & capacitance measurement of 400 kv & 220 kv CTs,winding,bushing of ICTs.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	24/09/2022	12:27	24/09/2022	19:45	EO	1) Replacement of Rph HV Bushing to gantry damaged jumper 2) Diagnostic Testing Work 3) Attending Oil leakage/hotspot if any 4) MTAMC work 5) NIFPS maint. work 6) For replacement of 70KN suspension type Disc of insulator by 120KN Disc insulator at LV Bay
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	23/09/2022	13:17	23/09/2022	17:57	EO	Rectification work of hot spots and damaged
EKLAHARE (OCR) - PADGHE	IntraState	19/09/2022	08:40	24/09/2022	12:15	HT	H/T TO CONTROL LINE LOADING OF BBLR

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 24/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - BIDRI	IntraState	23/09/2022	09:15	23/09/2022	17:44	PO	For CB timing, CRM & Tan delta testing
EKLAHARA(OCR)-RAYMOND	IntraState	23/09/2022	10:34	23/09/2022	12:50	EO	To attend red hot
SATANA - GANGAPUR	IntraState	23/09/2022	10:36			T	TRIPPED ON DISTANCE PROTECTION
CREEK SIDE BUS @ KALWA	IntraState	23/09/2022	11:26	23/09/2022	18:08	PO	Routine Maintenance works.
BAPGAON - KALWA	IntraState	23/09/2022	12:15	23/09/2022	14:05	EO	Shifting of 220KV Baggaon-Kalwa line on TBC Bay for own 245Kv CB Y Phase top palm nut-bolt hotspot attending work.
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	23/09/2022	16:36	23/09/2022	17:02	EO	RAISING SF6 GAS PRESSURE
CHINCHWAD-2 - TELCO	IntraState	23/09/2022	22:20	24/09/2022	07:16	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
CHAKAN - CHINCHWAD 2	IntraState	23/09/2022	22:35	24/09/2022	07:02	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
BUS SECTION - 1 @ BIDRI	IntraState	24/09/2022	09:52	24/09/2022	16:58	PO	For attending hotspot
BHALVANI - VARKUTI	IntraState	24/09/2022	10:34	24/09/2022	13:28	PO	Outage is required For Diagnostic Testing
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	24/09/2022	10:34	24/09/2022	13:13	PO	Refitting of Pilot strings suspension clamp at loc no 56 SD tower/ Tightening all Pilot clamps.
LONIKAND 2 - BHOSARI	IntraState	24/09/2022	11:51	24/09/2022	19:11	PO	Emergency tree cutting at loc no-36-37 and insulator cleaning work at loc no-32-36
TILLARI - AMONA LINE	IntraState	24/09/2022	14:05	24/09/2022	15:43	T	TRIPPED ON DISTANCE PROTECTION
PANDHARPUR - BHALVANI	IntraState	24/09/2022	14:05	24/09/2022	17:46	PO	Outage is required For Diagnostic Testing
CHINCHWAD-2 - TELCO	IntraState	24/09/2022	23:45		Continued.	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 25MVA TF NO.2 @ SAYNE	IntraState	15/09/2022	15:40	24/09/2022	20:20	PO	Work of Replacement of 220/33kv 25 MVA TF2 by 220/33kv 50MVA BHEL TF
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	21/09/2022	10:00			PO	OLTC Overhauling work
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/132KV 100MVA PTR 2 @ KHAREPATAN	IntraState	22/09/2022	16:35	23/09/2022	06:45	T	ICT 1 bursted due to which cable of ICT 2 was also burnt
220/22 KV 50 MVA PTR 2 @ ANANDNAGAR	IntraState	23/09/2022	10:00	23/09/2022	19:55	PO	PTR 2 Diagnostics testing work
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	23/09/2022	10:02	23/09/2022	18:30	PO	Quarterly Maintenance Work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 24/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 2 @ MAHAD	IntraState	23/09/2022	10:32	23/09/2022	13:50	PO	Hotspot attending work & Diagnostic testing work.
220/33KV 50MVA PTR 2 @ VITA	IntraState	24/09/2022	10:14	24/09/2022	17:15	PO	OLTC Overhauling Work
220/33KV 125 MVA TF 2 @ BORIVALI (AEML)	IntraState	24/09/2022	10:15	24/09/2022	21:14	PO	Reconnection of Disconnected 33kV cables.
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	24/09/2022	10:35	24/09/2022	17:20	PO	For CB Timing, CRM testing, Replacement of Insulator String
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	23/09/2022	14:42	23/09/2022	15:39	EO	Loc No:56 (Moverment of Crane under the 110KV line for 400KV Tower Erection work in Mankhurd)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage