

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 23/Oct/2024 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 153.164        | 3356.252        | 1) Gujrat                      | 5.070          | 181.503          |
| 2) Hydro            | 9.440          | 199.478         | 2) Madhya Pradesh              | 3.204          | 84.758           |
| 3) Gas              | 7.052          | 149.223         | 3) Chattisgarh                 | 4.700          | 82.980           |
| <b>Total MSPGCL</b> | <b>169.656</b> | <b>3704.953</b> | 4) Maharashtra                 | 204.527        | 4543.404         |
| B) 1) APML          | 48.124         | 1325.811        | 5) Goa (Amona)                 | -2.525         | -51.153          |
| 2) JSWEL            | 25.726         | 567.690         | <b>Total</b>                   | <b>214.976</b> | <b>4841.492</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 52.684         | 1126.127         |
| 4) RPL(AMT)         | 22.635         | 423.018         | b) Mumbai Drawl                | 56.180         | 1194.924         |
| 5) SWPGPL           | 8.603          | 206.420         | c) MSEDCL Bilateral *          | 87.789         | 2046.605         |
| 6) Other IPP        | 9.134          | 245.206         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 52.684         | 1121.793         |
| C) 1) TPCL Thermal  | 4.768          | 100.737         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 3.452          | 87.096          | Standby                        | 0.000          | 4.334            |
| 3) TPCL Gas         | 4.209          | 96.338          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 9.709          | 195.178         | 1) MSEDCL                      | 454.177        | 10445.114        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 78.318         | 1674.261         |
| 1) Thermal          | 281.863        | 6420.312        | 3) Other Discoms               | 12.566         | 280.801          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>545.061</b> | <b>12400.176</b> |
| 2) Hydro (A2+C2)    | 12.892         | 286.574         |                                |                |                  |
| 3) Gas (A3+B7+C3)   | 11.261         | 245.561         |                                |                |                  |
| 4) Wind             | 5.701          | 190.679         |                                |                |                  |
| 6) SOLAR            | 18.368         | 415.570         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>330.085</b> | <b>7558.696</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 5459                      | 6911                  | 6962                      | 6386                      |
| MSPGCL Hydro               | 239                       | 323                   | 1178                      | 544                       |
| MSPGCL Gas                 | 281                       | 278                   | 379                       | 294                       |
| MSPGCL Total Generation    | 5979                      | 7512                  | 8519                      | 7224                      |
| Central Sector Receipt     | 9455                      | 10003                 | 10002                     | 7335                      |
| WIND                       | 83                        | 399                   | 443                       | 217                       |
| CPP / IPP Thermal          | 3806                      | 5523                  | 5644                      | 4643                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2448                      | 243                   | 4                         | 0                         |
| Exchange with Mumbai       | -2639                     | -2561                 | -2380                     | -1823                     |
| <b>MSEDCL DEMAND MET</b>   | <b>18545</b>              | <b>20554</b>          | <b>21664</b>              | <b>17183</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 18545                     | 20554                 | 21664                     | 17183                     |
| TPCL GENERATION            | 556                       | 670                   | 811                       | 419                       |
| AEML GENERATION            | 497                       | 502                   | 502                       | 300                       |
| <b>MUMBAI DEMAND</b>       | <b>3692</b>               | <b>3733</b>           | <b>3693</b>               | <b>2542</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>587</b>                | <b>565</b>            | <b>568</b>                | <b>413</b>                |
| STATE DEMAND MET           | 22824                     | 24852                 | 25925                     | 20138                     |
| <b>STATE DEMAND</b>        | <b>22824</b>              | <b>24852</b>          | <b>25925</b>              | <b>20138</b>              |
| Frequency (Hz)             | 49.97                     | 50.04                 | 50.01                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.24 Hz at 13.02 Hrs | 49.8 Hz at 20.35 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 23/Oct/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.08         | 74.80         | 63       | 0        |
| Unit 8             | 10.50        | 272.58        | 470      | 361      |
| Unit 9             | 11.23        | 268.13        | 560      | 380      |
| Unit 10            | 11.52        | 264.05        | 590      | 370      |
| <b>Total</b>       | <b>33.33</b> | <b>879.55</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.22         | 61.96         | 160      | 115      |
| Unit 4             | 8.84         | 170.61        | 500      | 275      |
| Unit 5             | 8.51         | 193.00        | 475      | 285      |
| <b>Total</b>       | <b>20.58</b> | <b>425.57</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 3.82         | 87.05         | 222      | 141      |
| Unit 7             | 3.71         | 78.71         | 198      | 137      |
| Unit 8             | 3.88         | 88.44         | 210      | 146      |
| <b>Total</b>       | <b>11.42</b> | <b>254.20</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 1.52         | 76.42         | 179      | 0        |
| Unit 4             | 3.34         | 71.14         | 159      | 127      |
| Unit 5             | 7.53         | 175.51        | 375      | 275      |
| Unit 6             | 7.45         | 96.47         | 360      | 265      |
| Unit 7             | 7.55         | 171.21        | 349      | 274      |
| Unit 8             | 8.64         | 221.50        | 445      | 280      |
| Unit 9             | 9.22         | 66.51         | 465      | 279      |
| <b>Total</b>       | <b>45.24</b> | <b>878.77</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.28         | 103.24        | 235      | 141      |
| Unit 4             | 4.41         | 96.42         | 228      | 147      |
| <b>Total</b>       | <b>8.69</b>  | <b>199.66</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.60         | 67.71         | 170      | 115      |
| Unit 2             | 3.57         | 90.30         | 186      | 120      |
| Unit 3             | 3.84         | 80.78         | 171      | 130      |
| Unit 4             | 3.99         | 92.84         | 187      | 131      |
| Unit 5             | 9.77         | 219.83        | 485      | 290      |
| <b>Total</b>       | <b>24.77</b> | <b>551.46</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 2.96         | 75.22         | 136      | 109      |
| Unit 4             | 3.24         | 72.94         | 155      | 120      |
| Unit 5             | 2.95         | 18.87         | 138      | 99       |
| <b>Total</b>       | <b>9.14</b>  | <b>167.04</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.05         | 149.22        | 411      | 270      |
| <b>Total</b>       | <b>7.05</b>  | <b>149.22</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.42         | 18.62         | 38       | 0        |
| <b>Total</b>       | <b>0.42</b>  | <b>18.62</b>  |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 1.52         | 42.91         | 210      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 2.17          | 30.38          | 600      | 0        |
| Stage 3         | 0.84          | 17.13          | 208      | 0        |
| <b>Total</b>    | <b>4.53</b>   | <b>90.42</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.14          | 9.31           | 18       | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.54          | 5.69           | 62       | 0        |
| BHIRA T.R.      | 0.24          | 6.44           | 40       | 0        |
| SMLHY_PTN       | 3.49          | 81.32          | 152      | 132      |
| GHATGHAR        | 0.49          | 6.31           | 125      | 0        |
| <b>Total</b>    | <b>4.91</b>   | <b>109.06</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 5.70          | 190.68         | 0        | 0        |
| <b>Total</b>    | <b>5.70</b>   | <b>190.68</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 48.12         | 1325.81        | 0        | 0        |
| JSWEL(Mus)      | 25.73         | 567.69         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 22.64         | 423.02         | 0        | 0        |
| SWPGPL-Mus      | 8.60          | 206.42         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.44          | 129.98         | 271      | 183      |
| Other(Mus)      | 0.47          | 10.16          | 0        | 0        |
| JPL             | 3.22          | 105.07         | 136      | 131      |
| <b>Total</b>    | <b>114.22</b> | <b>2768.14</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 18.37         | 415.57         | 0        | 0        |
| <b>Total</b>    | <b>18.37</b>  | <b>415.57</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 0.00          | 0.00           | 0        | 0        |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.66          | 60.96          | 112      | 109      |
| Trombay 7B      | 1.54          | 35.37          | 65       | 64       |
| TATA Hydro      | 3.45          | 87.10          | 412      | 47       |
| Trombay 8       | 4.77          | 100.74         | 224      | 168      |
| <b>Total</b>    | <b>12.43</b>  | <b>284.17</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.71          | 195.18         | 503      | 300      |
| <b>Total</b>    | <b>9.71</b>   | <b>195.18</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 153.16      | 3356.25       | MSPGCL Total        | 169.66      | 3704.95       |
|                |             |         | MSPGCL Thml+Gas | 160.22      | 3505.48       | Koyna 1,2 & 4 Total | 3.70        | 73.29         |
|                |             |         | MSPGCL Hydro    | 9.44        | 199.48        | State Total         | 330.08      | 7558.70       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 23/Oct/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 6138        | 902  | 293  | 7333   | 253  | 4678      | 0    | 0     | 8330        | 8001        | -2213                | 17596                  | 0                | 0                           | 17596                         | 3009             | 456                       | 21061           | 50.00         |
| 2                  | 5961        | 852  | 294  | 7107   | 218  | 4583      | 0    | 0     | 7937        | 7865        | -2017                | 17323                  | 0                | 0                           | 17323                         | 2750             | 433                       | 20506           | 49.97         |
| 3                  | 6386        | 544  | 294  | 7224   | 217  | 4643      | 0    | 0     | 7294        | 7335        | -1823                | 17183                  | 0                | 0                           | 17183                         | 2542             | 413                       | 20138           | 49.98         |
| 4                  | 6581        | 210  | 295  | 7086   | 148  | 4734      | 0    | 0     | 7234        | 7604        | -1719                | 17433                  | 0                | 0                           | 17433                         | 2422             | 419                       | 20275           | 49.98         |
| 5                  | 6734        | 218  | 295  | 7247   | 106  | 4765      | 0    | 0     | 7746        | 7737        | -1674                | 17754                  | 0                | 0                           | 17754                         | 2369             | 427                       | 20550           | 49.98         |
| 6                  | 7208        | 218  | 294  | 7720   | 115  | 5047      | 0    | 0     | 8205        | 8243        | -1721                | 18941                  | 0                | 0                           | 18941                         | 2424             | 464                       | 21828           | 49.99         |
| 7                  | 7343        | 273  | 296  | 7912   | 124  | 5481      | 0    | 60    | 8668        | 8637        | -1846                | 19868                  | 0                | 0                           | 19868                         | 2548             | 500                       | 22916           | 50.01         |
| 8                  | 7030        | 310  | 294  | 7634   | 106  | 5205      | 0    | 483   | 8805        | 9042        | -1999                | 19944                  | 0                | 0                           | 19944                         | 2744             | 527                       | 23215           | 50.06         |
| 9                  | 6313        | 290  | 292  | 6895   | 103  | 4601      | 0    | 1263  | 8972        | 9037        | -2267                | 19062                  | 0                | 0                           | 19062                         | 3085             | 570                       | 22717           | 50.09         |
| 10                 | 5791        | 291  | 282  | 6364   | 130  | 4321      | 0    | 1996  | 9329        | 9028        | -2505                | 18743                  | 0                | 0                           | 18743                         | 3424             | 591                       | 22758           | 49.95         |
| 11                 | 5459        | 239  | 281  | 5979   | 83   | 3806      | 0    | 2448  | 9604        | 9455        | -2639                | 18545                  | 0                | 0                           | 18545                         | 3692             | 587                       | 22824           | 49.97         |
| 12                 | 5333        | 324  | 277  | 5934   | 121  | 3581      | 0    | 2586  | 8933        | 9386        | -2746                | 18270                  | 0                | 0                           | 18270                         | 3805             | 592                       | 22667           | 50.02         |
| 13                 | 5297        | 209  | 273  | 5779   | 138  | 3595      | 0    | 2705  | 8578        | 8892        | -2735                | 17825                  | 0                | 0                           | 17825                         | 3788             | 549                       | 22162           | 50.02         |
| 14                 | 5283        | 220  | 274  | 5777   | 168  | 3629      | 0    | 2438  | 8746        | 8947        | -2688                | 17717                  | 0                | 0                           | 17717                         | 3718             | 554                       | 21989           | 50.04         |
| 15                 | 5470        | 195  | 270  | 5935   | 206  | 3790      | 0    | 2014  | 9702        | 9587        | -2812                | 18164                  | 0                | 0                           | 18164                         | 3850             | 556                       | 22570           | 50.02         |
| 16                 | 5950        | 319  | 272  | 6541   | 218  | 4129      | 0    | 1436  | 9924        | 10203       | -2895                | 19065                  | 0                | 0                           | 19065                         | 3944             | 567                       | 23576           | 50.04         |
| 17                 | 6557        | 309  | 273  | 7139   | 209  | 4815      | 0    | 692   | 9712        | 9913        | -2811                | 19394                  | 0                | 0                           | 19394                         | 3873             | 563                       | 23830           | 49.98         |
| 18                 | 6911        | 323  | 278  | 7512   | 399  | 5523      | 0    | 243   | 9735        | 10003       | -2561                | 20554                  | 0                | 0                           | 20554                         | 3733             | 565                       | 24852           | 50.04         |
| 19                 | 6962        | 1178 | 379  | 8519   | 443  | 5644      | 0    | 4     | 9682        | 10002       | -2380                | 21664                  | 0                | 0                           | 21664                         | 3693             | 568                       | 25925           | 50.01         |
| 20                 | 7003        | 790  | 411  | 8204   | 448  | 5656      | 0    | 0     | 9901        | 10112       | -2343                | 21534                  | 0                | 0                           | 21534                         | 3581             | 543                       | 25658           | 50.04         |
| 21                 | 7043        | 405  | 280  | 7728   | 460  | 5664      | 0    | 0     | 9559        | 9616        | -2516                | 20405                  | 0                | 0                           | 20405                         | 3427             | 548                       | 24379           | 49.95         |
| 22                 | 6977        | 221  | 283  | 7481   | 503  | 5670      | 0    | 0     | 9184        | 9297        | -2542                | 19873                  | 0                | 0                           | 19873                         | 3333             | 536                       | 23742           | 50.01         |
| 23                 | 6961        | 172  | 285  | 7418   | 419  | 5587      | 0    | 0     | 8859        | 8574        | -2492                | 18976                  | 0                | 0                           | 18976                         | 3288             | 529                       | 22794           | 49.97         |
| 24                 | 6473        | 428  | 287  | 7188   | 366  | 5079      | 0    | 0     | 8853        | 8460        | -2236                | 18347                  | 0                | 0                           | 18347                         | 3276             | 510                       | 22133           | 49.97         |
| MUs                | 153.16      | 9.44 | 7.05 | 169.66 | 5.70 | 114.22    | 0.00 | 18.37 | 213.49      | 214.98      | -56.18               | 454.18                 | 0.00             | 0.00                        | 454.18                        | 78.32            | 12.57                     | 545.06          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

| Maximum Demand scenario for the date 23/Oct/2024 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 25925 MW                                         | 21664 MW                         | 3944 MW                           |
| 19 Hrs                                           | 19 Hrs                           | 16 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 23/Oct/2024**

Position as on 6.30 Hrs of 24/Oct/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Koyna Unit 4            | 70       | 23/10/2024   | 08:15        | 23/10/2024 | 18:00      | Bi-monthly preventive maintenance                                                                                                                       | 23/10/2024    |
| MSPGCL                        | Koyna Unit 1            | 70       | 24/10/2024   | 08:00        |            | Continued. | Bi-monthly preventive maintenance                                                                                                                       | 24/10/2024    |
| Total Capacity MSPGCL         |                         | 140      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | SWPGPL U-3              | 135      | 09/10/2024   | 01:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 26/10/2024    |
| Total Capacity IPP            |                         | 135      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE |                         | 275      |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/10/2024    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 26/11/2024    |
| MSPGCL                        | Koradi Unit 6           | 210      | 20/10/2024   | 20:45        | 23/10/2024 | 22:20      | ID Fan Problem                                                                                                                                          | 23/10/2024    |
| MSPGCL                        | Chandrapur Unit 3       | 210      | 23/10/2024   | 11:05        |            | Continued. | SUSPECTED BTL IN ECONOMISER ZONE.                                                                                                                       | 25/10/2024    |
| MSPGCL                        | Koradi Unit 8           | 660      | 24/10/2024   | 01:30        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 26/10/2024    |
| MSPGCL                        | Parli Unit 8            | 250      | 24/10/2024   | 08:55        |            | Continued. | furnace pressure very high                                                                                                                              |               |
| Total Capacity MSPGCL         |                         | 1575     |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         | Trombay 5               | 500      | 22/09/2024   | 16:14        |            | Continued. | Emergency withdrwan due to fire in cable vault.                                                                                                         |               |
| Total Capacity TPC-G          |                         | 500      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                                                                  | 31/10/2024    |
| IPP                           | JPL Unit 1              | 150      | 20/10/2024   | 15:11        |            | Continued. | Turbine bearing Vabration high                                                                                                                          | 03/11/2024    |
| IPP                           | Adani U-5               | 660      | 23/10/2024   | 10:21        |            | Continued. | APH-A HOT PA bellow leakage                                                                                                                             | 26/10/2024    |
| Total Capacity IPP            |                         | 1080     |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/12/2024    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/11/2024    |
| Total Capacity CENT.SECTOR    |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE  |                         | 3475     |              |              |            |            |                                                                                                                                                         |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 23/Oct/2024**

Position as on 6.30 Hrs of 24/Oct/2024

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                        | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-----------------------------------------|---------------|
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 14/10/2024   | 16:49        |           | Continued. | Zero Schedule By MSEDCL.                |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 21/10/2024   | 20:15        |           | Continued. | Zero Schedule Given By MSEDCL.          |               |
| Total Capacity MSPGCL                         |                         | 216      |              |              |           |            |                                         |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 216      |              |              |           |            |                                         |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                         |               |
| IPP                                           |                         |          |              |              |           |            |                                         |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                    |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                    |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019) |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)  |               |
| Total Capacity IPP                            |                         | 988      |              |              |           |            |                                         |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |           |            |                                         |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 23/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 24/Oct/2024

| Name of Line                                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                |
|----------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV TIEBAY Outages/Trippings</b>                   |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                 |
| TIE BAY (712) OF 765/400KV ICT-2 AND BUS RECTOR @ EKTUNI | IntraState                | 23/10/2024   | 10:41        | 23/10/2024 | 19:37      | PO          | Routine testing and Maintenance Works.                                                                                                                                                                                                                                                                                          |
| <b>765 KV LINE Outages/Trippings</b>                     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                 |
| 765KV-PUNE-GIS-AURANGABAD-1                              | InterState                | 22/10/2024   | 10:38        | 23/10/2024 | 23:22      | HT          | Load Management                                                                                                                                                                                                                                                                                                                 |
| <b>500 KV LR Outages/Trippings</b>                       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                 |
| POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC       | IntraState                | 24/10/2024   | 00:51        | 24/10/2024 | 03:19      | EO          | For attending hot spot at various locations, supported images are attached.                                                                                                                                                                                                                                                     |
| <b>400 KV TIEBAY Outages/Trippings</b>                   |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                 |
| TIE BAY (402) OF ICT - 1 & LINE - 4 @ KORADI 3           | IntraState                | 23/10/2024   | 09:10        | 23/10/2024 | 17:00      | PO          | Annual Maintenance of Bay Equipment at Koradi-III SS.                                                                                                                                                                                                                                                                           |
| TIE BAY (411) OF RPL CKT - 2 & AKOLA-1 CKT-2 @ AKOLA 2   | IntraState                | 23/10/2024   | 09:37        | 23/10/2024 | 18:30      | PO          | Annual Maintenance of Bay Equipment at Akola-II SS.                                                                                                                                                                                                                                                                             |
| TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI           | IntraState                | 23/10/2024   | 11:16        | 23/10/2024 | 14:28      | PO          | For attending compressor wiring problem.                                                                                                                                                                                                                                                                                        |
| <b>400 KV MAINBAY Outages/Trippings</b>                  |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                 |
| MAIN BAY - 412 OF WARDHA PGCIL @ KORADI 2                | IntraState                | 16/10/2024   | 10:19        |            |            | PO          | Overhauling of CB by Agency                                                                                                                                                                                                                                                                                                     |
| BUS COUPLER @ KORADI                                     | IntraState                | 23/10/2024   | 12:40        | 23/10/2024 | 17:23      | EO          | Emergency work on 400kV Bus-Coupler Bay for attending hotspot on Circuit Breaker 129 $\angle$ C on B Phase & 117 $\angle$ C Y Phase clamp nut bolt.                                                                                                                                                                             |
| <b>400 KV LINE Outages/Trippings</b>                     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                 |
| PUNE(GIS) - TALEGAON(PG) CKT - 1                         | InterState                | 22/10/2024   | 04:30        | 23/10/2024 | 02:13      | T           | Tripped on distance protection                                                                                                                                                                                                                                                                                                  |
| BUS REACTOR (50MVAR) @ PARLI                             | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.                                                                                                                                                                                                                                                             |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                      | IntraState                | 04/10/2024   | 08:31        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                                                                                        |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                      | IntraState                | 22/10/2024   | 13:29        | 23/10/2024 | 04:16      | HT          | Line hand trip for Load managment.                                                                                                                                                                                                                                                                                              |
| PADGHE - KALWA CKT - 2                                   | IntraState                | 23/10/2024   | 03:47        |            |            | PO          | During this outage, Kalwa Padghe Ckt -2 for the work of erection of 1 Nos of QD+9 towers and stringing on newly erected towers in Loc. No 1096 for the work of shifting/height rising of various EHV (400/220kV) Transmission lines infringing in Mumbai-Ahmedabad High Speed Rail Corporation Ltd. (NHSRCL) corridor under ORC |
| 220 KV DHULE (400 KV) - DHULE I/C -2                     | IntraState                | 23/10/2024   | 09:45        | 24/10/2024 | 00:15      | HT          | Diagnostic testing of cb & ct and bay maintenance work at both local and remote end. also at remote end work of converting single conductor to twin conductor from bus isolator to bus jumper by hotline team.                                                                                                                  |
| CHANDRAPUR 2 - WARORA CKT-2                              | IntraState                | 23/10/2024   | 10:35        | 23/10/2024 | 15:47      | PO          | Diagnostic testing and allied bay maintenance work                                                                                                                                                                                                                                                                              |
| CHANDRAPUR-PARLI CKT-3                                   | IntraState                | 23/10/2024   | 13:10        | 23/10/2024 | 19:36      | PO          | For replacement of polymer insulator string with long rod porcelain insulator string.                                                                                                                                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>                      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                 |
| STATION TF No 3 @ CHANDRAPUR GCR                         | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                                                                  |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 23/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 24/Oct/2024

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                   |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 400/132 KV 200 MVA ICT - 2 @ KHADKA     | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                                                                                                                                                                            |
| 400/220/33 KV 500MVA ICT - 2 @ WARORA   | IntraState                | 23/10/2024   | 06:34        |            |            | PO          | PROJECT RELATED WORK OF ERECTION OF 3X 167MVA 400/220/33KV ICT 1 IS IN PROCESS , FOR SAFETY PURPOSE AND AVOID INDUCTION EFFECT TO MOVEMENT OF HYDRA .                                                                                                                                                                                                                                              |
| 400/220 KV 315MVA ICT - 2 @ KARAD       | IntraState                | 23/10/2024   | 08:52        | 23/10/2024 | 18:23      | PO          | To attend oil leakage & replacement of MOG And Buchholz relay and maintenance work.                                                                                                                                                                                                                                                                                                                |
| <b>400 KV BR Outages/Tripping</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BUS REACTOR (80 MVA) - 1 @ BABHALESHWAR | IntraState                | 07/10/2024   | 09:40        |            |            | PO          | The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order |
| <b>220 KV TBC Outages/Tripping</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BUS COUPLER @ PHURSUNGI                 | IntraState                | 22/10/2024   | 12:33        | 23/10/2024 | 03:05      | HT          | For load management                                                                                                                                                                                                                                                                                                                                                                                |
| BUS COUPLER @ VILEBHAGAD                | IntraState                | 23/10/2024   | 10:40        | 23/10/2024 | 15:12      | PO          | Relay testing by testing team K'gaon & diagnostic testing by S/s                                                                                                                                                                                                                                                                                                                                   |
| <b>220 KV MAINBAY Outages/Tripping</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| 220KV YAWATMAL- WARDHA(DEOLI) PG CKT 1  | InterState                | 23/10/2024   | 09:56        | 23/10/2024 | 18:01      | PO          | FOR LINE BAY AMP WORKS                                                                                                                                                                                                                                                                                                                                                                             |
| 220KV BUS SECTION BAY @ PEDAMBE         | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                                                                                                                                       |
| 220 KV BUS COUPLER                      | IntraState                | 23/10/2024   | 17:23        | 23/10/2024 | 18:35      | HT          | Diagnostic testing of bay equipments.                                                                                                                                                                                                                                                                                                                                                              |
| <b>220 KV LINE Outages/Tripping</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BALE - SOLAPUR (PG)                     | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                      |
| OSMANABAD - SOLAPUR (BALE)              | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                      |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2   | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                                                                                                                                                |
| GHODBUNDER - GORAI                      | IntraState                | 29/07/2024   | 12:14        |            |            | PO          | Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.                                                                                                                                                                                                                                                                |
| 220kV Koradi-2 - Uppalwadi ckt 2        | IntraState                | 28/08/2024   | 00:14        |            |            | T           | Distance Protection                                                                                                                                                                                                                                                                                                                                                                                |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 23/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 24/Oct/2024

| Name of Line                                    | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                  |
|-------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| EKLAHARE (OCR) - PADGHE                         | IntraState                | 24/09/2024   | 07:48        |            |            | HT          | For load mgmt                                                                                                                                                                                                                     |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I       | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                           |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II      | IntraState                | 01/10/2024   | 13:11        |            |            | HT          | H/T From Koradi 2 end                                                                                                                                                                                                             |
| EKLAHARE (OCR) - NAVASARI CKT - 1               | IntraState                | 07/10/2024   | 15:10        |            |            | HT          | H/T For load management.                                                                                                                                                                                                          |
| EKLAHARE (OCR) - NAVASARI CKT - 2               | IntraState                | 09/10/2024   | 12:00        |            |            | PO          | 1) PLCC, CVT, WT Foundation , Erection, Testing & Commissioning work at 220kv Navsari substation 2) PLCC, CVT, WT Erection, Testing & Commissioning work at 220kv Eklahare (OCR) substation                                       |
| KARAD - DASGAON                                 | IntraState                | 14/10/2024   | 15:46        |            |            | PO          | i)Dismantling of Exst. S/C Tower Loc. No. 160 of 220 KV KaradDasgaon (Pedambe) line. ii) Foundation of In-Line M/C Narrow Base Tower (MCN+3). iii) Erection of Tower & stringing of 220 KV Karad - Dasgaon & 220 Karad Koyna line |
| KALWA - PRINT HOUSE LINE                        | IntraState                | 15/10/2024   | 16:31        |            |            | HT          | Hand tripped at Kalwa end for load management.                                                                                                                                                                                    |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1   | IntraState                | 16/10/2024   | 16:01        |            |            | HT          | Line Hand tripped for load management on 220kv Ulve - Waghivali ckt no 1.                                                                                                                                                         |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2   | IntraState                | 17/10/2024   | 06:26        |            |            | HT          | H/T for controlling load of 220kv Ulve-Waghivali ckt-1                                                                                                                                                                            |
| KALWA - PANCHANAND                              | IntraState                | 17/10/2024   | 12:10        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kv Taloja.                                                                                                             |
| KALWA - PRINT HOUSE LINE                        | IntraState                | 17/10/2024   | 12:23        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kv Taloja.                                                                                                             |
| HINJAWADI I- CHINCHWAD                          | IntraState                | 22/10/2024   | 08:22        | 23/10/2024 | 00:56      | HT          | For Load Management                                                                                                                                                                                                               |
| SAHARA-URSE                                     | IntraState                | 22/10/2024   | 12:39        | 23/10/2024 | 03:28      | HT          | For load management                                                                                                                                                                                                               |
| RANJANGAON - LONIKAND 2                         | IntraState                | 22/10/2024   | 13:06        | 23/10/2024 | 03:17      | HT          | For load management                                                                                                                                                                                                               |
| AMRAPUR - TAPTITANDA CKT - 2                    | IntraState                | 22/10/2024   | 14:02        | 23/10/2024 | 02:28      | T           | Distance Protection                                                                                                                                                                                                               |
| 132 KV KURDUWADI - PARANDA (220 KV) CKT         | IntraState                | 22/10/2024   | 18:25        |            |            | T           | Distance Protection                                                                                                                                                                                                               |
| URAN - ULWE GIS CKT - 1                         | IntraState                | 23/10/2024   | 06:29        | 23/10/2024 | 08:18      | EO          | Rph CT Hot spot Attending Work.                                                                                                                                                                                                   |
| ALEPHATA-PARGAON(KATHAPUR)                      | IntraState                | 23/10/2024   | 06:57        |            |            | HT          | Load management .                                                                                                                                                                                                                 |
| HINJAWADI I- CHINCHWAD                          | IntraState                | 23/10/2024   | 07:11        | 23/10/2024 | 21:06      | HT          | Load management .                                                                                                                                                                                                                 |
| POPHLI PEDHMBE LINE- 1                          | IntraState                | 23/10/2024   | 09:00        | 23/10/2024 | 11:00      | EO          | 220 KV P'mbe-Pophali I Line R phase CT Oil top up work                                                                                                                                                                            |
| EKLAHARE (GCR) - AIROLI KNOW PARK               | IntraState                | 23/10/2024   | 09:48        | 23/10/2024 | 15:09      | HT          | Load management .                                                                                                                                                                                                                 |
| 220kv Koradi-2 - Uppalwadi ckt 1                | IntraState                | 23/10/2024   | 09:55        | 23/10/2024 | 19:44      | HT          | Installation for cable termination activities.                                                                                                                                                                                    |
| 220KV BHUGAON-WARORA(400KV) CKT 1               | IntraState                | 23/10/2024   | 10:04        | 23/10/2024 | 12:33      | HT          | Routine maintenance , c and tan delta measurement of line ct ,ir values maintenance of bay equipment etc.                                                                                                                         |
| MIRAJ - MHAISHAL                                | IntraState                | 23/10/2024   | 10:10        | 23/10/2024 | 12:02      | PO          | Diagnostic Testing Work                                                                                                                                                                                                           |
| SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 2 | IntraState                | 23/10/2024   | 10:44        | 23/10/2024 | 18:47      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                      |
| 132 KV JALNA (220 KV) RAJUR CKT - II            | IntraState                | 23/10/2024   | 10:47        | 23/10/2024 | 18:08      | HT          | CT tan delta CB CRM.                                                                                                                                                                                                              |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 23/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 24/Oct/2024

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                   |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------|
| MAHAD - KANDALGAON                       | IntraState                | 23/10/2024   | 11:13        | 23/10/2024 | 19:07      | EO          | Emergency outage on 220 KV Mahad-Kandalgaon line at Mahad S/S for Hot-Spot attending work at R-ph Wave Trap palm . |
| MAIN BUS - 2 @ SOUTH SOLAPUR             | IntraState                | 23/10/2024   | 11:40        | 23/10/2024 | 18:00      | PO          | Outage is required for Quarter Maintenance                                                                         |
| 220 KV BALAPUR - MALKAPUR LINE           | IntraState                | 23/10/2024   | 12:09        | 23/10/2024 | 14:53      | HT          | Fixing of turbo bird guard on tower loc no 117 to 131 under ehv line maintenance sub division, khamgaon.           |
| KADEGAON-MIRAJ                           | IntraState                | 23/10/2024   | 12:17        | 23/10/2024 | 13:26      | PO          | Diagnostic Testing Work                                                                                            |
| 220KV BHUGAON-WARORA(400KV) CKT 2        | IntraState                | 23/10/2024   | 13:12        | 23/10/2024 | 15:02      | HT          | Routine maintainance , c and tan delta measurement of line ct ,ir values & maintenance of bay equipment etc.       |
| NAGOTHANE - POSCO                        | IntraState                | 23/10/2024   | 13:30        | 23/10/2024 | 17:04      | T           | Distance Protection                                                                                                |
| SHIVAJINAGAR - GANGAPUR                  | IntraState                | 23/10/2024   | 15:05        | 23/10/2024 | 17:17      | HT          | Diagnostic testing of bay equipments.                                                                              |
| 220 KV PARAS - MALKAPUR CKT              | IntraState                | 23/10/2024   | 15:12        | 23/10/2024 | 17:06      | HT          | Fixing of turbo bird guard on tower loc no 117 to 131 under ehv line maintenance sub division, khamgaon.           |
| GHATGHAR - JINDAL                        | IntraState                | 23/10/2024   | 15:26        | 23/10/2024 | 15:43      | HT          | Load management .                                                                                                  |
| EKLAHARE (GCR) - AIROLI KNOW PARK        | IntraState                | 23/10/2024   | 16:35        | 23/10/2024 | 23:50      | HT          | Load management .                                                                                                  |
| ADLABS - PEDAMBE                         | IntraState                | 23/10/2024   | 20:58        |            |            | T           | Distance Protection                                                                                                |
| KOLSHET - KHARBAO                        | IntraState                | 24/10/2024   | 00:13        | 24/10/2024 | 03:57      | PO          | For safety purpose for Work of metro rail project under near kolshet s/s                                           |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                    |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR   | IntraState                | 12/07/2024   | 13:35        |            |            | PO          | Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.                                                |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2         | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                        |
| 220/132 KV 100 MVA ICT I @ UPPALWADI     | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                        |
| 220/132 KV 100 MVA ICT II @ UPPALWADI    | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                        |
| 220/132KV 100MVA PTR 2 @ KHAREPATAN      | IntraState                | 21/10/2024   | 10:02        |            |            | PO          | HV CB poll overhauling activities.                                                                                 |
| 220/33 KV 50 MVA PTR 1 @ MALEGAON        | IntraState                | 23/10/2024   | 09:32        | 23/10/2024 | 20:26      | T           | bursting of Y ph pole of Incomer 1.                                                                                |
| 220/132 KV 200 MVA ICT 1 @ MALEGAON      | IntraState                | 23/10/2024   | 10:13        | 23/10/2024 | 00:02      | HT          | Oil filtration of ict 2) oltc overhauling work.                                                                    |
| 220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR  | IntraState                | 23/10/2024   | 11:29        | 23/10/2024 | 15:55      | PO          | Outage is required for ICT-2 HV-89B bus Isolator maintainance.                                                     |
| 220/132KV 200 MVA ICT 2 @ KANHAN         | IntraState                | 23/10/2024   | 12:05        | 23/10/2024 | 14:52      | HT          | Diagnostic testing work.                                                                                           |
| 220/33 KV 50MVA T/F - 2 @ MIRAJ          | IntraState                | 23/10/2024   | 14:37        | 23/10/2024 | 16:52      | PO          | Diagnostic testing work                                                                                            |
| 220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR | IntraState                | 23/10/2024   | 16:02        | 23/10/2024 | 17:32      | PO          | Outage is required for ICT-1 HV-89B bus Isolator maintainance.                                                     |
| 220/132 KV 100 MVA ICT 1                 | IntraState                | 23/10/2024   | 18:31        | 23/10/2024 | 18:39      | HT          | LV side iso.sparking problem.                                                                                      |
| 220/132 KV 200 MVA ICT 1 @ MALEGAON      | IntraState                | 24/10/2024   | 10:13        | 24/10/2024 | 00:02      | HT          | Oil filtration of ict 2) oltc overhauling work.                                                                    |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                    |
| MANSAR-PENCH                             | InterState                | 26/09/2024   | 14:40        |            |            | HT          | H/T at 132KV Pench end                                                                                             |
| CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP | IntraState                | 16/10/2024   | 07:02        |            |            | HT          | For Load Management                                                                                                |
| <b>110 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                    |
| BHIRA (T) - DAVDI                        | IntraState                | 23/10/2024   | 07:35        | 23/10/2024 | 10:13      | EO          | Attending hotspot near CT at Davdi of 110 KV Bhira Davdi Line                                                      |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 23/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 24/Oct/2024

| Name of Line               | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                |
|----------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|---------------------------------|
| AMBERNATH - KALYAN CKT - 1 | IntraState                   | 23/10/2024      | 10:40           | 23/10/2024 | 20:33         | PO             | Old brass insualtor replacement |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage