

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Dec/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.089	3492.664	1) Gujrat	-6.073	-144.320
2) Hydro	12.181	249.046	2) Madhya Pradesh	1.448	34.594
3) Gas	3.312	99.849	3) Chattisgarh	5.300	123.260
Total MSPGCL	177.582	3841.559	4) Maharashtra	182.838	3967.093
B) 1) APLM	50.112	1440.435	5) Goa (Amona)	-1.148	-29.369
2) JSWEL	11.779	292.386	Total	182.365	3951.258
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.115	669.206
4) RPL(AMT)	31.119	658.410	b) Mumbai Drawl	31.698	773.229
5) SWPGPL	9.148	192.642	c) MSEDCL Bilateral *	65.590	1681.236
6) Other IPP	44.622	1015.475	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.115	668.702
C) 1) TPCL Thermal	11.263	253.399	Include PX	0.000	0.000
2) TPCL Hydro	3.355	91.251	Standby	0.000	0.504
3) TPCL Gas	1.682	34.531	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.827	228.161	1) MSEDCL	484.084	10886.531
D) STATE			2) Mumbai Discoms	57.825	1380.572
1) Thermal	329.959	7573.572	3) Other Discoms	9.107	216.243
(A1+C1+C4+(B1-B6))			TOTAL STATE	551.016	12483.346
2) Hydro	15.536	340.297			
(A2+C2)					
3) Gas	4.994	134.380			
(A3+B7+C3)					
4) Wind	5.208	229.219			
6) SOLAR	12.954	254.619			
TOTAL STATE	368.651	8532.087			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	7047	6928	6995	6401
MSPGCL Hydro	1164	134	958	167
MSPGCL Gas	138	135	136	139
MSPGCL Total Generation	8349	7197	8089	6707
Central Sector Receipt	8734	9324	6518	6463
WIND	115	132	324	207
CPP / IPP Thermal	6619	6423	6754	5514
CPP / IPP Gas	0	0	0	0
SOLAR	1726	1905	0	0
Exchange with Mumbai	-1599	-1658	-1210	-1242
MSEDCL DEMAND MET	23556	22947	20052	17280
Load Shedding	0	0	0	0
MSEDCL DEMAND	23556	22947	20052	17280
TPCL GENERATION	822	765	1034	486
AEML GENERATION	501	476	497	287
MUMBAI DEMAND	2922	2899	2741	2015
OTHER DISCOM DEMAND	388	376	423	369
STATE DEMAND MET	26866	26222	23216	19664
STATE DEMAND	26866	26222	23216	19664
Frequency (Hz)	49.93	50.17	50.12	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.41 Hz at 14.03 Hrs	49.69 Hz at 09.14 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.98	115.14	215	195
Unit 7	0.00	0.00	0	0
Unit 8	12.63	294.36	555	495
Unit 9	12.47	299.86	563	485
Unit 10	12.33	297.18	543	439
Total	42.41	1006.54		
Bhusawal				
Unit 3	3.39	16.47	190	115
Unit 4	10.50	230.79	495	280
Unit 5	10.22	233.37	490	280
Total	24.10	480.63		
Parli				
Unit 6	4.54	100.23	237	146
Unit 7	4.65	102.50	248	140
Unit 8	3.90	78.18	180	144
Total	13.09	280.91		
Chandrapur				
Unit 3	3.43	76.69	155	120
Unit 4	2.68	71.29	127	102
Unit 5	7.02	147.35	320	255
Unit 6	8.55	173.16	410	283
Unit 7	0.00	0.00	0	0
Unit 8	9.53	191.76	460	251
Unit 9	11.53	236.42	500	450
Total	42.76	896.68		
Paras				
Unit 3	5.25	101.02	233	204
Unit 4	5.56	104.62	243	217
Total	10.82	205.64		
Khaparkheda				
Unit 1	2.58	63.32	120	100
Unit 2	3.00	64.51	138	115
Unit 3	3.79	79.51	181	131
Unit 4	3.22	75.17	152	126
Unit 5	10.19	196.53	455	405
Total	22.78	479.03		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.10	72.77	143	78
Unit 5	3.03	47.16	143	110
Total	6.13	143.24		
Uran				
All Units	3.31	99.85	144	133
Total	3.31	99.85		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	3.52	34	0
Total	0.16	3.52		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.48	76.68	445	40
Stage 4	3.88	70.50	507	0
Stage 3	1.61	31.93	320	0
Total	8.97	179.10		
Hydro				
KDPH	0.43	6.19	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.64	11.38	58	0
BHIRA T.R.	0.26	5.09	77	0
SMLHY_PTN	1.16	30.99	51	44
GHATGHAR	0.55	12.76	125	0
Total	3.05	66.42		
Wind				
Total	5.21	229.22	0	0
Total	5.21	229.22		
CPP				
APML(Mus)	50.11	1440.44	0	0
JSWEL(Mus)	11.78	292.39	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.12	658.41	0	0
SWPGPL-Mus	9.15	192.64	0	0
Other(Mus)	44.62	1015.48	0	0
Total	146.78	3599.35		
SOLAR				
Total	12.95	254.62	0	0
Total	12.95	254.62		
Tata				
Trombay 5	7.40	166.39	422	233
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.89	19.24	41	36
Trombay 7B	0.79	15.29	37	31
TATA Hydro	3.36	91.25	344	12
Trombay 8	3.87	87.01	232	131
Total	16.30	379.18		
AEMIL				
DTPS U-1&2	9.83	228.16	501	287
Total	9.83	228.16		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.09	3492.66	MSPGCL Total	177.58	3841.56
			MSPGCL Thml+Gas	165.40	3592.51	Koyna 1,2 & 4 Total	7.36	147.17
			MSPGCL Hydro	12.18	249.05	State Total	368.65	8532.09

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 23/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6285	165	140	6590	125	5442	0	0	7308	7359	-1343	17804	0	17804	2128	369	20301	50.01
2	6271	160	141	6572	143	5413	0	0	7273	7247	-1223	17813	0	17813	1992	339	20144	49.98
3	6284	161	141	6586	216	5452	0	0	7213	7183	-1124	17995	0	17995	1885	318	20198	49.92
4	6271	169	142	6582	235	5513	0	0	7318	7336	-1047	18306	0	18306	1813	313	20432	49.98
5	6261	164	141	6566	262	5487	0	0	7476	7640	-1037	18609	0	18609	1805	309	20723	49.93
6	6677	245	141	7063	242	5810	0	0	7546	8065	-1123	19711	0	19711	1899	346	21956	49.96
7	7084	562	144	7790	251	6191	0	1	7734	7538	-1175	20223	0	20223	2039	373	22635	50.03
8	7141	1456	144	8741	290	6601	0	202	7116	7200	-1061	21589	0	21589	2202	384	24175	49.98
9	7086	1180	144	8410	149	6734	0	787	7136	7429	-1232	21889	0	21889	2492	388	24769	50.00
10	7015	691	137	7843	115	6642	0	1298	7873	8074	-1413	22156	0	22156	2744	402	25303	49.84
11	7047	1164	138	8349	115	6619	0	1726	8445	8734	-1599	23556	0	23556	2922	388	26866	49.93
12	6967	497	135	7599	98	6581	0	1907	8952	9067	-1687	23171	0	23171	2962	394	26527	50.05
13	6928	134	135	7197	132	6423	0	1905	8965	9324	-1658	22947	0	22947	2899	376	26222	50.17
14	6959	291	134	7384	105	6206	0	1792	8536	8732	-1527	22306	0	22306	2740	386	25432	50.25
15	6949	559	134	7642	195	5987	0	1570	8910	9053	-1559	22495	0	22495	2744	393	25632	50.13
16	7006	625	135	7766	184	6136	0	1113	8516	8568	-1487	21887	0	21887	2775	393	25055	49.99
17	7020	830	134	7984	260	6560	0	580	7518	7299	-1304	20983	0	20983	2764	396	24143	49.99
18	6988	898	133	8019	253	6705	0	73	6854	6849	-1168	20310	0	20310	2721	421	23452	50.05
19	6995	958	136	8089	324	6754	0	0	6781	6518	-1210	20052	0	20052	2741	423	23216	50.12
20	6915	573	134	7622	411	6722	0	0	6758	6457	-1177	19619	0	19619	2634	416	22669	50.02
21	6699	193	138	7030	359	6212	0	0	6976	6574	-1477	18285	0	18285	2473	413	21171	49.98
22	6507	167	135	6809	288	5635	0	0	6820	6762	-1461	17624	0	17624	2295	409	20328	49.94
23	6333	172	137	6642	249	5441	0	0	6709	6894	-1364	17474	0	17474	2141	388	20003	50.01
24	6401	167	139	6707	207	5514	0	0	6580	6463	-1242	17280	0	17280	2015	369	19664	50.01
MUs	162.09	12.18	3.31	177.58	5.21	146.78	0.00	12.95	181.31	182.36	-31.70	484.08	0.00	484.08	57.83	9.11	551.02	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 23/Dec/2022

Position as on 6.30 Hrs of 24/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	JSW (J) U2	300	10/12/2022	15:51		Continued.	NO SCHEDULE	
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	26/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
MSPGCL	Uran Unit 6	108	20/12/2022	17:00		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-3	250	21/12/2022	09:53	24/12/2022	22:20	Generator lower guide bearing oil leakage	26/12/2022
IPP	RPL(AMT) U-2	270	24/12/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	24/12/2022	00:38		Continued.	Boiler Tube Leakage	27/12/2022
TPC-G	Trombay 7B	60	24/12/2022	03:07	24/12/2022	17:26	Gas shortage	
TPC-G	Trombay 7A	120	24/12/2022	03:24	24/12/2022	14:45	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 24/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (701) OF ICT @ TIRORA	IntraState	23/12/2022	11:01	23/12/2022	18:21	PO	For (701-52) CB Maintenance & for attending SF6 gas leakage
765 KV LR Outages/Trippings							
LR (704) OF KORADI CKT - 2@ TIRORA	IntraState	24/12/2022	12:46			PO	For LR (704-52LR) CB Maintenance & for attending SF6 gas leakage
400 KV TBC Outages/Trippings							
TBC @ NAGOTHANE	IntraState	19/12/2022	11:20			PO	for CB overhauling work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
PARLI(MS) - PARLI (PG) CKT - 2	InterState	24/12/2022	07:05			PO	POST OCC: BYPASSING OF 400KV PARLI(PG)-PARLI(M) 400KV D/C AND 400KV PARLI(PG)-PARLI (NEW) D/C QUAD LINE AT THE OUT SKIRT OF PARLI(PG) S/S SO AS TO FORM PARLI(M)-PARLI(NEW) 400KV D/C LINE
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
KHADKA-AURANGABAD (WALUJ)	IntraState	22/12/2022	21:05	23/12/2022	06:30	HT	H/T For Over Voltage.
LONIKAND 2 - KARJAT CKT - 2	IntraState	23/12/2022	13:10	23/12/2022	15:02	T	Tripped on distance protection
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	23/12/2022	13:24	23/12/2022	18:55	PO	Replacement of faulty disc insulator strings by new LRP strings
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	23/12/2022	19:12	24/12/2022	05:08	T	Tripped on distance protection
JAIGAD - KARAD CKT - 1	IntraState	23/12/2022	22:06	24/12/2022	09:51	HT	H/T For Over Voltage.
LONIKAND I - KOYNA STAGE-IV	IntraState	24/12/2022	00:51	24/12/2022	08:10	HT	H/T to Control Over Voltage
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/12/2022	06:42	24/12/2022	17:06	PO	Replacement of disc insulator strings by LRP strings
400 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 24/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	23/12/2022	06:17	23/12/2022	17:51	PO	Renovation of cooling system and replacement of Auxiliary protections like PRV Buchholz relay. Draining of oil up to top plate for each ICT units after that replacement of required auxiliary relays and then oil filtration,top up of oil if required to be carried out.Existing cables found damaged at several places by rodents during the execution of new cable termination work of the cooling systems to be replaced.Complete filtration of the oil to be carried out as in the DGA test results the Methane and Ethane gases are found in increasing trend.In addition to above work chemical washing of bay equipment,Bay maintenance and diagnostic testing work.
400/220/33 KV 167 MVA SPARE ICT @ WALUJ	IntraState	23/12/2022	12:04	23/12/2022	19:00	PO	Diagnostic Testing & Routine Maintenance
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	IntraState	23/12/2022	17:16	23/12/2022	17:51	EO	For attending hot spot of 29 D Rph ICT IV LV side by Hot line method. No elements to be disturbed.No operations to be done. Only permission required to carry out the hotline work as no shut down required on ICT .
220 KV MAINBAY Outages/Trippings							
AIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	23/12/2022	08:33	23/12/2022	15:26	PO	Annual Maintenance of Bay Equipments
BUS COUPLER @ SONKAR	IntraState	23/12/2022	15:28	23/12/2022	19:28	PO	1. Diagnostic testing 2. Painting work 3. Routine Maintenance work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
EKLAHARE (OCR) - PADGHE	IntraState	19/12/2022	18:12			HT	HT for Load Management
BAPGAON - KALWA	IntraState	23/12/2022	06:13	23/12/2022	17:06	PO	During the outage the 220KV Kalwa-Bappaon Line will be shifted on ERS towers from Loc no. 377 to 381 for height raising and shifting of line for NHSRCL.
KHAREPATAN -PAWAS LINE	IntraState	23/12/2022	08:59	23/12/2022	18:26	PO	Cold washing of line insulator.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	23/12/2022	09:28	23/12/2022	18:06	HT	to control overloading at bableshwar
ALEPHATA-PARGAON(KATHAPUR)	IntraState	23/12/2022	10:35	23/12/2022	11:13	HT	To control overloading
TROMBAY - DHARAVI 9	IntraState	23/12/2022	10:48	23/12/2022	17:15	PO	LA replacement at Trombay generating station
220KV SHIRSHUPHAL-SHIRSAI TSS CKT-1	IntraState	23/12/2022	11:38	23/12/2022	15:38	PO	DIAGNOSTIC TESTING & MAINTENANCE WORK.
ONGC PANVEL - TSS PANVEL	IntraState	23/12/2022	11:59	23/12/2022	20:22	PO	1. For stringing of 2 nos. conductors & 1 no.OPGW earthwire from new Monopole to Monopole of 220KV ONGC-Panvel-TSS line bet.loc no 2 & 3 for Height rising work of proposed DFCCIL Raailway track. 2. For stringing of 3 Nos conductor from loc No 4 to new tower of ONGCPanvel- TSS line and for erection of new tower loc no.3A tower type MDN+12

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 24/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - SAWANTWADI	IntraState	23/12/2022	12:46	23/12/2022	12:46	PO	For CB timing test at Insuli end.
BIDRI - SAWANTWADI	IntraState	23/12/2022	12:56	23/12/2022	13:31	PO	For CB timing test at Insuli end.
PADGHE - KAMBA 1	IntraState	23/12/2022	14:46	23/12/2022	19:04	EO	TO attend HOT spot on CT (132 deg), Diagnostic Testing Work, Breaker air pressure setting work. MTAMC Project Work.
SAKI - SAHAR	IntraState	24/12/2022	00:03	24/12/2022	03:04	PO	LBBU relay testing, Protection trials and CR trials
NERLE - PEDAMBE	IntraState	24/12/2022	08:50	24/12/2022	17:00	PO	for bay P/M work
FLAGSHIP-CHINCHWAD	IntraState	24/12/2022	09:11	24/12/2022	18:27	PO	Fabrication and painting of rusted CB mechanism boxes (individual pole operated ABB make CB BLK222).
EKLAHARA(OCR)-RAYMOND	IntraState	24/12/2022	10:08	24/12/2022	13:19	PO	work of attending of Red-Hot at Loc.No.07 Y-phase Nashik side(temp-75.4°C), R-phase Raymond side(temp-81.9°C) and also at loc.no.04 R-phase Raymond side(temp- 65.6°C).
SALSETTE BORIVLI - 1	IntraState	24/12/2022	10:40	24/12/2022	16:08	PO	Line Vue inspecƟon of conductor
KARAD - NERLE	IntraState	24/12/2022	17:51	24/12/2022	19:05	T	TRIPPED ON DISTANCE PROTECTION
TROMBAY - SALSETTE CKT - 1	IntraState	24/12/2022	23:20		Continued.	PO	Project work of Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 at Sahakar Plaza crossing Ghatkopar
TROMBAY SALSETTE LINE-2	IntraState	24/12/2022	23:25		Continued.	PO	Project work of Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 at Sahakar Plaza crossing Ghatkopar
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22-22 KV 100 MVA PTR NO 1 @ PARVATI	IntraState	22/12/2022	10:35	23/12/2022	19:25	PO	220/22-22 kV , 100 MVA TF 01 CB overhauling work
220/132KV 200MVA PTR 1 @ LONAND	IntraState	23/12/2022	10:50	23/12/2022	14:36	PO	Diagnostic testing work & quarterly maintenance work
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	23/12/2022	11:10	23/12/2022	13:12	PO	To Attaining Oil Leakage
220/132KV 200MVA PTR 2 @ LONAND	IntraState	23/12/2022	15:13	23/12/2022	18:26	PO	Diagnostic testing work & quarterly maintenance work
220/33 KV 50 MVA PTR 1 @ BABHLESHWAR	IntraState	24/12/2022	10:06	24/12/2022	17:25	PO	Replacement of damaged RCC support structures of BPIs with lattice type support structures.
220/33 KV 50 MVA PTR 2 @ BABHLESHWAR	IntraState	24/12/2022	10:12	24/12/2022	17:35	PO	Replacement of damaged RCC support structures of BPIs with lattice type support structures.
220/22 KV 50 MVA PTR NO 4 @ PARVATI	IntraState	24/12/2022	10:29		Continued.	PO	220/22 kV , 50 MVA TF 04 CB overhauling work
220/132KV 100 MVA ICT 2@ PETH	IntraState	24/12/2022	11:52	24/12/2022	16:33	PO	Quarterly Maintenance & Diagnostic testing work.
132 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 24/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS @ KOPARGAON	IntraState	23/12/2022	18:00			PO	For replacement of 132 KV Yeola line R ph bus jump and 132 KV bus section- R ph CT to bus jump for attending hotspot. Also diagnostic testing work of 132 kV PTs and allied equipments.
110 KV LINE Outages/Trippings							
TATA BORIVLI MSETCL BORIVLI 1	IntraState	24/12/2022	10:04		Continued.	PO	BUSBAR REPLACEMENT WORK AT BMC END
KALWA KALYAN	IntraState	24/12/2022	18:11	24/12/2022	18:33	EO	FACILATING OF TEST CHARGING OF NEW CTs

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage