

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Feb/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.268	3671.290	1) Gujrat	-7.040	-186.786
2) Hydro	26.243	410.620	2) Madhya Pradesh	8.549	141.236
3) Gas	3.603	180.012	3) Chattisgarh	6.050	156.670
Total MSPGCL	170.114	4261.922	4) Maharashtra	188.509	3580.812
B) 1) APLM	54.817	1494.626	5) Goa (Amona)	-1.564	-34.383
2) JSWEL	15.056	347.916	Total	194.504	3657.549
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.217	498.174
4) RPL(AMT)	25.698	649.573	b) Mumbai Drawl	29.453	563.780
5) SWPGPL	9.388	205.053	c) MSEDCL Bilateral *	110.480	1789.734
6) Other IPP	40.554	972.600	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.172	497.532
C) 1) TPCL Thermal	12.332	223.722	Include PX	0.000	0.000
2) TPCL Hydro	4.456	91.511	Standby	0.045	0.642
3) TPCL Gas	0.000	78.820	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.815	196.075	1) MSEDCL	488.338	11245.842
D) STATE			2) Mumbai Discoms	53.054	1153.907
1) Thermal	304.928	7760.855	3) Other Discoms	8.659	200.013
(A1+C1+C4+(B1-B6))			TOTAL STATE	550.051	12599.762
2) Hydro	30.699	502.131			
(A2+C2)					
3) Gas	3.603	258.832			
(A3+B7+C3)					
4) Wind	7.367	215.971			
6) SOLAR	8.952	204.425			
TOTAL STATE	355.549	8942.214			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	5767	5822	6018	5824
MSPGCL Hydro	2114	1060	1688	326
MSPGCL Gas	158	143	145	149
MSPGCL Total Generation	8039	7025	7851	6299
Central Sector Receipt	9523	9645	6880	7100
WIND	104	91	402	529
CPP / IPP Thermal	6164	6198	6223	5555
CPP / IPP Gas	0	0	0	0
SOLAR	1125	1289	0	0
Exchange with Mumbai	-1485	-1535	-1226	-1075
MSEDCL DEMAND MET	23207	22454	19858	18215
Load Shedding	0	0	0	0
MSEDCL DEMAND	23207	22454	19858	18215
TPCL GENERATION	939	889	1024	395
AEML GENERATION	283	284	285	284
MUMBAI DEMAND	2707	2708	2535	1754
OTHER DISCOM DEMAND	393	390	400	319
STATE DEMAND MET	26307	25552	22793	20288
STATE DEMAND	26307	25552	22793	20288
Frequency (Hz)	49.99	49.95	49.96	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 16.03 Hrs	49.71 Hz at 06.44 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 24/Feb/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.88	90.57	175	135
Unit 7	0.00	0.00	0	0
Unit 8	13.80	330.12	585	568
Unit 9	0.00	268.33	0	0
Unit 10	12.02	300.84	527	428
Total	29.70	989.86		
Bhusawal				
Unit 3	0.00	64.29	0	0
Unit 4	9.50	80.26	400	390
Unit 5	10.27	239.06	465	365
Total	19.76	383.62		
Parli				
Unit 6	3.63	94.00	155	146
Unit 7	3.55	94.73	165	137
Unit 8	0.06	87.09	65	0
Total	7.24	275.81		
Chandrapur				
Unit 3	4.42	67.94	187	169
Unit 4	4.14	58.07	177	161
Unit 5	7.68	177.31	350	295
Unit 6	9.71	133.33	420	366
Unit 7	9.94	201.69	435	370
Unit 8	6.80	219.88	456	0
Unit 9	7.48	236.07	409	180
Total	50.16	1094.28		
Paras				
Unit 3	0.00	104.31	0	0
Unit 4	0.00	105.15	0	0
Total	0.00	209.45		
Khaparkheda				
Unit 1	3.20	77.32	145	120
Unit 2	3.76	49.70	165	145
Unit 3	4.58	93.38	200	176
Unit 4	4.04	82.52	180	155
Unit 5	10.34	254.73	450	405
Total	25.91	557.66		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.01	85.27	195	122
Unit 5	3.48	75.34	174	115
Total	7.49	160.61		
Uran				
All Units	3.60	180.01	162	142
Total	3.60	180.01		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	5.16	33	0
Total	0.15	5.16		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.71	72.34	440	35
Stage 4	10.16	102.63	1016	0
Stage 3	3.34	37.93	320	0
Total	18.21	212.91		
Hydro				
KDPH	0.43	14.07	18	18
VTRNA	0.00	14.56	0	0
TILLARI	0.32	11.11	58	0
BHIRA T.R.	0.26	4.90	77	0
SMLHY_PTN	6.88	138.14	301	272
GHATGHAR	0.00	9.79	0	0
Total	7.89	192.55		
Wind				
Total	7.37	215.97	0	0
Total	7.37	215.97		
CPP				
APML(Mus)	54.82	1494.63	0	0
JSWEL(Mus)	15.06	347.92	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.70	649.57	0	0
SWPGPL-Mus	9.39	205.05	0	0
Other(Mus)	40.55	972.60	0	0
Total	145.51	3669.77		
SOLAR				
Total	8.95	204.42	0	0
Total	8.95	204.42		
Tata				
Trombay 5	8.14	135.38	420	255
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	47.96	0	0
Trombay 7B	0.00	30.86	0	0
TATA Hydro	4.46	91.51	433	0
Trombay 8	4.19	88.34	221	129
Total	16.79	394.05		
AEML				
DTPS U-1&2	6.82	196.08	285	283
Total	6.82	196.08		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	140.27	3671.29
MSPGCL Thml+Gas	143.87	3851.30
MSPGCL Hydro	26.24	410.62

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	170.11	4261.92
Koyna 1,2 & 4 Total	14.87	174.98
State Total	355.55	8942.21

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Feb/2022

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5824	326	149	6299	529	5681	0	0	7423	7100	-1075	18215	0	18215	1754	319	20288	49.98
2	5794	333	150	6277	532	5670	0	0	7474	7247	-957	18488	0	18488	1641	281	20410	49.95
3	5789	349	160	6298	524	5682	0	0	7595	7441	-888	18789	0	18789	1563	268	20620	50.00
4	5765	361	151	6277	505	5676	0	0	7664	7490	-850	18820	0	18820	1522	278	20620	49.96
5	5750	401	161	6312	450	5677	0	0	7867	7827	-859	19101	0	19101	1531	306	20938	49.99
6	5660	1442	151	7253	407	5680	0	0	7685	7869	-891	19997	0	19997	1633	321	21951	50.00
7	5669	1936	151	7756	249	5755	0	8	7867	7897	-738	20592	0	20592	1791	335	22718	49.87
8	5721	2121	162	8004	206	5826	0	129	8552	8364	-857	21310	0	21310	1996	362	23668	49.94
9	5796	1891	150	7837	138	6001	0	503	8657	8519	-1078	21519	0	21519	2293	401	24213	50.00
10	5786	2114	149	8049	124	6137	0	856	8658	9098	-1332	22544	0	22544	2543	388	25475	49.97
11	5767	2114	158	8039	104	6294	0	1125	9399	9523	-1485	23207	0	23207	2707	393	26307	49.99
12	5805	1579	145	7529	97	6341	0	1232	9697	9457	-1472	22792	0	22792	2752	392	25936	49.95
13	5822	1060	143	7025	91	6329	0	1289	9596	9645	-1535	22454	0	22454	2708	390	25552	49.95
14	5803	680	142	6625	131	6302	0	1197	9844	9939	-1642	22171	0	22171	2581	381	25133	49.99
15	5850	769	152	6771	107	6281	0	1076	10132	10148	-1714	22296	0	22296	2573	373	25242	50.00
16	5917	1239	142	7298	148	6258	0	846	9605	9543	-1644	22041	0	22041	2609	408	25058	49.96
17	5908	1568	143	7619	137	6285	0	517	8632	8226	-1394	20997	0	20997	2597	393	23987	49.96
18	5934	1421	144	7499	211	6318	0	170	7594	7337	-1248	19871	0	19871	2566	416	22853	49.92
19	5983	1088	155	7226	282	6350	0	4	7130	7208	-1267	19407	0	19407	2530	396	22333	49.94
20	6018	1688	145	7851	402	6351	0	0	7089	6880	-1226	19858	0	19858	2535	400	22793	49.96
21	6018	655	147	6820	407	6330	0	0	6994	6822	-1175	18804	0	18804	2363	400	21567	49.96
22	5934	430	157	6521	507	5972	0	0	7169	7382	-1446	18574	0	18574	2230	362	21166	50.00
23	6025	345	148	6518	568	6128	0	0	7015	6818	-1406	18273	0	18273	2087	353	20713	49.99
24	5930	333	148	6411	511	6189	0	0	6919	6724	-1274	18219	0	18219	1951	342	20512	50.02
MUs	140.27	26.24	3.60	170.11	7.37	145.51	0.00	8.95	196.26	194.50	-29.45	488.34	0.00	488.34	53.06	8.66	550.05	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Feb/2022

Position as on 6.30 Hrs of 25/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41	24/02/2022	23:04	Turbine vibrations high.	
IPP	JSW (J) U4	300	14/02/2022	16:08		Continued.	No Schedule	
IPP	RPL(AMT) U-3	270	16/02/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Ghatghar Unit-2	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Koyna Unit 9	80	19/02/2022	10:50		Continued.	Stator Earth Fault	
MSPGCL	Bhusawal Unit 3	210	20/02/2022	22:03		Continued.	Coal Shortage	
MSPGCL	Uran Unit 6	108	21/02/2022	00:37		Continued.	Gas shortage	
IPP	Adani U-2	660	21/02/2022	01:11	25/02/2022	04:24	APH-B support bearing abnormal sound	25/02/2022
MSPGCL	Chandrapur Unit 8	500	21/02/2022	04:40	24/02/2022	06:09	Furnace Pressure High	
MSPGCL	Koradi Unit 9	660	21/02/2022	12:42		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit A0	120	21/02/2022	21:57		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	21/02/2022	21:57		Continued.	Gas shortage	
MSPGCL	Paras Unit 3	250	22/02/2022	15:45		Continued.	Boiler Tube Leakage	
IPP	Adani U-5	660	22/02/2022	22:14	24/02/2022	07:35	Furnace Pressure High	
TPC-G	Trombay 7B	60	23/02/2022	02:12		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	23/02/2022	02:22		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Feb/2022

Position as on 6.30 Hrs of 25/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Paras Unit 4	250	23/02/2022	13:45		Continued.	Boiler Tube Leakage	
MSPGCL	Parli Unit 8	250	24/02/2022	01:00		Continued.	Coal Shortage	
IPP	JSW (J) U3	300	25/02/2022	01:14	25/02/2022	02:25	Coal Mill Tripped.	
MSPGCL	Khaparkheda Unit 3	210	25/02/2022	01:17		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (710) OF TIRORA CKT - 1 @ KORADI 3	IntraState	24/02/2022	09:23	24/02/2022	16:13	PO	Annual Maintenance of Bay Equipments
400 KV TBC Outages/Trippings							
TBC @ LONIKAND	IntraState	22/02/2022	12:30			EO	400 kV B ph CT replacement due to oil leakage.
400 KV LINE Outages/Trippings							
KARAD - SOLAPUR (PG)	InterState	22/02/2022	08:50				Commissioning of 400 kV 80 MVAr Kanohar make line shunt reactor with allied equipments under LE scheme
THAPTI TANDA - WALUJ	IntraState	01/02/2022	13:01			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
DEEPNAGAR - THAPTI TANDA	IntraState	01/02/2022	13:11			PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	04/02/2022	14:43			HT	H/T TO CONTROL 400KV TALEGAON PG -CHAKAN LINE LOADING.
NEW KOYNA - STAGE IV CKT - 2	IntraState	19/02/2022	10:01			PO	C.B. Overhauling work Shitting on TBC
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	24/02/2022	07:21	24/02/2022	21:06	PO	For replacement of polymer Insulator by Porecelain Long Rod Insulator
PADGHE - NAGOTHANE CKT - 2	IntraState	24/02/2022	09:17	24/02/2022	21:58	PO	1) PG isolator replacement work of 29C bus under LES scheme. Yph PG isolator structure is damaged. 2) MTAMC work 3) Bay maint work
LONIKAND I - CHAKAN	IntraState	24/02/2022	11:26	24/02/2022	18:09	PO	1.Priority insulator strings replacement Lno. 40 B ph detected in PID scanning as 5 nos of discs shown weak. Hence, its is to be replaced on urgent basis. 2. Chemical cleaning of insulator strings by taking line out of service.
BABHALESHWAR - RPL(NSK) CKT - 2	IntraState	25/02/2022	08:41			PO	Due to Erection of Monopole Tower for Samruddhi crossing
PADGHE - NAGOTHANE CKT - 1	IntraState	25/02/2022	09:02			PO	string replacement work needs to be done
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	21/02/2022	11:40	24/02/2022	18:09	PO	1) ICT Painting Work 2)Diagnostic Testing Work 3) Routine Maintenance Work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	24/02/2022	15:16	24/02/2022	18:12	EO	It is to inform that on dtd.- 24/02/2022 @ 11:30 hrs. low N2 pressure indication is appeared on control panel of CTR make N2 injection fire prevention and protection system. Upon inspection, it is found that there is N2 leakage problem from regulator assembly and N2 pressure in cylinder is dropping up to 80KG/CM2. Hence, it is very necessary to attend the leakage of N2 gas & replace low pressure N2 gas cylinder of CTR make Nitrogen injection and fire protection system considering the emergency and urgency. It is very necessary to have N2 pressure up to 130kg/cm2. The photographs of low N2 pressure gauge meter and low pressure indication appeared on control panel is attached h/w for reference.
400 KV BR Outages/Trippings							
80 MVAr Bus reactor @ Talandge	IntraState	24/02/2022	12:00	24/02/2022	18:30	PO	Bay AMP, Outage required on CB only. Bus reactor can be kept in service through TBC.
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	24/02/2022	07:38				Annual maintenance on opportunity outage of 220kV Ghodbunder-Gorai Line outage.
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
GOREGAON - AAREY CKT - 2	IntraState	15/02/2022	09:20	24/02/2022	17:22	PO	Under MMRC Line Diversion scheme for Metro-3 project 220kV Outdoor termination of 220kV AEML Aarey and overhead connection at MMRC pylon yard .
BORIVALI - TARAPUR	IntraState	18/02/2022	09:16			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2.Railway crossing stringing between loc.no.36 & 37a-38a-38
BOISAR II - TARAPUR	IntraState	18/02/2022	09:33			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2.Railway crossing stringing between loc.no.36 & 37a-38a-38
GHODBUNDER - GORAI	IntraState	20/02/2022	03:56			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VERSOVA - GHODBUNDER	IntraState	20/02/2022	04:00			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	22/02/2022	10:16			PO	GETCO WORK. SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C)CROSSING AT NHRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	22/02/2022	10:17			PO	GETCO WORK. SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C)CROSSING AT NHRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)
PEDAMBE-KALAMBANI(TSS)	IntraState	23/02/2022	15:55	24/02/2022	13:45	T	TRIPPED ON DIST. PROTN.
TROMBAY SALSETTE LINE-2	IntraState	23/02/2022	23:27	24/02/2022	05:56	PO	METRO-4 WORK
TROMBAY - SALSETTE CKT - 1	IntraState	23/02/2022	23:27	24/02/2022	05:51	PO	MERTO-4 WORK
URSE - TALEGAON (AMBI) CKT 2	IntraState	24/02/2022	10:54	24/02/2022	20:50	EO	Cu Palm Replacement of Main Bus Iso. Jumps by Hot-Line by shifting 220kV Urse-2 Bay on 220kV TBC Bay .
PARGAON(KATHAPUR)-LONIKAND	IntraState	24/02/2022	12:05	24/02/2022	15:15	PO	Hot spot attending work on CB
LONIKAND (400 KV)-THEUR I	IntraState	24/02/2022	12:30			PO	1. R,Y & B ph CT replacement work due to high ten delta. 2. CB Diagnostic Testing work. 3. Bay Maintenance work
KANDALGAON - SONA ALLOYS	IntraState	24/02/2022	12:45	24/02/2022	21:25	PO	1) Insulator string replacement at Loc.No.55 Top ph Kgaon side, Loc.No.53 Middle ph Kgaon side, Loc.No.60 Bot ph Kgaon side, Loc.No.64 Top ph Sona Alloys side, Loc.No.51 Top ph Sona Alloys side, Loc.No.49 Top & Bot ph Kgaon side.2) Conductor damaged to be attended at Loc.No.52-53,54-55 3) Emergency tree cutting at Loc.No.42-43,48-49,51-53
WAGHIVALI - DHARAVI 8	IntraState	24/02/2022	18:35	24/02/2022	18:56	EO	Hanging object at Kurla Location
TROMBAY MSETCL TIE - 2	IntraState	24/02/2022	23:22	25/02/2022	06:27	PO	For attending hotspot in MSEB end breaker terminal
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	IntraState	24/02/2022	09:22	24/02/2022	16:53	PO	Diagnostic testing and Relay testing work.
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	24/02/2022	10:51	24/02/2022	16:17	PO	NIFPS repairing and oil leakage attending work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100 MVA ICT 2 @ RANJANGAON	IntraState	24/02/2022	11:59	24/02/2022	17:48	PO	Diagnostic Testing & Annual maintenance work
220/100 KV 200 MVA ICT 1 @ APTA	IntraState	24/02/2022	12:54	24/02/2022	19:44	T	Faulty Buccholz cable.
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	25/02/2022	09:17			PO	Transformer oil leakage attending work
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	24/02/2022	08:18			PO	FOR DFCC PROJECT WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage