

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Feb/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	160.633	3731.816	1) Gujrat	3.273	-46.951
2) Hydro	24.949	357.068	2) Madhya Pradesh	1.954	91.140
3) Gas	3.108	108.331	3) Chattisgarh	3.840	108.070
Total MSPGCL	188.690	4197.215	4) Maharashtra	162.218	4082.689
B) 1) APLM	76.240	1767.362	5) Goa (Amona)	-0.874	-31.734
2) JSWEL	26.023	491.879	Total	170.411	4203.214
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.879	701.935
4) RPL(AMT)	25.520	720.802	b) Mumbai Drawl	36.566	848.571
5) SWPGPL	7.345	191.670	c) MSEDCL Bilateral *	68.983	1730.848
6) Other IPP	46.359	1026.440	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.879	701.484
C) 1) TPCL Thermal	13.238	203.304	Include PX	0.000	0.000
2) TPCL Hydro	4.087	93.430	Standby	0.000	0.452
3) TPCL Gas	0.000	31.445	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.774	239.717	1) MSEDCL	515.296	12122.520
D) STATE			2) Mumbai Discoms	65.665	1416.464
1) Thermal	367.132	8372.990	3) Other Discoms	10.184	238.804
(A1+C1+C4+(B1-B6))			TOTAL STATE	591.145	13777.788
2) Hydro	29.036	450.498			
(A2+C2)					
3) Gas	3.108	139.776			
(A3+B7+C3)					
4) Wind	5.245	232.338			
6) SOLAR	16.213	378.975			
TOTAL STATE	420.734	9574.577			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6840	6841	6696	6581
MSPGCL Hydro	1577	881	1536	671
MSPGCL Gas	133	127	131	138
MSPGCL Total Generation	8550	7849	8363	7390
Central Sector Receipt	7862	8326	6648	6023
WIND	152	108	399	255
CPP / IPP Thermal	7637	7579	7707	7708
CPP / IPP Gas	0	0	0	0
SOLAR	2017	2194	0	0
Exchange with Mumbai	-1731	-1998	-1530	-1438
MSEDCL DEMAND MET	24028	23606	21123	19544
Load Shedding	0	0	0	0
MSEDCL DEMAND	24028	23606	21123	19544
TPCL GENERATION	1003	781	992	566
AEML GENERATION	499	497	493	479
MUMBAI DEMAND	3233	3276	3015	2483
OTHER DISCOM DEMAND	459	452	464	394
STATE DEMAND MET	27720	27334	24602	22421
STATE DEMAND	27720	27334	24602	22421
Frequency (Hz)	49.97	50.02	50.04	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 18.03 Hrs	49.63 Hz at 09.06 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 24/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.86	102.86	210	170
Unit 8	13.57	328.41	602	530
Unit 9	12.65	315.48	560	510
Unit 10	12.71	292.83	600	429
Total	43.79	1039.58		
Bhusawal				
Unit 3	3.40	80.01	150	130
Unit 4	10.45	246.68	495	355
Unit 5	10.50	245.27	490	380
Total	24.34	571.96		
Parli				
Unit 6	0.00	97.35	0	0
Unit 7	5.63	76.76	248	184
Unit 8	3.66	83.84	177	131
Total	9.29	257.95		
Chandrapur				
Unit 3	3.92	86.43	170	161
Unit 4	2.89	72.33	151	0
Unit 5	0.00	76.31	0	0
Unit 6	9.64	206.17	425	300
Unit 7	0.00	0.00	0	0
Unit 8	11.77	271.92	500	481
Unit 9	11.85	188.10	500	483
Total	40.07	901.26		
Paras				
Unit 3	4.37	118.02	216	99
Unit 4	5.76	136.29	250	219
Total	10.13	254.31		
Khaparkheda				
Unit 1	1.94	43.90	125	0
Unit 2	3.31	67.80	150	110
Unit 3	4.36	90.26	186	170
Unit 4	4.58	81.22	198	185
Unit 5	11.09	258.82	500	422
Total	25.28	542.01		
Nasik				
Unit 3	4.03	89.65	175	110
Unit 4	3.70	8.22	168	129
Unit 5	0.00	66.90	0	0
Total	7.73	164.76		
Uran				
All Units	3.11	108.33	140	102
Total	3.11	108.33		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	9.59	47	0
Total	0.14	9.59		
Koyna				
Stage 1-2	7.08	94.52	545	45

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	9.54	102.16	753	0
Stage 3	3.60	41.95	320	0
Total	20.21	238.64		
Hydro				
KDPH	0.86	17.31	36	36
VTRNA	0.94	16.00	60	0
TILLARI	0.46	9.82	58	0
BHIRA T.R.	0.16	5.57	40	0
SMLHY_PTN	2.17	55.50	94	84
GHATGHAR	0.00	4.64	0	0
Total	4.60	108.84		
Wind				
Total	5.24	232.34	0	0
Total	5.24	232.34		
CPP				
APML(Mus)	76.24	1767.36	0	0
JSWEL(Mus)	26.02	491.88	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.52	720.80	0	0
SWPGPL-Mus	7.34	191.67	0	0
Dhariwal	5.18	31.81	244	209
IEPL	5.95	126.29	263	218
Other(Mus)	35.22	868.34	0	0
Total	181.49	4198.15		
SOLAR				
Total	16.21	378.98	0	0
Total	16.21	378.98		
Tata				
Trombay 5	8.59	104.28	462	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	17.51	0	0
Trombay 7B	0.00	13.94	0	0
TATA Hydro	4.09	93.43	358	8
Trombay 8	4.65	99.03	232	131
Total	17.32	328.18		
AEML				
DTPS U-1&2	11.77	239.72	501	454
Total	11.77	239.72		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	160.63	3731.82
MSPGCL Thml+Gas	163.74	3840.15
MSPGCL Hydro	24.95	357.07

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	188.69	4197.22
Koyna 1,2 & 4 Total	16.61	196.68
State Total	420.73	9574.58

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Feb/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6608	864	136	7608	188	7312	0	0	6268	6392	-1320	19796	0	19796	2339	384	22519	49.91
2	6610	851	138	7599	237	7371	0	0	6539	6563	-1250	20174	0	20174	2176	346	22696	49.96
3	6706	547	137	7390	144	7335	0	0	6823	6936	-1176	20305	0	20305	2074	324	22703	49.99
4	6706	420	139	7265	276	7342	0	0	6823	6777	-1117	20241	0	20241	2008	302	22551	50.01
5	6679	575	138	7392	213	7417	0	0	6838	6848	-1099	20427	0	20427	2020	344	22791	49.93
6	6687	1505	138	8330	206	7612	0	0	6309	6599	-1023	21341	0	21341	2137	383	23861	49.92
7	6802	1694	140	8636	331	7662	0	7	6625	6881	-995	22118	0	22118	2305	404	24827	49.98
8	6830	1797	139	8766	277	7682	0	316	6593	6974	-1106	22483	0	22483	2473	426	25382	49.88
9	6823	1857	136	8816	179	7701	0	971	6613	6808	-1336	22697	0	22697	2743	442	25882	49.98
10	6856	1507	133	8496	190	7658	0	1595	7316	7293	-1603	23173	0	23173	3013	456	26642	49.82
11	6840	1577	133	8550	152	7637	0	2017	7759	7862	-1731	24028	0	24028	3233	459	27720	49.97
12	6819	1366	132	8317	113	7645	0	2170	8043	7948	-1957	23764	0	23764	3289	472	27525	49.93
13	6841	881	127	7849	108	7579	0	2194	8322	8326	-1998	23606	0	23606	3276	452	27334	50.02
14	6565	570	102	7237	103	7206	0	2069	8698	8807	-2127	22846	0	22846	3139	449	26434	50.07
15	6547	570	108	7225	94	7304	0	1922	8844	8722	-2166	22632	0	22632	3186	469	26287	50.03
16	6606	966	109	7681	83	7580	0	1565	8264	8225	-2092	22587	0	22587	3233	455	26275	50.01
17	6697	1253	112	8062	118	7655	0	1017	7388	7443	-1792	22026	0	22026	3213	477	25716	50.00
18	6661	1231	114	8006	159	7674	0	357	6896	6796	-1590	20928	0	20928	3126	474	24528	50.02
19	6667	1215	119	8001	316	7700	0	13	6450	6478	-1554	20466	0	20466	3062	488	24016	50.02
20	6696	1536	131	8363	399	7707	0	0	6555	6648	-1530	21123	0	21123	3015	464	24602	50.04
21	6694	812	135	7641	422	7688	0	0	6198	6255	-1478	20074	0	20074	2849	454	23377	49.98
22	6534	277	137	6948	360	7647	0	0	6143	6405	-1526	19395	0	19395	2707	439	22541	49.99
23	6578	407	137	7122	322	7665	0	0	6307	6402	-1562	19536	0	19536	2566	413	22515	49.96
24	6581	671	138	7390	255	7708	0	0	6208	6023	-1438	19544	0	19544	2483	394	22421	49.99
MUs	160.63	24.95	3.11	188.69	5.25	181.49	0.00	16.21	168.82	170.41	-36.57	515.31	0.00	515.31	65.66	10.17	591.15	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Feb/2023

Position as on 6.30 Hrs of 25/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/03/2023
IPP	SWPGPL U-2	135	08/02/2023	00:01		Continued.	Bag Filter replacement work	02/03/2023
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	27/02/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	28/02/2023
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Uran Unit 6	108	15/02/2023	13:13	25/02/2023	07:40	Gas shortage	
TPC-G	Trombay 7B	60	15/02/2023	16:54		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 1	210	21/02/2023	02:49	24/02/2023	04:07	Air heater problem	24/02/2023
MSPGCL	Parli Unit 6	250	21/02/2023	20:15		Continued.	Air heater problem	28/02/2023
TPC-G	Trombay 7A	120	21/02/2023	20:26		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	22/02/2023	22:05		Continued.	Boiler Tube Leakage	24/02/2023
IPP	RPL(AMT) U-2	270	23/02/2023	11:01	25/02/2023	14:19	Gas shortage	
MSPGCL	Chandrapur Unit 4	210	24/02/2023	20:53	25/02/2023	00:35	TRIPPED ON AXIAL SHIFT HIGH	
MSPGCL	Uran Unit 8	108	25/02/2023	06:53	25/02/2023	09:02	CTO temperature high.	
MSPGCL	Uran Unit B0	120	25/02/2023	06:53		Continued.	CTO temperature high	
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00		Continued.	Boiler Tube Leakage	
IPP	RPL(AMT) U-4	270	25/02/2023	17:00		Continued.	Bottom Ash evacuation problem	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Feb/2023

Position as on 6.30 Hrs of 25/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	25/02/2023	19:41		Continued.	Gas shortage	
IPP	SWPGPL U-1	135	25/02/2023	22:45		Continued.	Enhancement of Unit for full load operation	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage	
400 KV MAINBAY Outages/Trippings								
MAIN BAY (414) OF 500 MVA ICT - 2 @ DEEPNAGAR	IntraState	24/02/2023	10:59			Continued.	PO	For servicing & overhauling of 400kV AREVA make ICT-2 Main C.B. Mechanism
MAIN BAY (407) OF ICT-1 @ KUDUS	IntraState	25/02/2023	14:41	25/02/2023	17:41		EO	Outage required for Oil Top-up in Conservator Y-phase Unit, as CTR Oil Drain Valve in CTR MK become Faulty and Oil drain observed from CTR inspection Window, CTR Engineer also replacing Butterfly Wall of CTR system.
400 KV LINE Outages/Trippings								
LONIKAND I - TALEGAON (PGCIL)	InterState	25/02/2023	13:34	25/02/2023	15:50		T	Field Fire observed under Loc no 47-48
PADGHE - KALWA CKT - 1	IntraState	20/02/2023	14:26				PO	1) CB pole Overhauling work as Bph pole SF6 gas contents SO2 beyond permissible limit . 2) Replacement of B bus PG isolator under LES scheme as HTLS conductor work in progress of Kalwa line 3) 400kV Kalwa -1 in service through TBC
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36				HT	HAND TRIPPED FOR LOAD MANAGEMENT
AKOLA-NANDGAONPETH (RPL-AMT)	IntraState	24/02/2023	10:48	24/02/2023	17:55		PO	DCRM, Tandelta & routine maintenance work
JAIGAD - KARAD CKT - 2	IntraState	24/02/2023	17:40	24/02/2023	19:24		HT	Due to heavy sparking on bus section at Karad Ss.
JAIGAD - KARAD CKT - 1	IntraState	24/02/2023	17:50	25/02/2023	01:30		HT	Due to heavy sparking on bus section at Karad Ss.
JAIGAD - KARAD CKT - 1	IntraState	24/02/2023	21:38	25/02/2023	00:21		EO	For repairing work of 29A Bph PG Isolator & 29 C Rph PG Isolator.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	25/02/2023	06:19	25/02/2023	22:32		PO	For string replacement work
MAIN BUS - 1 @ TALANDGE	IntraState	25/02/2023	12:20			Continued.	PO	For stringing of jack bus and erection of PG isolator in bay augmentation work of Kolhapur(PG)-Kolhapur(MSETCL) -1 Bay at MSETCL,
JAIGAD - KARAD CKT - 1	IntraState	25/02/2023	12:56	25/02/2023	17:01		EO	Replacement of damaged rotary insulator of R ph TBC PG isolator during operation of TBC PG isolator
KHADKA-AURANGABAD (WALUJ)	IntraState	25/02/2023	13:20	25/02/2023	18:00		EO	To attend hotspot on 89A Yph PG isolator box nut/bolts
400 KV ICT Outages/Trippings								
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	24/02/2023	11:36	24/02/2023	19:48		PO	Diagnostic testing & Relay testing work & Routine maint. Work ICT & CTR, CT oil leakage attending work
400/220/33 KV 500 MVA ICT - 2 @ NANDED	IntraState	24/02/2023	11:50	24/02/2023	18:24		PO	Diagnostic Testing Works as per test Frequency
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	24/02/2023	12:34	24/02/2023	22:19		PO	Diagnostic testing work of CB & Routine Maintenance
400/220kV 167MVA SPARE ICT @ DEEPNAGAR	IntraState	25/02/2023	10:32	25/02/2023	12:00		PO	for replacement of CTR system Nitrogen cylinder
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	25/02/2023	12:52	25/02/2023	15:17		EO	To attend Hot spot on R phase CT (220kV side)
220 KV TBC Outages/Trippings								
BUS SECTION BAY @ VSNL	IntraState	25/02/2023	11:27	25/02/2023	13:11		PO	Testing work of CB as CRM & Timing .
220 KV MAINBAY Outages/Trippings								

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS COUPLER @ RANJANGAON	IntraState	25/02/2023	16:02			EO	220kV Isolator alignment work is going on in co-ordination with hot line unit & M/s Bimco.Hot Line unit given clearance today dt 24.02.2023 evening to carry out above work.
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	24/02/2023	05:07	24/02/2023	09:32	EO	Attending hot spot work at loc.Nalasopara Gantry (B-Ph Nalasopara Side Temp-101 ζC), Loc No.102 (Y-Ph PGCIL Side Temp-90 & B-Ph Nalasopara Side Temp-100 ζC), 84 (R-Ph PGCIL Side Temp-76 ζC), 87(B-Ph Nalasopara Side Temp-75 ζC), 106 (B-Ph PGCIL Side Temp-87 ζC ,Y-Ph Nalasopara Side Temp-75 ζC & B-Ph Nalasopara Side Temp-73 ζC), 156(B-Ph Nalasopara Side Temp-75 ζC), 183 (Y-Ph PGCIL Side Temp-78 ζC)
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work.
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
KARAD - DASGAON	IntraState	22/02/2023	00:00	24/02/2023	19:25	PO	For Erection & stringing of In-line Narrow Base Multi circuit towers (Loc. No. 146 to 148) of new 220 KV Karad ζ Koyna line..
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	22/02/2023	06:12	24/02/2023	02:30	PO	Outage is required for safety purpose for:1) Erection of CTT Monopole in between Loc No- 398 & 399 of 220KV Kalwa-Bapgaon Line for the work of newly proposed substation of M/s.Estela Enterprises Pvt.Ltd.2) The monopole will be erected in line with cross-arm, in between both the Towers and 220 KV Kalwa Bapgaon line will charged through newly erected Monopole Tower after maintaining the sufficient distance from existing line.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BAPGAON - KALWA	IntraState	22/02/2023	06:15	24/02/2023	02:20	PO	1) Erection of CTT Monopole in between Loc No- 398 & 399 for the work of newly proposed substation of M/s.Estela Enterprises Pvt.Ltd.2) The monopole will be erected in line with cross-arm, in between both the Towers and 220 KV Kalwa Bapgaon line will charged through newly erected Monopole Tower after maintaining the sufficient distance from existing line.
KHARGHAR - TOPWORTH	IntraState	22/02/2023	08:27	25/02/2023	20:15	PO	Erection of Gantry & Beam at Proposed Panvel Timber Market and making connectivity of OPGW to KhandeshwarGIS.
KHARGHAR - TSS PANVEL	IntraState	22/02/2023	09:26	25/02/2023	20:48	PO	Erection of Granty & beam at proposed Panvel Timber Market and making connectivity of OPGE to Khandeshwar GIS.
TROMBAY - SALSETTE CKT - 1	IntraState	23/02/2023	23:06	24/02/2023	02:21	PO	400KVPTL work.
TALANDGE - BIDRI	IntraState	24/02/2023	09:20	24/02/2023	19:32	PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
TALANDGE - SAWANTWADI	IntraState	24/02/2023	09:32	24/02/2023	19:09	PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
CHEMBUR (AEML) - NERUL (M)	IntraState	24/02/2023	11:50	25/02/2023	01:30	PO	For Diagnostic and R & M work and to check Non operation of Auto-reclose of Nerul-Chembur (Adani) line by Testing Team, Kalwa at Nerul end.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	24/02/2023	12:31	24/02/2023	15:36		Replacement of R ph flashover string at loc No. 185 BY HOT LINE UNIT
PARANDA-BARSHI	IntraState	24/02/2023	14:40	24/02/2023	15:30	EO	For removing tarpoulin at location no 94 B phase
CHALISGAON - SAYNE	IntraState	24/02/2023	16:36	24/02/2023	18:50	PO	To attend heavy oil leakage of R ph CT.
ACCIL - APTA	IntraState	24/02/2023	17:04	24/02/2023	20:03	T	Tripped on Distance Protection.
URSE - TALEGAON (AMBI) CKT 1	IntraState	24/02/2023	17:08	25/02/2023	03:56	T	Tripped on Distance Protection.
SAHARA-URSE	IntraState	24/02/2023	17:08	25/02/2023	00:35	T	Due to LTS line tripped at Urse end.
KANDALGAON - ONGC PANVEL	IntraState	24/02/2023	18:18	24/02/2023	19:58	T	Tripped on Distance Protection.
TALANDGE - BIDRI	IntraState	25/02/2023	08:23	25/02/2023	19:01	PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
TALANDGE - SAWANTWADI	IntraState	25/02/2023	08:53	25/02/2023	18:48	PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	25/02/2023	08:59	25/02/2023	18:41	HT	For load management
EKLAHARA(OCR)-RAYMOND	IntraState	25/02/2023	10:22	25/02/2023	20:52	EO	To attend red hot

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV KARJAT-BELWANDI-CKT-1	IntraState	25/02/2023	11:40	25/02/2023	14:44		For attending Hot Spot on Y-ph and B-ph CT (95 Degrees and 138 Degrees). N.A.
SONKHAR - TROMBAY	IntraState	25/02/2023	14:03	25/02/2023	20:13	PO	Diagnostic testing work of Trombay Line bay, Isolator alignment work, CT CB painting work, RM work.
TAMBATI - ADLABS	IntraState	25/02/2023	14:14	25/02/2023	15:06	T	Field Fire observed at Loc no 526 to 528.
ACCIL - APTA	IntraState	25/02/2023	14:14	25/02/2023	19:27	T	Field Fire observed at Loc no 526 to 528
KAMBA - VASAI	IntraState	25/02/2023	23:01		Continued.	EO	To carry out the height raising work of AEML�s existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village � Gokhivare (Vasai) in connection with DFC project of Govt of India.
PADGHE - NALASOPARA - VASAI (T)	IntraState	25/02/2023	23:54		Continued.	EO	To carry out the height raising work of AEML's existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village Gokhivare (Vasai) in connection with DFC project of Govt of India.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	25/02/2023	09:50	25/02/2023	20:32	PO	ICT diagnostic testing work
220 KV BUSBAR Outages/Trippings							
LBB PROTECTION @ EKLAHARE (GCR)	IntraState	24/02/2023	14:40	24/02/2023	16:34		220kV and 132kV LBB Relay Testing
132 KV BUSBAR Outages/Trippings							
BUSBAR PROTECTION @ EKLAHARE (GCR)	IntraState	24/02/2023	10:43	24/02/2023	13:26		220kV and 132kV LBB Relay Testing
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
KALWA KALYAN	IntraState	24/02/2023	08:24	24/02/2023	20:48	PO	Project Work-For Runwal Project Line divesrion work
KARANJADE - BHOKARPADA	IntraState	24/02/2023	08:55	24/02/2023	17:10	PO	TREE TRIMMING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage