

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Feb/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	176.076	3965.840	1) Gujrat	4.229	-6.621
2) Hydro	6.187	180.090	2) Madhya Pradesh	6.394	139.746
3) Gas	7.097	163.021	3) Chattisgarh	4.310	90.450
Total MSPGCL	189.360	4308.951	4) Maharashtra	152.872	4150.196
B) 1) APLM	61.053	1551.126	5) Goa (Amona)	-1.945	-42.560
2) JSWEL	28.498	598.292	Total	165.860	4331.211
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.558	692.467
4) RPL(AMT)	31.540	755.244	b) Mumbai Drawl	27.766	789.502
5) SWPGPL	12.338	295.888	c) MSEDCL Bilateral *	83.606	2006.664
6) Other IPP	47.061	1150.213	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.558	692.465
C) 1) TPCL Thermal	10.603	217.099	Include PX	0.000	0.000
2) TPCL Hydro	3.214	79.395	Standby	0.000	0.003
3) TPCL Gas	3.106	80.678	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.810	234.059	1) MSEDCL	523.815	12553.579
D) STATE			2) Mumbai Discoms	54.499	1400.625
1) Thermal	376.979	8767.761	3) Other Discoms	10.362	251.688
(A1+C1+C4+(B1-B6))			TOTAL STATE	588.676	14205.892
2) Hydro	9.401	259.485			
(A2+C2)					
3) Gas	10.203	243.699			
(A3+B7+C3)					
4) Wind	8.556	218.328			
6) SOLAR	17.677	385.516			
TOTAL STATE	422.816	9874.789			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7776	6605	7847	7592
MSPGCL Hydro	171	165	587	167
MSPGCL Gas	290	283	292	308
MSPGCL Total Generation	8237	7053	8726	8067
Central Sector Receipt	8306	8391	6275	5693
WIND	121	274	593	240
CPP / IPP Thermal	7712	7101	8028	7385
CPP / IPP Gas	0	0	0	0
SOLAR	2130	2451	0	0
Exchange with Mumbai	-1530	-1612	-961	-788
MSEDCL DEMAND MET	24504	23223	22176	20254
Load Shedding	0	0	0	0
MSEDCL DEMAND	24504	23223	22176	20254
TPCL GENERATION	679	671	1140	572
AEML GENERATION	490	413	490	404
MUMBAI DEMAND	2699	2696	2591	1764
OTHER DISCOM DEMAND	472	435	485	343
STATE DEMAND MET	27675	26354	25252	22361
STATE DEMAND	27675	26354	25252	22361
Frequency (Hz)	49.98	50.02	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 06:02 Hrs	49.75 Hz at 09:06 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Feb/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.36	105.33	190	170
Unit 8	14.73	350.50	649	560
Unit 9	12.63	317.38	581	433
Unit 10	12.73	324.30	565	425
Total	44.44	1097.50		
Bhusawal				
Unit 3	3.45	83.56	175	125
Unit 4	10.26	165.62	500	295
Unit 5	9.85	216.02	500	280
Total	23.56	465.20		
Parli				
Unit 6	4.15	99.52	250	143
Unit 7	3.85	97.91	234	112
Unit 8	4.07	98.62	246	145
Total	12.07	296.05		
Chandrapur				
Unit 3	3.28	79.26	152	115
Unit 4	3.56	73.56	166	120
Unit 5	8.78	202.07	440	275
Unit 6	8.56	78.24	430	285
Unit 7	8.47	178.84	446	289
Unit 8	9.66	228.38	423	296
Unit 9	10.83	259.91	483	298
Total	53.15	1100.25		
Paras				
Unit 3	5.58	132.78	251	191
Unit 4	5.99	137.38	255	223
Total	11.57	270.17		
Khaparkheda				
Unit 1	4.14	93.08	180	160
Unit 2	3.88	44.24	181	137
Unit 3	4.11	91.48	176	147
Unit 4	4.08	88.30	192	152
Unit 5	11.58	264.80	500	460
Total	27.80	581.90		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.49	86.38	170	122
Unit 5	0.00	68.39	0	0
Total	3.49	154.77		
Uran				
All Units	7.10	163.02	309	279
Total	7.10	163.02		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	2.03	47	0
Total	0.14	2.03		
Koyna				
Stage 1-2	1.46	41.26	190	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.15	16.68	51	0
Stage 3	0.46	13.60	160	0
Total	2.08	71.55		
Hydro				
KDPH	0.86	20.74	36	36
VTRNA	0.16	4.19	60	0
TILLARI	0.52	6.14	65	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.05	63.06	91	80
GHATGHAR	0.38	12.39	125	0
Total	3.96	106.51		
Wind				
Total	8.56	218.33	0	0
Total	8.56	218.33		
CPP				
APML(Mus)	61.05	1551.13	0	0
JSWEL(Mus)	28.50	598.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.54	755.24	0	0
SWPGPL-Mus	12.34	295.89	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.60	133.01	268	162
Other(Mus)	38.68	955.12	0	0
JPL	2.78	62.08	131	109
Total	180.49	4350.76		
SOLAR				
Total	17.68	385.52	0	0
Total	17.68	385.52		
Tata				
Trombay 5	6.92	190.40	438	190
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.85	48.72	108	39
Trombay 7B	1.26	31.96	65	36
TATA Hydro	3.21	79.40	381	12
Trombay 8	3.68	26.70	221	131
Total	16.92	377.17		
AEML				
DTPS U-1&2	9.81	234.06	490	319
Total	9.81	234.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	176.08	3965.84	MSPGCL Total	189.36	4308.95
			MSPGCL Thml+Gas	183.17	4128.86	Koyna 1,2 & 4 Total	1.62	57.94
			MSPGCL Hydro	6.19	180.09	State Total	422.82	9874.79

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Feb/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7350	166	305	7821	173	7367	0	0	6235	6136	-949	20155	0	0	20155	1984	393	22532	49.95
2	7573	167	305	8045	216	7427	0	0	6044	5994	-856	20447	0	0	20447	1858	379	22684	49.99
3	7592	167	308	8067	240	7385	0	0	6032	5693	-788	20254	0	0	20254	1764	343	22361	49.99
4	7469	167	308	7944	279	7413	0	0	6208	5966	-825	20437	0	0	20437	1705	340	22482	50.01
5	7278	172	306	7756	267	7514	0	0	6321	6619	-837	20970	0	0	20970	1704	349	23023	49.95
6	7590	168	307	8065	281	8052	0	0	6266	6512	-908	21625	0	0	21625	1805	377	23807	50.01
7	7729	371	309	8409	275	8312	0	11	6152	6243	-684	22159	0	0	22159	1928	407	24494	50.01
8	7812	712	306	8830	309	8266	0	279	5879	6098	-473	22884	0	0	22884	2066	425	25375	50.02
9	7905	378	302	8585	214	8033	0	1003	6798	6623	-702	23296	0	18	23296	2285	460	26041	50.04
10	7681	300	293	8274	120	7685	0	1733	7899	8100	-1322	24125	0	29	24125	2514	465	27104	49.89
11	7776	171	290	8237	121	7712	0	2130	8657	8306	-1530	24504	0	43	24504	2699	472	27675	49.98
12	7300	185	290	7775	151	7341	0	2354	8663	8523	-1678	23994	0	40	23994	2746	472	27212	50.01
13	6605	165	283	7053	274	7101	0	2451	8234	8391	-1612	23223	0	35	23223	2696	435	26354	50.02
14	6383	165	282	6830	358	6833	0	2358	8090	8073	-1636	22383	0	84	22383	2556	433	25372	50.03
15	6377	164	279	6820	449	6718	0	2141	8106	8409	-1689	22402	0	8	22402	2561	446	25409	50.00
16	6830	164	280	7274	466	7037	0	1708	8249	8035	-1593	22450	0	7	22450	2578	477	25505	49.95
17	7038	164	283	7485	485	7296	0	1097	7780	7620	-1426	22064	0	0	22064	2527	493	25084	49.97
18	7524	231	286	8041	444	7483	0	403	7114	6817	-1242	21488	0	0	21488	2505	458	24451	50.04
19	7762	513	290	8565	461	7646	0	9	6736	6416	-1107	21516	0	0	21516	2528	474	24518	49.96
20	7847	587	292	8726	593	8028	0	0	6504	6275	-961	22176	0	0	22176	2591	485	25252	50.03
21	7362	394	296	8052	591	7712	0	0	6801	6202	-1210	20880	0	8	20880	2439	467	23786	50.00
22	6837	180	296	7313	577	7324	0	0	6801	6626	-1321	20051	0	0	20051	2295	468	22814	49.99
23	7229	169	300	7698	632	7399	0	0	6439	6089	-1262	20146	0	0	20146	2142	410	22698	49.95
24	7227	167	301	7695	580	7406	0	0	6306	6094	-1155	20188	0	0	20188	2023	432	22643	49.99
MUs	176.08	6.19	7.10	189.36	8.56	180.49	0.00	17.68	168.31	165.86	-27.77	523.82	0.00	0.27	523.82	54.50	10.36	588.68	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR carried out due to 50MVA T/F overload at Kopargaon S/stn. 2) ELR carried out due to overload of 132KV BBLSR-Rahuri line.3) ELR carried out due to overload of 220KV Nasik-BBLSR-I line.4) ELR carried out due to tripping of 220KV Lonikand I-Kathapur Line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Feb/2024

Position as on 6.30 Hrs of 25/Feb/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	29/02/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
Total Capacity MSPGCL		398						
CENT.SECTOR								
CENT.SECTOR	Tarapur 3	540	11/01/2024	21:45		Continued.	Annual Overhaul	29/02/2024
Total Capacity CENT.SECTOR		540						
Total Capacity PLANNED OUTAGE		938						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Nasik Unit 5	210	21/02/2024	16:38	25/02/2024	23:10	High DM water consumption.	25/02/2024
Total Capacity MSPGCL		438						
IPP								
IPP	JPL Unit 1	150	13/01/2024	01:00		Continued.	Due to low net sale realisation. (while rolling at 21.00hrs. dtd. 31/01/2024 tripped on high vibration during rolling)	26/02/2024
IPP	IEPL Unit 1	270	25/02/2024	02:02		Continued.	suspected leakage in the boiler	26/02/2024
Total Capacity IPP		420						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1178						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Feb/2024

Position as on 6.30 Hrs of 25/Feb/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 24/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
AKOLA II - EKTUNI CKT - 1	IntraState	25/02/2024	10:51	25/02/2024	16:05	PO	BCT cable replacement & cable tray installation work
400 KV MAINBAY Outages/Tripping							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Tripping							
DHULE - SSNNL CKT - 1	InterState	15/02/2024	09:24			PO	Major Maintenance of GIS
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
220 KV DEEPNAGAR (400 KV) - CHALISGAON CKT	IntraState	24/02/2024	10:51	24/02/2024	16:43	PO	Replacement of R Phase CT
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	24/02/2024	13:39	24/02/2024	20:31	PO	Spacer fixing in between Loc.3-4, Loc 4-5, Loc 4-5 & Loc 5 -6
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	24/02/2024	13:39	24/02/2024	20:31	PO	For replacement of polymer insulator string with long rod porcelain insulator string at loc. No. 75D & 75F
PARLI - KARJAT CKT - 2	IntraState	24/02/2024	19:52	24/02/2024	22:09	PO	H/W tightening and cleaning
NEW KOYNA-KARAD CKT - 1	IntraState	25/02/2024	23:05			HT	For voltage management
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
105 MVA SPARE ICT @ AKOLA	IntraState	04/02/2024	09:21			EO	for removal of 401 52 circuit breaker of spare ICT for replacement of 40952 B phase CB of Tie Bay 409
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	12/02/2024	10:28			PO	Erection of CS Type Gantry Beam Structure for RRS Scheme of ICTs
400/11.5KV STATION TRANSFORMER - 5 @ TIRORA	IntraState	20/02/2024	11:46			PO	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.
400/220KV 167 MVA SPARE ICT @ DHULE	IntraState	24/02/2024	10:16	24/02/2024	14:00	PO	For RRS Scheme / Project Work
400 KV BR Outages/Tripping							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV LINE Outages/Trippings							
JEUR - SOLAPUR PG	InterState	24/02/2024	11:15	24/02/2024	13:35	T	Tripped on Distance protection.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS & Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
BHIGWAN - WALCHAND NAGAR	IntraState	23/02/2024	09:35	24/02/2024	01:39	PO	For main bus isolator blade replacement work
WADA - BHAVEGHAR	IntraState	23/02/2024	11:15	24/02/2024	05:46	PO	For making cut point formation at proposed Loc.no.86A-01 (LILO tower) on 220kV Wada - Bhaveghar Line & for installation/Retrofitting of 87L relay at end s/sn i.e 220kV Wada in r/o LILO on 220kV Wada -Bhaveghar line for proposed new 220kV INOX Substation at village Nichole ,Taluka -Wada -Palghar under ORC Scheme under EHV Project Dn, Kalyan.
WARDHA-YEOTMAL	IntraState	24/02/2024	07:08	24/02/2024	16:13	PO	wok of increasing the ground clearance by de stringing and restringing of the conductor in span
BOISAR II - VIRAJ	IntraState	24/02/2024	09:41	24/02/2024	15:58	PO	For Bay maintenance & equipment testing work.
SIEMENS - RELIANCE GIS	IntraState	24/02/2024	09:43	24/02/2024	14:36	PO	1)To attend the leakage of building roof and gutter issue at 220kV Siemens Substation end. 2) Replacement of 220kV GIS bushing clamps at 220kV Reliance GIS substation End.
220 KV GHUGGUS - ACC CKT	IntraState	24/02/2024	10:22	24/02/2024	16:04	PO	Replacement of B Phase line side 220KV CT
220 KV UMRED - TOPWORTH CKT	IntraState	24/02/2024	10:40	24/02/2024	12:16	PO	Replacement of Flash over Insulator String
TROMBAY - MULUND	IntraState	24/02/2024	12:01	24/02/2024	18:50	PO	For 1) Diagnostic Testing work & 2) RM work
WAGHIVALI - DHARAVI 7	IntraState	24/02/2024	12:09	24/02/2024	18:33	PO	Project work-differential Protection testing of three terminal line
PARGAON(KATHAPUR)-LONIKAND	IntraState	24/02/2024	12:53	24/02/2024	18:16	T	Tripped on distance protection due to Bph. LA burst at Kathapur end.
220 KV VIRODA - AMALNER	IntraState	24/02/2024	15:54	24/02/2024	21:54	PO	Testing and Maintenance work
KADEGAON-MIRAJ	IntraState	24/02/2024	16:04	24/02/2024	19:32	PO	Fixing of turbine ventilator Rotating type Bird Guard
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	24/02/2024	19:51	24/02/2024	20:08	T	Distance Protection
WARDHA-YEOTMAL	IntraState	25/02/2024	06:43	25/02/2024	18:42	PO	work of increasing the ground clearance by de-stringing and restringing of conductor in span
KANDALGAON - PIRANGUT	IntraState	25/02/2024	08:05	25/02/2024	18:48	PO	1) Fixing of conductor vibration dampers. 2) Cold line cleaning of insulators.
SALSETTE BORIVLI - 2	IntraState	25/02/2024	09:12	25/02/2024	19:08	PO	Closer inspection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	20/02/2024	11:05			PO	1. Oil filtration Work 2. IED Commissioning & Installation work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 25/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/132 KV 200 MVA ICT 1 @ AHMEDNAGAR	IntraState	24/02/2024	10:32	24/02/2024	14:54	PO	Diagnostic testing and Quarterly Maintenance work.
220/33 KV 25 MVA PTR 1 @ AHMEDNAGAR	IntraState	24/02/2024	15:40	24/02/2024	18:00	PO	Diagnostic testing and Quarterly Maintenance work.
220 KV BUSBAR Outages/Trippings							
220KV BUS 2 @ TARAPUR-220 KV	InterState	23/02/2024	11:41			PO	Preventive Maintenance checks & SF6 gas leak rectification job
220KV BUS 1 @ TARAPUR-220 KV	InterState	23/02/2024	11:41			PO	Preventive Maintenance checks & SF6 gas leak rectification job
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	06/02/2024	19:55			PO	PROJECT WORK-Conductor replacement
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
KOLSHET - BMC - BORIVALI (T) - BORIVALI (M)	IntraState	25/02/2024	09:02	25/02/2024	12:24	PO	Work in vicinity for salsette Borivali 2 work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage