

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Mar/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	170.273	3799.690	1) Gujrat	-2.188	59.415
2) Hydro	9.008	256.365	2) Madhya Pradesh	10.690	136.444
3) Gas	2.669	91.886	3) Chattisgarh	4.680	105.960
Total MSPGCL	181.950	4147.941	4) Maharashtra	168.144	3952.786
B) 1) APML	71.791	1630.558	5) Goa (Amona)	-1.220	-37.342
2) JSWEL	20.142	579.307	Total	180.106	4217.263
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.509	746.351
4) RPL(AMT)	31.137	729.221	b) Mumbai Drawl	35.549	876.263
5) SWPGPL	8.483	237.258	c) MSEDCL Bilateral *	89.639	2051.788
6) Other IPP	29.772	920.026	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.509	746.351
C) 1) TPCL Thermal	10.272	255.304	Include PX	0.000	0.000
2) TPCL Hydro	5.014	78.335	Standby	0.000	0.000
3) TPCL Gas	2.352	64.009	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.311	251.234	1) MSEDCL	509.656	11955.630
D) STATE			2) Mumbai Discoms	63.498	1525.145
1) Thermal	352.181	8402.598	3) Other Discoms	10.504	243.010
(A1+C1+C4+(B1-B6))			TOTAL STATE	583.658	13723.785
2) Hydro	14.022	334.700			
(A2+C2)					
3) Gas	5.021	155.895			
(A3+B7+C3)					
4) Wind	15.598	284.527			
6) SOLAR	16.730	328.802			
TOTAL STATE	403.552	9506.522			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6668	6739	7423	7155
MSPGCL Hydro	660	239	411	246
MSPGCL Gas	111	110	110	112
MSPGCL Total Generation	7439	7088	7944	7513
Central Sector Receipt	9016	9239	6942	6581
WIND	268	300	1167	447
CPP / IPP Thermal	6700	6634	6926	6714
CPP / IPP Gas	0	0	0	0
SOLAR	2245	2135	0	0
Exchange with Mumbai	-1831	-1851	-1322	-1306
MSEDCL DEMAND MET	23366	23093	21186	19566
Load Shedding	0	0	0	0
MSEDCL DEMAND	23366	23093	21186	19566
TPCL GENERATION	874	863	1108	567
AEML GENERATION	499	447	449	456
MUMBAI DEMAND	3204	3161	2879	2329
OTHER DISCOM DEMAND	471	452	471	383
STATE DEMAND MET	27041	26706	24536	22278
STATE DEMAND	27041	26706	24536	22278
Frequency (Hz)	49.88	49.99	49.98	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 18.03 Hrs	49.7 Hz at 21.11 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.82	108.66	205	195
Unit 8	13.06	218.71	548	533
Unit 9	14.34	323.68	612	575
Unit 10	12.17	202.83	526	470
Total	44.39	853.87		
Bhusawal				
Unit 3	2.99	77.60	160	110
Unit 4	9.92	225.56	490	280
Unit 5	10.19	236.66	495	280
Total	23.10	539.82		
Parli				
Unit 6	3.81	108.26	240	141
Unit 7	3.81	106.36	238	140
Unit 8	2.92	83.50	131	114
Total	10.54	298.12		
Chandrapur				
Unit 3	3.18	83.05	164	114
Unit 4	3.14	76.57	149	116
Unit 5	7.39	103.50	400	275
Unit 6	8.47	206.17	385	330
Unit 7	8.05	198.32	430	280
Unit 8	10.91	254.59	497	292
Unit 9	10.92	222.79	496	337
Total	52.06	1144.99		
Paras				
Unit 3	4.44	110.58	219	146
Unit 4	4.86	125.36	244	144
Total	9.30	235.94		
Khaparkheda				
Unit 1	1.92	63.82	115	60
Unit 2	2.62	71.67	121	100
Unit 3	3.82	85.56	179	131
Unit 4	3.91	91.64	190	127
Unit 5	10.71	252.00	490	295
Total	22.97	564.68		
Nasik				
Unit 3	3.91	7.99	178	124
Unit 4	4.00	77.11	181	128
Unit 5	0.00	77.17	0	0
Total	7.92	162.28		
Uran				
All Units	2.67	91.89	112	110
Total	2.67	91.89		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.09	3.02	47	0
Total	0.09	3.02		
Koyna				
Stage 1-2	1.69	59.90	220	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.22	55.48	432	0
Stage 3	0.60	24.99	206	0
Total	3.50	140.36		
Hydro				
KDPH	0.86	20.29	36	36
VTRNA	1.20	26.33	61	0
TILLARI	0.46	7.30	58	0
BHIRA T.R.	0.24	3.25	80	0
SMLHY_PTN	2.64	55.80	112	108
GHATGHAR	0.00	0.00	0	0
Total	5.41	112.98		
Wind				
Total	15.60	284.53	0	0
Total	15.60	284.53		
CPP				
APML(Mus)	71.79	1630.56	0	0
JSWEL(Mus)	20.14	579.31	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.14	729.22	0	0
SWPGPL-Mus	8.48	237.26	0	0
Dhariwal	5.93	143.42	270	218
IEPL	5.03	119.34	268	196
Other(Mus)	18.81	657.27	0	0
Total	161.32	4096.37		
SOLAR				
Total	16.73	328.80	0	0
Total	16.73	328.80		
Tata				
Trombay 5	6.82	169.47	378	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.31	37.32	108	43
Trombay 7B	1.04	26.69	65	39
TATA Hydro	5.01	78.34	419	4
Trombay 8	3.46	85.84	213	130
Total	17.64	397.65		
AEML				
DTPS U-1&2	10.31	251.23	499	298
Total	10.31	251.23		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	170.27	3799.69	MSPGCL Total	181.95	4147.94
			MSPGCL Thml+Gas	172.94	3891.58	Koyna 1,2 & 4 Total	2.90	115.37
			MSPGCL Hydro	9.01	256.36	State Total	403.55	9506.52

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7155	246	112	7513	447	6714	0	0	6779	6581	-1306	19566	0	19566	2329	383	22278	49.98
2	7289	245	112	7646	573	6717	0	0	6802	6653	-1279	19953	0	19953	2160	357	22470	50.01
3	7419	245	112	7776	680	6719	0	0	6572	6307	-1207	19919	0	19919	2020	356	22295	49.97
4	7467	258	111	7836	683	6757	0	0	6557	6487	-1158	20266	0	20266	1944	339	22549	49.97
5	7433	279	111	7823	643	6767	0	0	6823	6971	-1127	20735	0	20735	1937	342	23014	50.00
6	7703	609	112	8424	645	6733	0	0	6787	6795	-1026	21196	0	21196	2054	375	23625	49.97
7	7820	1018	112	8950	673	6690	0	38	7042	7085	-1022	21995	0	21995	2186	419	24600	50.00
8	7853	668	112	8633	510	6717	0	452	7319	7439	-1168	22139	0	22139	2345	444	24928	50.04
9	7263	371	112	7746	333	6707	0	1085	7829	7847	-1487	21756	0	21756	2645	475	24876	50.02
10	7103	410	112	7625	301	6697	0	1688	8210	8028	-1745	22124	0	22124	2948	470	25542	50.07
11	6642	466	112	7220	251	6717	0	2099	9106	8971	-1786	22999	0	22999	3151	473	26623	49.92
12	6668	660	111	7439	268	6700	0	2245	9084	9016	-1831	23366	0	23366	3204	471	27041	49.88
13	6739	239	110	7088	300	6634	0	2135	9036	9239	-1851	23093	0	23093	3161	452	26706	49.99
14	6478	187	111	6776	423	6587	0	2064	9189	8940	-1929	22407	0	22407	2998	454	25859	50.06
15	6192	186	110	6488	425	6583	0	1887	9280	9206	-2010	22109	0	22109	3059	470	25638	49.99
16	6258	303	110	6671	491	6613	0	1602	9087	9218	-1979	22130	0	22130	3096	486	25712	50.01
17	6471	413	111	6995	773	6599	0	1009	8747	8630	-1903	21598	0	21598	3067	505	25170	49.95
18	7033	320	111	7464	944	6654	0	392	8052	7410	-1765	20615	0	20615	2993	484	24092	49.98
19	7459	330	112	7901	1093	6756	0	34	7129	6493	-1535	20247	0	20247	2897	495	23639	50.05
20	7423	411	110	7944	1167	6926	0	0	6655	6942	-1322	21186	0	21186	2879	471	24536	49.98
21	7250	325	112	7687	1110	6925	0	0	6396	6353	-1299	20319	0	20319	2766	457	23542	49.93
22	7006	306	110	7422	1004	6903	0	0	6399	6366	-1269	19961	0	19961	2625	465	23051	49.94
23	7059	263	110	7432	963	6732	0	0	6430	6517	-1216	19981	0	19981	2536	447	22964	49.99
24	7090	250	111	7451	898	6778	0	0	6585	6612	-1329	19996	0	19996	2498	414	22908	49.99
MUs	170.27	9.01	2.67	181.95	15.60	161.33	0.00	16.73	181.89	180.11	-35.55	509.66	0.00	509.66	63.50	10.50	583.66	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Mar/2023

Position as on 6.30 Hrs of 25/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U1	300	19/03/2023	17:29		Continued.	Zero Schedule	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Uran Unit 6	108	18/03/2023	12:44		Continued.	ZERO SCHEDULE.	
MSPGCL	Nasik Unit 5	210	23/03/2023	03:10		Continued.	Withdrawn due to changer from Unit3 to 5	27/03/2023
IPP	SWPGPL U-1	135	24/03/2023	12:22	24/03/2023	16:25	GOVERNOR TRIPPED	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 25/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
PADGHE - BOISAR (PG)	InterState	24/03/2023	14:02	24/03/2023	14:50	T	Tripped on Distance Protection.
PADGHE - NAGOTHANE CKT - 2	IntraState	20/03/2023	10:07	25/03/2023	12:35	PO	CB replacement work
PARLI - KARJAT CKT - 2	IntraState	23/03/2023	23:02	24/03/2023	05:22	PO	String replacement hardware tightening cold line washing
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	24/03/2023	10:17			HT	System loading
220 KV WAGHALA-KUMBHARGAON (400 KV) CKT -1	IntraState	24/03/2023	11:04	24/03/2023	17:57	PO	CT Replacement
MAIN BUS-1 @ BABHALESHWAR	IntraState	25/03/2023	08:45	25/03/2023	19 56	PO	Bus CVT Testing
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	IntraState	25/03/2023	09:48	25/03/2023	17:57	PO	1. Measurement of CB timing , CRM and DRCM. 2. Maintenance work of CB, PG-1(Bus-1) & PG-2(Bus-2) Isolators. This circuit will be in service via 400KV TBC-1
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	24/03/2023	08:40	24/03/2023	21:41	PO	1. DFRA of Rph & Bph Unit of ICT -2 2. 220KV side TC-2 supervision work. 3. Maintenance and alignment of PG-1, PG-2 , PG-3 & CBI Isolators.
400/220KV 167 MVA SPARE ICT @ DHULE	IntraState	25/03/2023	10:09	25/03/2023	16:26	PO	Outage required on 167 MVA Spare ICT-2 for diagnostic testing work
400 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ DHARIWAL	IntraState	18/03/2023	10:28			PO	STU CTU bus connection as per CERC order
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
JEJURI-PHURSUNGI 1	IntraState	23/03/2023	11:08	24/03/2023	16:42	PO	CB mechanism overhauling work. Line will be in service through TBC
TROMBAY - SALSETTE CKT - 1	IntraState	23/03/2023	22:57	24/03/2023	04:45	PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
TROMBAY DHARAVI - 5	IntraState	23/03/2023	23:01	24/03/2023	05:28	PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
NEW KOYNA - NIWALI	IntraState	24/03/2023	07:48	24/03/2023	14:38	PO	For cold washing of insulator strings.
ONGC URAN - JNPT	IntraState	24/03/2023	09:30	24/03/2023	13:25	PO	For diagnostic testing work at both end.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 25/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VANKUSWADE - KDPH	IntraState	24/03/2023	09:35	24/03/2023	18:30	PO	R & Y Phase Wave trap jump replacement work at 220kV KDPH S/Stn. Also, work of land/hill cutting between loc no.86-87 due to low ground clearance beside & below the conductor.
HINGANGHAT - BHUGAON	IntraState	24/03/2023	10:03	24/03/2023	15:19	PO	Replacement of Broken Disc Insulator
PUSAD - HINGOLI	IntraState	24/03/2023	10:30	24/03/2023	12:42	PO	Replacement of Flash over Insulator string
PARLI NEW TPS - BEED CKT 1	IntraState	24/03/2023	11:16	24/03/2023	16:00	PO	To attend Hot Spot
KALWA - TFIPL	IntraState	24/03/2023	11:55	24/03/2023	12:37	T	Tripped on distance protection
MALEGAON - SAYNE	IntraState	24/03/2023	12:32	24/03/2023	16:52	PO	for relay testing work cariied out by testing unit malegaon
NEW KOYNA - LOTEPARSHURAM	IntraState	24/03/2023	16:03	24/03/2023	20:36	PO	For cold washing of insulator strings.
MIRAJ - ICHALKARANJI	IntraState	24/03/2023	17:05	24/03/2023	19:40	EO	For removal of bunching arrangement between Ckt I & II of 220 KV Tilwani - Miraj line
NIGADE- PETH LINE	IntraState	24/03/2023	21:26	25/03/2023	18:15	T	Y phase CT burst at Nigade end
TROMBAY DHARAVI - 5	IntraState	24/03/2023	22:56			PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	25/03/2023	01:33	25/03/2023	04:48	HT	For load management
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	25/03/2023	02:18	25/03/2023	04:44	PO	For outage on 220 Kv Babhaleshwar NASIK Ckt 2 (DC LINE) for replacement of the burned jumper nut bolts due to hot spot (there is no hot spot temperature on this loc) at loc no 197 cut point detected in monkey patrolling of the line , outage on 25.03.2023 from 2.30 hrs. to 6.00 hrs
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	25/03/2023	02:18	25/03/2023	04:44	PO	For outage on 220 Kv Babhaleshwar NASIK Ckt 2 (DC LINE) for replacement of the burned jumper nut bolts due to hot spot (there is no hot spot temperature on this loc) at loc no 197 cut point detected in monkey patrolling of the line , outage on 25.03.2023 from 2.30 hrs. to 6.00 hrs
NEW KOYNA - NIWALI	IntraState	25/03/2023	08:28	25/03/2023	15:57	PO	For cold washing of insulator strings.
MAIN BUS - 2 @ BOISAR II	IntraState	25/03/2023	08:45	25/03/2023	19:56	PO	Bus Isolator R/M & other R/M Work
BUS SECTIONIZER @ BIDRI	IntraState	25/03/2023	09:40	25/03/2023	11:40	PO	quarterly Maintenance work
CHAKAN-BHOSARI 1	IntraState	25/03/2023	10:12	25/03/2023	13:14	PO	1.Testing of Coupling Capacitor & Wave Trap . 2.Cold Line washing of insulators strings. 3.Fixing of repair sleeve between loc No-52-53 (Sr no 2 & 3 is proposed by lines S/Dn work)
220 KV CHADRAPUR MIDC - GADCHANDUR CKT TAP	IntraState	25/03/2023	12:35	25/03/2023	18:50	T	Distance Protection
KANDALGAON - SONA ALLOYS	IntraState	25/03/2023	15:34	25/03/2023	21:12	PO	Midspan joint and replacement of Damaged long rod polymer at Loc.No.46, Outage tree cutting work and other line maintenance work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 25/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	25/03/2023	15:34	25/03/2023	21:12	PO	Repair Sleeve fixing work of damaged conductor between loc No.259 to 260 YB Ph.
NEW KOYNA - LOTEPARSHURAM	IntraState	25/03/2023	17:10	25/03/2023	19:55	PO	For cold washing of insulator strings.
PHURSUNGI-PARVATI	IntraState	25/03/2023	23:49		Continued.	PO	Half Yearly Maint. attending oil leakage from collar of R Ph CT
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100MVA ICT 1@ PETH	IntraState	24/03/2023	10:01	24/03/2023	13:40	PO	C & Tand testing work of LV R Ph CT
220/110kv 100MVA ICT - 3 @ PETH	IntraState	24/03/2023	10:05	24/03/2023	16:40	PO	Diagnostic testing work
220/33kv 50MVA TF-2 @ KOPARGAON	IntraState	24/03/2023	10:52	24/03/2023	18:08	PO	Overhauling and Maintenance of OLTC
220/132 KV 200 MVA ICT 2 @ RAYMOND	IntraState	25/03/2023	09:43	25/03/2023	20:10	PO	replacment of 3 nos of 220kv high tan delta CTs Measurement of winding resistance of ICT 2 Complete bay maintenance
220/132 KV 200 MVA PTR NO 6 @ PARVATI	IntraState	25/03/2023	10:06	25/03/2023	18:10	PO	OLTC Overhauling
220 KV BUSBAR Outages/Trippings							
GIS BUS - 2 @ SALSETTE	IntraState	22/03/2023	04:49	24/03/2023	18:58	PO	KS # 5 New Bay connection to GIS BUS
110 KV LINE Outages/Trippings							
BHIRA (T) - KHOPOLI 2	IntraState	24/03/2023	11:44	24/03/2023	18:06	T	Conductor snapping

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage