

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Apr/2020 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	62.456	1434.987	1) Gujrat	9.845	243.861
2) Hydro	26.352	446.610	2) Madhya Pradesh	12.589	356.180
3) Gas	6.730	165.962	3) Chattisgarh	7.730	182.280
Total MSPGCL	95.538	2047.559	4) Maharashtra	127.255	3002.982
B) 1) APMIL	71.327	1532.968	5) Goa (Amona)	0.000	0.000
2) JSWEL	19.868	381.440	Total	157.419	3785.303
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.485	439.628
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.471	396.460
5) WPCL	5.451	131.673	c) MSEDCL Bilateral *	57.929	1279.522
6) Other IPP	7.563	193.268	Include PX	35.056	817.138
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.485	439.628
C) 1) TPCL Thermal	6.498	261.806	Include PX	5.433	142.870
2) TPCL Hydro	4.978	101.976	Standby	0.000	0.000
3) TPCL Gas	4.408	83.597	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.975	248.570	1) MSEDCL	363.343	8150.495
D) STATE			2) Mumbai Discoms	49.330	1092.406
1) Thermal	182.138	4184.712	TOTAL STATE	412.673	9242.901
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	31.330	548.586			
3) Gas (A3+B7+C3)	11.138	249.559			
4) Wind	22.997	298.700			
6) SOLAR	7.651	176.044			
TOTAL STATE	255.254	5457.601			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2476	2404	2722	2680
MSPGCL Hydro	780	1109	1067	1454
MSPGCL Gas	276	276	284	279
MSPGCL Total Generation	3532	3789	4073	4413
Central Sector Receipt	8014	8037	5053	5740
WIND	430	615	1291	1054
CPP / IPP Thermal	4298	4251	4484	4268
CPP / IPP Gas	0	0	0	0
SOLAR	1007	1018	0	0
Exchange with Mumbai	-1095	-1104	-1066	-906
MSEDCL DEMAND MET	16186	16606	13835	14569
Load Shedding	0	0	0	0
MSEDCL DEMAND	16186	16606	13835	14569
TPCL GENERATION	571	580	805	706
AEML GENERATION	373	374	375	373
MUMBAI DEMAND	2039	2058	2246	1985
STATE DEMAND MET	18225	18664	16081	16554
STATE DEMAND	18225	18664	16081	16554
Frequency (Hz)	49.99	49.93	50.01	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.22 Hz at 16.01 Hrs	49.75 Hz at 12.17 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 24/Apr/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	112.89	0	0
Unit 9	0.00	112.84	0	0
Unit 10	0.00	108.90	0	0
Total	0.00	334.63		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	13.91	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	10.48	59.90	475	360
Unit 7	0.00	0.00	0	0
Unit 8	11.13	200.62	480	430
Unit 9	9.20	228.17	430	360
Total	30.81	502.61		
Paras				
Unit 3	5.88	129.41	250	225
Unit 4	6.02	118.03	256	223
Total	11.90	247.44		
Khaparkheda				
Unit 1	0.00	38.21	0	0
Unit 2	0.00	44.42	0	0
Unit 3	4.43	46.84	195	158
Unit 4	4.37	50.65	195	160
Unit 5	10.94	170.19	501	360
Total	19.75	350.31		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.73	165.96	300	266
Total	6.73	165.96		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	4.15	43	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.12	4.15		
Koyna				
Stage 1-2	6.80	131.28	545	40
Stage 4	12.49	176.02	974	46
Stage 3	4.31	64.08	320	80
Total	23.61	371.38		
Hydro				
KDPH	0.86	20.61	36	36
VTRNA	0.00	0.00	0	0
TILLARI	0.38	10.01	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.28	5.16	80	0
RNGR+BHTSA	0.31	6.85	13	12
BHANDARDRA	0.46	12.42	20	19
ELDARY	0.00	5.36	0	0
SMLHY_PTN	0.45	14.83	28	16
GHATGHAR	0.00	0.00	0	0
Total	2.74	75.23		
Wind				
Total	23.00	298.70	0	0
Total	23.00	298.70		
CPP				
APML(Mus)	71.33	1532.97	0	0
JSWEL(Mus)	19.87	381.44	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	5.45	131.67	0	0
Other(Mus)	7.56	193.27	0	0
Total	104.21	2239.35		
SOLAR				
Total	7.65	176.04	0	0
Total	7.65	176.04		
Tata				
Trombay 5	6.50	206.98	272	270
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	51.59	118	116
Trombay 7B	1.60	32.01	67	66
Trombay 8	0.00	54.82	0	0
TATA Hydro	4.98	101.98	399	56
Total	15.88	447.38		
AEML				
DTPS U-1&2	8.98	248.57	377	372
Total	8.98	248.57		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	62.46	1434.99	MSPGCL Total	95.54	2047.56
			MSPGCL Thml+Gas	69.19	1600.95	Koyna 1,2 & 4 Total	19.30	307.30
			MSPGCL Hydro	26.35	446.61	State Total	255.25	5457.60

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Apr/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2701	1270	287	4258	1035	4405	0	0	6281	6407	-1145	14960	0	14960	2302	17262	50.02
2	2662	1531	278	4471	924	4364	0	0	6008	5974	-1062	14671	0	14671	2198	16869	49.99
3	2676	1585	298	4559	1084	4233	0	0	5690	5689	-958	14607	0	14607	2078	16685	50.00
4	2680	1454	279	4413	1054	4268	0	0	5707	5740	-906	14569	0	14569	1985	16554	49.97
5	2680	1523	289	4492	1008	4327	0	0	5830	5856	-867	14816	0	14816	1929	16745	49.95
6	2681	1581	300	4562	1052	4347	0	0	6463	6680	-844	15797	0	15797	1910	17707	49.96
7	2648	1647	282	4577	835	4299	0	33	7248	7033	-779	15998	0	15998	1843	17841	50.01
8	2663	1454	299	4416	639	4263	0	229	7199	7094	-909	15732	0	15732	1850	17582	50.02
9	2652	1214	275	4141	523	4275	0	520	6858	7079	-968	15570	0	15570	1912	17482	50.02
10	2641	1087	281	4009	511	4285	0	769	6862	6835	-947	15462	0	15462	1971	17433	50.01
11	2506	403	269	3178	371	4300	0	927	7464	7617	-1014	15379	0	15379	2020	17399	50.07
12	2476	780	276	3532	430	4298	0	1007	7978	8014	-1095	16186	0	16186	2039	18225	49.99
13	2404	1109	276	3789	615	4251	0	1018	7896	8037	-1104	16606	0	16606	2058	18664	49.93
14	2427	1121	275	3823	631	4207	0	968	7794	7749	-1143	16235	0	16235	2069	18304	49.95
15	2519	1044	266	3829	723	4402	0	864	7660	7689	-1160	16347	0	16347	2101	18448	49.95
16	2670	591	267	3528	921	4433	0	671	7496	7649	-987	16215	0	16215	2076	18291	50.06
17	2543	598	278	3419	1066	4415	0	444	7126	7349	-945	15748	0	15748	2013	17761	50.09
18	2401	749	270	3420	1305	4375	0	190	6309	6259	-1047	14502	0	14502	1932	16434	50.03
19	2396	394	281	3071	1479	4173	0	11	5488	5675	-1004	13405	0	13405	1889	15294	50.01
20	2648	607	274	3529	1536	4494	0	0	5113	5096	-1095	13560	0	13560	2028	15588	50.00
21	2695	721	283	3699	1391	4487	0	0	4911	5064	-1100	13541	0	13541	2134	15675	49.96
22	2722	1067	284	4073	1291	4484	0	0	4806	5053	-1066	13835	0	13835	2246	16081	50.01
23	2696	1449	286	4431	1277	4474	0	0	5461	5767	-1119	14830	0	14830	2348	17178	50.02
24	2669	1373	277	4319	1296	4350	0	0	6019	6014	-1207	14772	0	14772	2399	17171	50.03
MUs	62.46	26.35	6.73	95.54	23.00	104.21	0.00	7.65	155.67	157.42	-24.47	363.34	0.00	363.34	49.33	412.67	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Apr/2020

Position as on 6.30 Hrs of 25/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00		Continued.	Zero Schedule.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
IPP	JSW (J) U2	300	26/03/2020	00.13		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 7	500	28/03/2020	23.56		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Apr/2020

Position as on 6.30 Hrs of 25/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30		Continued.	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	22/04/2020	20.45		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Khaparkheda Unit 2	210	22/04/2020	21.06		Continued.	Zero Schedule By MSEDCL	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	Adani U-1	660	25/04/2020	01.12		Continued.	APH 1A Flue Gas Bellow Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 25/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	21/04/2020	17.20		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	23/03/2020	18.12		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	24/03/2020	20.20		Continued.	HT	Over Voltage
New Koyana - Dabhol-I	IntraState	25/03/2020	18.01		Continued.	T	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot
Chandrapur - Parli	IntraState	19/04/2020	02.20		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Babhaleshtar - Padghe-II	IntraState	20/04/2020	09.25		Continued.	PO	Quarterly Maintenance work & Relay Testing, for CVT replacement work (RFC at 21.22 Hrs).
Girwali- Lonikand 2	IntraState	20/04/2020	14.23		Continued.	HT	Controlling loading of Parli Parli (PG D/C line).
Taptitanda Waluj	IntraState	22/04/2020	17.18		Continued.	T	Distance Protection (RFC at 14.08Hrs DT.24-4-20)
karad -kolhapur-II	IntraState	24/04/2020	19.49		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	24/04/2020	21.25	25/04/2020	06.23	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	25/03/2020	13.59		Continued.	EO	CT Tan Delta High(Kept on Humming at 15.52Hrs DT. 24-4-20)
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	25/03/2020	16.32		Continued.	HT	Maintenance work and ICT out LV side(kept on Humming at 20.10Hrs DT.24-04-20)
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	25/03/2020	17.57		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	25/03/2020	22.01		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/03/2020	18.07		Continued.	HT	Over Voltage
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19		Continued.	PO	Attending Hot Spot
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	19/04/2020	11.55		Continued.	HT	Over Voltage
400/220/33 Kv 315 MVA ICT-3 @Padghe	IntraState	24/04/2020	18.10		Continued.	T	Y Phase Stub Bus Conductor suspension string broke at Padgha
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Borivali - Tarapur	InterState	24/04/2020	06.50	24/04/2020	18.00	T	B Phase Conductor Fall
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Lonand-Baramati	IntraState	16/02/2020	09.37		Continued.	PO	Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 25/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Badnera-Akola I	IntraState	24/04/2020	07.38	24/04/2020	19.13	PO	Erection of MD+9 Tower of 220KV Badnera-Ner Line phase
Badnera-Akola li	IntraState	24/04/2020	07.39	24/04/2020	19.13	PO	Erection of MD+9 Tower of 220KV Badnera-Ner Line phase
Deoli(Pgcil)-Badnera	IntraState	24/04/2020	09.15	24/04/2020	19.48	PO	Construction work
Kalwa1- Airoli Knowledge Park	IntraState	24/04/2020	10.55	24/04/2020	12.33	PO	To replace the meter of R Phase LA
Padghe - Nalasopara	IntraState	24/04/2020	18.10	24/04/2020	19.28	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
Padghe-Kamba II	IntraState	24/04/2020	18.10	24/04/2020	19.29	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
Padghe-Temghar-II	IntraState	24/04/2020	18.10	24/04/2020	19.22	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
Eklahare (Ocr)Nasik - Padghe 2	IntraState	24/04/2020	18.10	24/04/2020	19.27	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
220 KV ICT Outages/Trippings							
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS
220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-li (Mudshingi)	IntraState	21/04/2020	17.50		Continued.	HT	Over Voltage
220/100 Kv 200 MVA ICT IV @Padghe	IntraState	24/04/2020	18.10	24/04/2020	20.12	T	Y Phase Stub Bus Conductor suspension string broke at Padghe
220/100 KV 200 MVA ICT II @Padghe	IntraState	24/04/2020	18.10	24/04/2020	20.15	T	Y Phase Stub Bus Conductor suspension string broke at Padghe

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage