

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/May/2021 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	133.911	2973.864	1) Gujrat	-4.881	-42.524
2) Hydro	36.660	564.260	2) Madhya Pradesh	5.365	247.236
3) Gas	1.395	161.061	3) Chattisgarh	4.820	123.777
Total MSPGCL	171.966	3699.185	4) Maharashtra	154.920	3171.030
B) 1) APLM	30.427	1265.136	5) Goa (Amona)	-2.410	-36.934
2) JSWEL	17.337	449.145	Total	157.814	3462.585
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.304	608.431
4) RPL(AMT)	31.352	709.460	b) Mumbai Drawl	28.269	559.449
5) SWPGPL	9.129	162.078	c) MSEDCL Bilateral *	37.997	823.470
6) Other IPP	10.346	294.108	Include PX	1.498	82.337
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.304	608.431
C) 1) TPCL Thermal	15.829	360.401	Include PX	14.630	263.750
2) TPCL Hydro	6.170	100.066	Standby	0.000	0.000
3) TPCL Gas	0.000	70.751	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.011	232.290	1) MSEDCL	432.141	10172.627
D) STATE			2) Mumbai Discoms	56.279	1322.958
1) Thermal	254.342	6446.482	TOTAL STATE	488.420	11495.585
(A1+C1+C4+(B1-B6))					
2) Hydro	42.830	664.326			
(A2+C2)					
3) Gas	1.395	231.812			
(A3+B7+C3)					
4) Wind	25.018	518.682			
6) SOLAR	7.021	171.697			
TOTAL STATE	330.606	8032.999			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5593	5507	5480	5632
MSPGCL Hydro	1496	1984	1689	788
MSPGCL Gas	22	72	117	0
MSPGCL Total Generation	7111	7563	7286	6420
Central Sector Receipt	7077	7912	5902	5700
WIND	933	455	1439	1310
CPP / IPP Thermal	4107	4093	4099	4125
CPP / IPP Gas	0	0	0	0
SOLAR	874	758	0	0
Exchange with Mumbai	-1314	-1424	-1021	-1048
MSEDCL DEMAND MET	18788	19357	17705	16507
Load Shedding	0	0	0	0
MSEDCL DEMAND	18788	19357	17705	16507
TPCL GENERATION	1005	977	1049	688
AEML GENERATION	250	250	251	251
MUMBAI DEMAND	2569	2651	2321	1987
STATE DEMAND MET	21357	22008	20026	18494
STATE DEMAND	21357	22008	20026	18494
Frequency (Hz)	50.00	49.89	50.01	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.13 Hz at 16.03 Hrs	49.79 Hz at 14.44 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation, Maximum, Minimum for 24/May/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.17	268.07	546	446
Unit 9	10.88	190.56	560	321
Unit 10	10.17	241.57	500	360
Total	33.23	700.20		
Bhusawal				
Unit 3	0.00	13.68	0	0
Unit 4	12.02	235.30	505	500
Unit 5	11.85	260.55	500	480
Total	23.86	509.53		
Parli				
Unit 6	0.00	17.62	0	0
Unit 7	0.00	24.02	0	0
Unit 8	0.00	26.80	0	0
Total	0.00	68.44		
Chandrapur				
Unit 3	3.56	65.17	155	142
Unit 4	0.00	0.00	0	0
Unit 5	9.76	171.97	420	340
Unit 6	9.19	220.10	411	285
Unit 7	0.00	0.00	0	0
Unit 8	11.12	211.62	485	434
Unit 9	10.09	201.67	441	411
Total	43.73	870.52		
Paras				
Unit 3	5.03	112.11	225	188
Unit 4	0.02	98.01	18	0
Total	5.05	210.11		
Khaparkheda				
Unit 1	2.82	62.06	130	105
Unit 2	0.00	0.00	0	0
Unit 3	4.77	93.95	205	195
Unit 4	4.49	70.58	195	175
Unit 5	11.64	222.14	500	470
Total	23.73	448.73		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.31	97.12	199	132
Unit 5	0.00	69.21	0	0
Total	4.31	166.32		
Uran				
All Units	1.40	161.06	142	0
Total	1.40	161.06		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.42	5.75	25	0
Total	0.42	5.75		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	6.02	118.08	440	40
Stage 4	19.98	217.02	1016	438
Stage 3	5.19	73.90	240	160
Total	31.20	409.00		
Hydro				
KDPH	0.34	17.02	14	14
VTRNA	0.86	20.75	59	0
TILLARI	0.52	12.25	58	0
BHIRA T.R.	0.34	5.37	80	0
SMLHY_PTN	2.49	94.08	121	10
GHATGHAR	0.91	5.78	125	0
Total	5.46	155.26		
Wind				
Total	25.02	518.68	0	0
Total	25.02	518.68		
CPP				
APML(Mus)	30.43	1265.14	0	0
JSWEL(Mus)	17.34	449.14	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.35	709.46	0	0
SWPGPL-Mus	9.13	162.08	0	0
Other(Mus)	10.35	294.11	0	0
Total	98.59	2879.93		
SOLAR				
Total	7.02	171.70	0	0
Total	7.02	171.70		
Tata				
Trombay 5	10.47	239.70	480	382
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	44.76	0	0
Trombay 7B	0.00	25.99	0	0
Trombay 8	5.36	120.70	225	218
TATA Hydro	6.17	100.07	449	0
Total	22.00	531.22		
AEML				
DTPS U-1&2	6.01	232.29	251	250
Total	6.01	232.29		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	133.91	2973.86	MSPGCL Total	171.97	3699.18
			MSPGCL Thml+Gas	135.31	3134.92	Koyna 1,2 & 4 Total	26.01	335.10
			MSPGCL Hydro	36.66	564.26	State Total	330.61	8033.00

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/May/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5670	1678	0	7348	1289	4054	0	0	5952	5634	-1277	17048	0	17048	2411	19459	49.99
2	5684	1304	0	6988	1401	4084	0	0	5882	5570	-1116	16927	0	16927	2248	19175	50.00
3	5636	1093	0	6729	1488	4107	0	0	5794	5541	-1038	16827	0	16827	2092	18919	49.98
4	5632	788	0	6420	1310	4125	0	0	5796	5700	-1048	16507	0	16507	1987	18494	49.98
5	5622	1350	0	6972	1186	4132	0	0	5640	5755	-1016	17029	0	17029	1952	18981	50.03
6	5695	1491	0	7186	1210	4129	0	0	6360	6480	-1021	17984	0	17984	1954	19938	50.04
7	5658	1647	0	7305	1088	4094	0	49	6870	7166	-979	18723	0	18723	1904	20627	50.02
8	5624	1666	19	7309	1065	4119	0	199	6592	6599	-1006	18285	0	18285	1990	20275	49.98
9	5551	1734	20	7305	1015	4151	0	468	6342	6497	-1118	18318	0	18318	2206	20524	50.07
10	5586	1747	20	7353	900	4097	0	693	6839	6835	-1269	18609	0	18609	2430	21039	50.08
11	5593	1496	22	7111	933	4107	0	874	7269	7077	-1314	18788	0	18788	2569	21357	50.00
12	5565	1194	45	6804	663	4118	0	961	7603	7441	-1308	18679	0	18679	2626	21305	49.99
13	5429	1701	70	7200	453	4134	0	927	7358	7455	-1334	18835	0	18835	2631	21466	49.96
14	5458	2041	69	7568	385	4148	0	861	7465	7704	-1352	19314	0	19314	2601	21915	49.99
15	5507	1984	72	7563	455	4093	0	758	8015	7912	-1424	19357	0	19357	2651	22008	49.89
16	5522	1717	76	7315	605	4105	0	629	8230	7921	-1486	19089	0	19089	2678	21767	49.94
17	5508	1357	108	6973	674	4120	0	403	7790	7568	-1421	18317	0	18317	2605	20922	49.96
18	5490	1439	119	7048	981	4116	0	171	6743	6590	-1183	17723	0	17723	2438	20161	49.97
19	5493	899	116	6508	1047	4086	0	28	6164	6085	-987	16767	0	16767	2287	19054	49.97
20	5560	1561	127	7248	1248	4056	0	0	5813	5826	-995	17383	0	17383	2311	19694	50.00
21	5480	1689	117	7286	1439	4099	0	0	5595	5902	-1021	17705	0	17705	2321	20026	50.01
22	5583	1648	117	7348	1526	4100	0	0	5798	5744	-1067	17651	0	17651	2356	20007	49.94
23	5726	1695	136	7557	1353	4091	0	0	6182	6274	-1178	18097	0	18097	2466	20563	49.95
24	5639	1741	142	7522	1304	4126	0	0	6354	6538	-1311	18179	0	18179	2565	20744	50.02
MUs	133.91	36.66	1.40	171.97	25.02	98.59	0.00	7.02	158.45	157.81	-28.27	432.14	0.00	432.14	56.28	488.42	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/May/2021

Position as on 6.30 Hrs of 25/May/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 4	210	16/03/2021	08.08		Continued.	Boiler Tube Leakage(converted to Capital overhaul)	
MSPGCL	Koyna Unit 6	80	22/04/2021	12.00		Continued.	UGC Oil Cooler Leakage.(Converted to Capital Overhaul from 08.00Hrs DT.23-4-2021)	25/06/2021
AEML	AEML Unit 1	250	19/05/2021	09.52		Continued.	HP turbine replacement.	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).	
MSPGCL	Koyna Unit 11	80	19/01/2021	10.05		Continued.	Tripped on stator earth fault (will not be available till dt.24.05.21)	
MSPGCL	Chandrapur Unit 7	500	20/02/2021	23.43		Continued.	Generator Earth Fault.	
IPP	JSW (J) U4	300	11/04/2021	03.02	24/05/2021	06.17	NO SCHEDULE.	
MSPGCL	Khaparkheda Unit 2	210	15/04/2021	16.54		Continued.	Critical coal stock position	
MSPGCL	Koradi Unit 6	210	27/04/2021	19.59		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Bhusawal Unit 3	210	04/05/2021	20.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	04/05/2021	20.00		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	05/05/2021	19.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	06/05/2021	19.45		Continued.	Zero Schedule	
IPP	Adani U-4	660	16/05/2021	10.01		Continued.	Zero Schedule.	
IPP	Adani U-1	660	16/05/2021	17.57		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 5	108	17/05/2021	11.52		Continued.	Due to jerk	
IPP	Adani U-5	660	17/05/2021	12.05		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 5	210	17/05/2021	12.50		Continued.	Zero schedule.	
MSPGCL	Uran Unit B0	120	17/05/2021	20.15	24/05/2021	16.01	Gas shortage	
MSPGCL	Uran Unit 8	108	17/05/2021	20.15	24/05/2021	07.04	Gas shortage	
MSPGCL	Uran Unit 6	108	17/05/2021	22.59		Continued.	Gas shortage.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/May/2021

Position as on 6.30 Hrs of 25/May/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit A0	120	17/05/2021	22.59		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	17/05/2021	23.29		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	17/05/2021	23.50		Continued.	Gas shortage	
MSPGCL	Paras Unit 4	250	22/05/2021	23.49	24/05/2021	23.38	High Drum Level	
MSPGCL	Koyna Unit 1	70	24/05/2021	09.50	25/05/2021	11.45	Needle Problem	
MSPGCL	Koradi Unit-8	660	25/05/2021	03.52		Continued.	Boiler Tube Leakage	
IPP	JSW (J) U1	300	25/05/2021	09.41		Continued.	CW DUCT Water Leakage.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/May/2021

Statement-VII

Position as on 6.30 Hrs of 25/May/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi III - Akola II- ckt-II	IntraState	25/05/2021	10.19	25/05/2021	15.32	EO	Attending Hot Spot On Y-PH Neutral Bushing Of 712 Line Reactor Of 765KV, KORADI-3-AKOLA-2 LINE-2.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	24/05/2021	16.15	25/05/2021	17.30	T	Distance Protection
Babhleshwar - RIPL(Nashik)	IntraState	18/03/2021	15.48		Continued.	PO	Hot spot attending.
Khadka - Bableshtar	IntraState	24/05/2021	06.32	24/05/2021	18.10	PO	For Replacement Of Y-Phase Conductor Of 400KV Deep-Walunj CKT(LOC NO. 44-45)At The Crossing Point Of 400KV KDK-BBL R CKT.
Deepnagar - Aurangabad	IntraState	24/05/2021	06.41	24/05/2021	16.19	PO	Replacement Of Faulty Dead End & Mid Span Joint.
Padghe - Nagothane - I	IntraState	24/05/2021	08.54	24/05/2021	17.09	PO	String Replacement Work At Loc No.105.
Main Bus-I @ Koradi III	IntraState	24/05/2021	11.19	24/05/2021	17.54	PO	Annual Maintenance Work
Padghe - Nagothane - I	IntraState	25/05/2021	08.15	25/05/2021	16.48	PO	Insulator String Replacement Work.
Bableshtar- Aurangabad (Waluj)	IntraState	25/05/2021	18.43	25/05/2021	19.57	EO	Avalied For LA Work At WALUJ S/STN.
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.(FTC DT 16/08/2021 At 14.42)
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	23/05/2021	00.19	24/05/2021	18.51	EO	TO attend the red hot 29 A R PH Hanger.
400/220 kV 500MVA ICT-I @ Alkud	IntraState	24/05/2021	11.45	24/05/2021	16.00	T	R-Phase OSR Tripped.
400/220 KV 300 MVA ICT- I @Koradi	IntraState	24/05/2021	12.42	25/05/2021	01.32	PO	For Checking SF6 Gas Leakage From R-Phase CB Pole. ICT 1 CB Is To Be Shifted On TBC.
400/132 Kv 200 Mva Ict 1 @Khadka	IntraState	25/05/2021	08.31	25/05/2021	11.03	PO	For pre-monsoon maintenance work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Ghodbunder - Gorai	IntraState	24/05/2021	10.12	24/05/2021	14.42	PO	Replacement Of Defected Polymer Insulator At Tower No. LS 303 & LS 303A As Per Defect Report Submitted By Olectra.
Kandalgaon - Koyna (Pophali)	IntraState	24/05/2021	10.40	24/05/2021	18.22	PO	Jumper Nut Bolt Tightening & Insulator String Replacement.
Kamba - Kolshet	IntraState	24/05/2021	12.25	24/05/2021	14.05	PO	Online Stringing Of OPGW able On 220KV Kamba Kolshet Line.
Kharghar-Borivali ckt II	IntraState	24/05/2021	12.40	24/05/2021	21.14	PO	Retrofitting Work Of Earth Isolator And R&M Work.
Sadawaghapur Karad Ckt 2	IntraState	24/05/2021	12.58	24/05/2021	16.15	PO	Replacement Of Jumps At Loc No.03.
Ghodbunder - Versova	IntraState	24/05/2021	14.49	24/05/2021	17.08	PO	Replacement Of Defected Polymer Insulator At Tower No.LS 307 As Per Defect Report Submitted By Olectra.
Dondaicha- Shahada	IntraState	24/05/2021	16.12	25/05/2021	01.02	T	Distance Protection
Taloja II - OCIL-I	IntraState	25/05/2021	08.13	25/05/2021	20.03	PO	Cleaning of 220kV switchgear & checking of tightness of 220kV Bus bars.
Dasturi-Kandalgaon Line	IntraState	25/05/2021	09.34	25/05/2021	17.50	PO	Jumper nut bolt tightening &

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/May/2021

Statement-VII

Position as on 6.30 Hrs of 25/May/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Insulator string replacement.
Karad - Vita Ckt- I	IntraState	25/05/2021	10.20	25/05/2021	19.49	PO	Relay testing & allied bay equipment maintenance work.
Kharepatan -Pawas Line	IntraState	25/05/2021	11.31	25/05/2021	13.18	PO	For alignment of line isolator B phase blade.
Padghe - Kambha	IntraState	25/05/2021	12.15	25/05/2021	16.19	EO	Attending Red Hot spot at LILO loc no. 1
Satara (MIDC)-Ajinkyatara	IntraState	25/05/2021	12.18	25/05/2021	14.21	PO	Quarterly maintenance work, Relay Testing Work.
satara MIDC- Malharpeth	IntraState	25/05/2021	14.48	25/05/2021	16.43	PO	Quarterly maintenance work, Relay Testing Work.
Lonikand-II- Kathapur	IntraState	25/05/2021	16.15	25/05/2021	20.02	T	Distance Protection
Boisar Versova Line	IntraState	25/05/2021	18.58	25/05/2021	22.13	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132 KV 150MVA ICT I @ Boisar	IntraState	17/05/2021	11.19		Continued.	T	ICT Failed due to internal fault.
220/66 Kv 150 Mva Emco Ict 2 @Gadchander	IntraState	24/05/2021	08.09	24/05/2021	20.04	PO	Attending Oil Leakage
220/33kV 125 MVA T/F-I @ Goregaon	IntraState	24/05/2021	11.42	24/05/2021	13.22	PO	Pre-Monsoon Maintenance Of Transformer.
220/100 Kv 200MVA ICT-I @Padghe	IntraState	24/05/2021	13.06	24/05/2021	14.18	T	Differential protection
220/110 Kv 100 Mva Ptr 3 @Niwaliphata	IntraState	24/05/2021	14.49	24/05/2021	17.42	PO	Plastic Paper Wrapping To Auxiliaries & Protection.
220/33kV 100 MVA Transformer 1 @Ghodbunder R/S	IntraState	25/05/2021	09.13	25/05/2021	11.52	PO	Pre-monsoon Maintenance Work.
220/33kV 125 MVA Transformer 1 @Chembur R/S	IntraState	25/05/2021	09.31	25/05/2021	12.36	PO	Pre-monsoon Maintenance of Transformer.
220/33kV 125 MVA T/F-II @ Goregaon	IntraState	25/05/2021	10.25	25/05/2021	12.17	PO	Pre monsoon Maintenance of Transformer.
220/132-110/11kv 200MVA ICT 1 @Miraj	IntraState	25/05/2021	11.00	25/05/2021	13.35	PO	Pre monsoon Maintenance. Quarterly Maintenance Work & Attending Hot Spot Work.
220/66 Kv 150 Mva Emco Ict 2 @Gadchander	IntraState	25/05/2021	11.20	25/05/2021	17.15	PO	For Oil Leakage Attending Work.
220/100 KV 200MVA ICT II @ Pal	IntraState	25/05/2021	11.27	25/05/2021	14.32	PO	Pre-monsoon maintenance work.
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	25/05/2021	11.36	25/05/2021	12.30	PO	Plastic paper wrapping work.
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	25/05/2021	12.49	25/05/2021	13.53	PO	Plastic paper wrapping work.
220/33kV 125 MVA Transformer 2 @Chembur R/S	IntraState	25/05/2021	13.02	25/05/2021	14.44	PO	Pre monsoon Maintenance of Transformer.
220/33kV 100 MVA Transformer 2 @Ghodbunder R/S	IntraState	25/05/2021	14.12	25/05/2021	15.54	PO	Pre-monsoon Maintenance Work.
220/132 Kv 100 Mva Ict 2 @Paranda	IntraState	25/05/2021	14.30	25/05/2021	15.20	PO	Pre-monsoon Maintenance.
220/132 Kv 100 Mva Ict 1 @Tuljapur	IntraState	25/05/2021	16.20	25/05/2021	18.10	PO	Pre-monsoon Work.
220/132 Kv 100 Mva Ict 2 @Paranda	IntraState	25/05/2021	17.32	25/05/2021	18.00	PO	Pre-monsoon Maintenance.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage