

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/May/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	164.833	4003.723	1) Gujrat	-4.879	-137.542
2) Hydro	38.710	508.123	2) Madhya Pradesh	4.347	128.075
3) Gas	3.240	138.158	3) Chattisgarh	3.770	83.640
Total MSPGCL	206.783	4650.004	4) Maharashtra	153.306	4434.234
B) 1) APLM	76.089	1527.358	5) Goa (Amona)	-1.791	-32.035
2) JSWEL	16.151	437.532	Total	154.753	4476.372
3) VIPL	0.000	0.000	a) Mumbai Schedule	41.134	850.942
4) RPL(AMT)	15.916	592.651	b) Mumbai Drawl	44.750	912.490
5) SWPGPL	9.425	200.337	c) MSEDCL Bilateral *	84.211	1820.746
6) Other IPP	16.759	482.992	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	41.134	850.821
C) 1) TPCL Thermal	13.494	345.413	Include PX	0.000	0.000
2) TPCL Hydro	4.430	98.277	Standby	0.000	0.121
3) TPCL Gas	0.000	55.388	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.671	267.501	1) MSEDCL	496.847	12207.547
D) STATE			2) Mumbai Discoms	73.345	1679.053
1) Thermal	323.338	7857.507	3) Other Discoms	6.954	223.655
(A1+C1+C4+(B1-B6))			TOTAL STATE	577.146	14110.255
2) Hydro	43.140	606.400			
(A2+C2)					
3) Gas	3.240	193.546			
(A3+B7+C3)					
4) Wind	42.895	759.441			
6) SOLAR	9.780	217.005			
TOTAL STATE	422.393	9633.899			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6920	6857	6729	6933
MSPGCL Hydro	1184	1991	2183	1547
MSPGCL Gas	130	130	130	140
MSPGCL Total Generation	8234	8978	9042	8620
Central Sector Receipt	7849	7782	5654	5781
WIND	947	1549	2037	2218
CPP / IPP Thermal	5405	5593	5918	5386
CPP / IPP Gas	0	0	0	0
SOLAR	1212	805	0	0
Exchange with Mumbai	-2298	-2205	-1675	-1629
MSEDCL DEMAND MET	21020	22165	20661	20137
Load Shedding	0	0	0	0
MSEDCL DEMAND	21020	22165	20661	20137
TPCL GENERATION	734	892	966	561
AEML GENERATION	468	488	497	329
MUMBAI DEMAND	3500	3585	3138	2519
OTHER DISCOM DEMAND	329	337	315	239
STATE DEMAND MET	24849	26087	24114	22895
STATE DEMAND	24849	26087	24114	22895
Frequency (Hz)	49.92	49.93	49.94	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 13.02 Hrs	49.69 Hz at 05.28 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.70	93.76	160	145
Unit 7	0.00	0.00	0	0
Unit 8	14.35	319.93	606	582
Unit 9	13.52	295.50	582	505
Unit 10	13.14	305.82	570	520
Total	44.72	1015.01		
Bhusawal				
Unit 3	2.32	74.35	140	0
Unit 4	10.40	189.38	450	405
Unit 5	10.01	212.95	450	360
Total	22.74	476.67		
Parli				
Unit 6	0.00	68.21	0	0
Unit 7	5.26	96.73	241	205
Unit 8	3.10	64.13	135	128
Total	8.36	229.06		
Chandrapur				
Unit 3	4.22	90.07	180	161
Unit 4	3.47	83.32	148	143
Unit 5	0.00	189.08	0	0
Unit 6	9.11	193.23	390	347
Unit 7	9.10	215.64	411	336
Unit 8	10.80	239.14	456	438
Unit 9	10.47	241.04	445	429
Total	47.17	1251.52		
Paras				
Unit 3	5.24	100.63	243	198
Unit 4	4.35	105.34	201	135
Total	9.58	205.97		
Khaparkheda				
Unit 1	2.99	70.89	140	115
Unit 2	3.32	84.36	155	120
Unit 3	3.83	85.05	183	135
Unit 4	3.22	76.19	140	127
Unit 5	11.36	263.59	475	470
Total	24.72	580.08		
Nasik				
Unit 3	0.00	79.46	0	0
Unit 4	3.66	82.28	161	143
Unit 5	3.88	83.68	174	141
Total	7.54	245.41		
Uran				
All Units	3.24	138.16	150	130
Total	3.24	138.16		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	2.73	24	0
Total	0.12	2.73		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	8.23	106.82	515	40
Stage 4	18.08	161.48	1017	0
Stage 3	6.25	59.63	320	80
Total	32.56	327.94		
Hydro				
KDPH	0.62	12.76	26	26
VTRNA	0.00	17.34	0	0
TILLARI	0.00	8.24	0	0
BHIRA T.R.	0.18	4.58	70	0
SMLHY_PTN	4.65	125.26	207	172
GHATGHAR	0.57	9.26	125	0
Total	6.03	177.45		
Wind				
Total	42.90	759.44	0	0
Total	42.90	759.44		
CPP				
APML(Mus)	76.09	1527.36	0	0
JSWEL(Mus)	16.15	437.53	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	15.92	592.65	0	0
SWPGPL-Mus	9.42	200.34	0	0
Other(Mus)	16.76	482.99	0	0
Total	134.34	3240.87		
SOLAR				
Total	9.78	217.00	0	0
Total	9.78	217.00		
Tata				
Trombay 5	8.86	225.23	447	270
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	34.32	0	0
Trombay 7B	0.00	21.07	0	0
TATA Hydro	4.43	98.28	331	69
Trombay 8	4.63	120.19	229	133
Total	17.92	499.08		
AEML				
DTPS U-1&2	10.67	267.50	500	329
Total	10.67	267.50		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	164.83	4003.72	MSPGCL Total	206.78	4650.00
			MSPGCL Thml+Gas	168.07	4141.88	Koyna 1,2 & 4 Total	26.31	268.31
			MSPGCL Hydro	38.71	508.12	State Total	422.39	9633.90

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/May/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6866	1400	140	8406	2701	5639	0	0	6435	6128	-1929	20692	0	20692	3027	253	23972	50.01
2	6901	1284	140	8325	2495	5656	0	0	6154	6148	-1867	20540	0	20540	2820	217	23577	49.92
3	6927	1497	130	8554	2343	5532	0	0	5796	5896	-1727	20373	0	20373	2640	225	23238	49.89
4	6933	1547	140	8620	2218	5386	0	0	5671	5781	-1629	20137	0	20137	2519	239	22895	50.00
5	6931	1812	150	8893	2026	5401	0	0	5666	5789	-1570	20278	0	20278	2460	261	22999	49.96
6	6922	2077	130	9129	1884	5405	0	0	5907	6074	-1526	20712	0	20712	2416	254	23382	49.82
7	6949	2057	140	9146	1505	5415	0	83	5949	6137	-1545	20473	0	20473	2414	268	23155	49.95
8	6932	1978	140	9050	1238	5384	0	346	6102	6453	-1638	20560	0	20560	2532	273	23365	50.05
9	6938	1153	140	8231	1377	5404	0	670	6573	6614	-1772	20236	0	20236	2834	288	23358	50.02
10	7002	609	130	7741	1502	5451	0	961	6983	6978	-1851	20497	0	20497	3158	285	23940	49.98
11	7004	490	140	7634	1126	5423	0	1220	7566	7743	-2192	20663	0	20663	3409	291	24363	49.99
12	6920	1184	130	8234	947	5405	0	1212	7786	7849	-2298	21020	0	21020	3500	329	24849	49.92
13	6884	1532	130	8546	1016	5501	0	1285	7767	7551	-2244	21325	0	21325	3508	330	25163	49.99
14	6842	1298	130	8270	1085	5533	0	1291	7730	7766	-2212	21418	0	21418	3447	315	25180	50.02
15	6885	1474	130	8489	1247	5575	0	1070	8031	8032	-2248	21830	0	21830	3531	335	25696	49.91
16	6857	1991	130	8978	1549	5593	0	805	7661	7782	-2205	22165	0	22165	3585	337	26087	49.93
17	6895	1516	130	8541	1730	5569	0	542	7064	6777	-2126	20706	0	20706	3527	327	24560	50.00
18	6768	1525	130	8423	2136	5612	0	252	6685	6688	-1965	20816	0	20816	3385	330	24531	50.03
19	6722	1691	130	8543	2056	5790	0	43	5319	5335	-1690	19755	0	19755	3182	322	23259	50.01
20	6729	2183	130	9042	2037	5918	0	0	5222	5654	-1675	20661	0	20661	3138	315	24114	49.94
21	6734	2194	130	9058	2271	5902	0	0	4978	5061	-1660	20325	0	20325	3095	307	23727	50.00
22	6765	2031	130	8926	2343	5934	0	0	4996	5147	-1663	20390	0	20390	3027	297	23714	49.88
23	6795	2030	150	8975	2132	5948	0	0	5164	5694	-1734	20725	0	20725	3066	290	24081	49.94
24	6732	2157	140	9029	1931	5964	0	0	5190	5676	-1784	20549	0	20549	3125	267	23941	49.82
MUs	164.83	38.71	3.24	206.78	42.89	134.34	0.00	9.78	152.40	154.75	-44.75	496.85	0.00	496.85	73.35	6.95	577.15	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/May/2022

Position as on 6.30 Hrs of 25/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 5	108	16/05/2022	12:59		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	16/05/2022	23:53	24/05/2022	12:26	Coal Shortage	
TPC-G	Trombay 7B	60	16/05/2022	23:59		Continued.	Non availability of APM gas.	
MSPGCL	Parli Unit 6	250	19/05/2022	20:00		Continued.	Boiler Tube Leakage	23/05/2022
TPC-G	Trombay 7A	120	21/05/2022	01:26		Continued.	Gas shortage	
MSPGCL	Nasik Unit 3	210	21/05/2022	17:14		Continued.	Boiler Tube Leakage	24/05/2022
MSPGCL	Chandrapur Unit 5	500	23/05/2022	07:45		Continued.	Boiler Tube Leakage	26/05/2022
IPP	RPL(AMT) U-3	270	24/05/2022	02:23		Continued.	Flame Failure	
MSPGCL	Bhusawal Unit 3	210	24/05/2022	17:31		Continued.	Withdrawn	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/May/2022

Statement-VII

Position as on 6.30 Hrs of 25/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (403) OF ICT - 1 & AURANGABAD CKT - 1 @ AKOLA	IntraState	24/05/2022	09:43	24/05/2022	15:29	PO	Routine maintenance & testing work
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 1	InterState	23/05/2022	09:06			PO	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM
400KV NANDED(KUMBHARGAON)-PARLY CKT 2	InterState	25/05/2022	06:22			PO	To attend broken conductor strands bet loc no 86 87,116 117
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	23/05/2022	21:23	24/05/2022	00:58	EO	Attending Red Hot Spot on 29 D, Centre break isolator B phase
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/05/2022	08:05	24/05/2022	17:35	PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	25/05/2022	06:20			PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
400 KV ICT Outages/Trippings							
400220kV 167MVA SPARE ICT @ DEEPNAGAR	IntraState	24/05/2022	08:28	24/05/2022	17:44	PO	FOR PRE MONSOON MAINTENANCE WORK ALONG WITH DIAGNOSTIC TESTING WORK CARRIED OUT.
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	24/05/2022	11:12	24/05/2022	14:41	PO	Pre Mansoon Maintanance of ICT.
400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	IntraState	24/05/2022	11:14	24/05/2022	14:44	PO	Pre mansoon Maintance work
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	25/05/2022	02:33			T	TRIPPED ON NDR
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	25/05/2022	02:33			T	Tripped on NDR Stage-1. Heavy Rain with High Speed Winds reported.
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	25/05/2022	08:19			PO	For RTV coating to Tertiary 33 kv connection & Pre-Monsoon maintenance
400 KV BR Outages/Trippings							
125MVar BUS REACTOR @ WARORA	IntraState	25/05/2022	08:21			PO	Premonsoon Maintenance work. Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	25/05/2022	07:55			PO	For safety purpose while doing maintenance of 100MVA TR-3
TBC @ AAREY	IntraState	25/05/2022	09:10			PO	For safety purpose while working on 100MVA TR-1
220 KV MAINBAY Outages/Trippings							
METERING BAY (CONSUMER) - 2 @ SERUM	IntraState	23/05/2022	16:05	24/05/2022	21:41	EO	Replacement of 06 Nos. of 75/1 A CT to New 100/1 A CT
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
BORIVALI - TARAPUR	IntraState	18/05/2022	14:36			PO	Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth wire and all insulator strings of the line.
PADGHE - TEMGHAR - 2	IntraState	20/05/2022	00:02			PO	Bunching at Loc no.82 and jumper opening at Loc.no. 80.
BUS SECTION-4 @ TEMGHAR	IntraState	20/05/2022	07:23			EO	For closing 220kv Bus section 3 isolator

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/May/2022

Statement-VII

Position as on 6.30 Hrs of 25/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
POPHLI PEDHMBE LINE- 1	IntraState	24/05/2022	08:40	24/05/2022	17:25	PO	For Bay R/M work.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2022	10:09	24/05/2022	16:41	PO	FOR SRI REPLACEMENT WORK AT LOC 20 S
JEJURI - KONDHWA	IntraState	24/05/2022	10:41			PO	220 kV Jejuri-Kondhwa bay CB mechanism overhauling work and attend of SF6 gas leakage of Y phase pole of CB.
VSNL - STT GIS CKT - 2	IntraState	24/05/2022	10:43			PO	Addition of New 02 Nos of GIS T/F Bay to existing 220kv Bus 2 at 220 KV STT GIS Substation end.
ALKUD - VITA	IntraState	24/05/2022	10:45	24/05/2022	18:22	PO	Replacement of distance protection relay of line bay at 220kV Vita S/s
ALEPHATA-PARGAON(KATHAPUR)	IntraState	24/05/2022	12:18	24/05/2022	18:59	PO	replacement of R Y B Ph CT of 220kV Alephata-Kathapur line due to high tan delta
AEML BORIVALI - TPC BORIVALI LINE	IntraState	24/05/2022	16:43	24/05/2022	20:48	PO	Outage required as safety precaution for work of Modular Cut out Sealing System.
EKLAHARE (OCR) - PADGHE	IntraState	24/05/2022	17:02			HT	To control line loading
NAGOTHANE - IPCL	IntraState	25/05/2022	02:34			T	Tripped HeavyRains with speedy Winds reported.
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	25/05/2022	08:43			PO	Hardware Tightening & Fitting work
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 2 @ KALWA	IntraState	24/05/2022	09:40	24/05/2022	18:13	PO	Fixing of aircell in the conservator tank.
220/33KV 50MVA BBL T/F @ OGLEWADI	IntraState	24/05/2022	10:35	24/05/2022	15:07	PO	Premonsoon maintenance work
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	24/05/2022	10:35	24/05/2022	12:22	PO	Premansoon & Bay maintenance work
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	24/05/2022	11:28	24/05/2022	16:59	PO	for quartly maintenance
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	24/05/2022	12:10	24/05/2022	19:20	PO	Diagnostic Testing
220/22 KV 50 MVA PTR 1 @ TALOJA	IntraState	24/05/2022	15:45	24/05/2022	20:16	PO	50MVA CGL make TF-1 LV side shifting in GIS
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	25/05/2022	07:48			PO	1)Routine Maintenance works Measurement of Neutral Earth Pit Resistance. 3) Premonsoon Maintenance Work
220/33kv 100 MVA TF 3 @ GHODBUNDER	IntraState	25/05/2022	07:54			PO	Annual & premonsoon maintenance
220/33kv 100 MVA TF 1 @ AAREY	IntraState	25/05/2022	09:09			PO	Annual and Premonsoon maintenance of Transformer, NGT and Bay Equipments
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/May/2022

Statement-VII

Position as on 6.30 Hrs of 25/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage