

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Jun/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	155.613	3852.610	1) Gujrat	-3.096	-44.240
2) Hydro	7.299	294.185	2) Madhya Pradesh	5.784	147.367
3) Gas	2.626	114.922	3) Chattisgarh	2.920	73.020
Total MSPGCL	165.538	4261.717	4) Maharashtra	203.859	5049.274
B) 1) APLM	57.586	1626.863	5) Goa (Amona)	-1.185	-32.735
2) JSWEL	22.074	570.291	Total	208.282	5192.686
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.506	1041.266
4) RPL(AMT)	25.548	640.690	b) Mumbai Drawl	43.928	1140.479
5) SWPGPL	10.682	253.121	c) MSEDCL Bilateral *	122.412	2945.000
6) Other IPP	6.635	137.064	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.506	1040.767
C) 1) TPCL Thermal	10.956	295.445	Include PX	0.000	0.000
2) TPCL Hydro	3.499	127.413	Standby	0.000	0.499
3) TPCL Gas	2.006	43.830	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.051	225.157	1) MSEDCL	484.824	12549.877
D) STATE			2) Mumbai Discoms	69.440	1832.324
1) Thermal	298.145	7601.241	3) Other Discoms	9.908	255.022
(A1+C1+C4+(B1-B6))			TOTAL STATE	564.172	14637.223
2) Hydro	10.798	421.598			
(A2+C2)					
3) Gas	4.632	158.752			
(A3+B7+C3)					
4) Wind	31.474	886.760			
6) SOLAR	10.841	376.186			
TOTAL STATE	355.890	9444.537			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6693	6444	6453	6332
MSPGCL Hydro	177	116	517	503
MSPGCL Gas	0	0	2	0
MSPGCL Total Generation	6870	6560	6972	6835
Central Sector Receipt	10046	10097	6907	6918
WIND	591	999	2379	1103
CPP / IPP Thermal	5361	4993	5057	4989
CPP / IPP Gas	0	0	0	0
SOLAR	1498	1497	0	0
Exchange with Mumbai	-2090	-2143	-1676	-1410
MSEDCL DEMAND MET	21847	21580	19184	18003
Load Shedding	0	0	0	0
MSEDCL DEMAND	21847	21580	19184	18003
TPCL GENERATION	659	636	828	947
AEML GENERATION	453	433	366	339
MUMBAI DEMAND	3202	3212	2870	2696
OTHER DISCOM DEMAND	430	423	455	431
STATE DEMAND MET	25478	25215	22509	21131
STATE DEMAND	25478	25215	22509	21131
Frequency (Hz)	50.01	50.01	50.01	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 13:03 Hrs	49.81 Hz at 14:11 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 24/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.77	110.10	180	140
Unit 8	13.12	256.41	583	461
Unit 9	12.65	237.00	558	501
Unit 10	12.59	307.42	534	510
Total	42.12	910.92		
Bhusawal				
Unit 3	3.19	59.85	150	115
Unit 4	10.73	245.64	465	390
Unit 5	11.05	262.08	485	360
Total	24.97	567.56		
Parli				
Unit 6	4.52	108.14	238	143
Unit 7	4.47	112.10	248	140
Unit 8	0.00	71.84	0	0
Total	8.99	292.08		
Chandrapur				
Unit 3	3.55	74.39	162	125
Unit 4	3.39	75.02	153	126
Unit 5	0.00	0.00	0	0
Unit 6	8.50	195.58	400	290
Unit 7	8.52	219.16	400	272
Unit 8	10.91	264.71	478	359
Unit 9	9.46	267.11	475	233
Total	44.35	1095.96		
Paras				
Unit 3	4.32	115.60	202	154
Unit 4	4.64	102.21	219	162
Total	8.97	217.81		
Khaparkheda				
Unit 1	2.06	66.14	110	0
Unit 2	2.59	68.42	122	96
Unit 3	0.59	77.70	160	0
Unit 4	3.48	93.87	178	125
Unit 5	10.38	262.11	460	380
Total	19.09	568.24		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	3.67	96.37	176	120
Unit 5	3.46	93.57	163	113
Total	7.13	200.03		
Uran				
All Units	2.63	114.92	222	0
Total	2.63	114.92		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	2.03	0	0
Total	0.00	2.03		
Koyna				
Stage 1-2	1.53	73.58	300	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	1.00	36.62	240	0
Total	2.53	191.42		
Hydro				
KDPH	0.00	6.01	0	0
VTRNA	1.18	27.28	60	0
TILLARI	0.45	4.02	58	0
BHIRA T.R.	0.26	7.43	77	0
SMLHY_PTN	2.86	53.24	125	116
GHATGHAR	0.02	2.76	15	0
Total	4.76	100.73		
Wind				
Total	31.47	886.76	0	0
Total	31.47	886.76		
CPP				
APML(Mus)	57.59	1626.86	0	0
JSWEL(Mus)	22.07	570.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.55	640.69	0	0
SWPGPL-Mus	10.68	253.12	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.97	86.89	269	154
Other(Mus)	1.66	50.18	0	0
Total	122.52	3228.03		
SOLAR				
Total	10.84	376.19	0	0
Total	10.84	376.19		
Tata				
Trombay 5	7.15	198.26	361	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.09	24.19	61	36
Trombay 7B	0.91	19.64	48	32
TATA Hydro	3.50	127.41	355	20
Trombay 8	3.81	97.19	216	129
Total	16.46	466.69		
AEML				
DTPS U-1&2	9.05	225.16	456	300
Total	9.05	225.16		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	155.61	3852.61	MSPGCL Total	165.54	4261.72
			MSPGCL Thml+Gas	158.24	3967.53	Koyna 1,2 & 4 Total	1.53	154.80
			MSPGCL Hydro	7.30	294.18	State Total	355.89	9444.54

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6700	437	216	7353	1549	5831	0	0	8274	8368	-1874	20862	0	0	20862	3224	365	24451	49.99
2	6609	288	216	7113	1274	5719	0	0	8715	8685	-1832	20620	0	0	20620	2970	339	23929	49.97
3	6657	542	217	7416	1043	5467	0	0	8744	8674	-1776	20489	0	0	20489	2790	335	23614	49.95
4	6637	303	217	7157	824	5399	0	0	8883	8799	-1675	20158	0	0	20158	2654	345	23158	50.03
5	6623	278	219	7120	657	5404	0	0	9554	9242	-1620	20455	0	7	20455	2581	349	23384	50.01
6	6694	278	222	7194	641	5511	0	0	9495	9644	-1570	21045	0	21	21045	2582	375	24002	50.02
7	6836	285	222	7343	572	5337	0	110	9720	9555	-1688	20826	0	0	20826	2534	403	23763	50.01
8	6862	351	218	7431	512	5330	0	389	9013	9079	-1712	20603	0	0	20603	2551	427	23580	49.98
9	6809	244	217	7270	581	5296	0	793	9167	8932	-1791	20640	0	0	20640	2681	441	23762	50.01
10	6648	224	217	7089	557	4930	0	1110	9506	9629	-1795	21071	0	0	21071	2891	449	24411	49.99
11	6622	191	97	6910	596	5119	0	1258	9804	9937	-2018	21369	0	0	21369	3102	433	24904	50.02
12	6693	177	0	6870	591	5361	0	1498	10272	10046	-2090	21847	0	0	21847	3202	430	25478	50.01
13	6444	116	0	6560	999	4993	0	1497	10516	10097	-2143	21580	0	0	21580	3212	423	25215	50.01
14	6249	123	14	6386	1558	4678	0	1349	9961	9709	-2091	21167	0	0	21167	3178	422	24767	50.03
15	6227	122	19	6368	1977	4705	0	1171	9687	9556	-2245	21116	0	0	21116	3245	416	24777	49.95
16	6073	117	58	6248	2240	4515	0	825	9443	9713	-2208	20891	0	0	20891	3275	442	24608	49.98
17	6329	211	82	6622	2297	4413	0	478	8518	8873	-2077	20152	0	0	20152	3134	454	23740	50.03
18	6206	267	73	6546	2459	4325	0	297	8073	7999	-2094	19080	0	0	19080	2968	452	22500	49.93
19	6188	367	100	6655	2402	4451	0	66	7499	7327	-1932	18520	0	0	18520	2904	449	21873	49.96
20	6453	517	2	6972	2379	5057	0	0	7375	6907	-1676	19184	0	0	19184	2870	455	22509	50.01
21	6195	459	0	6654	2123	5161	0	0	7158	6843	-1675	18670	0	0	18670	2795	436	21901	49.98
22	5887	402	0	6289	1679	4957	0	0	6972	7017	-1523	17981	0	0	17981	2717	437	21136	50.00
23	6332	503	0	6835	1103	4989	0	0	6936	6918	-1410	18003	0	0	18003	2696	431	21131	50.00
24	6640	497	0	7137	861	5577	0	0	7029	6733	-1413	18495	0	0	18495	2684	400	21579	50.04
MUs	155.61	7.30	2.63	165.54	31.47	122.53	0.00	10.84	210.31	208.28	-43.93	484.82	0.00	0.03	484.82	69.44	9.91	564.17	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

LTS stage 1 operated due to 220kv Lonand-Jejuri line overloading.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Jun/2023

Position as on 6.30 Hrs of 25/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	15/07/2023
MSPGCL	Koyna Unit 1	70	24/06/2023	07:40	24/06/2023	16:45	Maintenance work	24/06/2023
MSPGCL	Koyna Unit 3	70	24/06/2023	07:42	24/06/2023	16:57	Maintenance work	24/06/2023
MSPGCL	Koyna Unit 4	70	24/06/2023	07:43	24/06/2023	16:10	Maintenance work	
MSPGCL	Koyna Unit 5	80	24/06/2023	07:46	24/06/2023	17:22	Maintenance work	
MSPGCL	Koyna Unit 6	80	24/06/2023	07:53	24/06/2023	16:25	Maintenance work	
MSPGCL	Koyna Unit 7	80	24/06/2023	07:55	24/06/2023	17:45	Maintenance work	
MSPGCL	Koyna Unit 8	80	24/06/2023	07:57	24/06/2023	16:55	Maintenance work	
MSPGCL	Koyna Unit 8	80	25/06/2023	07:30	25/06/2023	15:45	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 7	80	25/06/2023	07:34	25/06/2023	15:20	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 6	80	25/06/2023	07:39	25/06/2023	15:20	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 5	80	25/06/2023	07:39	25/06/2023	16:05	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 4	70	25/06/2023	07:42	25/06/2023	19:25	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 3	70	25/06/2023	07:44	25/06/2023	15:40	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 2	70	25/06/2023	07:46	25/06/2023	19:05	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 11	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 12	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 10	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 9	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 1	70	25/06/2023	13:55	25/06/2023	14:45	220KV Bus section 1 tripped.	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Jun/2023

Position as on 6.30 Hrs of 25/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Khaparkheda Unit 3	210	22/06/2023	22:48	24/06/2023	19:01	Suspected BTL	25/06/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	
MSPGCL	Uran Unit B0	120	24/06/2023	10:45	24/06/2023	17:56	Turbine Vibration	
MSPGCL	Uran Unit 7	108	24/06/2023	10:46	24/06/2023	13:17	Due to Boiler Protection.	
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	On boiler protection	
MSPGCL	Khaparkheda Unit 1	210	24/06/2023	22:47		Continued.	Boiler Tube Leakage	27/06/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 25/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT @ AKOLA 2	IntraState	25/06/2023	10:47	25/06/2023	18:56	HT	Planned outage 567 OCC meeting
765/400kV 1500MVA ICT @ AKOLA 2	IntraState	25/06/2023	10:47	25/06/2023	18:56	PO	TAKING B-PH ICT IN SERVICE IN PLACE OF SPARE PHASE ICT AS PER CEA GUIDELINE.
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	24/06/2023	00:46	24/06/2023	02:42	HT	Emergency Outage for attending hot spot at Padghe end.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	24/06/2023	15:12	24/06/2023	20:25	T	Pole-2 tripped on Line fault at location 1533 to 1534.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	24/06/2023	23:52	25/06/2023	19:43	T	Tripped on differential protection.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 1	InterState	24/06/2023	04:41	24/06/2023	15:20	T	Tripped on Distance Protection.
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	24/06/2023	14:42	25/06/2023	01:17	T	Line tripped on distance protection
PUNE(GIS) - TALEGAON(PG) CKT - 3	InterState	25/06/2023	13:43		Continued.	T	Tripped on distance protection
PUNE(GIS) - TALEGAON(PG) CKT - 4	InterState	25/06/2023	21:32		Continued.	HT	Outage availed for safety purpose and to attend broken insulator of 400 kV Pune & Pune Ckt-3
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	14/06/2023	12:55	24/06/2023	18:00	HT	TO CONTROL LINE LOADING
NAGOTHANE - DABHOL CKT - 1	IntraState	24/06/2023	06:09	24/06/2023	07:22	T	Distance Protection
BUS COUPLER @ LONIKAND-1	IntraState	24/06/2023	12:05	24/06/2023	15:37	PO	400kV Bus Coupler 29-A & 29-B PG Isolator mechanicm box replacement and trials. Also, DT Work & Bay Maintenance
JEJURI - KARAD	IntraState	24/06/2023	18:46	25/06/2023	07:55	T	Tripped on distance protection
DABHOL - NAGOTHANE CKT - 1	IntraState	25/06/2023	06:24	25/06/2023	10:58	EO	Removing of cutted Earthwire between loc no. 68-69
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	25/06/2023	10:40		Continued.	HT	H/T for load management
LONIKAND - JEJURI CKT - 2	IntraState	25/06/2023	16:44	25/06/2023	20:34	HT	HT for Load Management
JEJURI - KARAD	IntraState	25/06/2023	20:28		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
220 KV TBC Outages/Trippings							
BUS COUPLER @ SAHAR	IntraState	24/06/2023	10:31	24/06/2023	20:05	PO	PROTECTION TESTING
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 25/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
GOREGAON - AAREY CKT - 2	IntraState	17/06/2023	18:14			PO	Shifting of existing 220kV AIS Bay no. 2 to New GIS Bay no. 19 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
URAN - KHARGHAR 1	IntraState	23/06/2023	17:36			PO	LILO and commissioning of 220kV Ulwe GIS
MUMEWADI -HALKARNI 1 LINE	IntraState	24/06/2023	09:30	24/06/2023	13:28	PO	For Diagnostic Testing of CT,CB & Premonsoon Maintenance work of bay equipments
BOISAR II - BOISAR (PG) CKT - 1	IntraState	24/06/2023	10:21	24/06/2023	15:38	PO	Annual bay maintenance. Diag. testing for CT, LA & Isolator work.
KADEGAON-MIRAJ	IntraState	24/06/2023	10:24	24/06/2023	13:32	PO	Pilot string replacement work at Loc No.127 Y Ph
RAYMOND - TKEC	IntraState	24/06/2023	10:30	24/06/2023	14:32	PO	1.Providing support to bus jump of bus isolator 2.Maintenance work at consumer end
RANJANGAON - U TECH SUGAR CKT	IntraState	24/06/2023	10:42	24/06/2023	11:35	T	Distance Protection
HAMIDWADA - MUMEWADI	IntraState	24/06/2023	15:17	24/06/2023	17:25	PO	For Diagnostic Testing of CT,CB & Premonsoon Maintenance work of bay equipments
URSE - TALEGAON (AMBI) CKT 1	IntraState	24/06/2023	20:33	25/06/2023	03:57	T	Tripped on distance protection
SAHARA-URSE	IntraState	24/06/2023	20:39	25/06/2023	04:02	HT	H/T for load management.
SONKHAR - TROMBAY	IntraState	25/06/2023	06:05	25/06/2023	06:44	T	AR successful at Trombay end only.
KHARGHAR - SONKHAR	IntraState	25/06/2023	06:05	25/06/2023	11:53	T	Tripped on Distance Protection.
KALMESHWAR-PANDHURNA	IntraState	25/06/2023	12:26	25/06/2023	17:39	T	Distance Protection
KALMESHWAR-PANDHURNA	IntraState	25/06/2023	12:26	25/06/2023	17:39	T	D/P OPTED:Y-B,19.99KM,7KA,6.94KA
POPHALI - KDPH	IntraState	25/06/2023	13:55	25/06/2023	14:50	T	220KV bus section 1 tripped at pophali.
KANDALGAON - KOYNA (POPHALI)	IntraState	25/06/2023	13:55	25/06/2023	14:40	T	220KV bus section 1 tripped at pophali.
POPHLI PEDHMBE LINE- 1	IntraState	25/06/2023	13:55	25/06/2023	14:35	T	220KV bus section 1 tripped at pophali.
HINJAWADI I- CHINCHWAD	IntraState	25/06/2023	16:44		Continued.	T	HT for Load Management
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132-110 KV 100 MVA ICT 2	IntraState	21/06/2023	11:00			EO	Replacement of HV CB
220/132 KV 150 MVA ICT @ BOISAR-II	IntraState	21/06/2023	12:04	24/06/2023	20:03	PO	Transformer oil filtration due to poor DGA result & Diagnostic testing.
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	22/06/2023	10:03	24/06/2023	15:38	PO	For Internal Inspection of ICT
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	24/06/2023	10:12	24/06/2023	11:40	PO	Bay Maintenance & Pre-Monsoon activity
PT-2 @ KHADKI	IntraState	24/06/2023	10:30	24/06/2023	12:23	PO	Half yearly Maint. work
220/132 KV 200 MVA ICT 2	IntraState	24/06/2023	11:00	24/06/2023	12:38	PO	Premonsoon maintenance work
100 MVA 220/132 KV ICT	IntraState	24/06/2023	11:31	24/06/2023	17:33	PO	Diagnostic testing work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 25/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	24/06/2023	12:00	24/06/2023	12:44	PO	Bay maintenance & Pre-Monsoon activity
100 MVA 220/132 KV ICT - I @ JALKOT	IntraState	24/06/2023	12:05	24/06/2023	15:39	EO	Testing/Maintenance of OSR Relay
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	24/06/2023	12:31	24/06/2023	13:28	PO	Outage is required for Oil leakage attending work
220/132 KV 200 MVA ICT 1 @ KALMESHWAR	IntraState	24/06/2023	12:43	24/06/2023	14:06	PO	Premonsoon Maintenance work
220/110 KV 250 MVA ICT - 2 @ VERSOVA (TATA)	IntraState	24/06/2023	13:01	24/06/2023	15:25	PO	Installation of Cable monitoring System in LT Box.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage