

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Jul/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	99.310	2714.474	1) Gujrat	3.635	-151.950
2) Hydro	11.012	291.548	2) Madhya Pradesh	7.713	142.760
3) Gas	3.314	90.631	3) Chattisgarh	2.760	91.250
Total MSPGCL	113.636	3096.653	4) Maharashtra	135.108	3383.448
B) 1) APML	53.480	1164.384	5) Goa (Amona)	-1.340	-35.022
2) JSWEL	14.920	331.766	Total	147.876	3430.486
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.023	808.755
4) RPL(AMT)	16.079	494.205	b) Mumbai Drawl	32.866	863.604
5) SWPGPL	4.891	167.812	c) MSEDCL Bilateral *	73.043	1772.900
6) Other IPP	6.579	141.117	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.023	806.662
C) 1) TPCL Thermal	10.643	240.896	Include PX	0.000	0.000
2) TPCL Hydro	4.519	127.832	Standby	0.000	2.093
3) TPCL Gas	0.000	6.389	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.470	167.626	1) MSEDCL	366.908	9043.703
D) STATE			2) Mumbai Discoms	52.499	1406.349
1) Thermal	210.372	5422.280	3) Other Discoms	8.520	209.731
(A1+C1+C4+(B1-B6))			TOTAL STATE	427.927	10659.783
2) Hydro (A2+C2)	15.531	419.380			
3) Gas (A3+B7+C3)	3.314	97.020			
4) Wind	45.837	1145.954			
6) SOLAR	4.996	144.661			
TOTAL STATE	280.050	7229.295			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4432	4019	4420	4032
MSPGCL Hydro	546	508	627	329
MSPGCL Gas	129	188	129	130
MSPGCL Total Generation	5107	4715	5176	4491
Central Sector Receipt	7394	6422	6368	5210
WIND	1876	2026	1618	2082
CPP / IPP Thermal	4137	3548	5015	3782
CPP / IPP Gas	0	0	0	0
SOLAR	462	693	0	0
Exchange with Mumbai	-1619	-1729	-1435	-1128
MSEDCL DEMAND MET	16974	15311	16361	14148
Load Shedding	0	0	0	0
MSEDCL DEMAND	16974	15311	16361	14148
TPCL GENERATION	496	518	711	579
AEML GENERATION	177	169	178	162
MUMBAI DEMAND	2292	2416	2324	1869
OTHER DISCOM DEMAND	383	364	381	289
STATE DEMAND MET	19649	18091	19066	16306
STATE DEMAND	19649	18091	19066	16306
Frequency (Hz)	50.04	49.96	49.90	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 10:04 Hrs	49.75 Hz at 19:51 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	1.52	54.81	100	35
Unit 7	0.00	0.00	0	0
Unit 8	0.00	43.27	0	0
Unit 9	10.00	166.41	480	380
Unit 10	10.70	255.02	505	370
Total	22.21	519.51		
Bhusawal				
Unit 3	0.00	44.11	0	0
Unit 4	8.18	186.79	450	280
Unit 5	7.62	170.59	380	280
Total	15.80	401.49		
Parli				
Unit 6	3.80	105.84	186	147
Unit 7	3.68	86.19	173	144
Unit 8	2.95	48.52	169	0
Total	10.43	240.55		
Chandrapur				
Unit 3	0.00	20.97	0	0
Unit 4	2.20	54.85	98	81
Unit 5	5.40	152.57	240	200
Unit 6	2.86	129.42	152	80
Unit 7	0.00	0.00	0	0
Unit 8	7.78	215.20	424	0
Unit 9	8.12	218.10	416	282
Total	26.36	791.11		
Paras				
Unit 3	3.24	82.95	147	95
Unit 4	3.04	84.60	152	98
Total	6.28	167.54		
Khaparkheda				
Unit 1	0.04	61.20	45	0
Unit 2	2.16	69.96	105	55
Unit 3	3.48	78.00	160	123
Unit 4	2.98	32.50	132	118
Unit 5	6.79	210.45	332	260
Total	15.46	452.09		
Nasik				
Unit 3	2.76	70.91	132	95
Unit 4	0.00	39.36	0	0
Unit 5	0.00	31.92	0	0
Total	2.76	142.18		
Uran				
All Units	3.31	90.63	194	127
Total	3.31	90.63		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	7.11	26	24
Total	0.60	7.11		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.45	51.48	195	40
Stage 4	0.00	28.98	0	0
Stage 3	0.96	32.74	160	0
Total	2.41	113.20		
Hydro				
KDPH	0.86	9.78	36	36
VTRNA	0.77	16.23	61	0
TILLARI	0.41	11.75	58	0
BHIRA T.R.	0.46	9.57	77	0
SMLHY_PTN	5.51	122.90	232	225
GHATGHAR	0.00	1.01	0	0
Total	8.00	171.24		
Wind				
Total	45.84	1145.95	0	0
Total	45.84	1145.95		
CPP				
APML(Mus)	53.48	1164.38	0	0
JSWEL(Mus)	14.92	331.77	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	16.08	494.20	0	0
SWPGPL-Mus	4.89	167.81	0	0
Other(Mus)	6.58	141.12	0	0
Total	95.95	2299.28		
SOLAR				
Total	5.00	144.66	0	0
Total	5.00	144.66		
Tata				
Trombay 5	7.06	149.28	457	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.82	0	0
Trombay 7B	0.00	2.57	0	0
TATA Hydro	4.52	127.83	299	101
Trombay 8	3.58	91.62	228	131
Total	15.16	375.12		
AEMIL				
DTPS U-1&2	4.47	167.63	245	156
Total	4.47	167.63		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	99.31	2714.47	MSPGCL Total	113.64	3096.65
			MSPGCL Thml+Gas	102.62	2805.10	Koyna 1,2 & 4 Total	1.45	80.46
			MSPGCL Hydro	11.01	291.55	State Total	280.05	7229.30

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4117	362	130	4609	2369	4111	0	0	5239	4771	-1318	14213	0	14213	2153	329	16695	50.02
2	4082	332	131	4545	2336	3889	0	0	5051	5127	-1195	14394	0	14394	2024	308	16726	50.01
3	4046	331	140	4517	2269	3719	0	0	5076	5142	-1156	14206	0	14206	1933	285	16424	50.00
4	4032	329	130	4491	2082	3782	0	0	5171	5210	-1128	14148	0	14148	1869	289	16306	50.00
5	4109	331	130	4570	2011	4221	0	0	5455	5520	-1153	14864	0	14864	1852	305	17021	50.01
6	4218	352	140	4710	2007	4494	0	1	6163	5931	-1199	15615	0	15615	1920	329	17864	50.03
7	4208	376	129	4713	1983	3784	0	27	7270	7077	-1226	15992	0	15992	1939	366	18297	50.03
8	4282	372	129	4783	1980	3665	0	123	7358	7529	-1309	16415	0	16415	2012	356	18783	50.00
9	4416	557	139	5112	1967	3656	0	296	7250	7293	-1438	16510	0	16510	2131	376	19017	50.02
10	4432	546	129	5107	1876	4137	0	462	7045	7394	-1619	16974	0	16974	2292	383	19649	50.04
11	4365	455	152	4972	1864	3859	0	552	7410	7402	-1726	16544	0	16544	2409	379	19332	50.08
12	3960	520	194	4674	1931	3657	0	640	7676	7394	-1766	16147	0	16147	2432	383	18962	50.02
13	4019	508	188	4715	2026	3548	0	693	6598	6422	-1729	15311	0	15311	2416	364	18091	49.96
14	3826	495	159	4480	1810	3715	0	646	6377	6426	-1610	15102	0	15102	2352	365	17819	50.04
15	3813	528	129	4470	1859	3361	0	580	6666	6202	-1314	14797	0	14797	2306	361	17464	50.08
16	3754	538	129	4421	2043	3414	0	498	6542	6130	-1184	14956	0	14956	2244	366	17566	50.04
17	3712	444	128	4284	2038	3368	0	322	6664	5985	-1153	14473	0	14473	2220	371	17064	50.03
18	3868	460	127	4455	1730	3365	0	132	6436	6556	-1235	14606	0	14606	2220	397	17223	50.02
19	4369	530	128	5027	1713	4196	0	24	6218	6324	-1251	15634	0	15634	2275	399	18308	50.02
20	4420	627	129	5176	1618	5015	0	0	6564	6368	-1435	16361	0	16361	2324	381	19066	49.90
21	4458	547	131	5136	1599	4984	0	0	6031	5925	-1482	15795	0	15795	2342	367	18504	49.97
22	4478	567	131	5176	1566	4694	0	0	5524	5594	-1459	15198	0	15198	2321	373	17892	49.97
23	4321	478	131	4930	1595	4880	0	0	5364	5017	-1419	14652	0	14652	2273	351	17276	50.01
24	4005	427	131	4563	1565	4435	0	0	5336	5137	-1362	14000	0	14000	2239	338	16577	50.03
MUs	99.31	11.01	3.31	113.64	45.84	95.95	0.00	5.00	150.48	147.88	-32.87	366.91	0.00	366.91	52.50	8.52	427.93	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Jul/2022

Position as on 6.30 Hrs of 25/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	31/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	25/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	25/07/2022
MSPGCL	Uran Unit 6	108	06/07/2022	17:51	24/07/2022	10:12	Gas shortage	
TPC-G	Trombay 7A	120	07/07/2022	01:09		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	07/07/2022	01:21		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	09/07/2022	11:58		Continued.	Furnace Pressure High	31/07/2022
MSPGCL	Nasik Unit 5	210	11/07/2022	17:00		Continued.	WET COAL	
AEML	AEML Unit 2	250	13/07/2022	00:38		Continued.	Coal Shortage	
IPP	SWPGPL U-3	135	14/07/2022	14:58		Continued.	FD Fan Problem(converted to coal shortage from 19-7-2022)	
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
MSPGCL	Bhusawal Unit 3	210	16/07/2022	06:30		Continued.	Critical coal stock	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Jul/2022

Position as on 6.30 Hrs of 25/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-5	270	20/07/2022	10:00		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 1	210	22/07/2022	14:37	24/07/2022	23:06	Drum level low	24/07/2022
MSPGCL	Parli Unit 8	250	23/07/2022	23:23	24/07/2022	03:58	Furnace Pressure High	
MSPGCL	Uran Unit 5	108	24/07/2022	13:14		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 8	500	24/07/2022	22:54	25/07/2022	05:28	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 25/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 1	IntraState	24/07/2022	10:15	24/07/2022	19:13	PO	Annual Maintenace of line
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KHADKA-AURANGABAD (WALUJ)	IntraState	20/07/2022	22:49	25/07/2022	06:44	HT	H/T DUE TO O/V
BUS COUPLER @ PADGHE	IntraState	22/07/2022	13:05			PO	1) Replacement of old Bhel make CB under LES scheme . 2) MTAMC work 3) Diagnostic Testing work
KARAD - LONIKAND I	IntraState	24/07/2022	01:07	25/07/2022	06:47	HT	H/T DUE TO O/V
PADGHE - KALWA CKT - 1	IntraState	24/07/2022	14:14	24/07/2022	15:41	EO	For taking LTS scheme in service for 400kV Kalwa-Padghe ckt-1 which is important and needed before carrying out Tapping arrangement of 400KV Kalwa-Padgha-2 on Kalwa- Kharghar line by availing it's outages on 24.07.22
PADGHE - KALWA CKT - 2	IntraState	24/07/2022	15:58	25/07/2022	04:11	PO	For Tapping of 400KV Kalwa-Padgha-2 line (loc no.1107) on 400KV Kalwa-Kharghar line (Loc no.173-174) on temporary basis for HTLS work on Kalwa-Padgha-2 line between dead portion loc no.1107-1135.
KALWA - KHARGHAR	IntraState	24/07/2022	16:02	25/07/2022	04:10	PO	1) For bunching work between 400KV Kalwa - Padgha 2 line (Loc No. 1107) and 400KV Kalwa - Kharghar line (Loc No. 174). 2) After above arrangement 400KV Padgha Kalwa-Kharghar will be Temporarily established and will be kept for 60 Days
JAIGAD - KARAD CKT - 2	IntraState	24/07/2022	23:08	25/07/2022	06:54	HT	H/T DUE TO O/V
400 KV ICT Outages/Trippings							
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	24/07/2022	00:48	24/07/2022	02:25	EO	To attend hot spot on 220kV Side A bus isolator jaws by replacing same with new one.
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	24/07/2022	00:48	24/07/2022	02:25	EO	For attending/ Replacement of Bph LV Bushing due to Oil leakage .
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	25/07/2022	10:18			PO	1.QM Work 2.C & tan delta testing 3. SFRA & DFRA testing
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	23/07/2022	19:31	24/07/2022	09:48	EO	Attending hot spot work at loc. No. 82 Horizontal Jumper (R-Ph PGCIL Side Temp-125 ºC),(Y-Ph PGCIL Side Temp-79ºC),(R-Ph Nallasopara Side Temp-81ºC),(Y-Ph Nallasopara Side Temp-58 ºC) & (B-Ph Nallasopara Side Temp-67 ºC)
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 25/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR - VERSOVA	IntraState	16/07/2022	00:30			PO	1. Metro-9 Project work(Erection of 02 new monopoles and shifting of existing lines at Mira Bhyander area)2. DFCCIL Project work(Erection of 03 new inline lattice type towers and shifting existing lines at Virar Area)3. NHSRCL project work(Erection of 02 new towers (01 ȳ Monopole & 01 Lattice) and shifting of existing lines at Vasai Area).
DAHANU - VERSOVA	IntraState	16/07/2022	01:07			PO	1. Metro-9 Project work (Erection of 02 new monopoles and shifting of existing lines at Mira Bhyander area) 2. DFCCIL Project work (Erection of 03 new inline lattice type towers and shifting existing lines at Virar Area) 3. NHSRCL project work (Erection of 02 new towers (01 ȳ Monopole & 01 Lattice) and shifting of existing lines at Vasai Area).
BORIVALI - BOISAR (PG)	IntraState	18/07/2022	16:18			EO	Shifting of Line on TBC due to damaged B-Ph jumper (Twin) between Main Bus & Bus Isolator.
PADGHE - TEMGHAR - 1	IntraState	21/07/2022	15:13	24/07/2022	12:33	EO	Partial A-Bus outage in lower section For making 220 KV pdg - Temghar -1 line stub bus twin arrangement at Padghe end during this outage 220kV Temgher-1 Will be kept off
PADGHE - TEMGHAR - 1	IntraState	21/07/2022	15:13	24/07/2022	12:12	PO	Partial A-Bus outage in lower section For making 220 KV pdg - Temghar -1 line stub bus twin arrangement at Padghe end during this outage 220kV Temgher-1 Will be kept off
BUS - A @ PADGHE	IntraState	23/07/2022	17:33	24/07/2022	12:12	EO	Partial A-Bus outage in lower section For making 220 KV pdg - Temghar -1 line stub bus twin arrangement at Padghe end during this outage 220kV Temgher-1 Will be kept off (Bay name 1. 220kV padghe-Jindal line-10MW 2. Kambha-2 170MW 3. Temghar-232MW 4. Wada 5. 600MVA ICT-4
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	23/07/2022	19:34	24/07/2022	13:52	EO	due to T joint conductor (Rph) of A&B Bus isolator towards CB has been found broken
TROMBAY SALSETTE LINE-2	IntraState	23/07/2022	23:20	24/07/2022	06:55	PO	METRO-4 WORK-Shifting of 220 kV Trombay Salsette 2 on 220 kV TDS RoW in section from loc. 44B to 60
PADGHE - TEMGHAR - 2	IntraState	23/07/2022	23:41	24/07/2022	07:57	EO	For replacement of existing 800-400/1 ratio CT by 1600-800/1 ratio (3nos.) at 220KV Temghar ss.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 25/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
RANJANGAON - U TECH SUGAR CKT	IntraState	24/07/2022	07:58	24/07/2022	13:30	PO	220 Kv Utech Ranjanjaon Ckt for tightening of CUT POINT TOWER Jumpers nut bolt , new damper fitting , etc from loc no 1 to 20 of Shri Gajanan maharaj sugar factory (UTECH SUGAR)
BABHALESHWAR - UTECH SUGAR	IntraState	24/07/2022	13:55	24/07/2022	17:47	PO	220 Kv Babhaleshwar UTECH Ckt for tightening of CUT POINT TOWER Jumpers nut bolt , new damper fitting , etc from loc no 1 to 20 of Shri Gajanan maharaj sugar factory (UTECH SUGAR)
OSMANABAD - BARSHI	IntraState	25/07/2022	09:09			PO	Outage is required for CRM & Timing of CB and Tan delta testing of CT's
TALANDGE - ICHALKARANJI 1	IntraState	25/07/2022	09:44			PO	1) Quarterly bay maintenance work at 220 kV Tilawani end. 2) Bay Diagnostic testing at tilawani end .
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132/11KV 200 MVA ICT 2 @ MALINAGAR	IntraState	20/07/2022	23:13			PO	Outage is required for Quarterly Maintenance
220/22 KV 50 MVA PTR 2	IntraState	24/07/2022	15:19	24/07/2022	17:00	T	Tripped on OSR optd
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage