

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Jul/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	115.295	3127.162	1) Gujrat	4.755	46.492
2) Hydro	9.306	167.486	2) Madhya Pradesh	-0.767	96.579
3) Gas	0.000	1.185	3) Chattisgarh	2.630	53.350
Total MSPGCL	124.601	3295.833	4) Maharashtra	155.532	3871.848
B) 1) APLM	46.012	1343.736	5) Goa (Amona)	-0.959	-24.974
2) JSWEL	19.531	473.298	Total	161.191	4043.295
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.496	827.008
4) RPL(AMT)	24.859	563.629	b) Mumbai Drawl	34.805	908.279
5) SWPGPL	6.531	205.574	c) MSEDCL Bilateral *	90.884	2189.115
6) Other IPP	6.005	153.444	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.496	826.157
C) 1) TPCL Thermal	10.521	198.249	Include PX	0.000	0.000
2) TPCL Hydro	4.998	111.621	Standby	0.000	0.851
3) TPCL Gas	2.785	79.348	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.630	212.143	1) MSEDCL	406.643	10261.838
D) STATE			2) Mumbai Discoms	61.739	1509.642
1) Thermal	237.384	6277.235	3) Other Discoms	10.051	235.309
(A1+C1+C4+(B1-B6))			TOTAL STATE	478.433	12006.789
2) Hydro	14.304	279.107			
(A2+C2)					
3) Gas	2.785	80.533			
(A3+B7+C3)					
4) Wind	51.965	1094.728			
6) SOLAR	10.804	231.889			
TOTAL STATE	317.242	7963.492			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4825	4372	5138	4439
MSPGCL Hydro	291	336	1293	242
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5116	4708	6431	4681
Central Sector Receipt	8324	7559	6513	5397
WIND	2131	2315	2148	2248
CPP / IPP Thermal	4422	3704	5184	3751
CPP / IPP Gas	0	0	0	0
SOLAR	1053	1443	0	0
Exchange with Mumbai	-2050	-2141	-1232	-937
MSEDCL DEMAND MET	18543	17154	18581	14815
Load Shedding	0	0	0	0
MSEDCL DEMAND	18543	17154	18581	14815
TPCL GENERATION	671	660	1122	623
AEML GENERATION	285	289	500	290
MUMBAI DEMAND	3006	3090	2854	1850
OTHER DISCOM DEMAND	453	434	463	325
STATE DEMAND MET	22002	20678	21898	16990
STATE DEMAND	22002	20678	21898	16990
Frequency (Hz)	49.99	49.96	49.98	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 13.03 Hrs	49.75 Hz at 11.38 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 24/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.22	85.43	150	110
Unit 8	11.25	238.86	530	378
Unit 9	10.98	283.85	527	377
Unit 10	0.00	111.14	0	0
Total	25.45	719.27		
Bhusawal				
Unit 3	3.00	69.74	135	95
Unit 4	7.85	227.77	411	268
Unit 5	8.32	234.62	415	280
Total	19.16	532.13		
Parli				
Unit 6	0.00	40.92	0	0
Unit 7	4.18	45.32	241	108
Unit 8	3.04	28.66	139	118
Total	7.22	114.90		
Chandrapur				
Unit 3	1.03	56.27	118	0
Unit 4	3.24	57.41	145	123
Unit 5	0.00	0.00	0	0
Unit 6	6.57	175.74	290	249
Unit 7	6.71	181.86	292	248
Unit 8	9.71	232.80	445	302
Unit 9	10.06	244.37	487	317
Total	37.31	948.45		
Paras				
Unit 3	0.00	85.09	0	0
Unit 4	3.75	102.74	168	145
Total	3.75	187.84		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.89	63.87	127	113
Unit 3	3.62	92.08	174	128
Unit 4	3.86	87.88	195	128
Unit 5	5.30	215.43	445	0
Total	15.67	459.26		
Nasik				
Unit 3	3.51	73.67	175	122
Unit 4	0.00	64.84	0	0
Unit 5	3.23	26.81	164	114
Total	6.74	165.31		
Uran				
All Units	0.00	1.18	0	0
Total	0.00	1.18		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.25	2.30	23	0
Total	0.25	2.30		
Koyna				
Stage 1-2	1.94	45.48	285	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.67	8.92	668	0
Stage 3	1.48	25.03	160	0
Total	5.09	79.44		
Hydro				
KDPH	0.14	0.28	18	0
VTRNA	0.00	0.64	0	0
TILLARI	0.00	1.16	0	0
BHIRA T.R.	0.44	10.46	80	0
SMLHY_PTN	3.28	67.39	141	127
GHATGHAR	0.10	5.81	80	0
Total	3.97	85.75		
Wind				
Total	51.96	1094.73	0	0
Total	51.96	1094.73		
CPP				
APML(Mus)	46.01	1343.74	0	0
JSWEL(Mus)	19.53	473.30	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.86	563.63	0	0
SWPGPL-Mus	6.53	205.57	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.76	122.81	271	153
Other(Mus)	1.24	30.63	0	0
Total	102.94	2739.68		
SOLAR				
Total	10.80	231.89	0	0
Total	10.80	231.89		
Tata				
Trombay 5	6.95	108.42	426	255
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.63	48.03	109	37
Trombay 7B	1.15	31.32	64	34
TATA Hydro	5.00	111.62	361	75
Trombay 8	3.57	89.83	218	129
Total	18.30	389.22		
AEML				
DTPS U-1&2	8.63	212.14	500	282
Total	8.63	212.14		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	115.30	3127.16	MSPGCL Total	124.60	3295.83
			MSPGCL Thml+Gas	115.30	3128.35	Koyna 1,2 & 4 Total	3.61	54.40
			MSPGCL Hydro	9.31	167.49	State Total	317.24	7963.49

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	4473	186	0	4659	2315	3798	0	0	6009	5686	-1110	14980	0	0	14980	2068	368	17416	49.94
2	4601	167	0	4768	2335	3745	0	0	5738	5438	-1001	14938	0	0	14938	1937	347	17222	50.01
3	4439	242	0	4681	2248	3751	0	0	5336	5397	-937	14815	0	0	14815	1850	325	16990	50.04
4	4828	253	0	5081	2226	3748	0	0	5217	5218	-899	15045	0	0	15045	1801	329	17175	50.01
5	4974	199	0	5173	2102	3894	0	0	5726	6028	-931	15921	0	0	15921	1820	345	18086	50.00
6	5097	254	0	5351	2012	4317	0	1	6649	6795	-1071	17023	0	0	17023	1964	382	19369	50.00
7	5174	341	0	5515	1881	4905	0	77	7575	7370	-1190	18159	0	0	18159	2140	399	20698	49.97
8	5170	419	0	5589	1917	4715	0	371	7796	7824	-1353	18635	0	0	18635	2402	428	21465	50.01
9	5057	336	0	5393	2019	4810	0	721	7919	7712	-1645	18557	0	0	18557	2722	453	21732	50.08
10	4825	291	0	5116	2131	4422	0	1053	8517	8324	-2050	18543	0	0	18543	3006	453	22002	49.99
11	4479	291	0	4770	2200	3739	0	1221	8621	8485	-2207	17747	0	0	17747	3179	461	21387	49.98
12	4538	430	0	4968	2357	3690	0	1343	7939	8006	-2195	17715	0	0	17715	3183	454	21352	49.92
13	4372	336	0	4708	2315	3704	0	1443	7556	7559	-2141	17154	0	0	17154	3090	434	20678	49.96
14	4301	471	0	4772	2609	3615	0	1328	7259	6878	-2006	16769	0	0	16769	2955	427	20151	50.00
15	4559	397	0	4956	2415	3580	0	1156	7130	6958	-2025	16611	0	0	16611	2953	429	19993	50.03
16	4598	265	0	4863	2359	3716	0	1041	7469	7551	-1962	17127	0	0	17127	2961	441	20529	50.03
17	4649	217	0	4866	2427	3750	0	645	7566	7599	-1885	16961	0	0	16961	2935	441	20337	50.00
18	4943	216	0	5159	2212	4216	0	331	7254	6929	-1664	16721	0	0	16721	2912	462	20095	49.99
19	5096	353	0	5449	2045	4870	0	73	7185	6892	-1450	17410	0	0	17410	2864	469	20743	50.02
20	5138	1293	0	6431	2148	5184	0	0	6693	6513	-1232	18581	0	0	18581	2854	463	21898	49.98
21	5170	915	0	6085	2160	5244	0	0	6275	5508	-1074	17460	0	0	17460	2743	463	20666	50.01
22	5009	599	0	5608	1921	5229	0	0	5904	5557	-986	16888	0	0	16888	2607	441	19936	50.02
23	4944	540	0	5484	1884	5200	0	0	5677	5616	-985	16767	0	0	16767	2462	432	19661	50.01
24	4861	296	0	5157	1727	5096	0	0	5583	5347	-806	16115	0	0	16115	2331	406	18852	49.99
MUs	115.30	9.31	0.00	124.60	51.97	102.94	0.00	10.80	164.59	161.19	-34.80	406.64	0.00	0.00	406.64	61.74	10.05	478.43	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Jul/2023

Position as on 6.30 Hrs of 25/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	28/07/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
MSPGCL	Bhusawal Unit 3	210	24/07/2023	23:46		Continued.	Boiler validity extension	26/07/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	25/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/07/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1 (250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	26/07/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	26/07/2023
MSPGCL	Nasik Unit 4	210	19/07/2023	10:50		Continued.	ID Fan Problem	26/07/2023
MSPGCL	Uran Unit 6	108	19/07/2023	21:11		Continued.	No schedule	
IPP	SWPGPL U-3	135	21/07/2023	01:54		Continued.	Non-availability of linkage coal stock and due to continuous rains.	28/07/2023
MSPGCL	Parli Unit 6	250	21/07/2023	23:44		Continued.	BTL,(Converted into Zero schedule wef 23:00hrs dated 23.07.23)	
MSPGCL	Paras Unit 3	250	22/07/2023	12:15		Continued.	Due to boiler drum LHS main hole door gasket leakage	27/07/2023

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Jul/2023

Position as on 6.30 Hrs of 25/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 5	500	24/07/2023	14:42		Continued.	Boiler Tube Leakage	27/07/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 25/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
TIRODA - KORADI 3 CKT - 2	IntraState	23/07/2023	21:52	24/07/2023	01:19	HT	Found one monkey is trapped in live conductor of 765KV tiroda-koradi-iii-2 And struggling to escape from the conductor.
TIRORA - KORADI 3 CKT - 1	IntraState	23/07/2023	21:52	24/07/2023	00:00	T	Tripped without indication at koradi-3 end only.
TIRORA - KORADI 3 CKT - 1	IntraState	24/07/2023	10:27	24/07/2023	20:45	PO	Installation of Bird Flight Divertor- In reference to the Hon'ble High Court, Nagpur Order dated 05th January 2022
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synch CVT.
BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	IntraState	24/07/2023	12:18	24/07/2023	14:23	PO	1)Annual testing work 2) QM work 3) CB Timing CRM
MAIN BUS - 1 @ ALKUD	IntraState	25/07/2023	11:30			PO	Diagnostic testing & Maintenance work
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
400KV-PARLI NEW-PARLI-M-2	InterState	24/07/2023	13:11	24/07/2023	18:04	PO	FOR ONGOING PROJECT OF "UPGRADATION OF 400KV LINE BAYS (02 NOS) OF PARLI (PG) I&II AT PARLI (MSETCL) FROM EXISTING CURRENT RATING OF 2000A TO 3150A TO SUIT THE RECONDUCTORING WITH TWIN HTLS�. AR TO BE KEPT IN NON AUTO MODE FOR 400KV-PARLINEW-PARLI-M-1.
PUNE(GIS) - TALEGAON(PG) CKT - 4	InterState	24/07/2023	20:13	25/07/2023	06:35	T	Tripped on Distance protection.
AKOLA - WARDHA(PG) CKT - 1	InterState	25/07/2023	09:25			PO	For Line Bay Amp Works. AR to be kept in non Auto mode for 400KV-WARDHA-AKOLA-2
AURANGABAD(MS) - AURANGABAD(PG) CKT - 2	InterState	25/07/2023	10:18			PO	409L AMP at Aurangabad & 404L AMP at Waluj and BHEL Insulator Replacement work. AR to be kept in non Auto mode for 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1
KHADKA-AURANGABAD (WALUJ)	IntraState	22/07/2023	23:52	24/07/2023	09:21	HT	For voltage management
KHADKA- DEEPNAGAR CKT 1	IntraState	24/07/2023	12:15	24/07/2023	17:58	EO	E/O required for attending Rotary problem of B phase Auxiliary isolator

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 25/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV JALKOT - KUMBHARGAON (400 KV) CKT - 1	IntraState	24/07/2023	12:28	24/07/2023	16:34	PO	To Emergency Tree Cutting Span.
KHADKA-AURANGABAD (WALUJ)	IntraState	25/07/2023	03:43	25/07/2023	08:24	HT	H/T on overvoltage
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	17/07/2023	13:04			PO	1.Replacement of HV CB under LES Scheme. 2.ICT will be in service through TBC.
400/11.5KV STATION TRANSFORMER - 1 @ TIRORA	IntraState	22/07/2023	09:43			HT	Planned outage in RC1 row No. 14
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	25/07/2023	08:38			PO	1.Commissioning of High velocity water spray system for 315MVA ICT-2 2. Routine maintenance of ICT 2. Maintenance and alignment of Isolators 3. Bay routine maintenance work
220 KV MAINBAY Outages/Trippings							
TBC @ FLAGSHIP	IntraState	24/07/2023	12:45			PO	220kV CB overhauling work by Agency
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
TROMBAY - KALWA	IntraState	22/07/2023	14:37			PO	Outage is required for safety purpose by M/s KVTL during stringing of 400KV Khargar-Vikhroli line between loc no. AP 59- AP 60 & 61-62 by M/s KVTL.
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
TALANDGE - MUDSHINGI CKT - 2	IntraState	24/07/2023	10:02	24/07/2023	13:55	PO	for quarterly maintenance work at Mudshingi substation
TALANDGE - ICHALKARANJI 1	IntraState	24/07/2023	10:39	24/07/2023	18:33	PO	Annual relay testing of bay CB Testing CT Testing CT ratio change from 800/1 to 1600/1
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	24/07/2023	11:58	24/07/2023	20:28	PO	To pull the OPGW cable on this line as induction level is very high due to heavy raining
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	24/07/2023	12:12	24/07/2023	20:15	PO	To pull the OPGW cable on this line as induction level is very high due to heavy raining
EKLAHARE (GCR) - GHATGHAR	IntraState	24/07/2023	12:43	24/07/2023	17:35		Outage required for PID faulty disc replacement insulator at loc.no.30 Y-phase DTN string Ghatghar side and at loc.no.42 B-phase DTN string Ghatghar side.
TALOJA - PANCHANAND	IntraState	24/07/2023	14:57	24/07/2023	17:18	EO	Panchanand end cable bushing R-ph Hot-spot attending work
NEW KOYNA - POPHALI	IntraState	24/07/2023	19:05	25/07/2023	08:00	T	220kV Bus-section Tripped at Pedambe.
POPHLI PEDHMBE LINE- 1	IntraState	24/07/2023	19:05	25/07/2023	02:57	T	220kV Bus-section Tripped at Pedambe.
NEW KOYNA - PEDAMBE	IntraState	24/07/2023	19:05	25/07/2023	02:52	T	220kV Bus-section Tripped at Pedambe.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 25/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS SECTION - 1 @ PEDAMBE	IntraState	24/07/2023	19:05	25/07/2023	02:57	T	220kV Bus-section Tripped at Pedambe.
VERSOVA - GHODBUNDER	IntraState	24/07/2023	23:29	25/07/2023	04:51	PO	For Safety Purpose while erection of U girder at P152 - P153LHS under metro 09 work
GHODBUNDER - GORAI	IntraState	24/07/2023	23:34	25/07/2023	04:59	PO	For Safety Purpose while erection of U girder at P152 - P153LHS under metro 09 work
PETH- MUDSHINGI 1 LINE	IntraState	25/07/2023	10:15			PO	For replacement of damaged B ph conductor between loc no 164 to 165.
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	25/07/2023	11:49			PO	To pull the OPGW cable on this line as induction level is very high due to heavy raining
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	25/07/2023	11:54			PO	To pull the OPGW cable on this line as induction level is very high due to heavy raining
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	24/07/2023	11:49	24/07/2023	17:41	EO	OLTC work to be carried out.
220 KV BUSBAR Outages/Trippings							
AUXILIARY BUS @ PHALTAN MIDC-220 KV	IntraState	16/07/2023	10:02			PO	For Gantry replacement from AH type to AF type
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage