

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Aug/2016 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	116.059	1798.987	1) Gujrat	6.579	145.373
2) Hydro	7.660	319.669	2) Madhya Pradesh	15.166	319.936
3) Gas	3.541	174.957	3) Chattisgarh	5.000	155.750
Total MSPGCL	127.260	2293.613	4) Maharashtra Net	76.264	1549.286
B) 1) APML	54.755	863.942	5) Goa (Amona)	-0.502	-15.803
2) JSWEL	21.781	504.288	Total	121.945	2613.212
3) VIPL	12.387	239.273	a) Mumbai Schedule	22.506	453.863
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.124	541.284
5) WPCL	4.442	106.402	c) MSEDCL Bilateral *	26.148	645.665
6) PGPL	6.874	43.644	Include PX	-0.197	-30.338
7) Other IPP	2.322	54.510	d) Mumbai Bilateral *	22.506	453.863
C) 1) TPCL Thermal	14.995	342.660	Include PX	1.432	41.866
2) TPCL Hydro	5.947	134.547	Include Standby	0.000	0.000
3) TPCL Gas	4.204	91.010	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	10.811	251.011	1) MSEDCL	352.353	7210.203
D) STATE			2) Mumbai Discoms	60.081	1360.507
1) Thermal	237.552	4161.073	TOTAL STATE	412.434	8570.710
(A1+C1+C4+(B1-B6))					
2) Hydro	13.607	454.216			
(A2+C2)					
3) Gas	14.619	309.611			
(A3+B6+C3)					
4) Wind	23.797	1012.228			
6) SOLAR	0.914	20.375			
TOTAL STATE	290.489	5957.503			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 14 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5083	5111	5288	4156
MSPGCL Hydro	670	630	362	87
MSPGCL Gas	149	147	148	148
MSPGCL Total Generation	5902	5888	5798	4391
Central Sector Receipt	5859	5452	5054	4405
WIND	947	1043	978	1020
CPP / IPP Thermal	4159	4147	4177	3728
CPP / IPP Gas	285	286	290	289
SOLAR	116	109	0	0
Exchange with Mumbai	-1291	-1137	-1126	-693
MSEDCL DEMAND MET	15977	15788	15171	13140
Load Shedding	0	0	0	0
MSEDCL DEMAND	15977	15788	15171	13140
TPCL GENERATION	1295	1295	1176	659
R-INFRA GENERATION	505	509	499	403
MUMBAI DEMAND	3091	2941	2801	1755
STATE DEMAND MET	19068	18729	17972	14895
STATE DEMAND	19068	18729	17972	14895
Frequency (Hz)	50.00	49.99	49.87	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 18.02 Hrs	49.68 Hz at 19.14 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 24/Aug/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.08	0.08	30	0
Unit 6	0.00	0.00	0	0
Unit 7	3.20	4.80	155	100
Unit 8	11.63	204.76	530	450
Total	14.91	209.64		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	5.83	16.39	470	0
Unit 5	10.35	12.54	500	350
Total	16.18	28.93		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.22	62.59	195	165
Unit 4	0.00	73.15	0	0
Unit 5	9.48	205.20	430	358
Unit 6	10.22	200.00	455	346
Unit 7	9.45	211.19	415	357
Unit 8	9.27	136.19	455	311
Total	42.64	888.33		
Paras				
Unit 3	5.74	72.26	253	209
Unit 4	5.64	119.94	250	200
Total	11.39	192.20		
Khaparkheda				
Unit 1	3.56	5.74	170	115
Unit 2	3.62	6.22	165	130
Unit 3	0.00	0.00	0	0
Unit 4	4.18	6.39	191	160
Unit 5	11.15	250.03	500	400
Total	22.52	268.38		
Nasik				
Unit 3	4.18	97.18	195	160
Unit 4	4.25	87.13	199	156
Unit 5	0.00	10.04	0	0
Total	8.42	194.35		
Uran				
All Units	3.54	174.96	150	137
Total	3.54	174.96		
PGPL				
Unit 1	4.34	27.27	183	179

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	2.54	16.38	107	105
Total	6.87	43.64		
PENCH (MS)				
Pench (MS)	0.56	6.69	25	21
Total	0.56	6.69		
Koyna				
Stage 1-2	2.91	96.98	395	40
Stage 4	0.56	87.80	183	0
Stage 3	0.91	55.18	160	0
Total	4.38	239.96		
Hydro				
KDPH	0.00	5.89	0	0
VTRNA	0.32	15.58	59	0
TILLARI	0.19	6.68	61	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.48	10.96	80	0
RNGR+BHTSA	0.00	4.33	0	0
BHANDARDRA	0.34	10.04	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.75	8.71	32	31
GHATGHAR	1.18	17.51	240	0
Total	3.28	79.70		
Wind				
Total	23.80	1012.23	0	0
Total	23.80	1012.23		
CPP				
APML(Mus)	54.76	863.94	0	0
JSWEL(Mus)	21.78	504.29	0	0
VIPL(Mus)	12.39	239.27	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	4.44	106.40	0	0
Other(Mus)	2.32	54.51	0	0
Total	95.69	1768.42		
SOLAR				
Total	0.91	20.38	0	0
Total	0.91	20.38		
Tata				
Trombay 5	9.65	217.09	488	312
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.66	56.25	115	65
Trombay 7B	1.55	34.76	66	51
Trombay 8	5.35	125.57	244	200
TATA Hydro	5.95	134.55	387	0
Total	25.15	568.22		
R-INFRA				
1-2	10.81	251.01	509	401
Total	10.81	251.01		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	17.16
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	116.06	1798.99
MSPGCL Thml+Gas	119.60	1973.94
MSPGCL Hydro	7.66	319.67

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	127.26	2293.61
Koyna 1,2 & 4 Total	3.48	184.78
State Total	290.49	5957.50

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Aug/2016

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4510	87	137	4734	1350	3876	287	0	4397	4500	-931	13816	0	13816	2024	15840	49.91
2	4352	87	148	4587	1241	3786	286	0	4455	4315	-809	13406	0	13406	1906	15312	49.99
3	4169	97	148	4414	1170	3637	287	0	4258	4415	-743	13180	0	13180	1809	14989	49.94
4	4156	87	148	4391	1020	3728	289	0	4417	4405	-693	13140	0	13140	1755	14895	49.94
5	4165	92	150	4407	903	3716	288	0	4422	4684	-681	13317	0	13317	1751	15068	49.97
6	4607	192	150	4949	1018	3836	289	0	4634	5011	-710	14393	0	14393	1865	16258	50.00
7	4808	96	150	5054	898	4005	286	1	4905	5579	-688	15135	0	15135	2023	17158	50.00
8	4893	562	149	5604	743	4037	286	22	5032	5530	-649	15573	0	15573	2208	17781	50.02
9	4950	497	150	5597	837	4061	286	52	5345	5872	-759	15946	0	15946	2500	18446	50.01
10	5009	839	150	5998	839	4112	286	97	5289	5366	-1082	15616	0	15616	2865	18481	49.99
11	5046	715	149	5910	980	4145	286	101	5319	5725	-1292	15855	0	15855	3059	18914	49.99
12	5083	670	149	5902	947	4159	285	116	5585	5859	-1291	15977	0	15977	3091	19068	50.00
13	5118	595	145	5858	865	4156	286	115	5656	5249	-1273	15256	0	15256	3072	18328	49.99
14	5111	630	147	5888	1043	4147	286	109	5569	5452	-1137	15788	0	15788	2941	18729	49.99
15	5130	310	146	5586	1133	4153	286	94	5476	5115	-1168	15199	0	15199	2969	18168	49.92
16	5218	423	147	5788	1232	4135	285	101	5388	5006	-1146	15401	0	15401	2951	18352	49.97
17	5218	211	147	5576	1464	4148	286	74	5266	4578	-1142	14984	0	14984	2922	17906	49.98
18	4781	107	147	5035	1472	3950	285	28	4810	4940	-1440	14270	0	14270	2856	17126	50.02
19	4696	293	148	5137	1145	3810	286	4	4998	4852	-1422	13812	0	13812	2786	16598	49.95
20	5288	362	148	5798	978	4177	290	0	5114	5054	-1126	15171	0	15171	2801	17972	49.87
21	5157	268	146	5571	785	4116	285	0	5106	5142	-1086	14813	0	14813	2715	17528	50.01
22	5076	143	146	5365	635	3940	286	0	4985	5272	-1029	14469	0	14469	2514	16983	50.00
23	4820	153	148	5121	579	3924	286	0	4849	5006	-915	14001	0	14001	2396	16397	49.97
24	4698	144	148	4990	520	3930	286	0	4725	5018	-912	13832	0	13832	2302	16134	50.00
MUs	116.06	7.66	3.54	127.26	23.80	95.69	6.87	0.91	120.00	121.95	-24.12	352.35	0.00	352.35	60.08	412.43	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Aug/2016

Position as on 6.30 Hrs of 25/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Koyana Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkhedda Unit 3	210	05/07/2016	23.52	25/08/2016	04.48	Zero Shedule By MSEDCL, converted for AOH from 00 Hrs Dt.25-7-16	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-2	270	18/06/2016	06.54		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	30/06/2016	10.11		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Koradi Unit 5	200	01/07/2016	02.23	24/08/2016	21.02	Zero Shedule By MSEDCL up to 22/08/2016, Schedule given from 00:00Hrs of 23/08/2016 and Unit synchronization delayed due to technical problem.	
IPP	RPL(AMT) U-1	270	01/07/2016	18.40		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	08/07/2016	23.57		Continued.	ID Fan Problem (Converted to Zero schedule by MSEDCL from 11-07-2016)	
IPP	Adani U-4	660	13/07/2016	02.22		Continued.	Zero Shedule By MSEDCL,Shedule Gliven On 21/08/2016	
MSPGCL	Nasik Unit 5	210	03/08/2016	17.30	25/08/2016	12.37	Zero shedule	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Aug/2016

Position as on 6.30 Hrs of 25/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 9	500	11/08/2016	22.11		Continued.	Oil Shortage.	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Uran Unit B0	120	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Bhusawal Unit 4	500	14/08/2016	21.28	24/08/2016	04.45	Zero schedule given by MSEDCL	
RGPL	Dabhol 3A	230	16/08/2016	17.24		Continued.	Change Over	
MSPGCL	Koyna Unit 8	80	19/08/2016	11.00		Continued.	High Vibration On LGB & UGB.	
MSPGCL	Uran Unit 5	108	19/08/2016	22.03	25/08/2016	11.57	Boiler trip.	
MSPGCL	Chandrapur Unit 4	210	21/08/2016	22.02		Continued.	ID Fan Problem	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Khaparkheda Unit 4	210	25/08/2016	13.50		Continued.	Boiler Tube Leakage	
MSPGCL	Nasik Unit 4	210	25/08/2016	18.40		Continued.	Zero Schedule given by MSEDCL.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 25/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	22/08/2016	19.53		Continued.	T	Buchholz Trip 330 MVA Converter Pole-2 Y-Phase T/F At Chandrapur End.
Chandrapur - Padghe Hvdc Pole 1	IntraState	24/08/2016	23.00	25/08/2016	00.40	EO	Inspection of Y Phase Converter T/F
400 KV LINE Outages/Trippings							
Kolhapur Solapur (PG) II	InterState	24/08/2016	03.03	24/08/2016	07.32	T	Over Voltage
Dhule Sar'Sarovar I	InterState	24/08/2016	03.30	24/08/2016	18.15	T	Distance Protection
Dhule Sar'Sarovar II	InterState	24/08/2016	05.31	24/08/2016	14.02	T	Distance Protection
Akola Aurangabad(PG) I	InterState	24/08/2016	10.35	24/08/2016	17.08	PO	Testing Work
Padgha Tarapur II	InterState	25/08/2016	13.11	25/08/2016	21.53	PO	Testing Work
Akola Aurangabad(PG) I	InterState	25/08/2016	18.40	25/08/2016	19.20	T	Tripped @ Akola,D.T.Received.
Padghe - Kharghar	IntraState	07/08/2016	17.07	24/08/2016	20.58	PO	Shifted on TBC at kharghar end
karad -kolhapur-II	IntraState	19/08/2016	09.20	24/08/2016	06.48	PO	For Isolator Assembly Replacement Work.
Karad - Jaigad - II	IntraState	22/08/2016	09.55	24/08/2016	06.54	PO	Annual Maintenance Work RFC-14:48.
Khadka-Aurangabad (Waluj)	IntraState	23/08/2016	17.43	24/08/2016	06.59	HT	Over Voltage
Chandrapur II - Chandrapur ckt 2	IntraState	24/08/2016	11.27		Continued.	PO	Routine Maintenance Work
Padghe - Kalwa-II	IntraState	24/08/2016	14.05	24/08/2016	14.43	T	DT Received at Padgha while taking line on TBC at Kalwa
Bus B @ Khargar	IntraState	24/08/2016	14.05	24/08/2016	20.40	PO	Isolator Maint.work
karad -kolhapur-I	IntraState	24/08/2016	17.59	25/08/2016	09.30	HT	Over Voltage
Karad - Jaigad - II	IntraState	24/08/2016	18.03	25/08/2016	09.52	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	24/08/2016	18.04	25/08/2016	09.27	HT	Over Voltage
Padghe - Nagothane - II	IntraState	25/08/2016	06.05	25/08/2016	20.13	T	LA Burst at Padgha end
karad -kolhapur-II	IntraState	25/08/2016	16.31		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	25/08/2016	16.33		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	25/08/2016	17.16		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	25/08/2016	18.14		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	20/08/2016	11.06		Continued.	PO	Shifted on TBC, by hot line jumper open for construction of kudas bay ektuni CKT-2 will remain off during this outage period.
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	24/08/2016	10.45	25/08/2016	18.55	PO	Isolator maint.work
400/220/33 Kv 315 Mva Ict 2 @Girwali	IntraState	25/08/2016	19.21	25/08/2016	19.37	T	Tripped During TBC Transfer.
220 KV LINE Outages/Trippings							
Talandge Chikodi	InterState	25/08/2016	14.44	25/08/2016	16.12	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Babhleshwar- Ranjangaon	IntraState	06/06/2016	07.22		Continued.	HT	Hand Tripped for Ranjangaon End.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Babhleshwar- Alephata	IntraState	24/07/2016	07.57		Continued.	HT	Load Diversion.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 25/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Pophali - Kdph	IntraState	19/08/2016	00.20	24/08/2016	19.25	HT	Due to Snapping of conductor
Shivajinagar - Satana	IntraState	23/08/2016	22.58	24/08/2016	19.17	T	Distance Protection
Chandrapur GCR - Sicom I	IntraState	24/08/2016	11.07	24/08/2016	20.48	PO	Testing Work
Butibori - Khaperkheda	IntraState	24/08/2016	11.38	24/08/2016	13.42	PO	New Bus Bar LED Panel Wiring
Koradi-Khaperkheda	IntraState	24/08/2016	14.20	24/08/2016	15.56	PO	New Bus Bar LED Panel Wiring
Bhugaon-Pusad	IntraState	25/08/2016	07.21	25/08/2016	18.36	PO	LILO Work @ Excisting Loc no.42 of Bhugaon Pusad Line for PGCIL Deoli S/S & Charging of Line as 220KV PGCIL Deoli-Bhugaon Line & PGCIL Deoli-Pusad Line.
Chandrapur GCR - Sicom II	IntraState	25/08/2016	11.00	25/08/2016	14.45	PO	Relay Instalation & Testing Work.
Khaparkheda-Kalmeshwar	IntraState	25/08/2016	11.21	25/08/2016	14.08	T	Distance Protection
Parli 2-(Girwali) -Murud	IntraState	25/08/2016	12.42	25/08/2016	17.03	PO	Attending Hot Spot
Chitegaon-Shendra Ckt-Ii	IntraState	25/08/2016	23.54		Continued.	T	Bus Bar Protection Operated
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 200mva Kanohar Ict 3 @Bale (Solapur 2)	IntraState	24/08/2016	09.43	24/08/2016	16.10	PO	Routine Maintenance Work
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	24/08/2016	10.38	24/08/2016	13.34	EO	To attend Hot Spot
220/132 Kv 200 Mva Bbl Ict 1 @Beed	IntraState	24/08/2016	11.21	24/08/2016	19.55	PO	Measurment of Tan Delta and SFRA of ICT
220/132 KV ICT II @ Kopergaon	IntraState	25/08/2016	15.25	25/08/2016	18.00	PO	Testing Work
132 KV LINE Outages/Trippings							
Parbhani-Bageshwari	IntraState	24/08/2016	04.25	24/08/2016	04.41	T	Distance Protection
100 KV LINE Outages/Trippings							
Vasai-Ii - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage