

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Aug/2020 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	77.006	2253.270	1) Gujrat	3.069	13.196
2) Hydro	13.158	194.738	2) Madhya Pradesh	10.999	160.898
3) Gas	6.657	114.211	3) Chattisgarh	5.570	114.120
Total MSPGCL	96.821	2562.219	4) Maharashtra	116.342	2586.945
B) 1) APLM	30.859	663.276	5) Goa (Amona)	-1.590	-39.845
2) JSWEL	15.882	379.417	Total	134.390	2835.314
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.741	584.362
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	23.611	574.048
5) WPCL	2.709	116.072	c) MSEDCL Bilateral *	29.825	731.745
6) Other IPP	8.313	188.672	Include PX	11.085	108.600
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.741	584.362
C) 1) TPCL Thermal	8.383	185.669	Include PX	12.118	340.078
2) TPCL Hydro	7.025	96.322	Standby	0.000	0.000
3) TPCL Gas	2.474	90.679	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.193	115.604	1) MSEDCL	318.348	7416.583
D) STATE			2) Mumbai Discoms	46.686	1062.323
1) Thermal	148.345	3901.980	TOTAL STATE	365.034	8478.906
(A1+C1+C4+(B1-B6))					
2) Hydro	20.183	291.060			
(A2+C2)					
3) Gas	9.131	204.890			
(A3+B7+C3)					
4) Wind	46.852	1143.057			
6) SOLAR	6.133	102.604			
TOTAL STATE	230.644	5643.591			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	3157	3360	3423	2876
MSPGCL Hydro	207	197	1962	327
MSPGCL Gas	270	280	280	280
MSPGCL Total Generation	3634	3837	5665	3483
Central Sector Receipt	7088	5814	5455	4357
WIND	2199	2217	1884	1879
CPP / IPP Thermal	2365	2358	2557	2267
CPP / IPP Gas	0	0	0	0
SOLAR	724	755	0	0
Exchange with Mumbai	-1332	-1348	-930	-834
MSEDCL DEMAND MET	14678	13633	14631	11152
Load Shedding	0	0	0	0
MSEDCL DEMAND	14678	13633	14631	11152
TPCL GENERATION	796	799	903	545
AEML GENERATION	189	189	251	189
MUMBAI DEMAND	2317	2336	2084	1568
STATE DEMAND MET	16995	15969	16715	12720
STATE DEMAND	16995	15969	16715	12720
Frequency (Hz)	49.99	50.02	49.94	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 15.22 Hrs	49.77 Hz at 18.23 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 24/Aug/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	139.54	0	0
Unit 9	0.00	129.48	0	0
Unit 10	0.00	59.72	0	0
Total	0.00	328.74		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	4.65	80.35	450	0
Unit 5	10.25	178.67	470	355
Total	14.90	259.02		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	29.00	0	0
Unit 4	3.66	82.71	155	150
Unit 5	8.99	204.61	410	345
Unit 6	9.35	171.86	410	360
Unit 7	0.00	44.52	0	0
Unit 8	0.00	161.64	0	0
Unit 9	10.82	229.22	485	400
Total	32.82	923.56		
Paras				
Unit 3	3.74	94.61	175	118
Unit 4	3.79	97.18	177	128
Total	7.53	191.79		
Khaparkheda				
Unit 1	3.40	78.46	165	100
Unit 2	0.00	75.29	0	0
Unit 3	3.94	77.22	180	155
Unit 4	3.75	89.01	175	140
Unit 5	10.67	230.17	490	395
Total	21.76	550.16		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.66	114.21	291	269
Total	6.66	114.21		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.18	23.71	53	46

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.18	23.71		
Koyna				
Stage 1-2	3.36	61.06	515	40
Stage 4	3.49	24.46	981	0
Stage 3	2.46	45.84	320	0
Total	9.31	131.37		
Hydro				
KDPH	0.88	8.08	37	36
VTRNA	0.00	0.00	0	0
TILLARI	0.60	16.62	58	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.45	9.30	40	0
RNGR+BHTSA	0.00	0.41	0	0
BHANDARDRA	0.34	5.99	15	14
ELDARY	0.52	4.98	22	21
SMLHY_PTN	1.06	17.99	45	44
GHATGHAR	0.00	0.00	0	0
Total	3.84	63.37		
Wind				
Total	46.85	1143.06	0	0
Total	46.85	1143.06		
CPP				
APML(Mus)	30.86	663.28	0	0
JSWEL(Mus)	15.88	379.42	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.71	116.07	0	0
Other(Mus)	8.31	188.67	0	0
Total	57.76	1347.44		
SOLAR				
Total	6.13	102.60	0	0
Total	6.13	102.60		
Tata				
Trombay 5	8.38	185.67	416	288
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.38	56.18	64	55
Trombay 7B	1.09	34.50	50	44
Trombay 8	0.00	0.00	0	0
TATA Hydro	7.02	96.32	387	91
Total	17.88	372.67		
AEML				
DTPS U-1&2	5.19	115.60	253	189
Total	5.19	115.60		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	77.01	2253.27	MSPGCL Total	96.82	2562.22
			MSPGCL Thml+Gas	83.66	2367.48	Koyna 1,2 & 4 Total	6.85	85.53
			MSPGCL Hydro	13.16	194.74	State Total	230.64	5643.59

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Aug/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3075	361	281	3717	1730	2516	0	0	4487	4340	-733	11570	0	11570	1732	13302	50.04
2	3049	316	271	3636	1664	2441	0	0	4489	4507	-830	11418	0	11418	1637	13055	50.01
3	2876	327	280	3483	1879	2267	0	0	4500	4357	-834	11152	0	11152	1568	12720	50.01
4	2871	327	271	3469	1842	2260	0	0	4411	4598	-801	11368	0	11368	1513	12881	50.02
5	2951	347	291	3589	1873	2344	0	0	4407	4623	-797	11632	0	11632	1489	13121	50.00
6	3036	473	280	3789	1856	2368	0	0	5095	5226	-762	12477	0	12477	1533	14010	49.99
7	3041	505	271	3817	1766	2401	0	44	6227	6377	-721	13684	0	13684	1579	15263	50.01
8	3056	336	281	3673	1857	2379	0	181	7118	7178	-770	14498	0	14498	1720	16218	50.01
9	3093	199	270	3562	1941	2372	0	459	7259	7641	-935	15040	0	15040	1922	16962	50.01
10	3093	202	290	3585	2050	2375	0	615	7302	7213	-1164	14674	0	14674	2150	16824	49.96
11	3157	207	270	3634	2199	2365	0	724	6859	7088	-1332	14678	0	14678	2317	16995	49.99
12	3222	332	280	3834	2193	2381	0	770	6262	6155	-1382	13951	0	13951	2369	16320	49.99
13	3360	197	280	3837	2217	2358	0	755	6019	5814	-1348	13633	0	13633	2336	15969	50.02
14	3170	227	269	3666	2560	2289	0	722	5587	5457	-1326	13368	0	13368	2266	15634	50.04
15	3232	334	279	3845	2230	2268	0	654	5569	5563	-1267	13293	0	13293	2236	15529	49.99
16	3339	269	270	3878	2432	2383	0	639	5525	5424	-1227	13529	0	13529	2211	15740	50.05
17	3355	282	279	3916	2122	2388	0	365	5832	5956	-1147	13600	0	13600	2149	15749	49.95
18	3415	537	270	4222	1994	2419	0	167	6095	5920	-1016	13706	0	13706	2095	15801	49.98
19	3402	1003	280	4685	1980	2484	0	38	5902	5991	-996	14182	0	14182	2052	16234	49.94
20	3423	1962	280	5665	1884	2557	0	0	5113	5455	-930	14631	0	14631	2084	16715	49.94
21	3445	1549	280	5274	1783	2599	0	0	5262	5081	-864	13873	0	13873	2019	15892	50.01
22	3451	1440	271	5162	1629	2605	0	0	4835	4873	-818	13451	0	13451	1957	15408	50.04
23	3467	931	281	4679	1692	2519	0	0	4872	4827	-796	12921	0	12921	1898	14819	50.02
24	3427	495	282	4204	1479	2425	0	0	4971	4726	-815	12019	0	12019	1854	13873	50.04
MUs	77.01	13.16	6.66	96.82	46.85	57.76	0.00	6.13	134.00	134.39	-23.61	318.35	0.00	318.35	46.69	365.03	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Aug/2020

Position as on 6.30 Hrs of 25/Aug/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U4	300	20/08/2020	15.57		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Parli Unit 8	250	01/06/2020	13.13		Continued.	Zero schedule By MSEDCL	
IPP	Adani U-1	660	03/06/2020	15.02		Continued.	Converted zero schedule from 03.06.2020	
IPP	Adani U-5	660	04/06/2020	12.29		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Aug/2020

Position as on 6.30 Hrs of 25/Aug/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	Adani U-4	660	12/06/2020	10.30		Continued.	Zero Schedule	
AEML	AEML Unit 1	250	27/06/2020	23.55		Continued.	Zero schedule.	
MSPGCL	Chandrapur Unit 7	500	06/08/2020	03.33		Continued.	Sparkling in generator R phase winding.	
MSPGCL	Chandrapur Unit 3	210	11/08/2020	10.00		Continued.	PA Fan problem	
CPP	SWPGL U-3	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
CPP	SWPGL U-4	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Koradi Unit 10	660	13/08/2020	00.08	25/08/2020	03.08	Zero Schedule.	
MSPGCL	Koradi Unit 9	660	14/08/2020	12.28		Continued.	Zero schedule.	
MSPGCL	Koradi Unit-8	660	14/08/2020	13.07		Continued.	Zero schedule.	
MSPGCL	Bhusawal Unit 4	500	15/08/2020	02.21	24/08/2020	10.39	Zero Schedule	
MSPGCL	Chandrapur Unit-8	500	21/08/2020	23.08		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 2	210	23/08/2020	10.07		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 10	660	25/08/2020	04.15		Continued.	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Aug/2020

Statement-VII

Position as on 6.30 Hrs of 25/Aug/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kv 1500MVA ICT @ Akola-II	IntraState	24/08/2020	11.03	24/08/2020	14.00	PO	For Testing Of Circuit Breaker.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	30/07/2020	12.45		Continued.	HT	Over Voltage
Akola Aurangabad(PG) II	InterState	24/08/2020	10.00	24/08/2020	11.25	HT	L/R Outage At Aurangabad PG.
Padgha Tarapur II	InterState	24/08/2020	11.00	24/08/2020	15.16	HT	Testing B-phases current.
Akola Aurangabad(PG) II	InterState	24/08/2020	16.45	24/08/2020	17.13	HT	Over Voltage
BABHALESHWAR - RPL(NASHIK) CKT - 1	IntraState	11/06/2020	10.40		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	07/08/2020	16.19		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/08/2020	23.23		Continued.	HT	Over Voltage
Jaigad-Karad Ckt-II	IntraState	13/08/2020	10.59		Continued.	EO	To attend CB problem
Chandrapur-II - Nanded ckt II	IntraState	15/08/2020	00.40		Continued.	T	Over Voltage
Akola II - RPL(Rattaniindia) Ckt I	IntraState	15/08/2020	11.39		Continued.	T	Over Voltage
karad -kolhapur-I	IntraState	19/08/2020	22.13	24/08/2020	09.53	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	23/08/2020	02.13	24/08/2020	08.56	T	Over Voltage
Dhule- Bableshtar - I	IntraState	23/08/2020	19.46		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	23/08/2020	19.56	24/08/2020	08.58	HT	Over Voltage
Babhaleshtar - Padghe-II	IntraState	23/08/2020	19.58		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	23/08/2020	23.21	24/08/2020	09.15	HT	Over Voltage
Khadka- Deepnagar Ckt 1	IntraState	24/08/2020	17.13	24/08/2020	18.01	HT	Over Voltage
Padghe - Kalwa- I	IntraState	24/08/2020	20.15		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	24/08/2020	20.31		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	24/08/2020	23.21		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement Of Existing 315 MVA ICT By 3*167 MVA ICT.
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	22/08/2020	23.48		Continued.	HT	Over Voltage
400/220 Kv 500 MVA ICT II @Jejuri	IntraState	23/08/2020	23.03	24/08/2020	06.04	HT	Over Voltage
400/220/33 Kv 315 MVA ICT I @Babhleshtar	IntraState	24/08/2020	00.02	24/08/2020	06.34	HT	Over Voltage
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	24/08/2020	00.29	24/08/2020	08.46	HT	Over Voltage
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Kharghar-Borivali ckt II	IntraState	11/08/2020	08.45		Continued.	T	Cable Faulty
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage arrangement HTLS work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage arrangement HTLS work.
Lonikand1 (400 Kv)-Theur I	IntraState	14/08/2020	10.38		Continued.	PO	Replacement of Existing 0.4 DEER Conductor, hardware & Insulator to HTLS Conductor.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower due to Railway crossing

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Aug/2020

Statement-VII

Position as on 6.30 Hrs of 25/Aug/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower due to Railway crossing
BHUGAON WARORA CKT-I	IntraState	22/08/2020	21.49		Continued.	T	'Y' Phase Flashover.
Pusad-Ghatodi	IntraState	23/08/2020	07.37	24/08/2020	13.30	HT	In View Of Outage On 220KV Wardha PG- Pusad Line.
Pusad-WardhaPG(Deoli)	IntraState	23/08/2020	22.54	24/08/2020	02.48	T	Distance Protection, BPH, Z1 106.9KM, 1.38KA.
Pusad-WardhaPG(Deoli)	IntraState	24/08/2020	02.56	24/08/2020	13.27	T	Distance Protection Y B PH.
Miraj-Ichalkaranji I	IntraState	24/08/2020	09.46	24/08/2020	13.27	PO	Quarterly Maintainance Work
Talandge-Hamidwada	IntraState	24/08/2020	10.06	24/08/2020	12.07	PO	Replacement Of Flashover String At Location 42 Y-Phase.
sawangi-Phulambri	IntraState	24/08/2020	11.02	24/08/2020	17.25	PO	Tightening Of Nutbolts At Various Location.
Gadchandur-Ultratech II	IntraState	24/08/2020	13.20	24/08/2020	16.57	T	Distance Protection
Ongc Uran - Jnpt	IntraState	24/08/2020	13.30	24/08/2020	18.50	PO	For Replacement Work Of faulty Distance Relay At 220 kV JNPT End.
New Koyna - Niwali	IntraState	24/08/2020	16.14	24/08/2020	16.45	HT	Sparking Observed On Bus Side Isolator At New Koyna End.
220 KV ICT Outages/Trippings							
220/132Kv 200MVA ICT-II @ Mudshingi	IntraState	24/08/2020	14.15	24/08/2020	18.10	EO	Repairing Of HV Side CB.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage