

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Sep/2018 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	109.280	2588.060	1) Gujrat	1.573	17.493
2) Hydro	27.872	325.971	2) Madhya Pradesh	20.958	374.136
3) Gas	7.192	110.428	3) Chattisgarh	5.880	121.990
Total MSPGCL	144.344	3024.459	4) Maharashtra Net	123.779	2975.016
B) 1) APML	58.844	1320.811	5) Goa (Amona)	-0.220	-7.238
2) JSWEL	28.401	515.706	Total	151.970	3481.397
3) VIPL	14.854	345.742	a) Mumbai Schedule	25.931	533.002
4) RPL(AMT)	6.528	634.211	b) Mumbai Drawl	24.536	555.068
5) WPCL	5.505	95.840	c) MSEDCL Bilateral *	66.488	1232.833
6) PGPL	0.000	0.000	Include PX	29.178	598.374
7) Other IPP	7.807	168.052	d) Mumbai Bilateral *	25.931	533.002
C) 1) TPCL Thermal	16.749	375.130	Include PX	3.390	35.998
2) TPCL Hydro	6.191	101.416	Include Standby	0.000	0.000
3) TPCL Gas	4.305	104.325	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	11.984	267.291	1) MSEDCL	408.479	9639.430
D) STATE			2) Mumbai Discoms	63.767	1403.228
1) Thermal	259.952	6310.843	TOTAL STATE	472.246	11042.658
(A1+C1+C4+(B1-B6))					
2) Hydro	34.063	427.387			
(A2+C2)					
3) Gas	11.497	214.753			
(A3+B6+C3)					
4) Wind	8.577	490.173			
6) SOLAR	6.185	118.107			
TOTAL STATE	320.274	7561.263			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 14 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	4428	4448	4891	4587
MSPGCL Hydro	1638	1791	1559	111
MSPGCL Gas	298	297	302	298
MSPGCL Total Generation	6364	6536	6752	4996
Central Sector Receipt	7760	7546	5933	5199
WIND	218	285	595	365
CPP / IPP Thermal	5100	5110	5129	5042
CPP / IPP Gas	0	0	0	0
SOLAR	829	750	0	0
Exchange with Mumbai	-1403	-1311	-1071	-731
MSEDCL DEMAND MET	18868	18916	17338	14871
Load Shedding	0	0	0	0
MSEDCL DEMAND	18868	18916	17338	14871
TPCL GENERATION	1318	1303	1357	886
R-INFRA GENERATION	499	502	499	500
MUMBAI DEMAND	3220	3116	2927	2117
STATE DEMAND MET	22088	22032	20265	16988
STATE DEMAND	22088	22032	20265	16988
Frequency (Hz)	49.92	49.96	49.93	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.02 Hz at 00.00 Hrs	49.57 Hz at 18.20 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 24/Sep/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.15	0	0
Unit 7	0.00	0.00	0	0
Unit 8	6.94	169.92	322	245
Unit 9	0.00	38.80	0	0
Unit 10	6.91	138.59	320	235
Total	13.85	347.46		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.27	82.76	400	305
Unit 5	8.16	226.30	400	305
Total	16.42	309.07		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	14.31	0	0
Unit 7	5.62	126.68	248	169
Unit 8	3.39	116.94	187	95
Total	9.01	257.93		
Chandrapur				
Unit 3	4.00	93.01	177	142
Unit 4	3.68	93.76	173	114
Unit 5	8.49	154.48	420	295
Unit 6	0.00	114.65	0	0
Unit 7	8.77	132.58	383	355
Unit 8	9.10	168.85	449	345
Unit 9	8.61	208.95	381	343
Total	42.63	966.28		
Paras				
Unit 3	0.00	59.46	0	0
Unit 4	4.62	114.18	207	175
Total	4.62	173.64		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	27.37	0	0
Unit 3	3.42	88.91	147	134
Unit 4	3.45	52.80	170	130
Unit 5	8.14	211.32	390	275
Total	15.01	380.40		
Nasik				
Unit 3	3.86	97.39	169	151
Unit 4	3.89	49.75	177	148
Unit 5	0.00	6.13	0	0
Total	7.75	153.27		
Uran				
All Units	7.19	110.43	309	287
Total	7.19	110.43		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.26	2.49	51	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.26	2.49		
Koyna				
Stage 1-2	7.36	89.01	545	40
Stage 4	14.43	133.60	1000	0
Stage 3	3.82	49.81	320	0
Total	25.61	272.41		
Hydro				
KDPH	0.89	14.29	37	37
VTRNA	0.00	5.30	0	0
TILLARI	0.00	5.98	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.20	7.44	40	0
RNGR+BHTSA	0.29	6.26	15	0
BHANDARDRA	0.08	2.87	15	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.20	8.06	17	6
GHATGHAR	0.60	3.36	125	0
Total	2.26	53.56		
Wind				
Total	8.58	490.17	0	0
Total	8.58	490.17		
CPP				
APML(Mus)	58.84	1320.81	0	0
JSWEL(Mus)	28.40	515.71	0	0
VIPL(Mus)	14.85	345.74	0	0
RPLAMT(Mus)	6.53	634.21	0	0
WPCL(Mus)	5.50	95.84	0	0
Other(Mus)	7.81	168.05	0	0
Total	121.94	3080.36		
SOLAR				
Total	6.18	118.11	0	0
Total	6.18	118.11		
Tata				
Trombay 5	11.32	247.67	478	457
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.71	65.89	116	97
Trombay 7B	1.59	38.43	68	62
Trombay 8	5.43	127.46	242	217
TATA Hydro	6.19	101.42	459	10
Total	27.24	580.87		
R-INFRA				
DTPS U-1&2	11.98	267.29	502	497
Total	11.98	267.29		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	109.28	2588.06	MSPGCL Total	144.34	3024.46
			MSPGCL Thml+Gas	116.47	2698.49	Koyna 1,2 & 4 Total	21.79	222.61
			MSPGCL Hydro	27.87	325.97	State Total	320.27	7561.26

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Sep/2018

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4611	583	306	5500	371	5054	0	0	5276	5167	-860	15232	0	15232	2282	17514	49.95
2	4587	111	298	4996	365	5042	0	0	5117	5199	-731	14871	0	14871	2117	16988	49.98
3	4528	156	307	4991	299	5069	0	0	4874	5315	-633	15041	0	15041	2006	17047	50.01
4	4464	156	307	4927	274	5062	0	0	4923	5441	-545	15159	0	15159	1918	17077	50.00
5	4415	442	309	5166	319	5065	0	0	5018	5274	-532	15292	0	15292	1904	17196	49.97
6	4445	1034	307	5786	325	5060	0	0	5683	5736	-621	16286	0	16286	1991	18277	49.93
7	4469	1357	299	6125	323	5055	0	22	6840	6749	-760	17514	0	17514	2131	19645	49.93
8	4367	1223	309	5899	222	5085	0	181	7274	7605	-905	18087	0	18087	2299	20386	50.00
9	4389	1254	305	5948	227	5082	0	529	6914	7054	-1054	17786	0	17786	2616	20402	49.99
10	4425	1554	303	6282	211	5061	0	634	6812	6811	-1172	17827	0	17827	2954	20781	49.89
11	4485	1449	292	6226	197	5081	0	786	6964	6881	-1348	17823	0	17823	3179	21002	49.97
12	4428	1638	298	6364	218	5100	0	829	7368	7760	-1403	18868	0	18868	3220	22088	49.92
13	4462	1858	288	6608	226	5091	0	834	7450	7445	-1357	18847	0	18847	3181	22028	49.97
14	4448	1791	297	6536	285	5110	0	750	7280	7546	-1311	18916	0	18916	3116	22032	49.96
15	4446	1798	287	6531	441	5097	0	699	7286	7423	-1330	18861	0	18861	3141	22002	49.93
16	4295	1905	297	6497	530	5091	0	538	7291	7543	-1309	18890	0	18890	3130	22020	49.89
17	4335	1473	287	6095	567	5084	0	297	6833	7452	-1257	18238	0	18238	3092	21330	49.96
18	4599	1866	299	6764	568	5108	0	83	6151	5990	-1170	17343	0	17343	3007	20350	49.93
19	4784	1490	289	6563	530	5077	0	3	5593	5627	-1106	16694	0	16694	2950	19644	49.77
20	4891	1559	302	6752	595	5129	0	0	5445	5933	-1071	17338	0	17338	2927	20265	49.93
21	4865	994	302	6161	453	5127	0	0	4946	5559	-1014	16286	0	16286	2819	19105	49.96
22	4866	1039	294	6199	392	5115	0	0	4975	5248	-1001	15953	0	15953	2657	18610	49.98
23	4820	780	305	5905	361	5098	0	0	5085	5585	-1057	15892	0	15892	2614	18506	49.98
24	4856	362	305	5523	278	4999	0	0	5119	5627	-989	15438	0	15438	2514	17952	50.02
MUs	109.28	27.87	7.19	144.34	8.58	121.94	0.00	6.18	146.52	151.97	-24.54	408.48	0.00	408.48	63.76	472.24	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Sep/2018

Position as on 6.30 Hrs of 25/Sep/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-3	660	03/09/2018	05.02		Continued.	Capital overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	Coal Swapping IEPL	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01:12		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
MSPGCL	Koradi Unit 7	210	03/08/2018	15.54		Continued.	Poor Coal Receipt.	
MSPGCL	Khaparkheda Unit 1	210	11/08/2018	23.57		Continued.	Poor coal Receipt	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Koradi Unit 9	660	04/09/2018	12.48		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn due to B0 & U-7	
MSPGCL	Koradi Unit 6	210	09/09/2018	05.52		Continued.	Inspection of Boiler Tubes by R & M Team.	
MSPGCL	Khaparkheda Unit 2	210	10/09/2018	02.35		Continued.	Poor Coal Receipt.	
MSPGCL	Nasik Unit 5	210	11/09/2018	18.45		Continued.	Coal Swapping with DIL	
MSPGCL	Parli Unit 6	250	12/09/2018	06.57		Continued.	Poor Coal receipt	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 6	500	20/09/2018	16:00		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-5	270	21/09/2018	00.05		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-1	270	22/09/2018	00.00		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-3	270	22/09/2018	22.54	25/09/2018	00.00	Furnace Pressure High	
MSPGCL	Koyna Unit 12	80	24/09/2018	16.13	25/09/2018	11.15	Bursting of Coupling Capacitor.	
MSPGCL	Koyna Unit 11	80	24/09/2018	16.13	24/09/2018	23.30	TRANSFORMER STATION TO GENERATION STATION LINE TRIPPED.	
IPP	RPL(AMT) U-3	270	25/09/2018	0.00		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 3	210	25/09/2018	00.02	25/09/2018	16.58	Turbine Relay Fault.	
MSPGCL	Khaparkheda Unit 3	210	25/09/2018	07.22	25/09/2018	12.20	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	25/09/2018	01.19	25/09/2018	05.32	EO	For Tripping COIL Replacement work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	21/09/2018	17.45	24/09/2018	11.32	HT	Over Voltage
Kudus-Padgha(PG) Ckt I	InterState	24/09/2018	11.30	24/09/2018	17.12	PO	Routine Maintenance Work
Parli(MS)-Parli (PG) I	InterState	24/09/2018	18.48	25/09/2018	00.45	HT	For Controlling Over Drawal
Dhule Sar'Sarovar II	InterState	24/09/2018	19.54	25/09/2018	08.40	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	25/09/2018	18.28		Continued.	HT	Over Voltage
Dhule - Bableshwar - li	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Dhule- Bableshwar - I	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Bhusawal-Aurangabad	IntraState	23/09/2018	18.05	24/09/2018	08.56	HT	Over Voltage
Deepnagar Taptitanda	IntraState	24/09/2018	07.09	24/09/2018	19.01	PO	Routine Maintenance Work
N.Koyna-Karad -Ckt II	IntraState	24/09/2018	09.04	24/09/2018	19.21	PO	Routine Maintenance Work
Deepnagar Taptitanda	IntraState	25/09/2018	07.20	25/09/2018	18.42	PO	Replacement Of Dead End And Mid Span Joint.
Warora -IEPL	IntraState	25/09/2018	08.19	25/09/2018	16.38	PO	CB DCRM,CRM.
Padghe - Nagothane - II	IntraState	25/09/2018	09.00	25/09/2018	18.50	PO	At Loc No-4&11 Jumper Replacement work.
Kala Kudus Ckt-II	IntraState	25/09/2018	09.48	25/09/2018	20.50	PO	Replacement Of String Insulator By Polymer.
Bhusawal-Aurangabad	IntraState	25/09/2018	17.52		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220KV 500MVA ICT 2@koradi 2	IntraState	18/09/2018	09.47		Continued.	HT	Emergency Hand Tripped due to R Phase Buchholz alarm Indication on ICT
400/220kv 315 Mva ICT II @Karad	IntraState	25/09/2018	09.05	25/09/2018	19.43	PO	Replacement Of Tertiary Bushing,R&Y PH.
400/220 Kv 315 Mva Ict -2 @New Koyna	IntraState	25/09/2018	16.31	25/09/2018	17.20	T	Oil Temp. High.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Badnera - Deoli (PG)	InterState	24/09/2018	16.30	25/09/2018	06.01	HT	Load Management By WRLDC.
Solapur (Pg) South Solapur I	InterState	24/09/2018	17.23	25/09/2018	06.30	HT	Load Management By WRLDC.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To control line loading.
Kalwa 52B Interconnector CB	IntraState	19/08/2018	18.25		Continued.	HT	Taken In Service To Control Load Of Temghar Ckt At Kalwa 1 S/5 In Lieu Of 220kv Bus Outage At Padgha.
Nerul-Trombay	IntraState	31/08/2018	22.04		Continued.	PO	Conductor Replacement
Badnera Tss-li	IntraState	23/09/2018	15.14	24/09/2018	10.01	T	Bus Bar Prot.Operated,R Phase Jack Bus Insulator String Burst
Mahindra Vehicle-Bridgestone	IntraState	24/09/2018	08.13	24/09/2018	17.45	PO	Stringing Work-Continuous.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Pandharpur - Malinagar	IntraState	24/09/2018	09.01	24/09/2018	10.18	EO	Replace Faulty String Insulator At LOC No-7.
Main Bus @ Lote	IntraState	24/09/2018	09.10	24/09/2018	17.32	PO	Routine Maintenance Work
Main Bus Section @ Ichalkaranji II	IntraState	24/09/2018	09.58	24/09/2018	15.45	PO	Routine Maintenance Work
Loteparshuram- Dasturi Line	IntraState	24/09/2018	10.55	25/09/2018	00.03	PO	Replacement Of Tower at LOC No. 97 of D/C Tower.
Balapur-Akola I	IntraState	24/09/2018	11.07	24/09/2018	16.33	PO	Routine Maintenance Work
Kandalgaon - Koyna	IntraState	24/09/2018	11.40	25/09/2018	17.40	T	Distance Protection, Zone 1, 14.12km From Pophali.
Theur-Phursungi	IntraState	24/09/2018	11.42	24/09/2018	12.42	EO	Attending Hot Spot
Mahad - Pedambe	IntraState	24/09/2018	12.08	24/09/2018	12.40	T	Distance Protection
Mahad-Kandalgaon	IntraState	24/09/2018	12.12	25/09/2018	18.27	T	Over Current Protection
Niwali - Pawas Line	IntraState	24/09/2018	14.55	24/09/2018	15.27	T	Distance Protection
Adlabs - Pedambe	IntraState	24/09/2018	16.13	24/09/2018	17.00	T	Bus Operated Due To Unit 11 Pole Discrepancy Problem.
Pophali - Pedambe II	IntraState	24/09/2018	16.13	24/09/2018	16.55	T	Bus Operated Due To Unit 11 Pole Discrepancy Problem.
Pedambe-Nerle	IntraState	24/09/2018	16.13	24/09/2018	17.08	T	Distance Protection
Main bus section-II @ Pedambe	IntraState	24/09/2018	16.13	24/09/2018	16.30	T	Bus Operated Due To Unit 11 Pole Discrepancy Problem.
Pophali - Nerale	IntraState	24/09/2018	16.15	25/09/2018	21.25	T	Distance Protection, Zone-1, 3.934KM From Pophali.
Nanded - Parli Ext. Ckt II	IntraState	24/09/2018	20.34	24/09/2018	23.03	PO	Attend Sparking on Isolator.
Kalwa - Mulund 2	IntraState	25/09/2018	06.30	25/09/2018	09.24	T	Distance Protection, Zone-1, 22KV CT Burst below the Line.
OSMANABAD BARSHI	IntraState	25/09/2018	09.14	25/09/2018	12.06	PO	Quarterly Maintanance Work
khaparkheda-Khaparkheda(new)-I	IntraState	25/09/2018	09.38	25/09/2018	15.03	PO	B-PH Wave Trap Jumper Recrimping Work.
Loteparshuram- Dasturi Line	IntraState	25/09/2018	10.05	25/09/2018	17.15	PO	For Dismantling Of Tower.
Dhule - Malegaon	IntraState	25/09/2018	12.40	25/09/2018	13.58	T	Distance Protection, Zone-1, B PH. 1.6KM, 14.8KA.
Kharepatan -Pawas Line	IntraState	25/09/2018	12.50	25/09/2018	13.08	T	Distance Protection, Zone-1, Y PH. 39KM, 1.03KA.
Phursungi-Parvati	IntraState	25/09/2018	13.30	25/09/2018	15.20	PO	Fixing Of Repair Sleeve In Span Between LOC 81to 82.
Butibori-Butibori Rly Tss	IntraState	25/09/2018	15.54	25/09/2018	18.52	T	Distance Protection Zone 1 R Phase
Koradi-Butibori Rly Tss	IntraState	25/09/2018	15.54	25/09/2018	16.59	T	Distance Protection Zone 1 R Phase
New Koyna - Loteparshuram	IntraState	25/09/2018	17.12	25/09/2018	17.46	T	Over Load.
Mudshingi-Wathar	IntraState	25/09/2018	18.27	25/09/2018	18.45	T	Distance Protection, LOC-10, Y-PH String Bursted & Replaced By Polymer String.
Deoli(Pgcil)-Badnera	IntraState	25/09/2018	19.07		Continued.	HT	System Constraint By WR.
220 KV ICT Outages/Trippings							
220/33kv 125 Mva Transformer 4 @Ghodbunder R/S	IntraState	24/09/2018	09.26		Continued.	PO	Isolator Earth Switch Shifting Work Of TF.
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	24/09/2018	11.25	24/09/2018	18.24	PO	Routine Maintenance Work
220/100 Kv 200 Mva Bhel Ict 1 @Kalwa	IntraState	25/09/2018	10.24	25/09/2018	11.31	EO	Attending Oil Leakage Of OLTC Conservator.
220/132 Kv Ict 1 200 Mva @Parbhani	IntraState	25/09/2018	11.52		Continued.	PO	Repairing / Servicing Of Intank OLTC.
132 KV LINE Outages/Trippings							
Sawangi - Cosmofilms	IntraState	23/09/2018	21.14	24/09/2018	03.02	T	Distance Protection Zone 1 Y-E
Jalna (220)-Ambad	IntraState	24/09/2018	03.11	24/09/2018	03.25	T	Distance Protection
Gadchiroli - Vayunandana	IntraState	24/09/2018	05.25	24/09/2018	05.40	T	Backup Protection Operated O/C & E/F.
Kalmeshwar-Saoner 1	IntraState	24/09/2018	06.02	24/09/2018	06.23	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Nilanga - Omerga	IntraState	25/09/2018	02.06	25/09/2018	02.40	T	Backup Protection Operated O/C and E/F
Harangul - Nilanga	IntraState	25/09/2018	02.06	25/09/2018	02.25	T	Distance Protection Zone 1 R & B Phase
Chikhali-Deulgaon Mahi	IntraState	25/09/2018	18.05	25/09/2018	18.14	T	Distance Protection Zone 1