

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Sep/2019 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	73.031	1941.824	1) Gujrat	15.628	322.525
2) Hydro	17.735	386.290	2) Madhya Pradesh	6.043	79.852
3) Gas	6.154	63.043	3) Chattisgarh	3.500	65.020
Total MSPGCL	96.920	2391.157	4) Maharashtra	144.476	2823.730
B) 1) APML	45.163	1170.122	5) Goa (Amona)	-0.440	-15.598
2) JSWEL	22.693	493.871	Total	169.207	3275.529
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.177	596.349
4) RPL(AMT)	23.716	498.223	b) Mumbai Drawl	32.525	751.031
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	17.599	359.673
6) Other IPP	3.269	66.128	Include PX	5.524	53.061
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.177	593.874
C) 1) TPCL Thermal	13.878	307.445	Include PX	12.771	272.746
2) TPCL Hydro	4.828	105.369	Standby	0.000	2.475
3) TPCL Gas	2.870	10.754	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.103	206.909	1) MSEDCL	338.666	8025.197
D) STATE			2) Mumbai Discoms	64.204	1381.499
1) Thermal	191.853	4684.522	TOTAL STATE	402.870	9406.696
(A1+C1+C4+(B1-B6))					
2) Hydro	22.563	491.659			
(A2+C2)					
3) Gas	9.024	73.797			
(A3+B7+C3)					
4) Wind	6.068	778.577			
6) SOLAR	4.155	102.621			
TOTAL STATE	233.663	6131.176			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	3253	3125	3052	3093
MSPGCL Hydro	258	1055	1536	262
MSPGCL Gas	250	247	250	261
MSPGCL Total Generation	3761	4427	4838	3616
Central Sector Receipt	8343	7438	7156	5845
WIND	207	245	147	313
CPP / IPP Thermal	3952	3535	4664	3901
CPP / IPP Gas	0	0	0	0
SOLAR	525	456	0	0
Exchange with Mumbai	-1922	-1808	-1167	-1069
MSEDCL DEMAND MET	14866	14293	15638	12606
Load Shedding	0	0	0	0
MSEDCL DEMAND	14866	14293	15638	12606
TPCL GENERATION	898	927	1311	538
AEML GENERATION	374	374	498	374
MUMBAI DEMAND	3194	3109	2976	1981
STATE DEMAND MET	18060	17402	18614	14587
STATE DEMAND	18060	17402	18614	14587
Frequency (Hz)	50.02	50.02	50.04	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 13.01 Hrs	49.85 Hz at 00.03 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 24/Sep/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	10.19	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	6.63	132.51	300	225
Unit 10	5.96	104.63	301	190
Total	12.59	247.34		
Bhusawal				
Unit 3	0.00	2.92	0	0
Unit 4	7.73	225.28	455	300
Unit 5	0.00	0.00	0	0
Total	7.73	228.20		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	85.81	0	0
Unit 7	5.00	117.06	248	130
Unit 8	0.00	0.00	0	0
Total	5.00	202.87		
Chandrapur				
Unit 3	2.22	12.45	138	0
Unit 4	2.49	68.41	122	65
Unit 5	0.00	152.04	0	0
Unit 6	6.63	158.42	300	240
Unit 7	0.00	0.00	0	0
Unit 8	8.04	146.79	360	315
Unit 9	7.01	170.69	340	220
Total	26.38	708.80		
Paras				
Unit 3	3.52	57.36	165	130
Unit 4	0.00	0.00	0	0
Total	3.52	57.36		
Khaparkheda				
Unit 1	0.00	34.17	0	0
Unit 2	0.00	3.77	0	0
Unit 3	3.36	64.74	150	134
Unit 4	2.14	81.55	145	0
Unit 5	5.19	164.54	225	205
Total	10.68	348.76		
Nasik				
Unit 3	1.92	58.13	149	0
Unit 4	3.22	52.70	147	96
Unit 5	1.98	37.69	158	10
Total	7.12	148.51		
Uran				
All Units	6.15	63.04	272	247
Total	6.15	63.04		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.27	19.69	54	50

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.27	19.69		
Koyna				
Stage 1-2	6.40	74.84	550	40
Stage 4	6.52	166.59	622	0
Stage 3	2.84	70.90	240	0
Total	15.76	312.34		
Hydro				
KDPH	0.63	19.36	37	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	12.86	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.18	8.64	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.34	8.27	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.41	19.87	18	16
GHATGHAR	0.42	4.96	250	0
Total	1.98	73.96		
Wind				
Total	6.07	778.58	0	0
Total	6.07	778.58		
CPP				
APML(Mus)	45.16	1170.12	0	0
JSWEL(Mus)	22.69	493.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	23.72	498.22	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	3.27	66.13	0	0
Total	94.84	2228.34		
SOLAR				
Total	4.16	102.62	0	0
Total	4.16	102.62		
Tata				
Trombay 5	9.05	194.47	473	314
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.06	6.72	116	0
Trombay 7B	0.82	4.04	67	0
Trombay 8	4.83	112.98	209	197
TATA Hydro	4.83	105.37	453	16
Total	21.58	423.57		
AEML				
DTPS U-1&2	10.10	206.91	499	373
Total	10.10	206.91		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	73.03	1941.82	MSPGCL Total	96.92	2391.16
			MSPGCL Thml+Gas	79.18	2004.87	Koyna 1,2 & 4 Total	12.92	241.43
			MSPGCL Hydro	17.74	386.29	State Total	233.66	6131.18

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Sep/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3121	347	252	3720	453	4175	0	0	5920	5927	-1023	13252	0	13252	2300	15552	49.99
2	3101	165	252	3518	291	3953	0	0	5812	5941	-1002	12701	0	12701	2114	14815	50.02
3	3093	262	261	3616	313	3901	0	0	5727	5845	-1069	12606	0	12606	1981	14587	49.99
4	3072	320	252	3644	368	3908	0	0	5916	5966	-1025	12861	0	12861	1909	14770	50.03
5	3075	76	272	3423	283	3938	0	0	6371	6328	-1023	12949	0	12949	1910	14859	50.04
6	3128	116	251	3495	208	3982	0	0	6987	7289	-1102	13872	0	13872	2008	15880	49.98
7	3195	637	253	4085	134	4028	0	11	7337	7396	-959	14695	0	14695	2187	16882	50.01
8	3244	569	262	4075	151	4020	0	139	7708	7851	-1040	15196	0	15196	2383	17579	50.01
9	3195	233	250	3678	189	3946	0	290	7990	8192	-1394	14901	0	14901	2680	17581	49.99
10	3253	248	270	3771	215	3944	0	446	8219	8435	-1748	15063	0	15063	2987	18050	50.00
11	3253	258	250	3761	207	3952	0	525	8335	8343	-1922	14866	0	14866	3194	18060	50.02
12	3267	655	247	4169	298	3645	0	592	7911	7698	-1960	14442	0	14442	3264	17706	50.03
13	3254	1136	269	4659	251	3512	0	441	7341	7126	-1893	14096	0	14096	3199	17295	50.04
14	3208	1153	248	4609	209	3540	0	495	7027	7220	-1790	14283	0	14283	3071	17354	50.04
15	3125	1055	247	4427	245	3535	0	456	7297	7438	-1808	14293	0	14293	3109	17402	50.02
16	2956	859	267	4082	231	3558	0	457	7525	7575	-1797	14106	0	14106	3124	17230	49.96
17	2834	1067	248	4149	264	3688	0	226	7227	7554	-1741	14140	0	14140	3114	17254	50.02
18	2811	1219	248	4278	246	3922	0	76	7424	7166	-1485	14203	0	14203	3063	17266	50.03
19	3072	1390	270	4732	229	4528	0	1	6886	6838	-1265	15063	0	15063	3010	18073	50.02
20	3052	1536	250	4838	147	4664	0	0	6903	7156	-1167	15638	0	15638	2976	18614	50.04
21	2889	1205	249	4343	197	4333	0	0	6661	6902	-1211	14564	0	14564	2829	17393	50.03
22	2677	1367	262	4306	316	4180	0	0	6377	6596	-1053	14345	0	14345	2704	17049	50.04
23	2545	958	252	3755	334	4020	0	0	6472	6310	-979	13440	0	13440	2600	16040	50.02
24	2611	904	272	3787	289	3969	0	0	6433	6115	-1069	13091	0	13091	2488	15579	50.01
MUs	73.03	17.73	6.15	96.92	6.07	94.84	0.00	4.16	167.81	169.21	-32.52	338.67	0.00	338.67	64.20	402.87	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Sep/2019

Position as on 6.30 Hrs of 25/Sep/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 8	250	04/06/2019	00.00		Continued.	Zero Schedule (converted to AOH from 25/06/2019)	
MSPGCL	Koyana STG- IV Unit - 1	250	18/07/2019	14.30		Continued.	Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019 for 60Days)	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Koradi Unit-8	660	25/08/2019	00.01		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 5	500	25/08/2019	00.13		Continued.	Capital Overhaul	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
IPP	Dhariwal	300	01/07/2019	00.01		Continued.	No Schedule.	
MSPGCL	Koyana Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(converted to zero schedule from 12.09.2019 at 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
TPC-G	Trombay 7B	60	03/09/2019	10.42	24/09/2019	11.23	Gas shortage due to fire at ONGC.	
TPC-G	Trombay 7A	120	03/09/2019	10.56	24/09/2019	05.47	Gas shortage due to fire at ONGC.	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule	
MSPGCL	Nasik Unit 5	210	12/09/2019	16.20	24/09/2019	06:40	HP control valve problem.(converted to zero schedule from 16/09/2019 at 19:00 hrs.)	
MSPGCL	Khaparkheda Unit 1	210	13/09/2019	14.05		Continued.	Poor Coal	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Sep/2019

Position as on 6.30 Hrs of 25/Sep/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	Adani U-1	660	19/09/2019	01.43		Continued.	Due to Low Coal Stock.	
MSPGCL	Parli Unit 6	250	19/09/2019	06.24		Continued.	Poor Coal Receipt.	
MSPGCL	Khaparkheda Unit 2	210	22/09/2019	02.16		Continued.	Furnace Pressure High	
MSPGCL	Uran Unit 5	108	23/09/2019	11.40	25/09/2019	19.49	Impedance Prot.Relay	
MSPGCL	Chandrapur Unit 5	500	24/09/2019	00.00		Continued.	Poor Coal Receipt	
MSPGCL	Nasik Unit 3	210	24/09/2019	13.45		Continued.	poor coal Receipt.	
MSPGCL	Khaparkheda Unit 4	210	24/09/2019	15.30		Continued.	Coal Shortage	
MSPGCL	Koyna STG-IV Unit-2	250	24/09/2019	16.35	24/09/2019	21.10	Safety bolt rupture fault	
MSPGCL	Chandrapur Unit 3	210	24/09/2019	22.16		Continued.	Poor Coal Receipt.	
MSPGCL	Khaparkheda Unit 5	500	25/09/2019	09.34		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 9	500	25/09/2019	20.23	25/09/2019	23.26	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2019

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	24/09/2019	17.43		Continued.	PO	Tower Height Rise work
Chandrapur - Padghe Hvdc Pole 1	IntraState	24/09/2019	17.56		Continued.	PO	Tower Height Rise work
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	10/09/2019	20.20		Continued.	HT	Over Voltage
Koradi Satpur	InterState	23/09/2019	15.55	24/09/2019	09.13	T	Distance Protection
Akola Wardha I	InterState	24/09/2019	11.47	24/09/2019	18.04	EO	Replacement Of Flash Cover Insulator String.
Akola Wardha I	InterState	24/09/2019	17.40	24/09/2019	18.04	PO	Isolator problem.
Chandrapur-II - Nanded ckt II	IntraState	16/09/2019	08:57		Continued.	PO	Replacement of Broken Spacer cum Damper.(RFC at 18:50 hrs)
Khadka-Aurangabad (Waluj)	IntraState	21/09/2019	19.32	24/09/2019	11.24	HT	Over Voltage
N.Koyna-Karad -Ckt II	IntraState	24/09/2019	04.39	24/09/2019	11.38	T	Distance Protection
Akola II - Akola I Ckt-II	IntraState	24/09/2019	11.30	24/09/2019	15.54	PO	Annual Maintenance Of Bay Equipment's.
Kharghar-Talegaon(PG)	IntraState	24/09/2019	11.43	24/09/2019	12.14	PO	Relay Testing Work.
New Koyna - Koyna Stage IV-II	IntraState	24/09/2019	14.00	25/09/2019	06.28	EO	To attend Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	24/09/2019	18.12		Continued.	HT	Over Voltage
Jejuri- Koynastage-IV	IntraState	25/09/2019	06.08	25/09/2019	18.10	T	Distance Protection
Lonikand I - Koyna stage-IV	IntraState	25/09/2019	11.27	25/09/2019	20.19	T	Trial taken but tripped again on distance protection.
Lonikand I - Koyna stage-IV	IntraState	25/09/2019	21.13		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 Kv 315 Mva Ict -2 @New Koyna	IntraState	23/09/2019	08.15	24/09/2019	00.32	EO	To attend Hot Spot and Faulty String replacement work
400/220/33kv 315MVA ICT-I @Lonikand	IntraState	23/09/2019	23.21	24/09/2019	02.35	HT	Smoke observed from ICT-I
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
PARLY (PG) - OLD GCR PARLI	InterState	24/09/2019	09.40	24/09/2019	19.05	PO	Conductor Stringing work.
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	T	Distance Protection
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Parli 3 (Old Gcr)-Girwali Ckt 2	IntraState	24/09/2019	10.02	24/09/2019	18.42	HT	Conductor Stringing Work,On Parli-Harangul LILo at Parli End.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	24/09/2019	10.03	24/09/2019	18.50	HT	Conductor Stringing Work,On Parli-Harangul LILo at Parli End.
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	24/09/2019	10.04	24/09/2019	18.54	HT	Conductor Stringing Work,On Parli-Harangul LILo at Parli End.
Ekalahara(Ocr)(Nashik)-Navasari II	IntraState	24/09/2019	10.35	24/09/2019	19:49	T	Distance Protection
Dhule-Amalner(220kv)	IntraState	24/09/2019	10.35	24/09/2019	15.21	PO	replacement of B PH jump from wave trap to line side.
UTECH SUGAR BABHALESHWAR	IntraState	24/09/2019	10.40	24/09/2019	16.56	PO	CT C & Tan Delta Testing.
satara MIDC- Malharpeth	IntraState	24/09/2019	11.33	24/09/2019	14:33	EO	Attending Hot Spot At Isolator.
Mahad - Pedambe	IntraState	24/09/2019	12.10	24/09/2019	18.45	T	Distance Protection
Warora - Wardha	IntraState	24/09/2019	16.11	24/09/2019	17.53	PO	Disconnection of IVT from bay.
Kandalgaon-POSCO	IntraState	24/09/2019	17.25	24/09/2019	19.30	T	Due To Heavy Lightening.
Kandalgaon - Bhira	IntraState	24/09/2019	18.18	25/09/2019	06.00	T	Due To Heavy Lightening.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2019

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Nalasopara-Boisar	IntraState	24/09/2019	20.03	24/09/2019	21.34	EO	To attend Hot Spot
Kharghar-Borivali ckt II	IntraState	24/09/2019	21.54	25/09/2019	02:08	T	Distance Protection
Pophali - Pedambe II	IntraState	25/09/2019	09.50	25/09/2019	10.05	PO	Breaker Maintenance Work.
Bableshtar - Bhenda	IntraState	25/09/2019	11.25	25/09/2019	17.07	PO	Distance & Backup Protection Testing.
Chandrapur GCR - Wani	IntraState	25/09/2019	12.21	25/09/2019	18.22	PO	Bus Extension Work.
Paranda-Barshi	IntraState	25/09/2019	13.22	25/09/2019	17.19	PO	Attending Hot Spot At Barshi End.
Adlabs - Pedambe	IntraState	25/09/2019	13.28	25/09/2019	15.03	T	Distance Protection
Vankuswade - Kdph	IntraState	25/09/2019	14.00	25/09/2019	16.30	EO	Attending Hot Spot
Kandalgaon - Bhira	IntraState	25/09/2019	14.45	25/09/2019	18.30	PO	Disk Insulator Replacement Work.
Nagothane - ACCIL	IntraState	25/09/2019	15.30	25/09/2019	17.35	EO	CT Hot Spot Attending Work B-Phase.
Nanded-Parbhani	IntraState	25/09/2019	19.28	25/09/2019	20.40	T	Tripped On PDR.
Nashik-Padgha	IntraState	25/09/2019	20.26	25/09/2019	22.19	T	To Control The Load Of Nashik Bableshtar-1.
220 KV ICT Outages/Trippings							
220/33kV 125 MVA T/F-III @ Goregaon	IntraState	24/09/2019	10.22	24/09/2019	12.49	PO	CB Motor Maintenance Work.
220/132 Kv 200mva Cgl Ptr No 3 @Chinchwad	IntraState	24/09/2019	11.07	24/09/2019	18.18	PO	Annual Maintenance Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage