

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Sep/2020 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	105.968	2932.180	1) Gujrat	15.309	263.284
2) Hydro	11.722	189.566	2) Madhya Pradesh	9.001	160.985
3) Gas	2.816	132.385	3) Chattisgarh	6.570	115.170
Total MSPGCL	120.506	3254.131	4) Maharashtra	103.935	3133.391
B) 1) APML	53.512	1012.170	5) Goa (Amona)	-1.744	-24.280
2) JSWEL	18.090	421.922	Total	133.071	3648.550
3) VIPL	0.000	0.000	a) Mumbai Schedule	20.095	597.129
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	22.606	660.135
5) WPCL	2.625	62.019	c) MSEDCL Bilateral *	27.806	704.128
6) Other IPP	7.496	178.889	Include PX	1.274	108.160
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	20.095	597.129
C) 1) TPCL Thermal	8.349	193.651	Include PX	13.399	414.203
2) TPCL Hydro	5.270	98.525	Standby	0.000	0.000
3) TPCL Gas	3.576	95.566	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.001	148.204	1) MSEDCL	335.852	8340.294
D) STATE			2) Mumbai Discoms	49.802	1196.080
1) Thermal	206.041	4949.035	TOTAL STATE	385.654	9536.374
(A1+C1+C4+(B1-B6))					
2) Hydro	16.992	288.091			
(A2+C2)					
3) Gas	6.392	227.951			
(A3+B7+C3)					
4) Wind	17.453	293.282			
6) SOLAR	5.705	129.466			
TOTAL STATE	252.583	5887.825			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	4316	4669	4611	4295
MSPGCL Hydro	273	841	1871	130
MSPGCL Gas	117	116	118	119
MSPGCL Total Generation	4706	5626	6600	4544
Central Sector Receipt	6614	5369	5010	4474
WIND	785	714	935	1011
CPP / IPP Thermal	3664	3672	3820	2899
CPP / IPP Gas	0	0	0	0
SOLAR	599	83	0	0
Exchange with Mumbai	-1193	-895	-735	-806
MSEDCL DEMAND MET	15175	14569	15630	12122
Load Shedding	0	0	0	0
MSEDCL DEMAND	15175	14569	15630	12122
TPCL GENERATION	645	906	1084	479
AEML GENERATION	452	498	499	370
MUMBAI DEMAND	2290	2299	2318	1655
STATE DEMAND MET	17465	16868	17948	13777
STATE DEMAND	17465	16868	17948	13777
Frequency (Hz)	50.00	49.87	49.98	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.11 Hz at 20.01 Hrs	49.64 Hz at 18.42 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 24/Sep/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.35	261.28	488	362
Unit 9	10.13	258.68	470	330
Unit 10	0.00	186.39	0	0
Total	20.48	706.36		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	170.22	0	0
Unit 5	9.42	226.52	500	350
Total	9.42	396.74		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	19.70	0	0
Unit 7	0.00	30.40	0	0
Unit 8	0.00	64.10	0	0
Total	0.00	114.20		
Chandrapur				
Unit 3	3.75	92.00	163	135
Unit 4	3.63	64.26	158	135
Unit 5	8.97	223.03	405	310
Unit 6	8.96	84.67	400	350
Unit 7	0.00	0.00	0	0
Unit 8	9.74	241.99	445	360
Unit 9	9.81	237.17	460	360
Total	44.86	943.13		
Paras				
Unit 3	4.36	102.63	200	150
Unit 4	3.84	97.52	217	0
Total	8.20	200.15		
Khaparkheda				
Unit 1	3.12	79.90	150	110
Unit 2	3.33	77.56	155	125
Unit 3	3.38	89.27	150	130
Unit 4	3.85	91.86	170	150
Unit 5	9.31	232.99	430	340
Total	23.00	571.59		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	2.82	132.38	120	105
Total	2.82	132.38		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.15	28.92	54	27

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.15	28.92		
Koyna				
Stage 1-2	3.68	63.74	490	40
Stage 4	2.47	44.54	752	0
Stage 3	1.63	27.43	320	0
Total	7.78	135.71		
Hydro				
KDPH	0.81	1.90	35	17
VTRNA	0.00	2.80	0	0
TILLARI	0.69	9.07	58	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.48	8.48	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	3.38	0	0
ELDARY	0.53	12.36	22	22
SMLHY_PTN	0.68	9.69	29	28
GHATGHAR	0.75	6.18	125	0
Total	3.94	53.86		
Wind				
Total	17.45	293.28	0	0
Total	17.45	293.28		
CPP				
APML(Mus)	53.51	1012.17	0	0
JSWEL(Mus)	18.09	421.92	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.62	62.02	0	0
Other(Mus)	7.50	178.89	0	0
Total	81.72	1675.00		
SOLAR				
Total	5.70	129.47	0	0
Total	5.70	129.47		
Tata				
Trombay 5	8.35	193.65	444	294
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.18	59.92	118	64
Trombay 7B	1.40	35.64	67	50
Trombay 8	0.00	0.00	0	0
TATA Hydro	5.27	98.52	459	2
Total	17.20	387.74		
AEML				
DTPS U-1&2	10.00	148.20	499	368
Total	10.00	148.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	105.97	2932.18	MSPGCL Total	120.51	3254.13
			MSPGCL Thml+Gas	108.78	3064.56	Koyna 1,2 & 4 Total	6.15	108.28
			MSPGCL Hydro	11.72	189.57	State Total	252.58	5887.82

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Sep/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4336	125	120	4581	1160	3029	0	0	4642	4494	-862	12402	0	12402	1746	14148	50.01
2	4295	130	119	4544	1011	2899	0	0	4492	4474	-806	12122	0	12122	1655	13777	50.00
3	4218	125	118	4461	929	2954	0	0	4421	4662	-737	12269	0	12269	1589	13858	50.01
4	4180	140	119	4439	858	3018	0	0	4469	4684	-684	12315	0	12315	1545	13860	50.01
5	4162	130	119	4411	799	3065	0	0	5054	5033	-663	12645	0	12645	1523	14168	50.00
6	4425	230	119	4774	825	3340	0	0	5224	5434	-706	13667	0	13667	1567	15234	49.99
7	4487	436	119	5042	614	3687	0	24	5512	5657	-712	14312	0	14312	1630	15942	49.96
8	4477	823	119	5419	700	3625	0	171	5914	5986	-716	15185	0	15185	1790	16975	50.00
9	4260	481	119	4860	672	3643	0	425	6394	6590	-926	15264	0	15264	2031	17295	50.00
10	4316	273	117	4706	785	3664	0	599	6846	6614	-1193	15175	0	15175	2290	17465	50.00
11	4177	238	115	4530	796	3509	0	722	7009	6588	-1429	14716	0	14716	2478	17194	50.00
12	4115	223	114	4452	690	3190	0	761	6786	6824	-1412	14505	0	14505	2538	17043	49.96
13	4211	310	105	4626	587	3170	0	766	6406	6360	-1396	14113	0	14113	2514	16627	49.96
14	4217	225	117	4559	484	3183	0	714	6037	6190	-1333	13797	0	13797	2427	16224	49.96
15	4357	430	116	4903	564	3176	0	624	6043	6186	-1343	14110	0	14110	2417	16527	49.91
16	4481	314	116	4911	598	3192	0	514	6126	6066	-1336	13945	0	13945	2389	16334	49.98
17	4583	628	117	5328	478	3308	0	299	5940	5815	-1171	14057	0	14057	2344	16401	49.98
18	4669	841	116	5626	714	3672	0	83	5615	5369	-895	14569	0	14569	2299	16868	49.87
19	4612	1573	117	6302	823	3793	0	3	5226	5075	-779	15217	0	15217	2323	17540	49.78
20	4611	1871	118	6600	935	3820	0	0	5153	5010	-735	15630	0	15630	2318	17948	49.98
21	4762	1054	119	5935	739	3839	0	0	4815	4847	-689	14671	0	14671	2220	16891	50.03
22	4740	774	119	5633	546	3839	0	0	4691	4954	-582	14390	0	14390	2128	16518	50.00
23	4662	219	120	5001	543	3731	0	0	5192	5139	-726	13688	0	13688	2050	15738	49.99
24	4615	129	119	4863	603	3377	0	0	5169	5020	-775	13088	0	13088	1991	15079	50.00
MUs	105.97	11.72	2.82	120.51	17.45	81.72	0.00	5.70	133.18	133.07	-22.61	335.85	0.00	335.85	49.80	385.65	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Sep/2020

Position as on 6.30 Hrs of 25/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	06/08/2020	03.33		Continued.	Sparkling in generator R phase winding.	
CPP	SWPGL U-4	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
CPP	SWPGL U-3	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
IPP	Adani U-2	660	01/09/2020	19.41		Continued.	Air pre-heater PA Bellow leakage.	
IPP	JSW (J) U3	300	09/09/2020	10.56		Continued.	CW Duct leakage	
MSPGCL	Parli Unit 6	250	11/09/2020	23.55		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	14/09/2020	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	14/09/2020	20.45		Continued.	Zero Schedule.	
MSPGCL	Koyna STG- IV Unit - 1	250	20/09/2020	12.00		Continued.	CT Maintenance Work.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Sep/2020

Position as on 6.30 Hrs of 25/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 4	500	20/09/2020	20.14		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Uran Unit 6	108	21/09/2020	00.14		Continued.	For Boiler RLA Work & Validity Extension.	
MSPGCL	Koradi Unit 10	660	21/09/2020	17.33		Continued.	conveyor Belt Problem.	
MSPGCL	Paras Unit 4	250	24/09/2020	08.13	24/09/2020	10.27	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 24/Sep/2020

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
Ektuni-Akola II Ckt 2	IntraState	24/09/2020	11.46	24/09/2020	19.07	PO	Diagnostic Testing & Routine Maintenance.
400 KV LINE Outages/Tripping							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Akola Wardha I	InterState	03/09/2020	11.24	24/09/2020	21.26	PO	Work At Wardha PG End.
Chandrapur Bhadravati III	InterState	21/09/2020	03.26	24/09/2020	23.54	PO	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in ICT-2 and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
Chandrapur Bhadravati IV	InterState	21/09/2020	04.27		Continued.	PO	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in ICT-2 and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
Dhule Khandwa II	InterState	23/09/2020	17.54		Continued.	HT	Over Voltage
Dabhol Nagothane II	InterState	24/09/2020	14.10	24/09/2020	19.49	PO	String Replacement Work.
Akola II - RPL(Rattanindia) Ckt I	IntraState	13/09/2020	17.56	24/09/2020	10.24	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	21/09/2020	21.54	24/09/2020	11.19	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	22/09/2020	20.06	24/09/2020	09.57	HT	Over Voltage
Padghe - Nagothane - II	IntraState	23/09/2020	12.32		Continued.	EO	To attend Hot Spot(RFC 16.36Hrs)
Padghe - Kalwa- I	IntraState	23/09/2020	23.15	24/09/2020	08.11	HT	Over Voltage
Lonikand I - Koyana stage-IV	IntraState	23/09/2020	23.28	24/09/2020	08.16	HT	Over Voltage
karad -kolhapur-I	IntraState	24/09/2020	00.20	24/09/2020	08.26	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	24/09/2020	19.54		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	24/09/2020	23.14		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	24/09/2020	23.16		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	24/09/2020	23.40		Continued.	HT	Over Voltage
400 KV ICT Outages/Tripping							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220kv 315 Mva ICT II @Karad	IntraState	24/09/2020	10.11	24/09/2020	19.55	PO	Erection Of 220KV New Cross Arm near ICT-2 Gantry Tower For RRS(Rapid Restoration Scheme) Under Scheme.
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	24/09/2020	10.50	24/09/2020	17.55	PO	Testing Work
220 KV LINE Outages/Tripping							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2020

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Lonikand1 (400 Kv)-Theur I	IntraState	14/08/2020	10.38		Continued.	PO	Replacement of Existing 0.4 DEER Conductor, hardware & Insulator to HTLS Conductor.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Uran - Jnpt	IntraState	18/09/2020	13.07		Continued.	PO	Removal of existing E/W and string of OPGW wire
Sawantwadi-Bidri	IntraState	23/09/2020	23.27	24/09/2020	09.40	HT	Over Voltage
Hinjawadi I- Chinchwad	IntraState	24/09/2020	07.17	24/09/2020	21.04	HT	For Load Management HTLS Work.
Lonikand1 (400 Kv)-Theur II	IntraState	24/09/2020	07.40	24/09/2020	20.45	PO	Replacement of Existing 0.4 ACSR Conductor, hardware & Insulator to HTLS Conductor.
220kv Halkarni- Tillary	IntraState	24/09/2020	09.22	24/09/2020	17.20	PO	Insulator Cleaning work.
Koradi-Ambazari-I	IntraState	24/09/2020	10.23	24/09/2020	15.35	PO	For CT & CC Tan Delta Measurement.
Kalwa - Siemens	IntraState	24/09/2020	10.28	24/09/2020	15.31	PO	To attend consumer request due to Low SF6 Gas Pressure alarm on Kalwa Siemens line at GIS substation.
Pedambe-Nerle	IntraState	24/09/2020	11.20		Continued.	PO	replacement of damaged conductor at Loc Nos. 39, 40, 41, 66 on urgent basis.
Nanded-Ghatodi	IntraState	24/09/2020	11.23	24/09/2020	13.50	PO	For Replacement Of B PH Flash over String at loc No.110.
Apta - Tambati	IntraState	24/09/2020	12.15	24/09/2020	14.56	PO	Routine maintenance work & tree cutting work.
SICOM - SAIL	IntraState	24/09/2020	13.40	24/09/2020	16.44	PO	For Commissioning Of AMR project panel (meter) & Diagnostic Testing.
SIEMENS - RELIANCE GIS	IntraState	24/09/2020	15.45	24/09/2020	17.47	PO	To attend consumer request due to Low SF6 Gas Pressure alarm on Siemens- RCP line at GIS substation.
WARDHA - WARDHA (PG) (Deoli)	IntraState	24/09/2020	18.50	24/09/2020	21.31	HT	To Control Load.
Waluj - Chitegaon I	IntraState	24/09/2020	19.00	24/09/2020	21.30	HT	To control load.
Sawantwadi-Bidri	IntraState	24/09/2020	23.10		Continued.	HT	Over Voltage
220 KV ICT Outages/Trippings							
220/132 Kv 200 MVA ICT I @Dhule	IntraState	23/09/2020	22.34	24/09/2020	01.50	T	Bus Bar Relay Maloperated
220/132 Kv 200MVA ICT II @Dhule	IntraState	23/09/2020	22.34	24/09/2020	01.53	T	Bus Bar Relay Maloperated
220/132 Kv 200 MVA ICT-III @Phursungi	IntraState	24/09/2020	09.03	24/09/2020	18.45	PO	Half yearly maintenance & CT Tan delta & C Testing work.
220/132 Kv 100 Mva Gec lct 1 @Pusad	IntraState	24/09/2020	09.35	24/09/2020	12.40	EO	Attending Oil Leakage
220/132 kv 100 MVA ICT II@Malegaon	IntraState	24/09/2020	10.36	24/09/2020	17.12	PO	CTR Fire Protection Nitrogen Injection System Testing & maintenance Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage