

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Sep/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	119.091	2711.147	1) Gujrat	15.580	231.812
2) Hydro	8.809	279.887	2) Madhya Pradesh	11.363	93.657
3) Gas	2.112	63.650	3) Chattisgarh	3.910	86.310
Total MSPGCL	130.012	3054.684	4) Maharashtra	134.455	3592.162
B) 1) APLM	59.928	1506.980	5) Goa (Amona)	-1.294	-28.925
2) JSWEL	16.168	431.490	Total	164.014	3975.016
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.226	781.641
4) RPL(AMT)	17.487	393.495	b) Mumbai Drawl	35.677	864.050
5) SWPGPL	5.677	108.778	c) MSEDCL Bilateral *	72.834	1375.293
6) Other IPP	4.889	134.115	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.220	781.426
C) 1) TPCL Thermal	10.391	269.299	Include PX	0.000	0.000
2) TPCL Hydro	3.781	125.983	Standby	0.006	0.215
3) TPCL Gas	0.000	13.433	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.206	213.936	1) MSEDCL	390.911	9276.382
D) STATE			2) Mumbai Discoms	58.055	1486.702
1) Thermal	241.837	5769.240	3) Other Discoms	8.731	215.711
(A1+C1+C4+(B1-B6))			TOTAL STATE	457.697	10978.795
2) Hydro (A2+C2)	12.590	405.870			
3) Gas (A3+B7+C3)	2.112	77.083			
4) Wind	26.530	542.181			
6) SOLAR	10.614	209.404			
TOTAL STATE	293.683	7003.778			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4509	4793	5381	4524
MSPGCL Hydro	513	268	1597	154
MSPGCL Gas	86	84	87	92
MSPGCL Total Generation	5108	5145	7065	4770
Central Sector Receipt	7838	7665	6572	5421
WIND	1107	1154	1039	1276
CPP / IPP Thermal	3816	4247	5461	4192
CPP / IPP Gas	0	0	0	0
SOLAR	1376	887	0	0
Exchange with Mumbai	-1935	-1948	-1297	-960
MSEDCL DEMAND MET	16902	16753	18454	14420
Load Shedding	0	0	0	0
MSEDCL DEMAND	16902	16753	18454	14420
TPCL GENERATION	544	482	971	456
AEML GENERATION	404	302	484	304
MUMBAI DEMAND	2883	2732	2752	1720
OTHER DISCOM DEMAND	408	397	387	279
STATE DEMAND MET	20193	19882	21592	16419
STATE DEMAND	20193	19882	21592	16419
Frequency (Hz)	50.01	49.98	50.02	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13.03 Hrs	49.79 Hz at 18.43 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.12	237.00	432	310
Unit 9	9.53	31.44	485	362
Unit 10	9.41	241.62	450	342
Total	28.06	549.42		
Bhusawal				
Unit 3	2.78	53.21	135	105
Unit 4	8.41	198.04	445	280
Unit 5	8.76	47.55	465	280
Total	19.94	298.80		
Parli				
Unit 6	4.38	102.27	230	148
Unit 7	3.91	83.87	202	144
Unit 8	3.51	88.17	174	134
Total	11.80	274.31		
Chandrapur				
Unit 3	3.13	69.43	150	119
Unit 4	3.07	71.70	140	120
Unit 5	6.21	127.80	283	230
Unit 6	6.94	133.97	310	240
Unit 7	7.20	137.19	338	275
Unit 8	0.00	49.00	0	0
Unit 9	8.40	222.01	441	274
Total	34.95	811.10		
Paras				
Unit 3	4.96	105.05	242	155
Unit 4	0.00	86.15	0	0
Total	4.96	191.20		
Khaparkheda				
Unit 1	3.06	62.84	140	120
Unit 2	0.00	38.82	0	0
Unit 3	0.00	76.36	0	0
Unit 4	3.15	71.07	163	121
Unit 5	7.60	192.14	435	270
Total	13.82	441.23		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	2.86	45.24	132	94
Unit 5	2.70	67.29	129	91
Total	5.56	145.10		
Uran				
All Units	2.11	63.65	93	83
Total	2.11	63.65		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	12.11	26	0
Total	0.18	12.11		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.18	53.08	365	35
Stage 4	1.15	44.01	625	0
Stage 3	0.86	25.76	240	0
Total	4.18	122.84		
Hydro				
KDPH	0.43	5.69	18	18
VTRNA	0.75	18.22	61	0
TILLARI	0.58	11.18	58	0
BHIRA T.R.	0.33	9.74	60	0
SMLHY_PTN	2.17	94.94	98	77
GHATGHAR	0.18	5.16	110	0
Total	4.45	144.94		
Wind				
Total	26.53	542.18	0	0
Total	26.53	542.18		
CPP				
APML(Mus)	59.93	1506.98	0	0
JSWEL(Mus)	16.17	431.49	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	17.49	393.50	0	0
SWPGPL-Mus	5.68	108.78	0	0
Other(Mus)	4.89	134.12	0	0
Total	104.15	2574.86		
SOLAR				
Total	10.61	209.40	0	0
Total	10.61	209.40		
Tata				
Trombay 5	7.01	181.18	412	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	8.68	0	0
Trombay 7B	0.00	4.76	0	0
TATA Hydro	3.78	125.98	374	50
Trombay 8	3.38	88.12	185	131
Total	14.17	408.72		
AEML				
DTPS U-1&2	8.21	213.94	484	290
Total	8.21	213.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	119.09	2711.15	MSPGCL Total	130.01	3054.68
			MSPGCL Thml+Gas	121.20	2774.80	Koyna 1,2 & 4 Total	3.33	97.08
			MSPGCL Hydro	8.81	279.89	State Total	293.68	7003.78

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4592	151	91	4834	1129	4001	0	0	5897	5869	-1050	14458	0	14458	1969	326	16752	50.01
2	4655	160	92	4907	1193	3876	0	0	5566	5726	-1002	14406	0	14406	1845	294	16545	50.02
3	4619	184	93	4896	1360	4152	0	0	5407	5246	-988	14381	0	14381	1766	285	16432	50.03
4	4524	154	92	4770	1276	4192	0	0	5518	5421	-960	14420	0	14420	1720	279	16419	50.04
5	4714	165	92	4971	1212	4217	0	0	5786	5804	-980	14928	0	14928	1737	296	16961	49.99
6	5290	144	92	5526	1216	4234	0	0	6363	6427	-1041	16036	0	16036	1867	326	18229	50.01
7	5612	213	90	5915	1115	4588	0	61	6851	6966	-1139	17153	0	17153	2040	353	19546	49.97
8	5630	181	90	5901	1247	4556	0	377	7471	7087	-1404	17407	0	17407	2243	357	20007	50.04
9	5413	198	90	5701	1317	4306	0	796	7449	7018	-1687	17069	0	17069	2526	382	19977	50.04
10	4544	257	89	4890	1410	3875	0	1133	7466	7730	-1685	16967	0	16967	2748	386	20101	50.03
11	4526	395	87	5008	1210	3820	0	1331	7368	7749	-1815	16905	0	16905	2870	398	20174	49.99
12	4509	513	86	5108	1107	3816	0	1376	7668	7838	-1935	16902	0	16902	2883	408	20193	50.01
13	4657	290	86	5033	942	4129	0	1393	7641	7548	-2096	16562	0	16562	2915	387	19864	50.07
14	4614	265	84	4963	932	3872	0	1371	7542	7552	-2049	16255	0	16255	2812	385	19453	50.06
15	4663	231	83	4977	987	4222	0	1156	7508	7759	-1933	16788	0	16788	2692	380	19860	49.96
16	4793	268	84	5145	1154	4247	0	887	7665	7665	-1948	16753	0	16753	2732	397	19882	49.98
17	4959	312	84	5355	1093	4264	0	570	7593	7678	-1816	16746	0	16746	2722	398	19866	49.99
18	5116	442	84	5642	1086	4509	0	163	7551	7219	-1701	16507	0	16507	2696	411	19614	49.94
19	5301	1392	86	6779	972	5376	0	0	6521	6129	-1389	17472	0	17472	2680	395	20547	49.90
20	5381	1597	87	7065	1039	5461	0	0	6329	6572	-1297	18454	0	18454	2752	387	21592	50.02
21	5310	497	86	5893	919	5016	0	0	7014	7218	-1665	16984	0	16984	2787	396	20168	50.04
22	5313	407	87	5807	862	4677	0	0	7053	6927	-1551	16329	0	16329	2539	393	19261	50.01
23	5142	238	88	5468	855	4368	0	0	6936	6816	-1361	15770	0	15770	2317	376	18463	50.00
24	5214	155	89	5458	897	4376	0	0	6450	6050	-1185	15258	0	15258	2197	338	17793	50.00
MUs	119.09	8.81	2.11	130.01	26.53	104.15	0.00	10.61	164.61	164.01	-35.68	390.91	0.00	390.91	58.06	8.73	457.70	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 24/Sep/2022

Position as on 6.30 Hrs of 25/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58		Continued.	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	14/09/2022	05:36	25/09/2022	19:00	Gas shortage	
TPC-G	Trombay 7B	60	14/09/2022	05:50		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	14/09/2022	21:39	24/09/2022	12:57	ID Fan Problem	25/09/2022
MSPGCL	Khaparkheda Unit 2	210	17/09/2022	13:00		Continued.	wet coal	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	29/09/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Sep/2022

Position as on 6.30 Hrs of 25/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 3	210	23/09/2022	22:04	25/09/2022	09:47	Boiler Tube Leakage	
MSPGCL	Koyna STG-IV Unit-2	250	24/09/2022	18:23	24/09/2022	21:00	Generator Elect. Fault	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	13/09/2022	21:00	25/09/2022	17:54	T	Reason awaited
400 KV TBC Outages/Trippings							
BUS COUPLER @ AURANGABAD (WALUJ)	IntraState	25/09/2022	16:06	25/09/2022	16:38	EO	To attend hot spot by operation of 89A Yph PG Isolator for proper fixing with hanger.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KORADI 2-WARDHA (PG)	InterState	21/09/2022	08:55		Continued.	PO	Diversion of 400 kv Koradi-Wardha Line through 6 nos of Newly constructed tower of POWERGRID. Configuration of 400 kv Koradi Bays at Wardha shall remain the same. MSETCL 400 kv IEPL-Warora Line shall be in non- A/R Mode for safety precautions
KALWA - TALEGAON (PG)	InterState	25/09/2022	09:50	25/09/2022	20:22	PO	Replacement of discs type insulator string with AF long rod type insulator string at cut point tower location for D/C portion
KHADKA-AURANGABAD (WALUJ)	IntraState	23/09/2022	20:16	24/09/2022	08:53	HT	HT for Overvoltage Control
CHANDRAPUR-PARLI CKT-3	IntraState	24/09/2022	08:53	24/09/2022	19:01	PO	for replacement of polymer insulator with log rod porcelain insulator strings
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/09/2022	09:14	24/09/2022	18:57	PO	Cold Line Washing work to be carried out in view of frequent tripping of line.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/09/2022	19:52	25/09/2022	09:19	T	TRIPPED ON DISTANCE PROTECTION
CHANDRAPUR-PARLI CKT-3	IntraState	25/09/2022	14:22	25/09/2022	19:38	PO	for replacement of of polymer insulator with long rod porcelain insulator strings.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	25/09/2022	16:48	25/09/2022	20:04	PO	Cold Line Washing work to be carried out in view of frequent tripping of line.
JEJURI- KOYNA STAGE-IV	IntraState	25/09/2022	17:23	25/09/2022	20:20	PO	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
KHADKA-AURANGABAD (WALUJ)	IntraState	25/09/2022	20:58		Continued.	HT	H/T for Over Voltage.
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	24/09/2022	12:27	24/09/2022	19:45	EO	1) Replacement of Rph HV Bushing to gantry damaged jumper 2) Diagnostic Testing Work 3) Attending Oil leakage/hotspot if any 4) MTAMC work 5) NIFPS maint. work 6) For replacement of 70KN suspension type Disc of insulator by 120KN Disc insulator at LV Bay
220 KV TBC Outages/Trippings							
BUS SECTION BAY @ VSNL	IntraState	25/09/2022	10:37	25/09/2022	13:18	EO	Replacement of damaged jumps from Bus to Bus Isolator of 220kV Bus Section
220 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 24/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - PADGHE	IntraState	19/09/2022	08:40	24/09/2022	12:15	HT	H/T TO CONTROL LINE LOADING OF BBLR
CHINCHWAD-2 - TELCO	IntraState	23/09/2022	22:20	24/09/2022	07:16	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
CHAKAN - CHINCHWAD 2	IntraState	23/09/2022	22:35	24/09/2022	07:02	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
BUS SECTION - 1 @ BIDRI	IntraState	24/09/2022	09:52	24/09/2022	16:58	PO	For attending hotspot
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	24/09/2022	10:34	24/09/2022	13:13	PO	Refitting of Pilot strings suspension clamp at loc no 56 SD tower/ Tightening all Pilot clamps.
BHALVANI - VARKUTI	IntraState	24/09/2022	10:34	24/09/2022	13:28	PO	Outage is required For Diagnostic Testing
LONIKAND 2 - BHOSARI	IntraState	24/09/2022	11:51	24/09/2022	19:11	PO	Emergency tree cutting at loc no-36-37 and insulator cleaning work at loc no-32-36
PANDHARPUR - BHALVANI	IntraState	24/09/2022	14:05	24/09/2022	17:46	PO	Outage is required For Diagnostic Testing
TILLARI - AMONA LINE	IntraState	24/09/2022	14:05	24/09/2022	15:43	T	TRIPPED ON DISTANCE PROTECTION
CHINCHWAD-2 - TELCO	IntraState	24/09/2022	23:45	25/09/2022	06:57	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
CHAKAN - CHINCHWAD 2	IntraState	25/09/2022	00:02	25/09/2022	06:47	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
VSNL- KHADKI	IntraState	25/09/2022	10:07	25/09/2022	13:19	EO	Replacement of damaged jumps from Bus to Bus Isolator of 220kV Bus Section
VSNL - STT GIS CKT - 1	IntraState	25/09/2022	10:13	25/09/2022	13:20	EO	Replacement of damaged jumps from Bus to Bus Isolator of 220kV Bus Section
KANDALGAON - PIRANGUT	IntraState	25/09/2022	14:25	25/09/2022	16:45	PO	1)Replacement of polymer insulators by longrod porcelain, loc no-32,33,34 2) Replacement of all nut bolt at loc no -33
KHARGHAR - BORIVALI CKT - 2	IntraState	25/09/2022	20:36		Continued.	PO	Outage required for safety purpose To carry out the work of making LILO arrangement at Loc no. 40 of 220KV Kalwa-TFIPL Line as both lines are on same M/C tower.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 25/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - TFIPL	IntraState	25/09/2022	20:54		Continued.	PO	For removing of bunching arrangement at Loc no.45 and connecting jumpers at Loc no.45 to newly proposed 220/22KV GIS S/stn at Pawane Mahape.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 25MVA TF NO.2 @ SAYNE	IntraState	15/09/2022	15:40	24/09/2022	20:20	PO	Work of Replacement of 220/33kv 25 MVA TF2 by 220/33kv 50MVA BHEL TF
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/33KV 50MVA PTR 2 @ VITA	IntraState	24/09/2022	10:14	24/09/2022	17:15	PO	OLTC Overhauling Work
220/33KV 125 MVA TF 2 @ BORIVALI (AEML)	IntraState	24/09/2022	10:15	24/09/2022	21:14	PO	Reconnection of Disconnected 33kV cables.
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	24/09/2022	10:35	24/09/2022	17:20	PO	For CB Timing, CRM testing, Replacement of Insulator String
220/33KV 50MVA PTR 1 @ VITA	IntraState	25/09/2022	10:35	25/09/2022	14:35	PO	OLTC Overhauling Work
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	25/09/2022	14:19	25/09/2022	15:17	T	Tripped from both HV & LV Side with WTI flag.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage