

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Oct/2019 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	88.070	2700.621	1) Gujrat	1.879	268.357
2) Hydro	8.283	176.074	2) Madhya Pradesh	2.919	202.944
3) Gas	10.193	231.550	3) Chattisgarh	6.560	91.370
Total MSPGCL	106.546	3108.245	4) Maharashtra	128.273	3082.667
B) 1) APML	43.475	954.924	5) Goa (Amona)	-0.484	-11.968
2) JSWEL	22.128	477.149	Total	139.147	3633.370
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.402	750.307
4) RPL(AMT)	21.779	504.994	b) Mumbai Drawl	32.110	833.474
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	20.641	539.045
6) Other IPP	9.331	206.179	Include PX	0.049	82.885
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.402	750.307
C) 1) TPCL Thermal	13.963	313.555	Include PX	5.128	266.923
2) TPCL Hydro	4.940	94.127	Standby	0.000	0.000
3) TPCL Gas	4.013	89.918	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.182	155.153	1) MSEDCL	326.659	8370.581
D) STATE			2) Mumbai Discoms	60.208	1486.223
1) Thermal	203.928	5312.575	TOTAL STATE	386.867	9856.804
(A1+C1+C4+(B1-B6))					
2) Hydro	13.223	270.201			
(A2+C2)					
3) Gas	14.206	321.468			
(A3+B7+C3)					
4) Wind	13.708	191.880			
6) SOLAR	2.655	127.314			
TOTAL STATE	247.720	6223.438			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	3868	3590	3802	3574
MSPGCL Hydro	271	183	780	192
MSPGCL Gas	418	416	422	437
MSPGCL Total Generation	4557	4189	5004	4203
Central Sector Receipt	6840	6768	5601	4870
WIND	876	922	700	284
CPP / IPP Thermal	4081	3940	4645	3723
CPP / IPP Gas	0	0	0	0
SOLAR	408	401	1	0
Exchange with Mumbai	-1796	-1937	-1395	-936
MSEDCL DEMAND MET	14966	14283	14556	12144
Load Shedding	0	0	0	0
MSEDCL DEMAND	14966	14283	14556	12144
TPCL GENERATION	1101	924	1294	625
AEML GENERATION	226	193	248	190
MUMBAI DEMAND	3123	3054	2937	1751
STATE DEMAND MET	18089	17337	17493	13895
STATE DEMAND	18089	17337	17493	13895
Frequency (Hz)	50.00	50.02	49.98	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.23 Hz at 13.01 Hrs	49.68 Hz at 07.06 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 24/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	1.70	69.41	320	0
Unit 9	0.77	214.78	190	0
Unit 10	9.13	241.57	405	350
Total	11.60	525.77		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.24	199.75	415	350
Unit 5	9.63	124.68	490	355
Total	18.86	324.43		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	41.35	0	0
Unit 7	0.00	109.68	0	0
Unit 8	0.00	71.04	0	0
Total	0.00	222.07		
Chandrapur				
Unit 3	4.20	78.58	190	155
Unit 4	3.84	86.95	167	133
Unit 5	8.44	196.52	365	340
Unit 6	9.61	204.19	450	355
Unit 7	0.00	0.00	0	0
Unit 8	8.57	214.78	420	310
Unit 9	8.50	208.96	427	300
Total	43.15	989.99		
Paras				
Unit 3	0.00	88.52	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	88.52		
Khaparkheda				
Unit 1	0.00	30.23	0	0
Unit 2	0.00	35.13	0	0
Unit 3	0.00	44.89	0	0
Unit 4	0.00	63.23	0	0
Unit 5	10.52	231.73	500	370
Total	10.52	405.22		
Nasik				
Unit 3	0.00	24.52	0	0
Unit 4	0.00	31.55	0	0
Unit 5	3.93	88.56	187	148
Total	3.93	144.63		
Uran				
All Units	10.19	231.55	438	405
Total	10.19	231.55		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.73	15.85	51	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.73	15.85		
Koyna				
Stage 1-2	3.48	72.51	495	40
Stage 4	0.00	43.69	0	0
Stage 3	1.72	28.49	160	0
Total	5.20	144.68		
Hydro				
KDPH	0.89	8.02	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.72	4.71	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.39	6.96	80	0
RNGR+BHTSA	0.04	0.04	13	0
BHANDARDRA	0.34	1.72	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.57	6.18	33	19
GHATGHAR	0.13	3.77	63	0
Total	3.08	31.39		
Wind				
Total	13.71	191.88	0	0
Total	13.71	191.88		
CPP				
APML(Mus)	43.48	954.92	0	0
JSWEL(Mus)	22.13	477.15	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	21.78	504.99	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	9.33	206.18	0	0
Total	96.71	2143.25		
SOLAR				
Total	2.66	127.31	0	0
Total	2.66	127.31		
Tata				
Trombay 5	9.10	198.64	483	305
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.52	55.94	117	70
Trombay 7B	1.50	33.98	66	52
Trombay 8	4.86	114.92	211	196
TATA Hydro	4.94	94.13	437	0
Total	22.92	497.60		
AEML				
DTPS U-1&2	5.18	155.15	250	190
Total	5.18	155.15		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	88.07	2700.62	MSPGCL Total	106.55	3108.24
			MSPGCL Thml+Gas	98.26	2932.17	Koyna 1,2 & 4 Total	3.48	116.20
			MSPGCL Hydro	8.28	176.07	State Total	247.72	6223.44

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3701	374	427	4502	267	3873	0	0	5062	5059	-1189	12512	0	12512	2083	14595	49.92
2	3640	192	438	4270	219	3961	0	0	4876	4927	-1080	12297	0	12297	1924	14221	50.00
3	3586	197	428	4211	224	3948	0	0	4818	4709	-1002	12090	0	12090	1818	13908	50.00
4	3574	192	437	4203	284	3723	0	0	4825	4870	-936	12144	0	12144	1751	13895	50.01
5	3636	322	428	4386	247	3570	0	0	4957	5097	-932	12368	0	12368	1749	14117	50.01
6	3659	522	428	4609	311	3665	0	0	5473	5539	-875	13249	0	13249	1834	15083	49.99
7	3636	277	427	4340	413	3729	0	26	6518	6409	-792	14125	0	14125	1963	16088	49.93
8	3721	287	427	4435	430	3731	0	101	6599	6659	-943	14413	0	14413	2172	16585	49.96
9	3782	786	426	4994	376	3760	0	200	6088	6590	-1190	14730	0	14730	2502	17232	50.01
10	3808	703	433	4944	563	3997	0	288	6146	6284	-1416	14660	0	14660	2837	17497	50.01
11	3873	419	423	4715	758	4119	0	332	6713	6319	-1750	14493	0	14493	3055	17548	50.04
12	3868	271	418	4557	876	4081	0	408	6847	6840	-1796	14966	0	14966	3123	18089	50.00
13	3590	183	416	4189	922	3940	0	401	6735	6768	-1937	14283	0	14283	3054	17337	50.02
14	3402	188	405	3995	916	3814	0	330	6568	6402	-1799	13658	0	13658	2914	16572	50.05
15	3370	176	425	3971	1053	3620	0	315	6669	6658	-1776	13841	0	13841	2949	16790	50.01
16	3357	171	417	3945	1174	3789	0	170	6310	6326	-1718	13686	0	13686	2968	16654	49.99
17	3350	171	417	3938	914	3944	0	64	6299	6403	-1623	13640	0	13640	2949	16589	49.98
18	3651	495	410	4556	683	4284	0	19	6007	6157	-1519	14180	0	14180	2933	17113	50.02
19	3802	780	422	5004	700	4645	0	1	5651	5601	-1395	14556	0	14556	2937	17493	49.98
20	3814	486	424	4724	474	4710	0	0	5704	5705	-1290	14323	0	14323	2822	17145	50.00
21	3924	490	425	4839	420	4682	0	0	5454	5373	-1265	14049	0	14049	2706	16755	50.05
22	4030	255	427	4712	489	4545	0	0	5266	5070	-1304	13512	0	13512	2533	16045	50.05
23	3717	203	437	4357	494	4357	0	0	5068	4744	-1320	12632	0	12632	2387	15019	50.02
24	3579	143	428	4150	501	4228	0	0	5085	4638	-1263	12254	0	12254	2245	14499	50.04
MUs	88.07	8.28	10.19	106.55	13.71	96.71	0.00	2.66	139.74	139.15	-32.11	326.66	0.00	326.66	60.21	386.87	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 24/Oct/2019

Position as on 6.30 Hrs of 25/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn on shaft seal water leakage. Converted to AOH from 1 Nov 2019.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyana Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-1	660	19/09/2019	01.43	24/10/2019	17.42	Due to Low Coal Stock.	
AEML	AEML Unit 2	250	07/10/2019	21.18		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)	
MSPGCL	Koradi Unit 9	660	21/10/2019	01.18	24/10/2019	18.30	Boiler Tube Leakage	
IPP	Adani U-2	660	21/10/2019	22.58	25/10/2019	16.05	APH Hot PA Bellow Leakage	
MSPGCL	Khaparkheda Unit 4	210	22/10/2019	23.52		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Oct/2019

Position as on 6.30 Hrs of 25/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Parli Unit 6	250	23/10/2019	03.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	23/10/2019	12.46	25/10/2019	04.14	Compress Bearing vibration high.	
MSPGCL	Parli Unit 7	250	23/10/2019	17.00		Continued.	Zero Schedule.	
IPP	Adani U-4	660	24/10/2019	04.39	24/10/2019	08.33	governing valve 1 &3 sudden Closing.	
MSPGCL	Koradi Unit-8	660	24/10/2019	05.27		Continued.	Rotary Air Preheater Trip.	
MSPGCL	Chandrapur Unit 3	210	25/10/2019	01.03		Continued.	Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).	
MSPGCL	Chandrapur Unit 5	500	25/10/2019	01.03		Continued.	Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).	
MSPGCL	Chandrapur Unit 6	500	25/10/2019	01.03	25/10/2019	23.00	Bus-1 LBB Operation.	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 6	108	25/10/2019	05.30	25/10/2019	09.53	Gas Skid Failure	
MSPGCL	Uran Unit 5	108	25/10/2019	05.30		Continued.	Gas Skid Failure	
MSPGCL	Uran Unit 8	108	25/10/2019	05.30	25/10/2019	15.43	Gas Skid Failure	
MSPGCL	Uran Unit 7	108	25/10/2019	05.30	25/10/2019	11.34	Gas Skid Failure.	
MSPGCL	Uran Unit B0	120	25/10/2019	05.30	25/10/2019	14.38	Gas Skid Failure.	
MSPGCL	Uran Unit A0	120	25/10/2019	05.30	25/10/2019	12.15	Gas Skid Failure.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Chandrapur Unit 6	500	25/10/2019	23.11		Continued.	Turbine Tripped	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 25/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe HvdC Pole 1	IntraState	25/10/2019	01.03	25/10/2019	4.12	T	LBB operated
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	19/10/2019	23.13		Continued.	HT	Over Voltage
Dhule Khandwa I	InterState	21/10/2019	22.06		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	23/10/2019	00.27	24/10/2019	11.43	T	Over Voltage
Padgha - Boisar (PG)	InterState	24/10/2019	14.25	24/10/2019	15.27	PO	Line Reactor Work.
Kolhapur Solapur (PG) II	InterState	24/10/2019	23.54		Continued.	T	Over Voltage
Chandrapur Bhadravati III	InterState	25/10/2019	01.03	25/10/2019	08.43	T	Bus-1 LBB Operated.
Chandrapur Bhadravati II	InterState	25/10/2019	01.03	25/10/2019	08.36	T	Bus-1 LBB Operated.
Jaigad-Karad Ckt-I	IntraState	19/10/2019	03.20		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	19/10/2019	19.15		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	24/10/2019	23.34	25/10/2019	12.16	HT	Over Voltage
Bus Coupler @ Chandrapur	IntraState	25/10/2019	01.03	25/10/2019	02.55	T	Bus-1 LBB Operated.
Chandrapur II - Chandrapur ckt 2	IntraState	25/10/2019	01.03	25/10/2019	07.24	T	Tripped With Bus -1 LBB Operated.
Main Bus I @ Chandrapur Sw	IntraState	25/10/2019	01.03	25/10/2019	2.55	T	On LBB Operated.
Chandrapur - Khaperkheda	IntraState	25/10/2019	01.03	25/10/2019	07.13	T	Bus-1 LBB Operated.
Chandrapur-II - Nanded ckt II	IntraState	25/10/2019	03.15		Continued.	T	Over Voltage
TBC @ Babhaleshwar	IntraState	25/10/2019	12.40	25/10/2019	13.47	EO	Attending Hot Spot On Line Work By Hot Line.
Lonikand I - Koyna stage-IV	IntraState	25/10/2019	23.04		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220kv 315 Mva ICT I @Karad	IntraState	23/10/2019	03.22	24/10/2019	10.35	T	Differential protection
400/11.5 kv 90MVA STN T/F-IV @ Chandrapur	IntraState	25/10/2019	01.03	25/10/2019	09.48	T	Tripped With Bus-1 LBB Operated.Taken In Service.
400/220/33 kv 315 MVA ICT-I @Chandrapur GCR	IntraState	25/10/2019	01.03	25/10/2019	03.05	T	Bus-1 LBB Operated.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	25/10/2019	06.44	25/10/2019	09.52	PO	Investigation Of Bucolz tripping/maloperation.
400/11.5 kv 90MVA STN T/F-IV @ Chandrapur	IntraState	25/10/2019	10.04	25/10/2019	18.55	PO	Generation End Breaker Tripped Due To Relay Problem.Charged Trough TBC.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Borivali - Tarapur	InterState	25/10/2019	04.19	25/10/2019	13.46	T	Distance Protection
Mahalakshmi Amona	InterState	25/10/2019	09.01	25/10/2019	09.27	T	Tripped At Amona End Only.
Tillari Amona	InterState	25/10/2019	09.01	25/10/2019	09.28	T	Tripped At Amona End Only.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Lonand-Baramati	IntraState	17/09/2019	11.13		Continued.	HT	To Control Overloading of Lonand-Jejuri Line.
Trombay Dharavi 9	IntraState	23/10/2019	08.50		Continued.	PO	Erection Of Tower LoC.I No.23
Trombay - Kalwa	IntraState	23/10/2019	20.02	24/10/2019	07.08	PO	Tower Piling Work At Loc.No.22A.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 25/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Bhambori Amalner	IntraState	23/10/2019	23.02	24/10/2019	07.39	T	Distance Protection
Raymond - TKES	IntraState	24/10/2019	08.20	24/10/2019	17.40	PO	Routine Maintenance Work Outages From Consumer End.
Pophali - Pedambe II	IntraState	24/10/2019	09.25	24/10/2019	09.38	PO	SF6 Gas Filling Work.
Halkarni-Olam(Agro)	IntraState	24/10/2019	12.20	24/10/2019	14.28	PO	LA Replacement.
Virur - Virurlytss1	IntraState	24/10/2019	13.05	24/10/2019	15.00	PO	ABT Meter Replacement Work.
Khadka-Chalisgaon-2	IntraState	24/10/2019	13.06	24/10/2019	14.35	EO	Attending Hot Spot On Line ISO R PH.
Virur - Virur Rly Tss 2	IntraState	24/10/2019	15.20	24/10/2019	16.15	PO	ABT Meter.
Chandrapur GCR - Sicom II	IntraState	25/10/2019	01.03	25/10/2019	01.44	T	Due To LTS Operation.
Chandrapur GCR - Sicom I	IntraState	25/10/2019	01.03	25/10/2019	01.33	T	Due To LTS Operation.
Bus section @ Kalwa	IntraState	25/10/2019	06.44	25/10/2019	10.08	PO	Due To Outage On ICT.
Butibori - Purti	IntraState	25/10/2019	09.20	25/10/2019	14.54	PO	STN To DTN Conversion At Loc 198 & SSN To DSN Conversion at 200
Dahanu Versova	IntraState	25/10/2019	09.33	25/10/2019	16.20	T	Distance Protection
Trombay - Mulund	IntraState	25/10/2019	10.04	25/10/2019	18.55	PO	Line Isolator Alignment Work.
Butibori - VIPL Ckt I	IntraState	25/10/2019	12.01	25/10/2019	18.09	PO	Testing Work
Bableshtar Ahamadnagar-Ii	IntraState	25/10/2019	14.12	25/10/2019	18.40	PO	Flash Over Disc Replacement.
Trombay - Kalwa	IntraState	25/10/2019	20.18		Continued.	PO	Piling work at Loc.No.22A
220 KV ICT Outages/Trippings							
220/132 KV 200 MVA ICT - 2 @ CHINCHWAD 2	IntraState	24/10/2019	06.33	24/10/2019	22.44	T	Differential protection
220/100 kV 200 MVA ICT-II @Kalwa	IntraState	24/10/2019	10.18	24/10/2019	13.10	PO	DC Leakage Attending Work.
220/100 kV 200 MVA ICT II @Padghe	IntraState	25/10/2019	08.26	25/10/2019	17.33	PO	U Bolt Replacement Work.
220/22 Kv 50 Mva Areva Ptr 2 @Anandnagar	IntraState	25/10/2019	10.45	25/10/2019	11.50	EO	Hot Spot LV CT.
220/100 Kv 200 MVA ICT I @Pal-Dombivali	IntraState	25/10/2019	11.24	25/10/2019	18.25	PO	Relay Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage