

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 24/Oct/2022 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 97.171         | 2802.956        | 1) Gujrat                      | 2.712          | 217.927          |
| 2) Hydro            | 5.228          | 198.202         | 2) Madhya Pradesh              | -2.477         | 130.493          |
| 3) Gas              | 2.183          | 53.047          | 3) Chattisgarh                 | 3.680          | 126.330          |
| <b>Total MSPGCL</b> | <b>104.582</b> | <b>3054.205</b> | 4) Maharashtra                 | 124.070        | 3788.610         |
| B) 1) APLM          | 52.183         | 1307.078        | 5) Goa (Amona)                 | -1.461         | -32.000          |
| 2) JSWEL            | 14.209         | 365.514         | <b>Total</b>                   | <b>126.524</b> | <b>4231.360</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 28.261         | 809.239          |
| 4) RPL(AMT)         | 22.854         | 563.717         | b) Mumbai Drawl                | 32.428         | 889.375          |
| 5) SWPGPL           | 4.622          | 163.771         | c) MSEDCL Bilateral *          | 62.940         | 1586.032         |
| 6) Other IPP        | 13.222         | 206.906         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 28.261         | 809.228          |
| C) 1) TPCL Thermal  | 9.246          | 243.128         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 2.431          | 95.983          | Standby                        | 0.000          | 0.012            |
| 3) TPCL Gas         | 2.143          | 58.091          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 7.189          | 220.586         | 1) MSEDCL                      | 316.712        | 9270.258         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 53.437         | 1507.141         |
| 1) Thermal          | 220.696        | 5873.656        | 3) Other Discoms               | 8.004          | 219.808          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>378.153</b> | <b>10997.207</b> |
| 2) Hydro (A2+C2)    | 7.659          | 294.185         |                                |                |                  |
| 3) Gas (A3+B7+C3)   | 4.326          | 111.138         |                                |                |                  |
| 4) Wind             | 5.460          | 249.777         |                                |                |                  |
| 6) SOLAR            | 13.488         | 237.113         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>251.629</b> | <b>6765.869</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 9 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 24 Hrs |
|----------------------------|--------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal             | 4276                     | 3831                  | 4462                      | 3607                       |
| MSPGCL Hydro               | 246                      | 186                   | 362                       | 157                        |
| MSPGCL Gas                 | 93                       | 87                    | 87                        | 92                         |
| MSPGCL Total Generation    | 4615                     | 4104                  | 4911                      | 3856                       |
| Central Sector Receipt     | 5309                     | 5719                  | 5825                      | 5265                       |
| WIND                       | 151                      | 246                   | 274                       | 137                        |
| CPP / IPP Thermal          | 4816                     | 4401                  | 5001                      | 4193                       |
| CPP / IPP Gas              | 0                        | 0                     | 0                         | 0                          |
| SOLAR                      | 1013                     | 95                    | 1                         | 0                          |
| Exchange with Mumbai       | -1319                    | -1390                 | -1502                     | -1466                      |
| <b>MSEDCL DEMAND MET</b>   | <b>14226</b>             | <b>12824</b>          | <b>14162</b>              | <b>11672</b>               |
| Load Shedding              | 0                        | 0                     | 0                         | 0                          |
| MSEDCL DEMAND              | 14226                    | 12824                 | 14162                     | 11672                      |
| TPCL GENERATION            | 539                      | 577                   | 652                       | 543                        |
| AEML GENERATION            | 297                      | 297                   | 309                       | 307                        |
| <b>MUMBAI DEMAND</b>       | <b>2155</b>              | <b>2264</b>           | <b>2463</b>               | <b>2316</b>                |
| <b>OTHER DISCOM DEMAND</b> | <b>359</b>               | <b>351</b>            | <b>349</b>                | <b>313</b>                 |
| STATE DEMAND MET           | 16740                    | 15439                 | 16973                     | 14301                      |
| <b>STATE DEMAND</b>        | <b>16740</b>             | <b>15439</b>          | <b>16973</b>              | <b>14301</b>               |
| Frequency (Hz)             | 50.03                    | 50.05                 | 50.07                     | 50.01                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|----------------------|----------------------|---------------|---------------------|
| 50.4 Hz at 13.06 Hrs | 49.7 Hz at 16.13 Hrs | 50.03         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 24/Oct/2022

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.72         | 53.49         | 205      | 95       |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 10.55        | 198.90        | 505      | 377      |
| Unit 9             | 0.00         | 59.24         | 0        | 0        |
| Unit 10            | 9.36         | 227.52        | 400      | 375      |
| <b>Total</b>       | <b>23.63</b> | <b>539.15</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 32.53         | 0        | 0        |
| Unit 4             | 7.42         | 192.66        | 415      | 255      |
| Unit 5             | 7.56         | 166.80        | 430      | 275      |
| <b>Total</b>       | <b>14.98</b> | <b>391.98</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 89.52         | 0        | 0        |
| Unit 7             | 0.00         | 77.24         | 0        | 0        |
| Unit 8             | 0.00         | 64.89         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>231.65</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 1.06         | 55.60         | 120      | 0        |
| Unit 4             | 1.18         | 66.19         | 149      | 0        |
| Unit 5             | 2.55         | 157.99        | 295      | 0        |
| Unit 6             | 2.43         | 167.31        | 275      | 0        |
| Unit 7             | 7.22         | 170.42        | 332      | 278      |
| Unit 8             | 7.43         | 88.53         | 440      | 265      |
| Unit 9             | 7.58         | 203.27        | 418      | 278      |
| <b>Total</b>       | <b>29.45</b> | <b>909.31</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.48         | 100.68        | 220      | 140      |
| Unit 4             | 0.00         | 0.16          | 0        | 0        |
| <b>Total</b>       | <b>4.48</b>  | <b>100.84</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.08         | 65.79         | 115      | 70       |
| Unit 2             | 2.88         | 68.84         | 135      | 115      |
| Unit 3             | 3.22         | 82.04         | 143      | 126      |
| Unit 4             | 3.09         | 76.48         | 136      | 124      |
| Unit 5             | 7.46         | 195.82        | 460      | 270      |
| <b>Total</b>       | <b>18.73</b> | <b>488.97</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 25.32         | 0        | 0        |
| Unit 4             | 3.04         | 73.55         | 162      | 111      |
| Unit 5             | 2.87         | 42.18         | 160      | 107      |
| <b>Total</b>       | <b>5.90</b>  | <b>141.04</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 2.18         | 53.05         | 95       | 86       |
| <b>Total</b>       | <b>2.18</b>  | <b>53.05</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.60         | 14.27         | 25       | 24       |
| <b>Total</b>       | <b>0.60</b>  | <b>14.27</b>  |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 1.38          | 49.36          | 225      | 40       |
| Stage 4         | 0.07          | 40.37          | 72       | 0        |
| Stage 3         | 0.50          | 21.76          | 160      | 0        |
| <b>Total</b>    | <b>1.95</b>   | <b>111.50</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 6.26           | 0        | 0        |
| VTRNA           | 0.00          | 4.54           | 0        | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.22          | 6.66           | 80       | 0        |
| SMLHY_PTN       | 2.33          | 49.90          | 106      | 87       |
| GHATGHAR        | 0.12          | 5.07           | 63       | 0        |
| <b>Total</b>    | <b>2.68</b>   | <b>72.44</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 5.46          | 249.78         | 0        | 0        |
| <b>Total</b>    | <b>5.46</b>   | <b>249.78</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 52.18         | 1307.08        | 0        | 0        |
| JSWEL(Mus)      | 14.21         | 365.51         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 22.85         | 563.72         | 0        | 0        |
| SWPGPL-Mus      | 4.62          | 163.77         | 0        | 0        |
| Other(Mus)      | 13.22         | 206.91         | 0        | 0        |
| <b>Total</b>    | <b>107.09</b> | <b>2606.99</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 13.49         | 237.11         | 0        | 0        |
| <b>Total</b>    | <b>13.49</b>  | <b>237.11</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 6.09          | 155.37         | 269      | 229      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.17          | 32.50          | 107      | 36       |
| Trombay 7B      | 0.97          | 25.59          | 64       | 34       |
| TATA Hydro      | 2.43          | 95.98          | 191      | 58       |
| Trombay 8       | 3.16          | 87.76          | 181      | 123      |
| <b>Total</b>    | <b>13.82</b>  | <b>397.20</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 7.19          | 220.59         | 334      | 282      |
| <b>Total</b>    | <b>7.19</b>   | <b>220.59</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 97.17       | 2802.96       | MSPGCL Total        | 104.58      | 3054.20       |
|                |             |         | MSPGCL Thml+Gas | 99.35       | 2856.00       | Koyna 1,2 & 4 Total | 1.45        | 89.73         |
|                |             |         | MSPGCL Hydro    | 5.23        | 198.20        | State Total         | 251.63      | 6765.87       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 24/Oct/2022

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | LOAD<br>SHED<br>DING | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAN<br>D | OTHER<br>DISCOM<br>DEMAN<br>D | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|------------------------|----------------------|-------------------------------|----------------------|-------------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                        |                      |                               |                      |                               |                 |               |
| 1                  | 4295        | 176  | 93   | 4564   | 191  | 4259      | 0    | 0     | 5435        | 5665        | -1320                | 13045                  | 0                    | 13045                         | 2272                 | 314                           | 15631           | 49.97         |
| 2                  | 4366        | 171  | 93   | 4630   | 181  | 3913      | 0    | 0     | 5275        | 5354        | -1259                | 12532                  | 0                    | 12532                         | 2129                 | 287                           | 14948           | 49.96         |
| 3                  | 4386        | 171  | 93   | 4650   | 129  | 4396      | 0    | 0     | 4863        | 4789        | -1022                | 12669                  | 0                    | 12669                         | 2012                 | 273                           | 14954           | 50.01         |
| 4                  | 4395        | 171  | 94   | 4660   | 116  | 4417      | 0    | 0     | 4977        | 5008        | -991                 | 12958                  | 0                    | 12958                         | 1909                 | 252                           | 15119           | 50.02         |
| 5                  | 4736        | 174  | 94   | 5004   | 123  | 4600      | 0    | 0     | 5137        | 5425        | -1058                | 13807                  | 0                    | 13807                         | 1886                 | 286                           | 15980           | 50.01         |
| 6                  | 5059        | 452  | 95   | 5606   | 138  | 5026      | 0    | 0     | 5205        | 5595        | -1144                | 14908                  | 0                    | 14908                         | 1973                 | 313                           | 17194           | 50.00         |
| 7                  | 5142        | 492  | 94   | 5728   | 192  | 5528      | 0    | 78    | 5680        | 5834        | -1114                | 15909                  | 0                    | 15909                         | 2021                 | 337                           | 18267           | 49.97         |
| 8                  | 4839        | 165  | 95   | 5099   | 236  | 5350      | 0    | 502   | 5949        | 5529        | -1128                | 15242                  | 0                    | 15242                         | 2066                 | 346                           | 17654           | 50.05         |
| 9                  | 4276        | 246  | 93   | 4615   | 151  | 4816      | 0    | 1013  | 5543        | 5309        | -1319                | 14226                  | 0                    | 14226                         | 2155                 | 359                           | 16740           | 50.03         |
| 10                 | 3720        | 245  | 93   | 4058   | 168  | 4335      | 0    | 1462  | 5090        | 5490        | -1415                | 13741                  | 0                    | 13741                         | 2225                 | 356                           | 16323           | 50.03         |
| 11                 | 3500        | 165  | 92   | 3757   | 417  | 4055      | 0    | 1742  | 5041        | 5279        | -1508                | 13382                  | 0                    | 13382                         | 2315                 | 360                           | 16057           | 50.06         |
| 12                 | 3458        | 163  | 91   | 3712   | 464  | 3719      | 0    | 1849  | 5142        | 4815        | -1509                | 12677                  | 0                    | 12677                         | 2357                 | 374                           | 15407           | 50.09         |
| 13                 | 3430        | 157  | 89   | 3676   | 399  | 3720      | 0    | 1865  | 4863        | 4483        | -1507                | 12268                  | 0                    | 12268                         | 2333                 | 368                           | 14969           | 50.12         |
| 14                 | 3396        | 154  | 87   | 3637   | 305  | 3725      | 0    | 1744  | 4283        | 4696        | -1496                | 12256                  | 0                    | 12256                         | 2295                 | 355                           | 14906           | 50.19         |
| 15                 | 3479        | 152  | 86   | 3717   | 269  | 3799      | 0    | 1511  | 4121        | 4724        | -1458                | 12200                  | 0                    | 12200                         | 2267                 | 362                           | 14829           | 50.05         |
| 16                 | 3597        | 154  | 86   | 3837   | 230  | 4320      | 0    | 1101  | 4666        | 4774        | -1432                | 12472                  | 0                    | 12472                         | 2250                 | 358                           | 15080           | 49.95         |
| 17                 | 3565        | 153  | 86   | 3804   | 215  | 4289      | 0    | 525   | 5603        | 5625        | -1398                | 12706                  | 0                    | 12706                         | 2230                 | 354                           | 15290           | 49.91         |
| 18                 | 3831        | 186  | 87   | 4104   | 246  | 4401      | 0    | 95    | 5667        | 5719        | -1390                | 12824                  | 0                    | 12824                         | 2264                 | 351                           | 15439           | 50.05         |
| 19                 | 4462        | 362  | 87   | 4911   | 274  | 5001      | 0    | 1     | 5821        | 5825        | -1502                | 14162                  | 0                    | 14162                         | 2463                 | 349                           | 16973           | 50.07         |
| 20                 | 4249        | 284  | 89   | 4622   | 262  | 5167      | 0    | 0     | 5949        | 5303        | -1486                | 13519                  | 0                    | 13519                         | 2514                 | 349                           | 16382           | 50.05         |
| 21                 | 3902        | 245  | 91   | 4238   | 269  | 4812      | 0    | 0     | 5640        | 5491        | -1466                | 13015                  | 0                    | 13015                         | 2445                 | 330                           | 15789           | 50.03         |
| 22                 | 3761        | 258  | 91   | 4110   | 187  | 4717      | 0    | 0     | 5056        | 5397        | -1516                | 12567                  | 0                    | 12567                         | 2387                 | 329                           | 15282           | 50.00         |
| 23                 | 3720        | 175  | 92   | 3987   | 161  | 4532      | 0    | 0     | 4962        | 5130        | -1524                | 11955                  | 0                    | 11955                         | 2353                 | 331                           | 14639           | 50.01         |
| 24                 | 3607        | 157  | 92   | 3856   | 137  | 4193      | 0    | 0     | 5133        | 5265        | -1466                | 11672                  | 0                    | 11672                         | 2316                 | 313                           | 14301           | 50.01         |
| MUs                | 97.17       | 5.23 | 2.18 | 104.58 | 5.46 | 107.09    | 0.00 | 13.49 | 125.10      | 126.52      | -32.43               | 316.71                 | 0.00                 | 316.71                        | 53.44                | 8.00                          | 378.15          | 50.03         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 24/Oct/2022

Position as on 6.30 Hrs of 25/Oct/2022

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                         |               |
| MSPGCL                | Koyna Unit 9            | 80       | 15/06/2022   | 08:00        |           | Continued. | Capital Overhaul                                                                                                                                        | 15/11/2022    |
| MSPGCL                | Bhusawal Unit 3         | 210      | 15/10/2022   | 15:10        |           | Continued. | ZERO SCHEDULE                                                                                                                                           |               |
| MSPGCL                | Parli Unit 6            | 250      | 23/10/2022   | 00:00        |           | Continued. | Zero Schedule                                                                                                                                           |               |
| MSPGCL                | Parli Unit 7            | 250      | 23/10/2022   | 00:30        |           | Continued. | Zero schedule                                                                                                                                           |               |
| MSPGCL                | Parli Unit 8            | 250      | 23/10/2022   | 13:20        |           | Continued. | Zero schedule                                                                                                                                           |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 24/10/2022   | 09:13        |           | Continued. | Zero schedule by MSEDCL                                                                                                                                 |               |
| MSPGCL                | Chandrapur Unit 5       | 500      | 24/10/2022   | 09:16        |           | Continued. | Zero schedule by MSEDCL                                                                                                                                 |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 24/10/2022   | 09:27        |           | Continued. | Zero schedule by MSEDCL                                                                                                                                 |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 24/10/2022   | 09:30        |           | Continued. | Zero schedule by MSEDCL                                                                                                                                 |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                                                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |           | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                                                                                   | 30/12/2022    |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |           | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |           | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |           | Continued. | Stator Earth Fault                                                                                                                                      | 15/11/2022    |
| MSPGCL                | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |           | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      |               |
| MSPGCL                | Uran Unit 5             | 108      | 27/09/2022   | 17:11        |           | Continued. | Gas shortage                                                                                                                                            |               |
| IPP                   | RPL(AMT) U-5            | 270      | 06/10/2022   | 21:33        |           | Continued. | Furnace Pressure High                                                                                                                                   | 27/10/2022    |
| MSPGCL                | Nasik Unit 3            | 210      | 08/10/2022   | 20:05        |           | Continued. | PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)          |               |
| MSPGCL                | Uran Unit B0            | 120      | 09/10/2022   | 11:53        |           | Continued. | TURBINE PROTECTION OPERATED                                                                                                                             | 28/10/2022    |
| MSPGCL                | Uran Unit 8             | 108      | 09/10/2022   | 12:30        |           | Continued. | BOILER PROBLEM                                                                                                                                          | 28/10/2022    |
| IPP                   | JSW (J) U1              | 300      | 11/10/2022   | 02:40        |           | Continued. | No Schedule                                                                                                                                             |               |
| MSPGCL                | Koradi Unit 9           | 660      | 18/10/2022   | 17:15        |           | Continued. | Boiler Tube Leakage                                                                                                                                     | 27/10/2022    |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 24/Oct/2022**

**Position as on 6.30 Hrs of 25/Oct/2022**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage         | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------|---------------|
| IPP                | SWPGPL U-3              | 135      | 21/10/2022   | 01:33        |            | Continued. | Coal Shortage            |               |
| MSPGCL             | Paras Unit 4            | 250      | 22/10/2022   | 16:51        |            | Continued. | Turbine Vibration        | 05/11/2022    |
| IPP                | SWPGPL U-1              | 135      | 23/10/2022   | 20:29        |            | Continued. | PA Fan Vibration Problem | 26/10/2022    |
| MSPGCL             | Khaparkheda Unit 4      | 210      | 25/10/2022   | 13:17        | 25/10/2022 | 17:53      | Governing problem        |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 24/Oct/2022**

**Statement-VII**

Position as on 6.30 Hrs of 25/Oct/2022

| Name of Line                                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                     |
|-------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>                              |                           |              |              |            |            |             |                                                                                                                                                                                                                                                      |
| CHANDRAPUR - PADGHE HVDC POLE 1                                   | IntraState                | 24/10/2022   | 16:28        | 24/10/2022 | 20:19      | EO          | For attending oil leakage of Pole-1 R-ph Converter transformer at 3b turret                                                                                                                                                                          |
| <b>400 KV TIEBAY Outages/Trippings</b>                            |                           |              |              |            |            |             |                                                                                                                                                                                                                                                      |
| TIE BREAKER (411) OF KORADI CKT 1 AND STATION TF-2 @ NANDGAONPETH | InterState                | 13/10/2022   | 11:42        |            |            | EO          | SF6 Gas Replenishment in Tie breaker (411) due to low SF6 Gas Alarm is coming intermittently and Density Monitor level is showing near alarm value.                                                                                                  |
| TIE BAY (405) OF PGCIL & ICT - 2 @ LAMBOTI                        | IntraState                | 24/10/2022   | 12:29        | 24/10/2022 | 14:00      | EO          | AIR LEAKAGE FROM EMERGENCY SWITCH ASSEMBY OF CB 405                                                                                                                                                                                                  |
| <b>400 KV MAINBAY Outages/Trippings</b>                           |                           |              |              |            |            |             |                                                                                                                                                                                                                                                      |
| 400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2                    | InterState                | 23/06/2022   | 20:33        |            |            | EO          | for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425                                                                                                                                      |
| <b>400 KV LINE Outages/Trippings</b>                              |                           |              |              |            |            |             |                                                                                                                                                                                                                                                      |
| DHULE - SSNNL CKT - 1                                             | InterState                | 24/10/2022   | 22:04        | 25/10/2022 | 05:47      | HT          | Overvoltage                                                                                                                                                                                                                                          |
| KARAD - LONIKAND I                                                | IntraState                | 10/10/2022   | 09:28        |            |            | PO          | 1. Errection of 315A & 316 in line tower.<br>2. Loc no. 315 to 315A S/C stringing.<br>3. Loc no. 315A to 33(D/C LILO tower) stringing.<br>4. Loc No. 316 to 33(D/C LILO tower) stringing.<br>5. Dismantling of existing in line tower at loc no 316. |
| JAIGAD - KARAD CKT - 1                                            | IntraState                | 21/10/2022   | 23:47        |            |            | HT          | H/T to control Over Voltage.                                                                                                                                                                                                                         |
| KHADKA-AURANGABAD (WALUJ)                                         | IntraState                | 22/10/2022   | 23:41        |            |            | HT          | To control overvoltage                                                                                                                                                                                                                               |
| PADGHE - NAGOTHANE CKT - 1                                        | IntraState                | 24/10/2022   | 21:50        |            | Continued. | HT          | Overvoltage                                                                                                                                                                                                                                          |
| LONIKAND I - KOYNA STAGE-IV                                       | IntraState                | 24/10/2022   | 23:48        | 25/10/2022 | 08:17      | HT          | HT for Overvoltage control                                                                                                                                                                                                                           |
| NEW KOYNA - DABHOL CKT - 1                                        | IntraState                | 25/10/2022   | 19:38        |            |            | T           | Tripped due to Overvoltage                                                                                                                                                                                                                           |
| LONIKAND I - KOYNA STAGE-IV                                       | IntraState                | 25/10/2022   | 23:25        |            | Continued. | HT          | HT for Overvoltage Control                                                                                                                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>                               |                           |              |              |            |            |             |                                                                                                                                                                                                                                                      |
| 400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE                          | IntraState                | 24/10/2022   | 16:35        | 24/10/2022 | 17:57      | EO          | To attained Damaged Neutral CT                                                                                                                                                                                                                       |
| <b>220 KV LINE Outages/Trippings</b>                              |                           |              |              |            |            |             |                                                                                                                                                                                                                                                      |
| BORIVALI - TARAPUR                                                | IntraState                | 18/10/2022   | 09:21        | 24/10/2022 | 20:36      | PO          | Conductor replacement work under Scheme from Loc No.19-28 ( Yph & Bph).                                                                                                                                                                              |
| GOREGAON - AAREY CKT - 2                                          | IntraState                | 23/10/2022   | 00:23        | 25/10/2022 | 17:18      | EO          | Hot spot observed on Y phase CB 252 Connector Pad                                                                                                                                                                                                    |
| BIDRI - SAWANTWADI                                                | IntraState                | 23/10/2022   | 22:12        | 24/10/2022 | 09:53      | HT          | To control overvoltage                                                                                                                                                                                                                               |
| TROMBAY MSETCL TIE - 2                                            | IntraState                | 24/10/2022   | 11:13        | 24/10/2022 | 15:28      | EO          | Oil leakage                                                                                                                                                                                                                                          |
| DASTURI-KANDALGAON LINE                                           | IntraState                | 24/10/2022   | 14:45        | 24/10/2022 | 19:30      | T           | Tripped on Dist. Protection                                                                                                                                                                                                                          |
| BIDRI - SAWANTWADI                                                | IntraState                | 24/10/2022   | 15:10        | 25/10/2022 | 08:50      | HT          | H/T For voltage control                                                                                                                                                                                                                              |
| AAREY - MSETCL BORIVALI CKT - 2                                   | IntraState                | 24/10/2022   | 22:53        |            |            | T           | R-ph Differential Protection                                                                                                                                                                                                                         |
| HALKARNI - TILARI LINE                                            | IntraState                | 25/10/2022   | 10:02        | 25/10/2022 | 13:55      | PO          | For attending hot spot at Loc. No. 287 B Ph                                                                                                                                                                                                          |
| BABLESHWAR - AHAMADNAGAR-I-JEUR TAP                               | IntraState                | 25/10/2022   | 14:04        | 25/10/2022 | 16:21      | EO          | Replacement of R ph string at loc No. 98 (As line was AR on dt 24.10.2022, found during vertical patrolling)                                                                                                                                         |
| BHUGAON - WARDHA (PG)                                             | IntraState                | 25/10/2022   | 18:24        | 25/10/2022 | 19:52      | HT          | H/T due to low frequency                                                                                                                                                                                                                             |
| BIDRI - SAWANTWADI                                                | IntraState                | 25/10/2022   | 19:45        |            | Continued. | HT          | For control Over voltage                                                                                                                                                                                                                             |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 24/Oct/2022**

**Statement-VII**

Position as on 6.30 Hrs of 25/Oct/2022

| Name of Line                                 | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                  |
|----------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>220 KV ICT Outages/Trippings</b>          |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                   |
| 220 / 110 / 22kV 250 MVA ICT 1 @<br>SALSETTE | IntraState                   | 12/10/2020      | 11:35           |            |               | T              | Tripped due to Grid disturbance.                                                                                                                                                                                                                                                                                                                  |
| 220/132KV 100MVA PTR 1 @<br>KHAREPATAN       | IntraState                   | 22/09/2022      | 16:35           |            |               | T              | ICT bursted                                                                                                                                                                                                                                                                                                                                       |
| 220/33kV 50MVA TF-3 @ 5 STAR<br>MIDC         | IntraState                   | 24/10/2022      | 09:45           | 24/10/2022 | 14:05         | PO             | For diagnostic testing of TF 3 and<br>HV CB, CTs, relay testing,<br>quarterly maintenance.                                                                                                                                                                                                                                                        |
| <b>110 KV LINE Outages/Trippings</b>         |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                   |
| DHARAVI VIKHROLI                             | IntraState                   | 30/08/2021      | 00:03           |            |               | PO             | Shifting of OPGW and stringing of<br>conductor of 220 kV Trombay-<br>Dharavi- Salsette line and<br>replacement and shifting of<br>conductor of Dharavi Powai and<br>Dharavi Vikhroli line on new tower<br>and dismantling old towers in<br>section 32 to 38. 110 KV Vikhroli<br>Powai line will be formed for dual<br>feed to Vikhroli and Powai. |
| DHARAVI POWAI                                | IntraState                   | 30/08/2021      | 00:03           |            |               | PO             | Shifting of OPGW and stringing of<br>conductor of 220 kV Trombay-<br>Dharavi- Salsette line and<br>replacement and shifting of<br>conductor of Dharavi Powai and<br>Dharavi Vikhroli line on new tower<br>and dismantling old towers in<br>section 32 to 38. 110 KV Vikhroli<br>Powai line will be formed for dual<br>feed to Vikhroli and Powai. |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage