

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Nov/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.290	3393.449	1) Gujrat	-9.062	-201.217
2) Hydro	12.022	204.921	2) Madhya Pradesh	1.179	-36.857
3) Gas	5.600	58.083	3) Chattisgarh	7.100	149.160
Total MSPGCL	157.912	3656.453	4) Maharashtra	165.442	4054.866
B) 1) APMIL	73.977	1588.396	5) Goa (Amona)	-1.403	-33.219
2) JSWEL	11.345	294.880	Total	163.256	3932.733
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.815	741.190
4) RPL(AMT)	31.180	643.863	b) Mumbai Drawl	33.842	851.913
5) SWPGPL	7.970	178.007	c) MSEDCL Bilateral *	63.116	1660.384
6) Other IPP	43.402	831.376	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.815	741.188
C) 1) TPCL Thermal	11.016	258.792	Include PX	0.000	0.000
2) TPCL Hydro	3.757	83.822	Standby	0.000	0.002
3) TPCL Gas	0.367	13.475	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.870	212.114	1) MSEDCL	463.461	10650.389
D) STATE			2) Mumbai Discoms	58.852	1420.116
1) Thermal	329.050	7400.877	3) Other Discoms	9.530	224.170
(A1+C1+C4+(B1-B6))			TOTAL STATE	531.843	12294.675
2) Hydro (A2+C2)	15.779	288.743			
3) Gas (A3+B7+C3)	5.967	71.558			
4) Wind	6.343	314.525			
6) SOLAR	11.448	286.239			
TOTAL STATE	368.587	8361.942			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6199	5969	6128	5419
MSPGCL Hydro	685	269	1534	126
MSPGCL Gas	232	229	231	238
MSPGCL Total Generation	7116	6467	7893	5783
Central Sector Receipt	8454	8191	6234	5637
WIND	171	129	147	450
CPP / IPP Thermal	7072	7043	7370	6510
CPP / IPP Gas	0	0	0	0
SOLAR	1570	1716	0	0
Exchange with Mumbai	-1755	-1776	-1431	-919
MSEDCL DEMAND MET	22191	21346	19772	17165
Load Shedding	0	0	0	0
MSEDCL DEMAND	22191	21346	19772	17165
TPCL GENERATION	704	671	989	483
AEML GENERATION	499	499	488	302
MUMBAI DEMAND	2958	2946	2908	1704
OTHER DISCOM DEMAND	437	424	441	296
STATE DEMAND MET	25586	24716	23121	19165
STATE DEMAND	25586	24716	23121	19165
Frequency (Hz)	49.91	49.97	50.02	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 14:04 Hrs	49.81 Hz at 09:43 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.22	107.82	145	0
Unit 7	0.00	0.00	0	0
Unit 8	13.97	306.88	635	494
Unit 9	13.57	305.87	600	530
Unit 10	12.67	163.12	545	515
Total	40.42	883.69		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.43	195.42	415	275
Unit 5	8.50	223.20	435	275
Total	16.93	418.62		
Parli				
Unit 6	4.30	95.97	227	148
Unit 7	4.20	90.22	227	140
Unit 8	3.66	81.90	162	144
Total	12.16	268.09		
Chandrapur				
Unit 3	3.51	75.84	173	125
Unit 4	3.03	69.49	135	116
Unit 5	6.37	154.59	280	250
Unit 6	6.63	127.68	295	255
Unit 7	7.29	173.03	345	16
Unit 8	9.09	228.99	445	285
Unit 9	8.85	176.86	425	255
Total	44.75	1006.48		
Paras				
Unit 3	5.37	118.32	232	216
Unit 4	5.41	63.70	236	209
Total	10.78	182.02		
Khaparkheda				
Unit 1	2.56	64.42	115	95
Unit 2	2.73	64.58	120	100
Unit 3	3.72	77.70	179	129
Unit 4	0.00	77.25	0	0
Unit 5	0.00	210.83	0	0
Total	9.01	494.77		
Nasik				
Unit 3	3.17	13.73	162	114
Unit 4	3.06	67.06	145	115
Unit 5	0.00	58.99	0	0
Total	6.23	139.78		
Uran				
All Units	5.60	58.08	241	222
Total	5.60	58.08		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	11.83	46	0
Total	0.10	11.83		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.32	57.15	525	40
Stage 4	3.70	48.55	759	0
Stage 3	1.58	23.47	314	0
Total	8.59	129.18		
Hydro				
KDPH	0.43	8.51	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.55	6.42	58	0
BHIRA T.R.	0.12	4.29	40	0
SMLHY_PTN	1.78	38.39	81	66
GHATGHAR	0.45	6.30	125	0
Total	3.33	63.91		
Wind				
Total	6.34	314.52	0	0
Total	6.34	314.52		
CPP				
APML(Mus)	73.98	1588.40	0	0
JSWEL(Mus)	11.34	294.88	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.18	643.86	0	0
SWPGPL-Mus	7.97	178.01	0	0
Other(Mus)	43.40	831.38	0	0
Total	167.87	3536.52		
SOLAR				
Total	11.45	286.24	0	0
Total	11.45	286.24		
Tata				
Trombay 5	7.52	175.54	434	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.20	7.77	41	0
Trombay 7B	0.16	5.71	34	0
TATA Hydro	3.76	83.82	377	16
Trombay 8	3.50	83.26	178	127
Total	15.14	356.09		
AEMIL				
DTPS U-1&2	9.87	212.11	502	302
Total	9.87	212.11		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.29	3393.45	MSPGCL Total	157.91	3656.45
			MSPGCL Thml+Gas	145.89	3451.53	Koyna 1,2 & 4 Total	7.02	105.70
			MSPGCL Hydro	12.02	204.92	State Total	368.59	8361.94

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5102	125	238	5465	331	6877	0	0	5709	5676	-1169	16822	0	16822	1994	358	19174	49.99
2	5334	124	240	5698	409	6849	0	0	5935	5719	-1041	17289	0	17289	1864	345	19498	50.03
3	5417	124	240	5781	442	6652	0	0	5922	5580	-954	17185	0	17185	1763	316	19264	50.00
4	5419	126	238	5783	450	6510	0	0	5877	5637	-919	17165	0	17165	1704	296	19165	49.98
5	5620	160	240	6020	439	6842	0	0	5651	5766	-921	17830	0	17830	1711	316	19857	49.97
6	6125	130	238	6493	455	7084	0	0	6171	6626	-1072	19233	0	19233	1839	353	21425	50.01
7	6189	469	241	6899	442	7060	0	17	6920	6793	-1174	19654	0	19654	2018	383	22055	49.97
8	6228	1532	239	7999	428	7127	0	294	6563	6921	-1322	21048	0	21048	2194	399	23641	50.00
9	6179	861	238	7278	274	7104	0	821	7470	7574	-1522	21098	0	21098	2496	431	24025	50.00
10	6157	664	238	7059	190	7105	0	1265	7682	7906	-1574	21529	0	21529	2783	422	24734	49.92
11	6199	685	232	7116	171	7072	0	1570	8151	8454	-1755	22191	0	22191	2958	437	25586	49.91
12	6096	474	231	6801	174	7003	0	1796	8318	8196	-1831	21718	0	21718	3007	421	25146	50.00
13	5969	269	229	6467	129	7043	0	1716	8050	8191	-1776	21346	0	21346	2946	424	24716	49.97
14	6020	374	227	6621	89	7025	0	1514	7606	7538	-1667	20710	0	20710	2847	410	23967	49.98
15	6059	399	222	6680	81	7018	0	1248	8064	8182	-1642	21156	0	21156	2881	411	24448	49.97
16	6012	323	223	6558	92	7017	0	837	8363	8040	-1653	20471	0	20471	2922	420	23813	50.00
17	5920	589	226	6735	96	7070	0	332	7803	7504	-1568	19717	0	19717	2899	452	23068	49.98
18	6094	1430	226	7750	156	7316	0	38	6316	6192	-1567	19433	0	19433	2876	452	22761	49.92
19	6128	1534	231	7893	147	7370	0	0	6068	6234	-1431	19772	0	19772	2908	441	23121	50.02
20	6037	777	232	7046	186	7023	0	0	6599	6742	-1542	19008	0	19008	2770	447	22225	50.00
21	5638	273	230	6141	257	6979	0	0	6084	6149	-1418	17690	0	17690	2604	418	20712	49.97
22	5467	281	232	5980	208	6897	0	0	5804	6196	-1497	17373	0	17373	2428	411	20212	50.00
23	5433	162	233	5828	288	6929	0	0	5710	5728	-1438	16952	0	16952	2268	383	19603	49.96
24	5448	137	236	5821	409	6902	0	0	5667	5712	-1389	17074	0	17074	2172	381	19627	50.00
MUs	140.29	12.02	5.60	157.91	6.34	167.87	0.00	11.45	162.50	163.26	-33.84	463.46	0.00	463.46	58.85	9.53	531.84	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Nov/2022

Position as on 6.30 Hrs of 25/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.	25/11/2022
MSPGCL	Koyana STG-IV Unit-3	250	19/11/2022	09:25		Continued.	Trunnion Seal repair work.	25/11/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20		Continued.	Boiler Tube Leakage	26/11/2022
MSPGCL	Khaparkheda Unit 5	500	23/11/2022	12:45		Continued.	WITHDRAWN DUE TO CLINKER FORMATION	29/11/2022
MSPGCL	Chandrapur Unit 7	500	23/11/2022	21:04	24/11/2022	00:51	HP Turbine Leakage	
MSPGCL	Koradi Unit 6	210	23/11/2022	22:04	24/11/2022	22:11	Station T/F Fail	24/11/2022
MSPGCL	Khaparkheda Unit 4	210	24/11/2022	00:01		Continued.	Boiler Tube Leakage	25/11/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 25/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (712) OF AKOLA CKT - 2 @ KORADI 3	IntraState	24/11/2022	09:45	24/11/2022	18:32	PO	Annual Maintenance of Bay Equipment
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	18/11/2022	00:36			PO	For Pole 1 Scheduled Annual Outage and Pole1 Y Phase Converter Transformer replacement work.
400 KV TIEBAY Outages/Trippings							
TIE BAY (408) OF STN T/F-2 & KORADI 3 CKT-1 @ KORADI 2	IntraState	24/11/2022	10:16	24/11/2022	18:33	PO	Diagnostic Testing of CT & CB and routine bay maintenance work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (404) OF ICT - 2 @ JEJURI	IntraState	24/11/2022	10:35	24/11/2022	18:01	PO	Testing and Maintenance Work
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
PADGHE - PADGHE HVDC CKT- 1	IntraState	18/11/2022	00:36			PO	1) Bay Maint work 2) Diagnostic Testing work 3)A Bus :- PG Isolator replacement of 400kV HVDC-I Y&B-ph ϕ 4) Bhel CB Pole Overhauling work. If pole overhauling not completed within outage period line will be charge on TBC.
LONIKAND I - KOYNA STAGE-IV	IntraState	19/11/2022	18:23			EO	For shifting 400kV Lonikand-Stage IV line on 400kV TBC due to hotspot on 29 B Isolator B phase on hanger rod assembly
BUS - 2 @ NEW KOYNA	IntraState	21/11/2022	12:51			PO	1) 21/11/2022 to 22/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 23/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 3) 24/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 25/11/2022 Bus Insulator replacement work at section Koyana -I & II and damage conductor replacement work 5) 26/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 27/11/2022 to 28/11/2022 Bus Insulator replacement work at section Jaigad - I & II
KHADKA-AURANGABAD (WALUJ)	IntraState	23/11/2022	20:29	24/11/2022	06:19	HT	For voltage control
BABHALESHWAR - PADGHE CKT-1	IntraState	24/11/2022	00:09	24/11/2022	02:58	EO	To attend Hot spot at Cut point Tower Loc No.108 (R)phase under 400kV R.S.(O&M) Division Babhaleshwar
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	24/11/2022	06:30	24/11/2022	17:56	PO	1) String Disc Replacement Work 2) Maintenance Work
KORADI - KHADKA	IntraState	24/11/2022	10:34			PO	For CB Mechanism Overahuling work by agency

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 25/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
FUTURE CKT - 1 @ WARORA	IntraState	24/11/2022	11:16	24/11/2022	14:20	PO	Routine maintenance and Relay Testing works and isolater maintenance work, CT tan delta .
BABHALESHWAR - PADGHE CKT - 2	IntraState	24/11/2022	15:10			EO	During Yard Inspection a leakage is observed on Bph Grading capacitor of 400 KV Padghe-II and it is requested to give permission for shifting of 400 KV BBLR-Padghe-II on 400 KV TBC to attend the same.
JAIGAD - NEW KOYNA CKT - 2	IntraState	25/11/2022	08:57			PO	Bus Insulator replacement work at section Jaigad - I & II
JAIGAD - NEW KOYNA CKT - 1	IntraState	25/11/2022	09:14			PO	Bus Insulator replacement work at section Jaigad - I & II
400 KV ICT Outages/Trippings							
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	24/11/2022	10:00	24/11/2022	18:33	PO	Bus Insulator replacement work at section ICT I & ICT-II
400/220/33 KV 315MVA ICT - 1 @ CHAKAN	IntraState	24/11/2022	12:06	24/11/2022	22:51	PO	For Overhauling of Bus C 89C Rph, Yph and Bph PG Isolators and Routine Testing and Maintenance Work.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	24/11/2022	13:27	24/11/2022	17:27	T	TRIPPED ON NDR
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	25/11/2022	08:00			PO	Erection of 400 kV bushing & testing of ICT-I unit after internal inspection is required for internal inspection of ICT-I R ph unit & taking R ph unit in service & spare ICT-I unit is to be taken out from RRS & kept on humming.
220 KV MAINBAY Outages/Trippings							
220KV SHIVAJINAGAR - MALEGAON	IntraState	24/11/2022	14:35	24/11/2022	19:25	PO	For replacement of Faulty disc insulators
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KHARGHAR - NERUL	IntraState	22/11/2022	06:38			EO	A bus to B bus shift Via TBC for prevent to further avoid damage of A bus B phase conductor near Nerul bay.
KHARGHAR - SONKHAR	IntraState	22/11/2022	10:45			EO	B bus to A bus shift Via TBC for balancing of Bus loading & Nerul ,Sonkhar line connected to MMR region for saftey purpose both are charged throuh different Bus.
EKLAHARE (OCR) - PADGHE	IntraState	23/11/2022	08:22			HT	H/T TO CONTROL 220KV NASIK-BBLSR LINEL OADING

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 25/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ONGC PANVEL - TSS PANVEL	IntraState	23/11/2022	09:05			PO	1. Outage on 220kV ONGC Panvel TSS line for Retrofitting the Differential Relay at 220kV ONGC S/s for New 220kV Panvel TSS on dt. 23.11.2022 2. Outage on 220kV ONGC Panvel TSS line and 220kV Kharghar-Panvel TSS line for connecting the second circuit and making the LILO to 220kV New Panvel TSS on dt. 24.11.2022 from Loc No. 3 Lattice Tower to Monopole No.1
CHALISGAON -BABHALESHWAR	IntraState	23/11/2022	09:46			HT	APPROVED OUTAGE FOR C.T REPLACEMENT WORK AT CHALISGAON END
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	23/11/2022	10:08	24/11/2022	16:33	EO	In view of tripping on PDR and while closing of CB of navsari1 giving dummy strokes hence as per CGL Engineer it is necessary to do mech. Overhauling of CB Line will be shifted on TBC at eklahare end. Outage on line not required.
POPHLI PEDHMBE LINE- 2	IntraState	23/11/2022	18:42	24/11/2022	16:55	T	R ph LA burst
LONIKAND 2 - VSNL	IntraState	24/11/2022	07:10	24/11/2022	15:42	PO	Digital Bay Relay Testing Work (CB A/R Testing) and fixing of earth rod for line isolator.
EKLAHARE (GCR) - GHATGHAR	IntraState	24/11/2022	08:47	24/11/2022	16:02	PO	Diagnosis of testing work
LONAND-BARAMATI	IntraState	24/11/2022	09:28	24/11/2022	17:06	PO	To increase ground clearance between loc no 4 to 14
PHURSUNGI-SERUM	IntraState	24/11/2022	10:00	24/11/2022	18:08	PO	Maintenance of main bus isolators of PTR-2, metering bay-1 & Phursungi bay.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	24/11/2022	16:00	24/11/2022	21:13	HT	For load management
AAREY - MSETCL BORIVALI CKT - 1	IntraState	24/11/2022	17:39			T	Tripped on Differential protection
PEDHAMBE ONI LINE	IntraState	25/11/2022	09:00			PO	C & Tan delta test of Line CT and bay equipment maintenance
JAMBHUL - ANANDNAGAR	IntraState	25/11/2022	09:13			PO	1) Jaw Replacement and Servicing, Overhauling, alignment of 220 kV Bus Isolators of Jambhul-Anandnagar Line. 2) Bus Isolators Maintenance Work of ICT-2 & Section-2 Isolators.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	25/11/2022	09:38			HT	H/T TO CONTROL LOAD MANAGEMENT
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	23/11/2022	18:56	24/11/2022	00:09	PO	Replacement of gasket due to oil leakage and replacement of PID faulty insulator string
220/132-110 KV 100MVA ICT No-02 @ OGLEWADI	IntraState	24/11/2022	10:17	24/11/2022	20:53	PO	HV Y Ph Bushing replacement work
220/33kV 100 MVA TF 3 @ GHODBUNDER	IntraState	24/11/2022	10:21	24/11/2022	15:53	PO	Annual maintenance of Circuit Breaker.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	24/11/2022	10:40	24/11/2022	20:52	PO	To attending the SF6 gas leakage problem of Siemens make 245 kV CB , Sr No. 2021/33052

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 25/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	24/11/2022	11:17	24/11/2022	13:36	PO	EARTH BLADE FIXING
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	25/11/2022	09:10			PO	1) Jaw Replacement and Servicing, Overhauling, alignment of 220 kV Bus Isolators of Jambhul-Anandnagar Line. 2) Bus Isolators Maintenance Work of ICT-2 & Section-2 Isolators.
220/132KV 200MVA PTR 1 @ LONAND	IntraState	25/11/2022	09:25			PO	Oil leakage attending work
110 KV LINE Outages/Trippings							
AMBERNATH - KALYAN CKT - 2	IntraState	24/11/2022	15:37	24/11/2022	18:40	PO	Project Work for closing loop at loc-1 after install and commissioning new 110 KV breaker at OFA.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage