

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Nov/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	165.235	4009.896	1) Gujrat	6.336	83.044
2) Hydro	5.893	174.228	2) Madhya Pradesh	3.940	101.297
3) Gas	6.841	141.778	3) Chattisgarh	7.820	185.780
Total MSPGCL	177.969	4325.902	4) Maharashtra	214.769	4899.918
B) 1) APLM	49.350	1109.176	5) Goa (Amona)	-1.857	-38.067
2) JSWEL	18.314	566.515	Total	231.008	5231.972
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.311	915.811
4) RPL(AMT)	25.542	588.863	b) Mumbai Drawl	39.853	986.814
5) SWPGPL	7.056	249.196	c) MSEDCL Bilateral *	99.432	2308.416
6) Other IPP	34.650	623.260	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.311	915.794
C) 1) TPCL Thermal	12.112	280.177	Include PX	0.000	0.000
2) TPCL Hydro	3.556	65.547	Standby	0.000	0.017
3) TPCL Gas	2.406	55.282	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.684	187.060	1) MSEDCL	514.006	11986.951
D) STATE			2) Mumbai Discoms	67.611	1574.860
1) Thermal	321.943	7614.143	3) Other Discoms	10.566	250.199
(A1+C1+C4+(B1-B6))			TOTAL STATE	592.183	13812.010
2) Hydro	9.449	239.775			
(A2+C2)					
3) Gas	9.247	197.060			
(A3+B7+C3)					
4) Wind	9.619	215.706			
6) SOLAR	10.917	313.374			
TOTAL STATE	361.175	8580.058			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7079	6910	6881	6919
MSPGCL Hydro	381	134	347	133
MSPGCL Gas	282	278	282	295
MSPGCL Total Generation	7742	7322	7510	7347
Central Sector Receipt	11321	10938	9608	8532
WIND	396	254	341	515
CPP / IPP Thermal	5514	5140	6282	5209
CPP / IPP Gas	0	0	0	0
SOLAR	1458	1753	0	0
Exchange with Mumbai	-1889	-1989	-1615	-1203
MSEDCL DEMAND MET	24072	22960	21642	20038
Load Shedding	0	0	0	0
MSEDCL DEMAND	24072	22960	21642	20038
TPCL GENERATION	852	862	1203	542
AEML GENERATION	493	498	483	319
MUMBAI DEMAND	3234	3349	3301	2064
OTHER DISCOM DEMAND	470	458	484	362
STATE DEMAND MET	27776	26767	25427	22464
STATE DEMAND	27776	26767	25427	22464
Frequency (Hz)	50.03	50.00	50.04	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 06.03 Hrs	49.72 Hz at 09.17 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Nov/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.89	97.84	180	135
Unit 8	14.65	281.80	628	570
Unit 9	11.93	260.00	623	0
Unit 10	13.87	334.06	601	540
Total	44.34	973.70		
Bhusawal				
Unit 3	3.98	16.91	175	150
Unit 4	9.11	216.72	445	325
Unit 5	5.95	232.51	380	160
Total	19.04	466.14		
Parli				
Unit 6	4.67	112.43	249	151
Unit 7	4.69	98.97	248	148
Unit 8	5.05	121.76	250	156
Total	14.42	333.16		
Chandrapur				
Unit 3	2.96	71.80	151	48
Unit 4	3.50	78.10	151	135
Unit 5	9.93	248.15	435	350
Unit 6	0.00	177.58	0	0
Unit 7	6.88	181.67	324	233
Unit 8	10.78	260.07	477	422
Unit 9	10.74	266.43	459	431
Total	44.78	1283.80		
Paras				
Unit 3	5.50	130.95	238	220
Unit 4	5.66	130.36	249	222
Total	11.17	261.31		
Khaparkheda				
Unit 1	3.61	84.36	170	125
Unit 2	2.54	55.35	120	84
Unit 3	3.51	80.31	170	55
Unit 4	4.38	71.54	190	171
Unit 5	10.49	229.72	460	420
Total	24.53	521.29		
Nasik				
Unit 3	3.55	72.07	164	126
Unit 4	0.00	53.00	0	0
Unit 5	3.42	45.42	154	121
Total	6.96	170.49		
Uran				
All Units	6.84	141.78	295	269
Total	6.84	141.78		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.33	14.99	47	0
Total	0.33	14.99		
Koyna				
Stage 1-2	1.72	46.40	320	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.19	23.05	153	0
Stage 3	0.86	16.48	160	0
Total	2.78	85.93		
Hydro				
KDPH	0.20	6.27	18	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	2.54	0	0
SMLHY_PTN	2.26	58.33	97	90
GHATGHAR	0.33	6.16	125	0
Total	2.79	73.30		
Wind				
Total	9.62	215.71	0	0
Total	9.62	215.71		
CPP				
APML(Mus)	49.35	1109.18	0	0
JSWEL(Mus)	18.31	566.52	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.54	588.86	0	0
SWPGPL-Mus	7.06	249.20	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.38	126.36	267	186
Other(Mus)	29.27	492.09	0	0
JPL	0.00	4.81	0	0
Total	134.91	3137.01		
SOLAR				
Total	10.92	313.37	0	0
Total	10.92	313.37		
Tata				
Trombay 5	8.03	183.67	451	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.34	31.46	108	38
Trombay 7B	1.06	23.82	65	36
TATA Hydro	3.56	65.55	395	50
Trombay 8	4.08	96.50	231	131
Total	18.07	401.01		
AEML				
DTPS U-1&2	9.68	187.06	500	305
Total	9.68	187.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	165.24	4009.90	MSPGCL Total	177.97	4325.90
			MSPGCL Thml+Gas	172.08	4151.67	Koyna 1,2 & 4 Total	1.92	69.45
			MSPGCL Hydro	5.89	174.23	State Total	361.18	8580.06

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 24/Nov/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6898	134	290	7322	484	5402	0	0	8764	8421	-1569	19649	0	0	19649	2463	411	22523	49.99
2	6826	134	293	7253	417	5273	0	0	8674	8794	-1360	19998	0	0	19998	2296	379	22673	50.01
3	6870	135	292	7297	522	5231	0	0	8524	8704	-1303	20091	0	0	20091	2155	360	22606	50.02
4	6919	133	295	7347	515	5209	0	0	8518	8532	-1203	20038	0	0	20038	2064	362	22464	50.02
5	6952	131	293	7376	553	5353	0	0	8838	9046	-1194	20775	0	0	20775	2038	359	23172	49.99
6	7026	132	292	7450	476	5545	0	0	9359	9500	-1271	21310	0	0	21310	2118	390	23818	50.00
7	7218	133	293	7644	448	5608	0	5	9591	9643	-1387	21542	0	5	21542	2245	419	24206	50.02
8	7281	490	294	8065	358	5810	0	179	9402	9862	-1430	22396	0	4	22396	2400	448	25244	49.98
9	7236	739	295	8270	357	5992	0	573	9689	9845	-1707	22867	0	12	22867	2686	463	26016	49.98
10	7249	458	289	7996	435	6108	0	990	10237	10233	-1633	23657	0	69	23657	3006	472	27135	49.93
11	7079	381	282	7742	396	5514	0	1458	11659	11321	-1889	24072	0	18	24072	3234	470	27776	50.03
12	6943	278	276	7497	304	5130	0	1739	11543	11378	-2000	23584	0	0	23584	3348	464	27396	50.04
13	6910	134	278	7322	254	5140	0	1753	10982	10938	-1989	22960	0	0	22960	3349	458	26767	50.00
14	6879	241	269	7389	246	4840	0	1556	10551	10902	-1878	22606	0	0	22606	3241	449	26296	50.03
15	6944	160	269	7373	240	5110	0	1311	10844	11065	-1899	22741	0	0	22741	3300	459	26500	49.99
16	6915	174	271	7360	206	5340	0	909	11022	10813	-1983	22172	0	0	22172	3334	473	25979	50.03
17	6829	269	273	7371	221	5507	0	382	10499	10194	-1927	21275	0	0	21275	3296	473	25044	50.03
18	6946	301	278	7525	250	6145	0	62	9032	9364	-1558	21318	0	0	21318	3264	470	25052	50.03
19	6881	347	282	7510	341	6282	0	0	9618	9608	-1615	21642	0	0	21642	3301	484	25427	50.04
20	6661	336	283	7280	436	6298	0	0	9402	9250	-1811	20974	0	0	20974	3164	479	24617	50.03
21	6353	173	286	6812	458	6233	0	0	8389	8336	-1763	19601	0	0	19601	2983	475	23059	49.95
22	6349	167	289	6805	534	6068	0	0	8160	8296	-1839	19402	0	0	19402	2853	462	22717	50.04
23	6455	154	288	6897	578	5891	0	0	8456	8522	-1829	19606	0	0	19606	2757	453	22816	50.01
24	6616	159	291	7066	590	5883	0	0	8673	8441	-1816	19729	0	0	19729	2716	435	22880	49.99
MUs	165.23	5.89	6.84	177.97	9.62	134.91	0.00	10.92	230.43	231.01	-39.85	514.01	0.00	0.11	514.01	67.61	10.57	592.18	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried due to overloading of 220KV BBLR-I & II

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 24/Nov/2023

Position as on 6.30 Hrs of 25/Nov/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyana Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Nasik Unit 4	210	19/11/2023	15:48		Continued.	Stator Earth Fault (Converted into AOH from 00:00 hrs dt.20/11/2023)	12/12/2023
MSPGCL	Koyana STG-IV Unit-3	250	24/11/2023	08:00		Continued.	Capital Overhauling	19/01/2024
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	15/12/2023
IPP	JPL Unit 1	150	03/11/2023	00:01		Continued.	Under shutdown condition Due to low net sales Realization cost.	29/11/2023
IPP	Adani U-5	660	16/11/2023	23:16		Continued.	Zero Schedule	
IPP	JSW (J) U1	300	22/11/2023	09:54		Continued.	CW Pump Discharge pipe heavy leakage.	
MSPGCL	Chandrapur Unit 6	500	22/11/2023	20:58		Continued.	Boiler Tube Leakage	26/11/2023
IPP	SWPGPL U-4	135	23/11/2023	07:00	24/11/2023	14:51	ID Fan Problem	24/11/2023
IPP	SWPGPL U-2	135	23/11/2023	11:27		Continued.	Bottom ash conveying system issue.	28/11/2023
MSPGCL	Koradi Unit 9	660	24/11/2023	19:40	24/11/2023	22:12	PA Fan problem	
MSPGCL	Nasik Unit 3	210	25/11/2023	00:45		Continued.	Suspected condenser tube leakage.	26/11/2023
MSPGCL	Chandrapur Unit 4	210	25/11/2023	05:19	25/11/2023	08:45	Low Vacuum	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 25/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	22/11/2023	20:43			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	22/11/2023	20:43			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
400 KV TIEBAY Outages/Trippings							
TIE BAY (405) OF TAPTITANDA CKT - 1 @ EKTUNI	IntraState	24/11/2023	10:35	24/11/2023	13:50	PO	Diagnostic Testing & Routine Maintenance
400 KV MAINBAY Outages/Trippings							
400/11.5 KV 110MVA STN T/F 6A @ DEEPNAGAR	InterState	09/11/2023	15:36			PO	For alignment work of 89L isolator of Station Transformer 6A
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
MAIN BAY (410) OF KARJAT CKT - 2 @ LONIKAND 2	IntraState	25/11/2023	09:33	25/11/2023	14:06	PO	Diagnostic testing and Maintenance
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\epsilon Y \epsilon$ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/11/2023	09:06	25/11/2023	08:22	HT	For managing over load on 400 kv PUNEGIS- TALEGAONPG line .
PADGHE - PADGHE HVDC CKT- 1	IntraState	22/11/2023	23:09			PO	1.Bay Maintenance Work. 2. Diagnostic Testing Work. 3. MTAMC work.
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	23/11/2023	11:55			PO	Scheme work of replacement of existing 0.5 ACSR conductor by HTLS conductor
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	25/11/2023	08:19		Continued.	HT	H/T For load management.
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	25/11/2023	09:23	25/11/2023	18:15	PO	To carry out conductor re-stringing / Sag adjustment work at span 222-225
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	28/10/2023	22:20			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	28/10/2023	22:27			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	28/10/2023	22:32			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 25/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	25/11/2023	08:27	25/11/2023	19:11	PO	Bay maintenance and Bus-I R phase Isolator alignment problem
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	25/11/2023	08:27	25/11/2023	19:11	PO	For quarterly bay maintenance problem and attending Bus - 1 R phase Isolator alignment problem.
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	25/11/2023	11:15	25/11/2023	13:35	PO	For attending oil leakage form 220 kV Side B Ph. CT Stud
400 KV BR Outages/Trippings							
BUS REACTOR (125MVA _r) @ VIKHROLI GIS	IntraState	25/11/2023	09:39	25/11/2023	18:00	PO	For inspection of MOG
220 KV TIEBAY Outages/Trippings							
BUS SECTIONALIZER @ BOMBAY DYING	IntraState	24/11/2023	12:05	24/11/2023	14:05	EO	220 kV bus sectionlizer isolator nut bolts red hot (replacement by hot line unit)
220 KV LINE Outages/Trippings							
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
NEW KOYNA - POPHALI	IntraState	20/11/2023	12:20		Continued.	EO	For black start mock drill at Koyna hydro power plant.
EKLAHARE (OCR) - PADGHE	IntraState	20/11/2023	17:31			HT	HT for load management from Padghe end
URAN - SEZ JNPT	IntraState	21/11/2023	11:18		Continued.	EO	Replacement of flashover polymer insulator at Loc no. 6(bottom phase)
CTRLS - NET MAGIC GIS	IntraState	23/11/2023	22:25	24/11/2023	01:33	PO	For new EHCC earthing connection to LILO Tower to avoid sparking at LILO tower.
TROMBAY DHARAVI - 6	IntraState	24/11/2023	00:02	24/11/2023	03:33	PO	OPGW stringing in Span 17 To 18 of Trombay - Salsette Link.
MAHAPE - TFIPL	IntraState	24/11/2023	08:33	24/11/2023	16:35	PO	Bay maintenance and diagnostic testing work .
AAREY - AEML SAKI CKT - 1	IntraState	24/11/2023	09:01			PO	Control Cable rewiring from LCC and CRP panels for Commissioning of New CRP
ALKUD - VITA	IntraState	24/11/2023	16:57	25/11/2023	00:00	PO	Cold Washing of Insulator Strings
URAN - KHARGHAR 2	IntraState	24/11/2023	22:18	25/11/2023	00:01	PO	Replacement of Y ph LA due to High LCM
SALSETTE - VIKHROLI (GIS) CKT - 3	IntraState	24/11/2023	23:17	25/11/2023	01:32	EO	Work in vicinity to attending critical hot spots on loop connections at loc. 89A A-Ph (106 deg) of 110KV Salsette Vikhroli -1 line
POPHLI PEDHMBE LINE- 1	IntraState	25/11/2023	09:05	25/11/2023	11:42	PO	220 KV. Pedhambe Pophali I line R phase CT. oil top up work
KARAD - WATHAR	IntraState	25/11/2023	10:03	25/11/2023	17:35	PO	For stringing of Earth wire at tower loc no. 96 to 99.
KARAD -MUDSHINGI CKT- 4	IntraState	25/11/2023	10:20	25/11/2023	17:25	PO	For stringing of Earth wire at tower loc no. 96 to 99.
CHAKAN-BHOSARI 1	IntraState	25/11/2023	11:11	25/11/2023	16:12	PO	1.Replacement of B ph damaged conductor between loc no-20-21 2.R & B phase CC Replacement work- SNR problem, & Half Yearly Bay Maintenance at 220kV Bhosari I S/s.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 25/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIWALI - PAWAS LINE	IntraState	25/11/2023	12:18	25/11/2023	18:25	PO	EHV LMSDn New Koyna & Kankavali- For cold washing of insulator strings, tree cutting and others maintenance work.
MHAISAL - ALKUD	IntraState	25/11/2023	17:59		Continued.	PO	Cold Washing of Insulator
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
250 MVA ICT-4 @ TROMBAY	IntraState	18/11/2023	09:05		Continued.	PO	1.Transformer complete gasket replacement (except bell tank) 2.Transformer complete oil filtration post gasket replacement 3.Cooler cabinet replacement 4.Radiator replacement at Trombay Generating Station.
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	24/11/2023	09:11	24/11/2023	19:12	PO	For OLTC overhauling of ICT & diagnostic testing work.
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	24/11/2023	09:44	24/11/2023	16:22	PO	For Diagnostic Testing & Bay maintenance work. Hot spot attending work of B-ph HV CB lower palm in ICT-2 bay.
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	IntraState	24/11/2023	10:01	24/11/2023	15:53	PO	Diagnostic Testing and bay maintenance wor
220/132 KV 100 MVA ICT - I	IntraState	24/11/2023	11:01	24/11/2023	15:23	PO	Diagnostic Testing Work.
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	25/11/2023	09:05	25/11/2023	14:00	PO	For diagnostic testing of ICT
220/132 KV 100 MVA ICT 1	IntraState	25/11/2023	14:07	25/11/2023	17:12	PO	Oil Top Up in ICT
220/132 KV 100 MVA ICT 2	IntraState	25/11/2023	17:33	25/11/2023	19:46	PO	Oil Top Up in ICT
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
DHARAVI - VIKHROLI CKT - 2	IntraState	23/11/2023	12:33	24/11/2023	15:16	PO	Cable terminations on Monopole No 4a and 4b at KVTL Vikhroli for 220 KV Trombay Salsette 3, 4 Circuits and Tower replacement work at S G Barve Marg, Kurla for Metro work.
DHARAVI VIKHROLI CKT - 1	IntraState	23/11/2023	12:33	24/11/2023	15:16	PO	Cable terminations on Monopole No 4a and 4b at KVTL Vikhroli for 220 KV Trombay Salsette 3, 4 Circuits and Tower replacement work at S G Barve Marg, Kurla for Metro work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage