

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Dec/2021 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	153.775	3297.553	1) Gujrat	-11.808	-177.230
2) Hydro	6.560	176.914	2) Madhya Pradesh	2.051	33.918
3) Gas	5.779	115.693	3) Chattisgarh	5.840	139.540
Total MSPGCL	166.114	3590.160	4) Maharashtra	135.429	3238.590
B) 1) APLM	69.527	1457.985	5) Goa (Amona)	-1.346	-39.356
2) JSWEL	11.793	334.209	Total	130.166	3195.462
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.716	604.432
4) RPL(AMT)	26.326	624.008	b) Mumbai Drawl	25.530	640.179
5) SWPGPL	7.676	186.026	c) MSEDCL Bilateral *	46.441	1178.292
6) Other IPP	40.148	901.168	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.716	604.432
C) 1) TPCL Thermal	7.404	191.468	Include PX	2.313	3.902
2) TPCL Hydro	5.249	104.784	Standby	0.000	0.000
3) TPCL Gas	2.223	70.452	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.452	232.482	1) MSEDCL	426.618	9753.356
D) STATE			2) Mumbai Discoms	49.858	1239.358
1) Thermal	326.101	7224.899	3) Other Discoms	9.946	234.971
(A1+C1+C4+(B1-B6))			TOTAL STATE	486.422	11227.685
2) Hydro (A2+C2)	11.809	281.698			
3) Gas (A3+B7+C3)	8.002	186.145			
4) Wind	3.973	196.484			
6) SOLAR	6.371	143.004			
TOTAL STATE	356.256	8032.230			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	7300	6919	6713	4982
MSPGCL Hydro	288	237	419	310
MSPGCL Gas	236	229	231	242
MSPGCL Total Generation	7824	7385	7363	5534
Central Sector Receipt	7122	6410	4905	4804
WIND	68	138	258	212
CPP / IPP Thermal	7100	6963	6922	5647
CPP / IPP Gas	0	0	0	0
SOLAR	843	948	3	0
Exchange with Mumbai	-1273	-1418	-1064	-1001
MSEDCL DEMAND MET	16008	15050	12565	10458
Load Shedding	0	0	0	0
MSEDCL DEMAND	16008	15050	12565	10458
TPCL GENERATION	777	670	947	481
AEML GENERATION	501	474	445	329
MUMBAI DEMAND	2551	2562	2456	1811
OTHER DISCOM DEMAND	378	358	388	316
STATE DEMAND MET	24235	22988	20843	17007
STATE DEMAND	24235	22988	20843	17007
Frequency (Hz)	49.93	50.02	50.02	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 14.03 Hrs	49.81 Hz at 09.16 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.44	86.00	180	115
Unit 7	0.00	0.00	0	0
Unit 8	14.94	330.93	660	428
Unit 9	14.07	195.61	631	460
Unit 10	12.88	312.93	592	380
Total	45.33	925.47		
Bhusawal				
Unit 3	3.22	49.58	155	120
Unit 4	8.53	207.50	450	280
Unit 5	8.85	208.48	470	275
Total	20.60	465.56		
Parli				
Unit 6	4.47	43.34	250	155
Unit 7	4.37	26.29	245	148
Unit 8	4.16	78.26	219	149
Total	13.00	147.89		
Chandrapur				
Unit 3	3.75	54.19	180	120
Unit 4	3.61	75.98	173	125
Unit 5	8.37	131.72	400	300
Unit 6	8.98	183.82	445	275
Unit 7	7.42	184.27	347	280
Unit 8	9.01	218.66	416	179
Unit 9	9.22	220.80	426	280
Total	50.37	1069.45		
Paras				
Unit 3	4.38	102.96	244	140
Unit 4	4.27	104.65	237	139
Total	8.66	207.61		
Khaparkheda				
Unit 1	0.00	24.87	0	0
Unit 2	0.00	25.46	0	0
Unit 3	0.00	27.06	0	0
Unit 4	0.00	20.47	0	0
Unit 5	9.42	227.86	450	279
Total	9.42	325.72		
Nasik				
Unit 3	3.26	44.49	172	120
Unit 4	0.00	33.17	0	0
Unit 5	3.13	78.19	178	115
Total	6.39	155.85		
Uran				
All Units	5.78	115.69	255	224
Total	5.78	115.69		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.66	4.82	37	17
Total	0.66	4.82		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.44	52.89	180	35
Stage 4	0.00	18.31	0	0
Stage 3	0.47	16.53	150	0
Total	1.90	87.74		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.46	7.46	58	0
BHIRA T.R.	0.26	6.07	40	0
SMLHY_PTN	3.93	75.59	192	139
GHATGHAR	0.00	0.00	0	0
Total	4.66	89.18		
Wind				
Total	3.97	196.48	0	0
Total	3.97	196.48		
CPP				
APML(Mus)	69.53	1457.98	0	0
JSWEL(Mus)	11.79	334.21	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.33	624.01	0	0
SWPGPL-Mus	7.68	186.03	0	0
Other(Mus)	40.15	901.17	0	0
Total	155.47	3503.40		
SOLAR				
Total	6.37	143.00	0	0
Total	6.37	143.00		
Tata				
Trombay 5	7.40	169.67	443	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.22	41.76	72	45
Trombay 7B	1.00	28.69	53	38
Trombay 8	0.00	21.80	0	0
TATA Hydro	5.25	104.78	444	8
Total	14.88	366.70		
AEML				
DTPS U-1&2	9.45	232.48	501	311
Total	9.45	232.48		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	153.78	3297.55	MSPGCL Total	166.11	3590.16
			MSPGCL Thml+Gas	159.55	3413.25	Koyna 1,2 & 4 Total	1.44	71.20
			MSPGCL Hydro	6.56	176.91	State Total	356.26	8032.23

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 24/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5043	193	250	5486	116	5587	0	0	5353	5377	-962	15291	0	15291	1656	313	17260	50.02
2	5354	204	243	5801	95	5653	0	0	5259	5242	-855	15645	0	15645	1554	291	17490	49.99
3	5825	201	255	6281	94	5596	0	0	5178	4692	-775	15620	0	15620	1476	268	17364	50.01
4	5933	197	246	6376	93	5635	0	0	5137	4846	-733	15952	0	15952	1439	265	17656	50.00
5	5974	187	245	6406	90	5808	0	0	5227	5465	-733	16747	0	16747	1452	289	18488	50.01
6	6084	190	252	6526	133	6596	0	0	5348	5296	-810	17436	0	17436	1543	305	19284	50.06
7	6697	195	243	7135	111	7014	0	6	5274	5249	-732	18455	0	18455	1663	328	20446	49.99
8	7228	350	254	7832	46	7113	0	83	5546	5556	-736	19541	0	19541	1844	353	21738	50.01
9	7392	260	245	7897	60	7115	0	362	6191	5650	-931	19776	0	19776	2132	377	22285	50.01
10	7237	323	252	7812	68	7054	0	646	6775	6757	-1149	20813	0	20813	2380	375	23568	49.89
11	7300	288	236	7824	68	7100	0	843	7085	7122	-1273	21306	0	21306	2551	378	24235	49.93
12	7247	286	247	7780	92	7077	0	968	6942	6439	-1342	20645	0	20645	2610	369	23624	49.99
13	6919	237	229	7385	138	6963	0	948	6665	6410	-1418	20068	0	20068	2562	358	22988	50.02
14	6461	247	226	6934	181	6841	0	906	6568	6456	-1413	19570	0	19570	2399	335	22304	50.05
15	6626	347	232	7205	229	6771	0	789	6608	6017	-1480	19203	0	19203	2398	328	21929	50.07
16	6815	365	224	7404	318	6816	0	518	6106	5591	-1346	18943	0	18943	2405	358	21706	50.01
17	7124	327	227	7678	324	6898	0	256	5219	4745	-1232	18302	0	18302	2393	367	21062	49.94
18	6927	272	239	7438	249	6916	0	38	4412	4260	-1080	17437	0	17437	2395	384	20216	50.01
19	6713	419	231	7363	258	6922	0	3	4824	4905	-1064	17999	0	17999	2456	388	20843	50.02
20	6958	379	243	7580	268	7005	0	0	4535	4230	-1061	17632	0	17632	2409	390	20431	50.03
21	5997	261	234	6492	266	6219	0	0	4843	4889	-1149	16323	0	16323	2274	394	18991	50.02
22	5564	297	247	6108	216	5603	0	0	5215	5127	-1127	15564	0	15564	2106	363	18033	50.00
23	5375	225	237	5837	248	5521	0	0	5234	5041	-1128	15162	0	15162	1950	357	17469	50.00
24	4982	310	242	5534	212	5647	0	0	4978	4804	-1001	14880	0	14880	1811	316	17007	50.00
MUs	153.78	6.56	5.78	166.11	3.97	155.47	0.00	6.37	134.52	130.17	-25.53	428.31	0.00	428.31	49.86	8.25	486.42	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 24/Dec/2021

Position as on 6.30 Hrs of 25/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 8	500	25/12/2021	00:01		Continued.	CW DEBRIS FILTER INSPECTION AND MAINTENENCE WORK	
IPP	SWPGL U-2	135	25/12/2021	00:09		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00	25/12/2021	11:45	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 3	210	09/12/2021	00:01	25/12/2021	11:20	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56		Continued.	CHP coal feeding problem	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22		Continued.	withdrawn against case 4 to dhariwal	
MSPGCL	Koradi Unit 8	660	25/12/2021	09:56		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 25/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	24/12/2021	21:16	24/12/2021	23:50	EO	Red hot observed at connecting jumper of capacitor bushing
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	24/12/2021	23:54	25/12/2021	01:20	EO	Red hot observed at connecting jumper of capacitor bushing
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ PARLI	IntraState	24/12/2021	03:20	24/12/2021	05:32	T	Bus Bar Operated at Bus-1 Parli
400 KV LINE Outages/Trippings							
PARLI(MS) - PARLI (PG) CKT -1	InterState	24/12/2021	03:20	24/12/2021	05:22	T	Bus Bar Operated at Bus-1 Parli
PARLI(MS) - PARLI (PG) CKT -2	InterState	24/12/2021	17:07	25/12/2021	00:25	HT	Emergency outage at Parli PG end to attend hotspot
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadraple CB. 3) Measurement of Timing, DCRM and CRM of CB.
KHADKA-AURANGABAD	IntraState	23/12/2021	07:17	25/12/2021	08:59	PO	For Reconnection of Live 400 KV Main Bus-1&2 section jumpers of 400 KV Akola & Aurangabad section after replacement of damaged bus section
KARAD - LONIKAND I	IntraState	23/12/2021	09:19	25/12/2021	09:43	PO	PID faulty disc insulator replacement work and cold line washing work
KARAD - LONIKAND I	IntraState	23/12/2021	09:19	25/12/2021	09:43	PO	Half yearly bay maintenance and DT work. Diagnostic testing and maintenance work.
KARAD - LONIKAND I	IntraState	23/12/2021	09:19	25/12/2021	09:43	PO	Distance Protection relay (M-1) replacement under MTAMC Project. Existing relay ABB REL521 & new relay Siemens 7SA52
JAIGAD - KARAD CKT - 2	IntraState	23/12/2021	22:49	24/12/2021	10:36	HT	HT for Overvoltage
PARLI-SOLAPUR (LAMBOTI)	IntraState	24/12/2021	03:17	24/12/2021	20:29	T	Y-ph and R-ph Breaker Pole Burst
CHANDRAPUR-PARLI CKT-3	IntraState	24/12/2021	03:20	24/12/2021	05:47	T	Bus Bar operated at Bus-1 Parli
PARLI - LONIKAND 2 CKT - 1	IntraState	24/12/2021	03:20	24/12/2021	05:59	T	Bus Bar operated at Bus-1 Parli
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	24/12/2021	03:20	24/12/2021	07:27	T	Bus Bar operated at Bus-1 Parli
TBC @ KORADI-1	IntraState	24/12/2021	13:40			EO	"Heavy air leakage in ABB make 400 kV CB R pole observed and CB got lockout due to 0 bar air pressure in CB. To attend the heavy air leakage of ABB make 400 kV CB R pole emergency outage is required on 400 kV TBC Bay ."
JAIGAD - KARAD CKT - 1	IntraState	24/12/2021	22:21	25/12/2021	09:59	HT	over voltage
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	IntraState	25/12/2021	09:16	25/12/2021	18:16	PO	1) Measurement of tan delta & capacitance of CTs and CVTs. 2) Maintenance & alignment of Isolators. 3) MTAMC project work
JAIGAD - KARAD CKT - 2	IntraState	25/12/2021	19:56		Continued.	HT	over voltage
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	24/12/2021	03:20	24/12/2021	05:39	T	Bus Bar Operated at Bus-1 Parli
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	24/12/2021	03:20	24/12/2021	06:09	T	Bus Bar Operated at Bus-1 Parli

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 25/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	24/12/2021	06:29	24/12/2021	07:10	T	Tripped on Pole Discrepancy Relay
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	25/12/2021	10:12	25/12/2021	23:34	PO	1) Bay maintenance work 2) Diagnostic testing work 3) MTAMC work 4) attending Hot Spot on R & Y Ph IV Bushing 120,102deg resp., B-Ph CT 102deg
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	25/12/2021	18:00	25/12/2021	19:30	EO	For attending of red hot on HV Side 2Y2 Ph bushing of ICT 1
220 KV MAINBAY Outages/Trippings							
MAIN BAY(208) OF 220KV-SOLAPUR-FUTURE 1 @SOLAPUR (PG)-220 KV	InterState	20/12/2021	17:22		Continued.	PO	reorientation work along with the disconnection of 220KV Bale-Tuljapur line at Loc.NO. 37 and establishment of link between Solapur PG to 220KV Bale substation will be carried out by utilizing D/C portion of Solapur PG -Bale line and jumpering work at substation end.
AIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	24/12/2021	09:56	24/12/2021	15:31	PO	Annual maintenance of Bay equipments and Circuit Breaker
TBC @ BABHLESHWAR	IntraState	25/12/2021	15:00	25/12/2021	16:40		R phase CT oil top up
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	23/12/2021	22:09	24/12/2021	04:27	EO	Attending hot spot at atloc no.80 (Bottom Y-Ph-Nalasopara side,Temp-106)& (Bottom R-ph PGCIL Side,Temp-115)
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
SOLAPUR(BALE) - TULJAPUR	IntraState	20/12/2021	10:54		Continued.	PO	Outage is required 1. Testing & communication work of line and bay at both substation (Bale & PGCIL) 2. Jumpering work at loc 37 on 220kV PGCIL Bale Line 3. Shifting of WT, CC & LMU (in existing Tuljapur bay) at 220kV Bale Substaion.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	23/12/2021	22:42	24/12/2021	09:32	T	Distance Trip z-1 15 km from AKP, 7.5 KAMP
NAGOTHANE - POSCO	IntraState	24/12/2021	10:45	24/12/2021	17:38	PO	1) Earthwire (7/3.66 sq.mm) replacement work and other line maintenance work
TROMBAY SALSETTE LINE-2	IntraState	24/12/2021	23:27	25/12/2021	05:25		Metro -4 project work
KALWA SALSETTE - 4	IntraState	25/12/2021	06:50	25/12/2021	08:06	PO	BREAKER TESTING
BOISAR II - BOISAR (PG) CKT - 2	IntraState	25/12/2021	09:42	25/12/2021	21:55	PO	FIXING OF MISSING SPACERS

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 25/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DASTURI-KANDALGAON LINE	IntraState	25/12/2021	12:09	25/12/2021	16:02	PO	For C & tan delta testing of Line CTs at 220kV Dasturi S/s.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 3 @ PADGHE	IntraState	24/12/2021	09:47		Continued.	PO	1. Retrofitting of REF relay & 86 Master trip relay for MTAMC work 2. Diagnostic Testing Work 3. For Attending Hotspot
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	24/12/2021	10:30	24/12/2021	17:00	PO	Diagnostic testing of Transformer and CT
220/132-110 KV 100MVA ICT No-02 @ OGLEWADI	IntraState	24/12/2021	10:43	24/12/2021	12:50	EO	Attending oil leakage for HV B phase bushing
220/22 KV 50 MVA PTR 5 @ TEMGHAR	IntraState	24/12/2021	10:56	24/12/2021	15:36	PO	Buffer wall painting work and diagnostic testing work of TF No. 5.
220/132 KV 200 MVA PTR NO 6 @ PARVATI	IntraState	24/12/2021	11:08	24/12/2021	17:53	PO	Annual relay testing work by testing department & CTR system fire detector cable replacement & healthiness checking.
220/22 KV 50 MVA PTR 3 @ TEMGHAR	IntraState	24/12/2021	15:43	24/12/2021	16:26	PO	Buffer wall painting work of TF No. 3
220/132 KV 200 MVA ICT 2 @ SATANA	IntraState	25/12/2021	10:46	25/12/2021	19:27	PO	Outage proposal for LV CB Overhauling Work
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	25/12/2021	12:55	25/12/2021	16:04	EO	For topping of oil

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage