

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 24/Dec/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	161.172	3653.836	1) Gujrat	-6.562	-150.882
2) Hydro	13.963	263.009	2) Madhya Pradesh	1.337	35.931
3) Gas	3.346	103.195	3) Chattisgarh	5.240	128.500
Total MSPGCL	178.481	4020.040	4) Maharashtra	178.065	4145.158
B) 1) APML	51.183	1491.618	5) Goa (Amona)	-1.242	-30.611
2) JSWEL	12.616	305.002	Total	176.838	4128.096
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.642	691.848
4) RPL(AMT)	25.391	683.801	b) Mumbai Drawl	25.755	798.984
5) SWPGPL	9.156	201.798	c) MSEDCL Bilateral *	63.975	1745.211
6) Other IPP	44.163	1059.638	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.642	691.344
C) 1) TPCL Thermal	11.827	265.226	Include PX	0.000	0.000
2) TPCL Hydro	2.345	93.596	Standby	0.000	0.504
3) TPCL Gas	1.336	35.867	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.568	237.729	1) MSEDCL	479.801	11366.332
D) STATE			2) Mumbai Discoms	50.831	1431.403
1) Thermal	325.076	7898.648	3) Other Discoms	9.261	225.504
(A1+C1+C4+(B1-B6))			TOTAL STATE	539.893	13023.239
2) Hydro (A2+C2)	16.308	356.605			
3) Gas (A3+B7+C3)	4.682	139.062			
4) Wind	3.981	233.200			
6) SOLAR	13.008	267.627			
TOTAL STATE	363.055	8895.142			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6970	6925	6928	6249
MSPGCL Hydro	460	161	1285	167
MSPGCL Gas	136	135	139	142
MSPGCL Total Generation	7566	7221	8352	6558
Central Sector Receipt	9230	9230	6512	6455
WIND	114	127	113	327
CPP / IPP Thermal	6280	6002	6427	5259
CPP / IPP Gas	0	0	0	0
SOLAR	1922	1894	0	0
Exchange with Mumbai	-1377	-1402	-947	-1010
MSEDCL DEMAND MET	23342	22684	20021	17228
Load Shedding	0	0	0	0
MSEDCL DEMAND	23342	22684	20021	17228
TPCL GENERATION	649	603	1019	536
AEML GENERATION	488	465	493	288
MUMBAI DEMAND	2514	2470	2459	1834
OTHER DISCOM DEMAND	393	388	436	361
STATE DEMAND MET	26249	25542	22916	19423
STATE DEMAND	26249	25542	22916	19423
Frequency (Hz)	50.03	49.98	50.06	50.05

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.38 Hz at 07.45 Hrs	49.62 Hz at 14.58 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 24/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.92	120.06	215	180
Unit 7	0.00	0.00	0	0
Unit 8	12.34	306.70	578	465
Unit 9	12.35	312.21	585	478
Unit 10	11.79	308.97	516	419
Total	41.39	1047.94		
Bhusawal				
Unit 3	0.07	16.54	66	0
Unit 4	11.15	241.94	500	330
Unit 5	10.97	244.34	495	310
Total	22.19	502.82		
Parli				
Unit 6	4.66	104.88	240	150
Unit 7	4.78	107.29	248	148
Unit 8	3.66	81.84	182	140
Total	13.10	294.01		
Chandrapur				
Unit 3	2.86	79.54	128	100
Unit 4	2.90	74.19	134	100
Unit 5	6.96	154.31	300	260
Unit 6	8.40	181.56	405	275
Unit 7	0.00	0.00	0	0
Unit 8	11.33	203.09	495	350
Unit 9	11.40	247.82	500	362
Total	43.84	940.52		
Paras				
Unit 3	5.07	106.09	228	202
Unit 4	5.40	110.02	248	198
Total	10.48	216.12		
Khaparkheda				
Unit 1	2.65	65.96	115	100
Unit 2	3.04	67.55	145	96
Unit 3	3.88	83.39	182	129
Unit 4	3.46	78.63	161	127
Unit 5	10.94	207.46	475	390
Total	23.97	503.00		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.25	76.03	151	121
Unit 5	2.95	50.11	149	115
Total	6.20	149.44		
Uran				
All Units	3.35	103.20	144	135
Total	3.35	103.20		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.25	3.78	47	0
Total	0.25	3.78		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.99	81.66	555	40
Stage 4	3.75	74.25	500	0
Stage 3	1.89	33.82	296	0
Total	10.63	189.73		
Hydro				
KDPH	0.43	6.62	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.64	12.02	58	0
BHIRA T.R.	0.22	5.31	77	0
SMLHY_PTN	1.14	32.13	51	44
GHATGHAR	0.65	13.41	125	0
Total	3.08	69.50		
Wind				
Total	3.98	233.20	0	0
Total	3.98	233.20		
CPP				
APML(Mus)	51.18	1491.62	0	0
JSWEL(Mus)	12.62	305.00	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.39	683.80	0	0
SWPGPL-Mus	9.16	201.80	0	0
Other(Mus)	44.16	1059.64	0	0
Total	142.51	3741.86		
SOLAR				
Total	13.01	267.63	0	0
Total	13.01	267.63		
Tata				
Trombay 5	7.87	174.26	449	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.92	20.15	112	0
Trombay 7B	0.42	15.71	53	0
TATA Hydro	2.34	93.60	260	5
Trombay 8	3.96	90.96	234	130
Total	15.51	394.69		
AEMIL				
DTPS U-1&2	9.57	237.73	499	285
Total	9.57	237.73		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	161.17	3653.84	MSPGCL Total	178.48	4020.04
			MSPGCL Thml+Gas	164.52	3757.03	Koyna 1,2 & 4 Total	8.74	155.91
			MSPGCL Hydro	13.96	263.01	State Total	363.06	8895.14

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 24/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6045	167	141	6353	221	5293	0	0	7168	7170	-1103	17584	0	17584	1901	350	19835	49.94
2	6118	211	142	6471	185	5390	0	0	6716	6934	-981	17662	0	17662	1781	337	19780	49.83
3	6511	251	141	6903	185	5421	0	0	6572	6703	-912	17992	0	17992	1691	308	19991	49.99
4	6546	166	142	6854	194	5332	0	0	6799	6937	-925	18081	0	18081	1641	311	20033	50.02
5	6563	167	143	6873	206	5417	0	0	7203	7404	-932	18637	0	18637	1638	331	20606	50.03
6	6777	109	144	7030	190	5792	0	0	7381	7610	-990	19278	0	19278	1716	354	21348	50.01
7	6935	403	143	7481	210	6164	0	7	7320	7344	-918	19913	0	19913	1807	375	22095	50.01
8	6953	1360	143	8456	149	6427	0	206	6733	6986	-810	21022	0	21022	1916	392	23330	50.25
9	6956	1481	143	8580	129	6445	0	772	6595	7022	-878	21646	0	21646	2129	424	24199	49.95
10	6970	1450	141	8561	117	6443	0	1324	7282	7612	-1161	22464	0	22464	2323	432	25219	49.81
11	6958	1456	136	8550	93	6415	0	1733	8101	8233	-1304	23295	0	23295	2493	425	26213	49.94
12	6970	460	136	7566	114	6280	0	1922	9024	9230	-1377	23342	0	23342	2514	393	26249	50.03
13	6925	161	135	7221	127	6002	0	1894	8944	9230	-1402	22684	0	22684	2470	388	25542	49.98
14	6935	174	135	7244	131	5813	0	1836	8309	8548	-1243	21962	0	21962	2335	367	24664	50.04
15	6912	385	135	7432	128	5998	0	1564	8398	8575	-1199	22095	0	22095	2333	403	24831	49.88
16	6869	346	135	7350	130	6355	0	1131	8531	8427	-1106	21867	0	21867	2334	420	24621	49.87
17	6950	644	135	7729	105	6419	0	532	7444	7255	-1013	20604	0	20604	2340	423	23367	49.98
18	6935	1177	138	8250	89	6412	0	87	6466	6480	-907	19988	0	19988	2391	423	22802	50.04
19	6928	1285	139	8352	113	6427	0	0	6392	6512	-947	20021	0	20021	2459	436	22916	50.06
20	6892	1047	138	8077	140	6339	0	0	6258	6335	-931	19536	0	19536	2407	424	22367	50.06
21	6697	268	137	7102	204	6009	0	0	6455	6622	-1270	18262	0	18262	2274	405	20941	49.97
22	6438	311	140	6889	211	5435	0	0	6441	6613	-1300	17459	0	17459	2140	389	19988	49.93
23	6140	317	142	6599	283	5222	0	0	6648	6601	-1136	17178	0	17178	1964	391	19533	50.00
24	6249	167	142	6558	327	5259	0	0	6633	6455	-1010	17228	0	17228	1834	361	19423	50.05
MUs	161.17	13.96	3.35	178.48	3.98	142.51	0.00	13.01	173.81	176.84	-25.76	479.80	0.00	479.80	50.83	9.26	539.89	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 24/Dec/2022

Position as on 6.30 Hrs of 25/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	JSW (J) U2	300	10/12/2022	15:51	25/12/2022	23:11	NO SCHEDULE	
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	26/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
MSPGCL	Uran Unit 6	108	20/12/2022	17:00		Continued.	Gas shortage	
MSPGCL	Koyna STG-IV Unit-3	250	21/12/2022	09:53	24/12/2022	22:20	Generator lower guide bearing oil leakage	26/12/2022
IPP	RPL(AMT) U-2	270	24/12/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	24/12/2022	00:38		Continued.	Boiler Tube Leakage	27/12/2022
TPC-G	Trombay 7B	60	24/12/2022	03:07	24/12/2022	17:26	Gas shortage	
TPC-G	Trombay 7A	120	24/12/2022	03:24	24/12/2022	14:45	Gas shortage	
IPP	RPL(AMT) U-3	270	25/12/2022	17:45		Continued.	Bottom Ash evacuation problem	28/12/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 25/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LR Outages/Trippings							
LR (704) OF KORADI CKT - 2@ TIRORA	IntraState	24/12/2022	12:46			PO	For LR (704-52LR) CB Maintenance & for attending SF6 gas leakage
400 KV TBC Outages/Trippings							
TBC @ NAGOTHANE	IntraState	19/12/2022	11:20			PO	for CB overhauling work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
PARLI(MS) - PARLI (PG) CKT -2	InterState	24/12/2022	07:05			PO	POST OCC: BYPASSING OF 400KV PARLI(PG)-PARLI(M) 400KV D/C AND 400KV PARLI(PG)-PARLI (NEW) D/C QUAD LINE AT THE OUT SKIRT OF PARLI(PG) S/S SO AS TO FORM PARLI(M)-PARLI(NEW) 400KV D/C LINE
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	23/12/2022	19:12	24/12/2022	05:08	T	Tripped on distance protection
JAIGAD - KARAD CKT - 1	IntraState	23/12/2022	22:06	24/12/2022	09:51	HT	H/T For Over Voltage.
LONIKAND I - KOYNA STAGE-IV	IntraState	24/12/2022	00:51	24/12/2022	08:10	HT	H/T to Control Over Voltage
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/12/2022	06:42	24/12/2022	17:06	PO	Replacement of disc insulator strings by LRP strings
LONIKAND I - KOYNA STAGE-IV	IntraState	25/12/2022	00:53	25/12/2022	10:05	HT	H/T to Control Over Voltage.
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	25/12/2022	09:12	25/12/2022	18:38	PO	Main-I & Main -II Distance relay testing
KHADKA-AURANGABAD (WALUJ)	IntraState	25/12/2022	22:19		Continued.	HT	HAND TRIPPED FOR OVER VOLTAGE.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 24/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 25/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BABHALESHWAR - PADGHE CKT - 2	IntraState	25/12/2022	22:54		Continued.	EO	"To attend Hot-Spot at jumpers of Cut-point Towers. Loc. No. 54, 52, 33,15 under 500kV HVDC TL O&M Sub Division, Padghe. The high temperatures at Jumper joints are as follows :- Loc No. 54 - B-Phase(BBLR side) - 165.8451;; Loc No. 54 - B-Phase(PDG side) - 122.8451;; Loc No. 52- B-Phase (BBLR side) - 126.8451;. Loc No. 52- B-Phase (PDG side) - 81.5.8451;. Loc No. 33 - Y-Phase (PDG-Side) - 120.8451;; Loc No. 33 - Y-Phase - (BBLR-Side) - 81.4.8451;; Loc No. 15 - Y-Phase (PDG Side) - 100.8451;; "
JAIGAD - KARAD CKT - 2	IntraState	25/12/2022	23:15	25/12/2022	10:02	HT	H/T to Control Over Voltage.
400 KV ICT Outages/Trippings							
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	25/12/2022	08:06	25/12/2022	19:16	PO	All diagnostic testing work, Bay maintenance work, leakage attending from OLTC of R ph unit.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
EKLAHARE (OCR) - PADGHE	IntraState	19/12/2022	18:12			HT	HT for Load Management
SAKI - SAHAR	IntraState	24/12/2022	00:03	24/12/2022	03:04	PO	LBBU relay testing, Protection trials and CR trials
NERLE - PEDAMBE	IntraState	24/12/2022	08:50	24/12/2022	17:00	PO	for bay P/M work
FLAGSHIP-CHINCHWAD	IntraState	24/12/2022	09:11	24/12/2022	18:27	PO	Fabrication and painting of rusted CB mechanism boxes (individual pole operated ABB make CB BLK222).
EKLAHARA(OCR)-RAYMOND	IntraState	24/12/2022	10:08	24/12/2022	13:19	PO	work of attending of Red-Hot at Loc.No.07 Y-phase Nashik side(temp-75.4°C), R-phase Raymond side(temp-81.9°C) and also at loc.no.04 R-phase Raymond side(temp- 65.6°C).
SALSETTE BORIVLI - 1	IntraState	24/12/2022	10:40	24/12/2022	16:08	PO	Line Vue inspec&on of conductor
KARAD - NERLE	IntraState	24/12/2022	17:51	24/12/2022	19:05	T	TRIPPED ON DISTANCE PROTECTION
TROMBAY - SALSETTE CKT - 1	IntraState	24/12/2022	23:20	25/12/2022	06:16	PO	Project work of Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 at Sahakar Plaza crossing Ghatkopar
TROMBAY SALSETTE LINE-2	IntraState	24/12/2022	23:25	25/12/2022	06:23	PO	Project work of Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 at Sahakar Plaza crossing Ghatkopar
MAIN BUS SECTION - 1 @ MAHAPE	IntraState	25/12/2022	05:47	25/12/2022	15:16	PO	Overhauling of main bus Isolator & Bus maintenance work.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	25/12/2022	06:39	25/12/2022	21:35	PO	For shifting of the line on ERS between Loc no. 379 to 381 i/r of Height raising & shifting of the line for NHSRCL.
MALEGAON-SATANA	IntraState	25/12/2022	10:12	25/12/2022	18:22	HT	HT for Load Management

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 24/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 25/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PEDHAMBE ONI LINE	IntraState	25/12/2022	14:58	25/12/2022	19:37	T	Tripped on Distance protection
TROMBAY - SALSETTE CKT - 1	IntraState	25/12/2022	23:03		Continued.	PO	Project work of Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 at Sahakar Plaza crossing Ghatkopar
TROMBAY SALSETTE LINE-2	IntraState	25/12/2022	23:08		Continued.	PO	Project work of Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 at Sahakar Plaza crossing Ghatkopar
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/33 KV 50 MVA PTR 1 @ BABHLESHWAR	IntraState	24/12/2022	10:06	24/12/2022	17:25	PO	Replacement of damaged RCC support structures of BPIs with lattice type support structures.
220/33 KV 50 MVA PTR 2 @ BABHLESHWAR	IntraState	24/12/2022	10:12	24/12/2022	17:35	PO	Replacement of damaged RCC support structures of BPIs with lattice type support structures.
220/22 KV 50 MVA PTR NO 4 @ PARVATI	IntraState	24/12/2022	10:29	25/12/2022	16:20	PO	220/22 kV , 50 MVA TF 04 CB overhauling work
220/132KV 100 MVA ICT 2@ PETH	IntraState	24/12/2022	11:52	24/12/2022	16:33	PO	Quarterly Maintenance & Diagnostic testing work.
220/132 KV 150 MVA ICT 1 @ SATANA	IntraState	25/12/2022	10:21	25/12/2022	17:53	PO	To attend oil leakages of ICT.
132 KV BUSBAR Outages/Trippings							
MAIN BUS @ KOPARGAON	IntraState	23/12/2022	18:00			PO	For replacement of 132 KV Yeola line R ph bus jump and 132 KV bus section- R ph CT to bus jump for attending hotspot. Also diagnostic testing work of 132 kV PTs and allied equipments.
110 KV LINE Outages/Trippings							
TATA BORIVLI MSETCL BORIVLI 1	IntraState	24/12/2022	10:04	25/12/2022	18:06	PO	BUSBAR REPLACEMENT WORK AT BMC END
KALWA KALYAN	IntraState	24/12/2022	18:11	24/12/2022	18:33	EO	FACILATING OF TEST CHARGING OF NEW CTs

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage