

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Jan/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	132.587	3569.732	1) Gujrat	-9.002	-172.263
2) Hydro	16.995	299.882	2) Madhya Pradesh	3.884	122.022
3) Gas	4.269	117.835	3) Chattisgarh	6.680	149.350
Total MSPGCL	153.851	3987.449	4) Maharashtra	144.147	3299.275
B) 1) APLM	69.812	1699.131	5) Goa (Amona)	-1.440	-36.181
2) JSWEL	14.686	354.745	Total	144.269	3362.203
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.629	543.480
4) RPL(AMT)	24.046	620.733	b) Mumbai Drawl	22.985	587.800
5) SWPGPL	8.086	155.150	c) MSEDCL Bilateral *	63.937	1481.675
6) Other IPP	40.367	962.589	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.629	543.358
C) 1) TPCL Thermal	10.506	260.642	Include PX	0.000	0.000
2) TPCL Hydro	3.384	95.381	Standby	0.000	0.123
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.727	206.580	1) MSEDCL	438.254	10736.299
D) STATE			2) Mumbai Discoms	42.602	1159.742
1) Thermal	305.817	7829.302	3) Other Discoms	8.237	233.147
(A1+C1+C4+(B1-B6))			TOTAL STATE	489.093	12129.188
2) Hydro	20.379	395.263			
(A2+C2)					
3) Gas	4.269	127.175			
(A3+B7+C3)					
4) Wind	6.142	248.661			
6) SOLAR	8.217	166.585			
TOTAL STATE	344.824	8766.986			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	5964	5921	5658	4719
MSPGCL Hydro	1513	757	883	290
MSPGCL Gas	150	147	241	245
MSPGCL Total Generation	7627	6825	6782	5254
Central Sector Receipt	7866	7556	6076	5034
WIND	251	152	127	299
CPP / IPP Thermal	6970	6873	6768	5578
CPP / IPP Gas	0	0	0	0
SOLAR	1042	1225	6	0
Exchange with Mumbai	-1235	-1300	-965	-857
MSEDCL DEMAND MET	21040	19873	17281	13963
Load Shedding	0	0	0	0
MSEDCL DEMAND	21040	19873	17281	13963
TPCL GENERATION	775	632	920	398
AEML GENERATION	247	249	247	246
MUMBAI DEMAND	2257	2181	2132	1501
OTHER DISCOM DEMAND	370	364	378	336
STATE DEMAND MET	24778	23512	20926	16809
STATE DEMAND	24778	23512	20926	16809
Frequency (Hz)	50.01	49.92	49.97	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 06.02 Hrs	49.74 Hz at 12.21 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.88	76.58	190	120
Unit 7	0.00	0.00	0	0
Unit 8	0.00	316.33	0	0
Unit 9	13.23	294.90	562	544
Unit 10	12.70	294.56	550	510
Total	29.81	982.37		
Bhusawal				
Unit 3	3.50	70.44	175	110
Unit 4	0.00	100.73	0	0
Unit 5	9.67	215.28	465	285
Total	13.16	386.45		
Parli				
Unit 6	0.72	95.97	132	0
Unit 7	4.62	99.37	238	140
Unit 8	4.46	100.01	215	144
Total	9.81	295.35		
Chandrapur				
Unit 3	0.00	49.03	0	0
Unit 4	0.00	58.23	0	0
Unit 5	7.11	191.61	310	280
Unit 6	8.04	207.56	410	272
Unit 7	7.68	141.33	378	273
Unit 8	10.23	213.86	482	355
Unit 9	9.84	233.85	455	355
Total	42.89	1095.48		
Paras				
Unit 3	4.89	109.64	247	140
Unit 4	4.83	95.13	239	141
Total	9.72	204.76		
Khaparkheda				
Unit 1	3.25	66.90	155	115
Unit 2	0.00	0.00	0	0
Unit 3	3.66	78.41	177	120
Unit 4	3.56	66.52	177	129
Unit 5	9.95	243.61	440	313
Total	20.42	455.44		
Nasik				
Unit 3	3.37	75.35	169	118
Unit 4	0.00	18.28	0	0
Unit 5	3.41	56.26	181	119
Total	6.78	149.88		
Uran				
All Units	4.27	117.84	254	143
Total	4.27	117.84		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	6.07	35	0
Total	0.15	6.07		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.38	61.46	460	35
Stage 4	3.85	37.81	755	0
Stage 3	1.75	22.29	240	0
Total	8.98	121.56		
Hydro				
KDPH	0.43	7.70	18	18
VTRNA	0.78	14.78	60	0
TILLARI	0.52	13.05	58	0
BHIRA T.R.	0.20	5.58	40	0
SMLHY_PTN	5.44	134.51	243	211
GHATGHAR	0.64	2.69	125	0
Total	8.02	178.32		
Wind				
Total	6.14	248.66	0	0
Total	6.14	248.66		
CPP				
APML(Mus)	69.81	1699.13	0	0
JSWEL(Mus)	14.69	354.74	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.05	620.73	0	0
SWPGPL-Mus	8.09	155.15	0	0
Other(Mus)	40.37	962.59	0	0
Total	157.00	3792.35		
SOLAR				
Total	8.22	166.58	0	0
Total	8.22	166.58		
Tata				
Trombay 5	6.90	170.70	438	258
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	3.61	89.94	223	131
TATA Hydro	3.38	95.38	368	0
Total	13.89	365.36		
AEML				
DTPS U-1&2	5.73	206.58	250	209
Total	5.73	206.58		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	132.59	3569.73	MSPGCL Total	153.85	3987.45
			MSPGCL Thml+Gas	136.86	3687.57	Koyna 1,2 & 4 Total	7.23	99.27
			MSPGCL Hydro	17.00	299.88	State Total	344.82	8766.99

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/Jan/2022

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5142	281	153	5576	126	5771	0	0	5045	4922	-691	15409	0	15409	1314	295	17018	50.01
2	5091	275	152	5518	194	5759	0	0	5030	4738	-590	15332	0	15332	1227	287	16846	49.99
3	5096	286	163	5545	233	5813	0	0	5026	4872	-540	15644	0	15644	1167	279	17090	50.00
4	5215	275	152	5642	247	5943	0	0	5034	4763	-512	15817	0	15817	1136	266	17219	50.02
5	5276	279	151	5706	285	6228	0	0	5096	4820	-548	16192	0	16192	1166	299	17657	50.05
6	5432	274	162	5868	342	6669	0	0	5116	5132	-656	17042	0	17042	1272	313	18627	50.02
7	5767	264	151	6182	381	6867	0	6	5681	5600	-739	17980	0	17980	1415	317	19712	50.04
8	5953	852	153	6958	391	6956	0	115	5965	5695	-837	18934	0	18934	1646	344	20924	49.99
9	5947	1507	151	7605	312	6986	0	413	6334	6442	-989	20398	0	20398	1942	371	22711	50.04
10	5969	1714	160	7843	312	6981	0	782	7237	7347	-1080	21811	0	21811	2157	374	24342	50.02
11	5964	1513	150	7627	251	6970	0	1042	8057	7866	-1235	22151	0	22151	2257	370	24778	50.01
12	6022	1278	149	7449	199	6903	0	1196	7789	7690	-1229	21844	0	21844	2236	364	24444	49.97
13	5921	757	147	6825	152	6873	0	1225	7724	7556	-1300	20967	0	20967	2181	364	23512	49.92
14	5715	579	154	6448	223	6859	0	1138	7182	7300	-1234	20383	0	20383	2034	351	22768	50.01
15	5650	531	143	6324	251	6811	0	1056	7289	7322	-1212	20199	0	20199	2019	353	22571	50.00
16	5426	623	145	6194	238	6728	0	754	7557	7473	-1175	19847	0	19847	2016	365	22228	49.99
17	5629	896	145	6670	182	6766	0	389	6455	6555	-1153	19045	0	19045	2019	364	21428	49.99
18	5639	863	216	6718	128	6790	0	95	6121	6040	-1109	18286	0	18286	2042	376	20704	50.01
19	5658	883	241	6782	127	6768	0	6	5790	6076	-965	18416	0	18416	2132	378	20926	49.97
20	5620	1353	252	7225	142	6759	0	0	5697	5566	-1014	18285	0	18285	2143	393	20821	50.00
21	5635	747	237	6619	325	6713	0	0	5299	5292	-1182	17386	0	17386	2037	381	19804	50.03
22	5188	391	254	5833	436	6549	0	0	5475	5081	-1133	16413	0	16413	1863	353	18629	50.00
23	4913	284	243	5440	366	5957	0	0	5381	5087	-1005	15502	0	15502	1680	343	17525	50.01
24	4719	290	245	5254	299	5578	0	0	5223	5034	-857	14972	0	14972	1501	336	16809	49.97
MUs	132.59	16.99	4.27	153.85	6.14	157.00	0.00	8.22	146.60	144.27	-22.99	438.25	0.00	438.25	42.60	8.24	489.09	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Jan/2022

Position as on 6.30 Hrs of 26/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
AEML	AEML Unit 2	250	20/01/2022	08:54		Continued.	Boiler Validity Renevoation	
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
IPP	JSW (J) U3	300	15/01/2022	07:46		Continued.	non availability of load schedule.	
MSPGCL	Chandrapur Unit 4	210	18/01/2022	23:47		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 3	210	19/01/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	20/01/2022	12:42	25/01/2022	16:22	Gas shortage	
IPP	RPL(AMT) U-5	270	20/01/2022	21:15	25/01/2022	00:07	Coal Shortage	
MSPGCL	Koradi Unit 8	660	24/01/2022	14:38		Continued.	Boiler Tube Leakage	
IPP	RPL(AMT) U-4	270	24/01/2022	14:40		Continued.	Leakage Work	
MSPGCL	Parli Unit 6	250	25/01/2022	05:35	26/01/2022	17:20	BOILER FURNACE PRESSURE VERY HIGH	
MSPGCL	Khaparkheda Unit 4	210	26/01/2022	02:36	26/01/2022	05:19	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 25/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 26/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Tripping							
DHULE - SSNNL CKT - 1	InterState	25/01/2022	09:48	25/01/2022	17:36	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	04/01/2022	15:46	26/01/2022	12:39	PO	Height raising work of 400kV Waluj-Babhleshwar line at Loc No. 239 to 240 crossing to Samruddhi Highway i.e. 1. Dismantling of loc No. 239,240,241 (all DA+01) 2. Erection of new towers at loc No.239, 240,241 (All DD+9) 3. Restraining between Loc No. 237 to 242
TBC 2 @ CHANDRAPUR	IntraState	20/01/2022	12:35			EO	It is very necessary to attend the SF6 gas leakage considering the emergency and urgency. Low gas alarm is continuously appearing in short duration, Hence the problem needs to attend. To attend the SF6 gas leakage from NRV valve of R-ph pole of 400KV BHEL make Circuit Breaker.
NEW KOYNA - DABHOL CKT - 2	IntraState	24/01/2022	08:30	26/01/2022	09:24	PO	Hill cutting work & stay erection Excavation work for tower loc. No.94 & Cold washing work & Diagnostic testing & Relay testing work & C.B. Overhauling work Shutting on TBC
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	24/01/2022	16:05	25/01/2022	06:31	HT	For Load Management
PADGHE - NAGOTHANE CKT - 2	IntraState	24/01/2022	22:36	25/01/2022	08:31	HT	OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	24/01/2022	23:09	25/01/2022	08:55	HT	HT OV
LONIKAND I - KOYNA STAGE-IV	IntraState	24/01/2022	23:09	25/01/2022	08:55	HT	Overvoltage
JAIGAD - KARAD CKT - 1	IntraState	25/01/2022	21:05	26/01/2022	09:36	HT	o/v.
JAIGAD - KARAD CKT - 1	IntraState	25/01/2022	21:07	26/01/2022	09:36	HT	HT for Overvoltage
LONIKAND I - KOYNA STAGE-IV	IntraState	25/01/2022	23:10	26/01/2022	08:35	HT	o/v.
PADGHE - NAGOTHANE CKT - 1	IntraState	25/01/2022	23:55	26/01/2022	08:33	HT	H/T FOR O/V
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	26/01/2022	10:04			EO	To attend 89C B-phase PG isolator Pad clamp Hot Spot
JEJURI- KOYNA STAGE-IV	IntraState	26/01/2022	13:11	26/01/2022	14:08	T	tripped on main -2 protection operated at Jejuri end. line h/t from Stage-4 end at 13:24hrs
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	26/01/2022	14:31	26/01/2022	16:28	HT	HT for Load Management
BUS COUPLER @ NEW KOYNA	IntraState	26/01/2022	16:19	26/01/2022	20:47	EO	Trip circuit 2 faulty indication on Y phase
JAIGAD - KARAD CKT - 2	IntraState	26/01/2022	17:48			HT	HT For Overvoltage
LONIKAND I - KOYNA STAGE-IV	IntraState	26/01/2022	20:59			HT	HT for Overvoltage
PADGHE - NAGOTHANE CKT - 2	IntraState	26/01/2022	21:38			HT	O/V.
KHADKA-AURANGABAD	IntraState	26/01/2022	21:55			HT	O/V.
400 KV ICT Outages/Tripping							
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	26/01/2022	10:04	26/01/2022	20:00	EO	Acetylene (C2H2) contents in oil found to be beyond permissible limit

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 26/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	20/01/2022	09:30	25/01/2022	17:28	PO	Annual Maintenance of 220kV Ghodbunder to Dahanu Line -1 & 2
220 KV MAINBAY Outages/Trippings							
BUS SECTION - 2 @ WASHALA	IntraState	25/01/2022	10:30	25/01/2022	19:08	PO	TF-II, Winding & Bushing Tan-D, CT Tan-D, IR, PI, measurement work, earth wire replacement of 220kV Bus Section-II, B Phase LA of TF-II, replacement work.
220 KV LINE Outages/Trippings							
DAHANU - GHODBUNDER CKT - 1	IntraState	20/01/2022	09:23				Modification / relocation of existing tower no LS 45 to 47 at Vangoan for NHRCL Project. 2) Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Towers. 4. Re-stringing of conductors & OPGW cable.
DAHANU - GHODBUNDER CKT - 2	IntraState	20/01/2022	09:27				Modification / relocation of existing tower no LS 45 to 47 at Vangoan for NHRCL Project. 2) Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Towers. 4. Re-stringing of conductors & OPGW cable.
TPC BORIVALI - AAREY	IntraState	20/01/2022	09:32		Continued.	PO	For shifting to new GIS with cable extension with transition joint
PADGHE - JAMBHUL 2	IntraState	25/01/2022	01:52	25/01/2022	02:02	T	Tripped on D/P from Padghe end only, Fault current 8 KAm, R-Ph to Earth.
MAHALAXMI - AMONA	IntraState	25/01/2022	06:07	25/01/2022	07:20	T	tripped on dist. protn
ALKUD - VITA	IntraState	25/01/2022	09:34	25/01/2022	14:56	PO	Providing & fixing of suspension clamps at various locations
KARAD - NERLE	IntraState	25/01/2022	09:45	25/01/2022	15:19	PO	Replacement of damaged conductor between loc No.162 to S/s gantry Y Ph
KARAD - WATHAR	IntraState	25/01/2022	09:58	25/01/2022	14:19	PO	Replacement of damaged conductor between loc No.162 to S/s gantry Y Ph of 220kV Karad-Nerle line (Wathar line is crossing to Karad-Nerle line)
URAN - APTA 4	IntraState	25/01/2022	10:12	25/01/2022	19:33	PO	1) For providing Auto Reclose facility & taking it in service for APTA-4 line at Uran End 2) CT Tan Delta testing work 3) HOT SPOT Attending work.
RAYMOND - WASHALA	IntraState	25/01/2022	10:20	25/01/2022	19:08	PO	TF-II, Winding & Bushing Tan-D, CT Tan-D, IR, PI, measurement work, earth wire replacement of 220kV Bus Section-II, B Phase LA of TF-II, replacement work.
PHALTAN MIDC - CSSK BHAVANI NAGAR	IntraState	25/01/2022	14:26	25/01/2022	16:10	PO	RELAY TESTING & MAINTENANCE WORK.
KALWA SALSETTE - 4	IntraState	26/01/2022	07:09	26/01/2022	10:26	PO	FOR TREE TRIMMING
LONIKAND (400 KV)-THEUR II	IntraState	26/01/2022	09:19	26/01/2022	18:55	PO	Replacement of Higher Tan Delta CT- Rph, Yph & Bph.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 26/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AURANGABAD (WALUJ)-BHENDA	IntraState	26/01/2022	09:56	26/01/2022	20:35	HT	H/T TO CONTROL LOADING ON WALUJ ICT AND TO AVAIL E/O ON ICT-3
CREEK SIDE BUS @ KALWA	IntraState	26/01/2022	13:33			PO	1) 220 KV Main Bus conductor replacement 2) Earthwire replacement
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/22 KV 25 MVA PTR 2 @ WASHALA	IntraState	25/01/2022	10:05	25/01/2022	19:08	PO	TF-II, Winding & Bushing Tan-D, CT Tan-D, IR,PI, measurement work, earth wire replacement of 220kV Bus Section-II, B Phase LA of TF-II, replacement work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage