

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Feb/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	160.012	3891.828	1) Gujrat	2.799	-44.152
2) Hydro	33.420	390.488	2) Madhya Pradesh	-0.103	91.037
3) Gas	3.387	111.718	3) Chattisgarh	3.390	111.460
Total MSPGCL	196.819	4394.034	4) Maharashtra	157.458	4240.147
B) 1) APLM	75.620	1842.982	5) Goa (Amona)	-0.960	-32.694
2) JSWEL	26.592	518.471	Total	162.584	4365.798
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.644	726.579
4) RPL(AMT)	25.743	746.545	b) Mumbai Drawl	33.062	881.633
5) SWPGPL	7.254	198.924	c) MSEDCL Bilateral *	62.807	1793.654
6) Other IPP	47.042	1073.482	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.644	726.128
C) 1) TPCL Thermal	13.750	217.054	Include PX	0.000	0.000
2) TPCL Hydro	3.676	97.106	Standby	0.000	0.452
3) TPCL Gas	0.000	31.445	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.776	251.493	1) MSEDCL	519.542	12642.062
D) STATE			2) Mumbai Discoms	62.264	1478.728
1) Thermal	367.789	8740.779	3) Other Discoms	9.903	248.707
(A1+C1+C4+(B1-B6))			TOTAL STATE	591.709	14369.497
2) Hydro	37.096	487.594			
(A2+C2)					
3) Gas	3.387	143.163			
(A3+B7+C3)					
4) Wind	5.248	237.586			
6) SOLAR	15.605	394.580			
TOTAL STATE	429.125	10003.702			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6871	6745	6456	6733
MSPGCL Hydro	1595	997	1829	1099
MSPGCL Gas	161	158	177	137
MSPGCL Total Generation	8627	7900	8462	7969
Central Sector Receipt	8187	8321	6393	6015
WIND	116	149	495	169
CPP / IPP Thermal	7658	7332	7661	7428
CPP / IPP Gas	0	0	0	0
SOLAR	2061	2141	0	0
Exchange with Mumbai	-1843	-1890	-1384	-1128
MSEDCL DEMAND MET	24364	23512	21163	20157
Load Shedding	0	0	0	0
MSEDCL DEMAND	24364	23512	21163	20157
TPCL GENERATION	711	652	1056	410
AEML GENERATION	488	490	482	495
MUMBAI DEMAND	3042	3032	2922	2033
OTHER DISCOM DEMAND	442	441	464	296
STATE DEMAND MET	27848	26985	24549	22486
STATE DEMAND	27848	26985	24549	22486
Frequency (Hz)	49.99	50.03	49.93	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.36 Hz at 18:02 Hrs	49.7 Hz at 09:05 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.68	107.54	205	170
Unit 8	13.57	341.98	602	530
Unit 9	13.08	328.56	598	502
Unit 10	12.45	305.28	566	440
Total	43.78	1083.36		
Bhusawal				
Unit 3	3.58	83.59	155	125
Unit 4	10.74	257.41	500	385
Unit 5	10.52	255.80	485	390
Total	24.84	596.80		
Parli				
Unit 6	0.00	97.35	0	0
Unit 7	5.54	82.30	241	198
Unit 8	3.29	87.13	177	92
Total	8.83	266.78		
Chandrapur				
Unit 3	4.01	90.44	173	146
Unit 4	2.84	75.16	129	22
Unit 5	0.00	76.31	0	0
Unit 6	9.91	216.08	430	390
Unit 7	0.00	0.00	0	0
Unit 8	11.88	283.80	505	490
Unit 9	11.72	199.82	500	470
Total	40.35	941.62		
Paras				
Unit 3	4.61	122.63	240	120
Unit 4	5.78	142.08	250	221
Total	10.40	264.70		
Khaparkheda				
Unit 1	2.82	46.73	130	100
Unit 2	3.27	71.07	147	111
Unit 3	4.31	94.57	182	175
Unit 4	4.49	85.72	191	184
Unit 5	11.52	270.34	500	450
Total	26.41	568.42		
Nasik				
Unit 3	2.01	91.66	180	0
Unit 4	3.39	11.60	164	60
Unit 5	0.00	66.90	0	0
Total	5.40	170.16		
Uran				
All Units	3.39	111.72	212	14
Total	3.39	111.72		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	9.77	48	0
Total	0.18	9.77		
Koyna				
Stage 1-2	9.68	104.20	535	90

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	14.15	116.32	761	188
Stage 3	4.94	46.89	320	0
Total	28.77	267.41		
Hydro				
KDPH	0.86	18.17	36	36
VTRNA	1.03	17.03	61	0
TILLARI	0.46	10.29	58	0
BHIRA T.R.	0.16	5.73	40	0
SMLHY_PTN	1.95	57.45	87	75
GHATGHAR	0.00	4.64	0	0
Total	4.47	113.31		
Wind				
Total	5.25	237.59	0	0
Total	5.25	237.59		
CPP				
APML(Mus)	75.62	1842.98	0	0
JSWEL(Mus)	26.59	518.47	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.74	746.54	0	0
SWPGPL-Mus	7.25	198.92	0	0
Dhariwal	5.79	37.60	271	179
IEPL	6.00	132.28	262	234
Other(Mus)	35.25	903.60	0	0
Total	182.25	4380.40		
SOLAR				
Total	15.60	394.58	0	0
Total	15.60	394.58		
Tata				
Trombay 5	9.02	113.30	463	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	17.51	0	0
Trombay 7B	0.00	13.94	0	0
TATA Hydro	3.68	97.11	365	10
Trombay 8	4.73	103.76	236	132
Total	17.43	345.60		
AEML				
DTPS U-1&2	11.78	251.49	501	474
Total	11.78	251.49		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	160.01	3891.83	MSPGCL Total	196.82	4394.03
			MSPGCL Thml+Gas	163.40	4003.55	Koyna 1,2 & 4 Total	23.83	220.52
			MSPGCL Hydro	33.42	390.49	State Total	429.12	10003.70

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 25/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6624	837	136	7597	248	7708	0	0	5778	6009	-1294	19895	0	19895	2377	373	22645	49.99
2	6742	1215	137	8094	196	7734	0	0	5682	5813	-1202	20304	0	20304	2230	331	22865	49.98
3	6732	1247	136	8115	171	7608	0	0	5812	5919	-1175	20318	0	20318	2113	320	22751	50.01
4	6733	1099	137	7969	169	7428	0	0	5969	6015	-1128	20157	0	20157	2033	296	22486	49.98
5	6741	1480	137	8358	178	7702	0	0	5653	5748	-1078	20590	0	20590	2031	318	22939	49.96
6	6803	1693	138	8634	135	7736	0	0	5591	6215	-950	21422	0	21422	2117	348	23887	49.93
7	6879	1874	123	8876	250	7698	0	6	5783	6268	-920	21796	0	21796	2245	382	24423	50.02
8	6835	1907	14	8756	274	7708	0	265	5826	6469	-992	22062	0	22062	2329	418	24809	50.01
9	6874	1729	87	8690	193	7701	0	871	6391	6989	-1228	22773	0	22773	2529	443	25745	50.06
10	6856	1335	118	8309	177	7728	0	1509	7166	7585	-1483	23381	0	23381	2761	444	26586	49.97
11	6936	1456	153	8545	140	7745	0	1887	7744	7992	-1701	24172	0	24172	2961	436	27569	49.98
12	6871	1595	161	8627	116	7658	0	2061	7758	8187	-1843	24364	0	24364	3042	442	27848	49.99
13	6745	997	158	7900	149	7332	0	2141	8075	8321	-1890	23512	0	23512	3032	441	26985	50.03
14	6641	1008	156	7805	131	7153	0	2092	7966	7980	-1930	22786	0	22786	2951	445	26182	50.02
15	6553	1081	157	7791	133	7213	0	1915	8774	8549	-1938	23227	0	23227	2952	436	26615	49.91
16	6531	1503	154	8188	137	7416	0	1533	7979	8125	-1956	23002	0	23002	3001	441	26444	49.94
17	6516	1645	162	8323	185	7736	0	965	7150	7179	-1462	22464	0	22464	2991	462	25917	49.93
18	6472	1591	186	8249	196	7626	0	341	6718	6738	-1368	21316	0	21316	2913	466	24695	50.02
19	6466	1545	212	8223	362	7666	0	19	6134	6254	-1380	20678	0	20678	2898	466	24042	50.03
20	6456	1829	177	8462	495	7661	0	0	6203	6393	-1384	21163	0	21163	2922	464	24549	49.93
21	6468	1396	136	8000	369	7575	0	0	5891	5761	-1150	20110	0	20110	2635	445	23190	50.02
22	6435	1017	138	7590	308	7562	0	0	5868	5900	-1256	19672	0	19672	2502	432	22606	50.01
23	6552	1124	137	7813	285	7537	0	0	5823	6188	-1208	20189	0	20189	2393	426	23008	50.02
24	6551	1217	137	7905	251	7620	0	0	5789	5987	-1146	20205	0	20205	2306	412	22923	50.00
MUs	160.01	33.42	3.39	196.82	5.25	182.25	0.00	15.60	157.52	162.58	-33.06	519.56	0.00	519.56	62.26	9.89	591.71	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Feb/2023

Position as on 6.30 Hrs of 26/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/03/2023
IPP	SWPGPL U-2	135	08/02/2023	00:01		Continued.	Bag Filter replacement work	02/03/2023
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	27/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	28/02/2023
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Uran Unit 6	108	15/02/2023	13:13	25/02/2023	07:40	Gas shortage	
TPC-G	Trombay 7B	60	15/02/2023	16:54		Continued.	Gas shortage	
MSPGCL	Parli Unit 6	250	21/02/2023	20:15		Continued.	Air heater problem	28/02/2023
TPC-G	Trombay 7A	120	21/02/2023	20:26		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	22/02/2023	22:05	26/02/2023	03:00	Boiler Tube Leakage	24/02/2023
IPP	RPL(AMT) U-2	270	23/02/2023	11:01	25/02/2023	14:19	Gas shortage	
MSPGCL	Chandrapur Unit 4	210	24/02/2023	20:53	25/02/2023	00:35	TRIPPED ON AXIAL SHIFT HIGH	
MSPGCL	Uran Unit B0	120	25/02/2023	06:53		Continued.	CTO temperature high	
MSPGCL	Uran Unit 8	108	25/02/2023	06:53	25/02/2023	09:02	CTO temperature high.	
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00		Continued.	Boiler Tube Leakage	
IPP	RPL(AMT) U-4	270	25/02/2023	17:00		Continued.	Bottom Ash evacuation problem	
MSPGCL	Uran Unit 6	108	25/02/2023	19:41		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Feb/2023

Position as on 6.30 Hrs of 26/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	SWPGPL U-1	135	25/02/2023	22:45	26/02/2023	20:45	Enhancement of Unit for full load operation	
IPP	JSW (J) U3	300	26/02/2023	04:13	26/02/2023	07:29	On Drum Level High.	
MSPGCL	Parli Unit 8	250	26/02/2023	06:38		Continued.	Oil Pressure Low and Coal Mill Problem.	
MSPGCL	Paras Unit 3	250	26/02/2023	17:53	26/02/2023	20:34	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 26/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	26/02/2023	00:02	26/02/2023	01:10	EO	To attend 1 nos Hotspot of Pole 2 Converter Transformer B1 Bushing of OLTC1.
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	26/02/2023	03:17	26/02/2023	07:17	EO	To attend water leakages from Y-Phase thyristor pex pipe line inside pole 1 valve hall.
400 KV MAINBAY Outages/Trippings							
MAIN BAY (414) OF 500 MVA ICT - 2 @ DEEPNAGAR	IntraState	24/02/2023	10:59	26/02/2023	22:57	PO	For servicing & overhauling of 400kV AREVA make ICT-2 Main C.B. Mechanism
MAIN BAY (407) OF ICT-1 @ KUDUS	IntraState	25/02/2023	14:41	25/02/2023	17:41	EO	Outage required for Oil Top-up in Conservator Y-phase Unit, as CTR Oil Drain Valve in CTR MK become Faulty and Oil drain observed from CTR inspection Window, CTR Engineer also replacing Butterfly Wall of CTR system.
400 KV LINE Outages/Trippings							
LONIKAND I - TALEGAON (PGCIL)	InterState	25/02/2023	13:34	25/02/2023	15:50	T	Field Fire observed under Loc no 47-48
PADGHE - KALWA CKT - 1	IntraState	20/02/2023	14:26			PO	1) CB pole Overhauling work as Bph pole SF6 gas contents SO2 beyond permissible limit . 2) Replacement of B bus PG isolator under LES scheme as HTLS conductor work in progress of Kalwa line 3) 400kV Kalwa -1 in service through TBC
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
JAIGAD - KARAD CKT - 1	IntraState	24/02/2023	17:50	25/02/2023	01:30	HT	Due to heavy sparking on bus section at Karad Ss.
JAIGAD - KARAD CKT - 1	IntraState	24/02/2023	21:38	25/02/2023	00:21	EO	For repairing work of 29A Bph PG Isolator & 29 C Rph PG Isolator.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	25/02/2023	06:19	25/02/2023	22:32	PO	For string replacement work
MAIN BUS - 1 @ TALANDGE	IntraState	25/02/2023	12:20	26/02/2023	19:19	PO	For stringing of jack bus and erection of PG isolator in bay augmentation work of Kolhapur(PG)-Kolhapur(MSETCL) -1 Bay at MSETCL,
JAIGAD - KARAD CKT - 1	IntraState	25/02/2023	12:56	25/02/2023	17:01	EO	Replacement of damaged rotary insulator of R ph TBC PG isolator during operation of TBC PG isolator
KHADKA-AURANGABAD (WALUJ)	IntraState	25/02/2023	13:20	25/02/2023	18:00	EO	To attend hotspot on 89A Yph PG isolator box nut/bolts
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	26/02/2023	06:17	26/02/2023	17:02	EO	At loc 107-108 bottom phase conductor strands damaged hence it is necessary to attend with fixing of repair sleeves urgently.
DEEPNAGAR - THAPTI TANDA	IntraState	26/02/2023	06:34	26/02/2023	15:42	PO	for Strings replacement work
BABHALESHWAR - PADGHE CKT-1	IntraState	26/02/2023	08:52	26/02/2023	19:35	PO	Chemical Cleaning of Insulator string and Routine Line maintenance work
400 KV ICT Outages/Trippings							
400220KV 167MVA SPARE ICT @ DEEPNAGAR	IntraState	25/02/2023	10:32	25/02/2023	12:00	PO	for replacement of CTR system Nitrogen cylinder
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	25/02/2023	12:52	25/02/2023	15:17	EO	To attend Hot spot on R phase CT (220kV side)
220 KV TBC Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 26/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS SECTION BAY @ VSNL	IntraState	25/02/2023	11:27	25/02/2023	13:11	PO	Testing work of CB as CRM & Timing .
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ RANJANGAON	IntraState	25/02/2023	16:02			EO	220kV Isolator alingnment work is going on in co-ordination with hot line unit & M/s Bimco.Hot Line unit given clearence today dt 24.02.2023 evening to carry out above work.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work.
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
KHARGHAR - TOPWORTH	IntraState	22/02/2023	08:27	25/02/2023	20:15	PO	Erection of Gantry & Beam at Proposed Panvel Timber Market and making connectivity of OPGW to KhandeshwarGIS.
KHARGHAR - TSS PANVEL	IntraState	22/02/2023	09:26	25/02/2023	20:48	PO	Erection of Granty & beam at proposed Panvel Timber Market and making connectivity of OPGE to Khandeshwar GIS.
CHEMBUR (AEML) - NERUL (M)	IntraState	24/02/2023	11:50	25/02/2023	01:30	PO	For Diagnostic and R & M work and to check Non operation of Auto-reclose of Nerul-Chembur (Adani) line by Testing Team, Kalwa at Nerul end.
URSE - TALEGAON (AMBI) CKT 1	IntraState	24/02/2023	17:08	25/02/2023	03:56	T	Tripped on Distance Protection.
SAHARA-URSE	IntraState	24/02/2023	17:08	25/02/2023	00:35	T	Due to LTS line tripped at Urse end.
TALANDGE - BIDRI	IntraState	25/02/2023	08:23	25/02/2023	19:01	PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
TALANDGE - SAWANTWADI	IntraState	25/02/2023	08:53	25/02/2023	18:48	PO	For Reconductoring of 400 KV Kolhapur- Kolhapur -1 (PGCIL) Moose conductor with HTLS conductor for system improvement
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	25/02/2023	08:59	25/02/2023	18:41	HT	For load management
EKLAHARA(OCR)-RAYMOND	IntraState	25/02/2023	10:22	25/02/2023	20:52	EO	To attend red hot
220 KV KARJAT-BELWANDI-CKT-1	IntraState	25/02/2023	11:40	25/02/2023	14:44		For attending Hot Spot on Y-ph and B-ph CT (95 Degrees and 138 Degrees). N.A.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 26/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SONKHAR - TROMBAY	IntraState	25/02/2023	14:03	25/02/2023	20:13	PO	Diagnostic testing work of Trombay Line bay, Isolator alignment work, CT CB painting work, RM work.
ACCIL - APTA	IntraState	25/02/2023	14:14	25/02/2023	19:27	T	Field Fire observed at Loc no 526 to 528
TAMBATI - ADLABS	IntraState	25/02/2023	14:14	25/02/2023	15:06	T	Field Fire observed at Loc no 526 to 528.
KAMBA - VASAI	IntraState	25/02/2023	23:01	26/02/2023	06:03	EO	To carry out the height raising work of AEMLs existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village Gokhivare (Vasai) in connection with DFC project of Govt of India.
PADGHE - NALASOPARA - VASAI (T)	IntraState	25/02/2023	23:54	26/02/2023	06:13	EO	To carry out the height raising work of AEMLs existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village Gokhivare (Vasai) in connection with DFC project of Govt of India.
KOLSHET - KHARBAO	IntraState	26/02/2023	08:20	26/02/2023	19:00	PO	Shifting of existing line to ERS towers between loc no 113 to 116.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	26/02/2023	11:24	26/02/2023	21:44	HT	For load management
BUS SECTION - 1 @ TROMBAY	IntraState	26/02/2023	11:30	26/02/2023	18:28	PO	For 1) Bus Isolator alignment & maintenance work of ICT-2, Chembur-3 line & Bus PT Isolator 2) GIS Incommer-1 Cable Takeoff Gantry jumper nut-bolts tightening 3) ICT-2 Oil leakage attending & OLTC o/h work 4) Addition of OFF Delay timer in cooling pump circuit & AMC work of NIFPS of ICT-2 5) RM work.
CHIKHALI-JALNA I	IntraState	26/02/2023	18:42	26/02/2023	23:07	HT	To control loading on akola ICT.
KAMBA - VASAI	IntraState	26/02/2023	21:41		Continued.	EO	To carry out the height raising work of AEMLs existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village Gokhivare (Vasai) in connection with DFC project of Govt of India.
PADGHE - NALASOPARA - VASAI (T)	IntraState	26/02/2023	21:52		Continued.	EO	To carry out the height raising work of AEMLs existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village - Gokhivare (Vasai) in connection with DFC project of Govt of India.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	25/02/2023	09:50	25/02/2023	20:32	PO	ICT diagnostic testing work
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 26/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	26/02/2023	00:03	26/02/2023	05:25	PO	PROJECT WORK-MOVEMENT OF JACK UP BARGE IN VICINITY OF LINE
KHOPOLI - KARANJADE	IntraState	26/02/2023	08:00	26/02/2023	12:58	PO	R/M AT KHOPOLI END
110 KV BUSBAR Outages/Trippings							
BUS ZONE - 2 @ AMBERNATH	IntraState	26/02/2023	01:02	26/02/2023	03:17	PO	R/M

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage