

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Mar/2020 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	116.651	3768.664	1) Gujrat	6.057	176.940
2) Hydro	7.518	216.235	2) Madhya Pradesh	10.798	335.887
3) Gas	6.510	172.105	3) Chattisgarh	4.620	138.050
Total MSPGCL	130.679	4157.004	4) Maharashtra	95.075	2980.419
B) 1) APMIL	40.243	1680.729	5) Goa (Amona)	0.000	-8.470
2) JSWEL	11.845	397.862	Total	116.550	3622.826
3) VIPL	0.000	0.000	a) Mumbai Schedule	17.448	526.367
4) RPL(AMT)	0.000	64.411	b) Mumbai Drawl	18.397	553.297
5) WPCL	5.545	80.306	c) MSEDCL Bilateral *	34.770	871.386
6) Other IPP	9.927	346.152	Include PX	11.843	137.655
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	17.448	526.367
C) 1) TPCL Thermal	10.900	322.204	Include PX	3.275	148.631
2) TPCL Hydro	2.203	87.297	Standby	0.000	0.000
3) TPCL Gas	2.546	72.686	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.257	243.254	1) MSEDCL	314.719	10305.281
D) STATE			2) Mumbai Discoms	43.303	1278.743
1) Thermal	204.368	6903.582	TOTAL STATE	358.022	11584.024
(A1+C1+C4+(B1-B6))					
2) Hydro	9.721	303.532			
(A2+C2)					
3) Gas	9.056	244.791			
(A3+B7+C3)					
4) Wind	12.574	322.993			
6) SOLAR	5.753	186.295			
TOTAL STATE	241.472	7961.193			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	4901	4774	4251	4155
MSPGCL Hydro	212	366	485	140
MSPGCL Gas	261	270	276	277
MSPGCL Total Generation	5374	5410	5012	4572
Central Sector Receipt	6764	6959	3016	3392
WIND	633	506	804	515
CPP / IPP Thermal	2829	2767	2515	2526
CPP / IPP Gas	0	0	0	0
SOLAR	929	924	0	0
Exchange with Mumbai	-791	-811	-850	-932
MSEDCL DEMAND MET	15738	15755	10497	10073
Load Shedding	0	0	0	0
MSEDCL DEMAND	15738	15755	10497	10073
TPCL GENERATION	648	618	746	673
AEML GENERATION	374	375	372	373
MUMBAI DEMAND	1813	1804	1968	1978
STATE DEMAND MET	17551	17559	12465	12051
STATE DEMAND	17551	17559	12465	12051
Frequency (Hz)	50.02	50.05	50.03	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.25 Hz at 09.59 Hrs	49.82 Hz at 21.04 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 25/Mar/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.11	270.06	555	456
Unit 9	12.09	281.45	600	428
Unit 10	11.51	269.39	520	450
Total	35.71	820.90		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	211.68	0	0
Unit 5	0.00	212.19	0	0
Total	0.00	423.87		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	77.26	0	0
Unit 7	0.00	69.80	0	0
Unit 8	0.00	120.48	0	0
Total	0.00	267.54		
Chandrapur				
Unit 3	4.07	105.37	190	163
Unit 4	3.94	100.27	175	160
Unit 5	9.16	154.89	445	363
Unit 6	0.00	221.38	0	0
Unit 7	8.98	215.33	440	357
Unit 8	9.67	220.90	480	362
Unit 9	9.28	247.74	450	360
Total	45.09	1265.87		
Paras				
Unit 3	5.06	118.76	250	184
Unit 4	5.28	122.51	255	192
Total	10.34	241.27		
Khaparkheda				
Unit 1	2.36	96.24	160	0
Unit 2	2.95	101.78	180	0
Unit 3	3.92	100.65	195	122
Unit 4	3.84	95.80	180	142
Unit 5	9.22	253.69	450	360
Total	22.30	648.15		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.22	101.06	197	0
Unit 5	0.00	0.00	0	0
Total	3.22	101.06		
Uran				
All Units	6.51	172.10	289	260
Total	6.51	172.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	1.40	40	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.06	1.40		
Koyna				
Stage 1-2	3.38	69.38	400	40
Stage 4	0.63	56.62	213	0
Stage 3	0.92	27.58	132	0
Total	4.93	153.59		
Hydro				
KDPH	0.89	18.04	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.27	9.14	60	0
BHTGR/VEER	0.00	0.36	0	0
BHIRA T.R.	0.00	4.09	0	0
RNGR+BHTSA	0.34	8.28	15	14
BHANDARDRA	0.47	8.50	20	19
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.62	12.75	26	25
GHATGHAR	0.00	1.49	0	0
Total	2.59	62.64		
Wind				
Total	12.57	322.99	0	0
Total	12.57	322.99		
CPP				
APML(Mus)	40.24	1680.73	0	0
JSWEL(Mus)	11.84	397.86	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	64.41	0	0
WPCL(Mus)	5.54	80.31	0	0
Other(Mus)	9.93	346.15	0	0
Total	67.56	2569.46		
SOLAR				
Total	5.75	186.30	0	0
Total	5.75	186.30		
Tata				
Trombay 5	6.89	207.36	402	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.42	43.09	60	58
Trombay 7B	1.13	29.59	48	47
Trombay 8	4.01	114.84	240	152
TATA Hydro	2.20	87.30	221	18
Total	15.65	482.19		
AEML				
DTPS U-1&2	9.26	243.25	503	371
Total	9.26	243.25		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	116.65	3768.66	MSPGCL Total	130.68	4157.00
			MSPGCL Thml+Gas	123.16	3940.77	Koyna 1,2 & 4 Total	4.01	126.01
			MSPGCL Hydro	7.52	216.24	State Total	241.47	7961.19

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/Mar/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5201	276	278	5755	255	3431	0	0	4846	4776	-959	13258	0	13258	1967	15225	50.06
2	5222	152	277	5651	314	3177	0	0	5055	4835	-910	13067	0	13067	1873	14940	50.03
3	4935	143	267	5345	442	2963	0	0	5034	4779	-855	12674	0	12674	1776	14450	50.03
4	4881	153	277	5311	434	2861	0	0	4815	4793	-788	12611	0	12611	1711	14322	50.02
5	4967	208	268	5443	489	2898	0	0	4791	4951	-756	13025	0	13025	1676	14701	49.99
6	5290	193	289	5772	409	3001	0	0	5275	5300	-760	13722	0	13722	1684	15406	49.96
7	5483	733	269	6485	370	3039	0	5	5858	5803	-514	15188	0	15188	1707	16895	49.99
8	5475	379	269	6123	315	3017	0	139	6088	5951	-458	15087	0	15087	1726	16813	50.02
9	5432	257	287	5976	342	2954	0	356	5781	5750	-565	14813	0	14813	1775	16588	50.01
10	5506	266	264	6036	459	2874	0	575	5809	5700	-750	14894	0	14894	1816	16710	50.02
11	5113	197	273	5583	594	2953	0	792	6026	6060	-829	15153	0	15153	1827	16980	50.06
12	4901	212	261	5374	633	2829	0	929	6690	6764	-791	15738	0	15738	1813	17551	50.02
13	4774	366	270	5410	506	2767	0	924	6303	6959	-811	15755	0	15755	1804	17559	50.05
14	4825	477	260	5562	433	2809	0	764	6241	6659	-792	15435	0	15435	1782	17217	50.04
15	4788	797	270	5855	397	2794	0	604	6346	6220	-735	15135	0	15135	1776	16911	50.00
16	4830	337	261	5428	544	2787	0	381	6323	5633	-755	14018	0	14018	1752	15770	50.04
17	4729	158	262	5149	833	2651	0	220	5175	4367	-720	12500	0	12500	1710	14210	50.00
18	4725	140	283	5148	995	2569	0	60	3598	3105	-727	11150	0	11150	1688	12838	50.08
19	4376	275	265	4916	682	2564	0	4	2606	2761	-695	10232	0	10232	1746	11978	49.99
20	4310	567	264	5141	639	2543	0	0	2697	2951	-741	10533	0	10533	1860	12393	50.03
21	4245	450	275	4970	483	2518	0	0	2696	2846	-803	10014	0	10014	1926	11940	50.01
22	4251	485	276	5012	804	2515	0	0	3065	3016	-850	10497	0	10497	1968	12465	50.03
23	4237	157	268	4662	687	2520	0	0	3227	3179	-901	10147	0	10147	1962	12109	50.01
24	4155	140	277	4572	515	2526	0	0	3274	3392	-932	10073	0	10073	1978	12051	50.02
MUs	116.65	7.52	6.51	130.68	12.57	67.56	0.00	5.75	117.62	116.55	-18.40	314.72	0.00	314.72	43.30	358.02	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 25/Mar/2020

Position as on 6.30 Hrs of 26/Mar/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
IPP	JSW (J) U1	300	01/03/2020	06.10		Continued.	Governor Valve Replacement.	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit 6	108	21/03/2020	15.15		Continued.	Gas shortage	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00		Continued.	Zero Schedule.	
IPP	Adani U-4	660	23/03/2020	18.27		Continued.	Hot PA bellow leakage.	
MSPGCL	Chandrapur Unit 6	500	23/03/2020	21.59		Continued.	Clinker Removal Work.	
IPP	Adani U-1	660	25/03/2020	01.30		Continued.	APH-A Hot PA Bellow Leakage.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Mar/2020

Position as on 6.30 Hrs of 26/Mar/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 2	210	25/03/2020	18.02		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 1	210	25/03/2020	18.03		Continued.	Reserve Shut Down.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 3	210	25/03/2020	23.55		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 4	210	25/03/2020	23.58		Continued.	Reserve Shut Down.	
IPP	JSW (J) U2	300	26/03/2020	00.13		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 3	210	26/03/2020	14.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Mar/2020

Statement-VII

Position as on 6.30 Hrs of 26/Mar/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	23/03/2020	17.19		Continued.	HT	Over Voltage
Chakan Talegaon(Pg)	InterState	25/03/2020	17.04	26/03/2020	07.05	T	Over Voltage
Padgha Tarapur I	InterState	25/03/2020	17.12		Continued.	T	Over Voltage
Padgha - Boisar (PG)	InterState	25/03/2020	18.00		Continued.	T	Over Voltage
Babhaleshwar - Padghe-II	IntraState	22/03/2020	08.19		Continued.	T	Over Voltage
Padghe - Kalwa-II	IntraState	22/03/2020	16.57		Continued.	HT	Over Voltage
Koradi-Bhusawal	IntraState	23/03/2020	11.54	25/03/2020	08.56	T	Distance Protection
Karad - Jaigad - II	IntraState	23/03/2020	18.12		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	23/03/2020	20:37		Continued.	HT	Over Voltage
Dhule- Bableswhar - I	IntraState	24/03/2020	20.20		Continued.	HT	Over Voltage
Koradi-RattanIndia	IntraState	25/03/2020	11.56	25/03/2020	14.47	PO	Replacement Of Flashover Bph String At Loc No.111
Bhusawal-Aurangabad	IntraState	25/03/2020	15.38		Continued.	HT	Over Voltage
Jejuri- Koynastage-IV	IntraState	25/03/2020	15.54	26/03/2020	11.18	T	Distance Protection
Padghe - Nagothane - I	IntraState	25/03/2020	16.10		Continued.	T	Over Voltage
Padghe - Kalwa- I	IntraState	25/03/2020	17.12		Continued.	T	Over Voltage
New Koyna - Dabhol-I	IntraState	25/03/2020	18.01		Continued.	T	Over Voltage
New Koyna - Koyna Stage IV-II	IntraState	25/03/2020	18.01		Continued.	T	Over Voltage
Khadka - Bableswhar	IntraState	25/03/2020	18.07	26/03/2020	06.33	T	Over Voltage
BABHALESHWAR - RPL(NASHIK) CKT - 1	IntraState	25/03/2020	18.25	25/03/2020	22.55	T	Over Voltage
Koradi-Bhusawal	IntraState	25/03/2020	20.21		Continued.	T	Distance Protection
Koradi-Khaperkheda I	IntraState	25/03/2020	20.21		Continued.	T	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	22/03/2020	10.13		Continued.	HT	Hand tripped from LV end to control Over Voltage.
400/220 kV 500 MVA ICT III @ Jejuri	IntraState	25/03/2020	03.30	25/03/2020	08.09	T	Tripped on Teed protection.
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	25/03/2020	13.59		Continued.	EO	CT Tan Delta High.
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	25/03/2020	16.32		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	25/03/2020	17.57		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	25/03/2020	17.57	26/03/2020	06.09	HT	LV Side CB Hand Tripped For Voltage.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	25/03/2020	18.45	26/03/2020	06:44	T	NDR Protection Operated.
400/220/33 Kv 315 MVA ICT II @Babhleshwar	IntraState	25/03/2020	20.12	26/03/2020	05.46	HT	LV Side CB Hand Tripped For Voltage.
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	25/03/2020	22.00		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	25/03/2020	22.01		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220 kV 500 MVA ICT III @ Jejuri	IntraState	26/03/2020	14.21	26/03/2020	19.51	EO	To replace the faulty cable of 408 CTT Teed protection
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Mar/2020

Statement-VII

Position as on 6.30 Hrs of 26/Mar/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Lonand-Baramati	IntraState	16/02/2020	09.37		Continued.	PO	Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	02/03/2020	11.12		Continued.	PO	Stringing Of New Earth Wire at loc no.112 to 132.
Deepnagar Bambhori	IntraState	24/03/2020	18.14	25/03/2020	06.30	HT	Damage of Adjacent string Of B-Phase Of DSN.
Karad - Vita Ckt- I	IntraState	24/03/2020	22.50	25/03/2020	13.57	T	Distance Protection
Dhule-Chalisagaon	IntraState	25/03/2020	06.24	25/03/2020	08.13	T	To Control ICT Loading.
Pophli Pedhmbe Line- 1	IntraState	25/03/2020	13.10	25/03/2020	13.55	PO	Oil Top Up In CT.
Adlabs - Pedambe	IntraState	25/03/2020	15.19	26/03/2020	03.23	T	Distance Protection
Jejuri-Phursungi ckt-1	IntraState	25/03/2020	17.26	25/03/2020	19.44	PO	Work Of Broken String Replacement.
Miraj - Mhaishal	IntraState	25/03/2020	21.32	26/03/2020	04.45	T	Distance Protection
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Nanded-Ghatodi	IntraState	26/03/2020	12.41	26/03/2020	15.06	PO	Line Maintenance work
220 KV ICT Outages/Trippings							
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS
220/33 Kv 100 Mva Alstom Ptr 1 @Valve	IntraState	26/03/2020	17.20	26/03/2020	18.42	T	Tripped Without Any Indication

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage