

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Apr/2015 SATURDAY

| I GENERATION (MUs) | | | II EXCHANGES (MUs) | | |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL | Daily | Monthly | E) InterState Exchanges | Daily | Monthly |
| 1) Thermal | 120.138 | 2976.818 | 1) Gujrat | -4.935 | -21.192 |
| 2) Hydro | 15.524 | 586.635 | 2) Madhya Pradesh | 13.079 | 409.417 |
| 3) Gas | 6.676 | 140.152 | 3) Chattisgarh | 6.590 | 142.440 |
| Total MSPGCL | 142.338 | 3703.605 | 4) Maharashtra Net | 100.603 | 2263.116 |
| B) 1) APLM | 58.110 | 1219.780 | 5) Goa | -7.830 | -180.461 |
| 2) JSWEL | 24.560 | 554.140 | 6) TAPS 1&2 Injection | 3.506 | 89.246 |
| 3) VIPL | 11.112 | 288.525 | 7) RGPPL Injection | 0.000 | 0.000 |
| 4) RPL(AMT) | 4.360 | 162.089 | 8) Pench (MS) | 0.047 | 1.609 |
| 5) WPCL | 9.673 | 98.470 | 9) Pench (Excess) | -0.047 | -1.222 |
| 6) Other IPP | 6.008 | 194.855 | Total | 110.966 | 2701.344 |
| C) 1) TPCL Thermal | 17.657 | 432.726 | a) Mumbai Schedule | 24.237 | 589.191 |
| 2) TPCL Hydro | 2.429 | 104.991 | b) Mumbai Drawl | 26.289 | 638.375 |
| 3) TPCL Gas | 2.660 | 64.672 | c) MSEDCL Bilateral * | 33.013 | 604.890 |
| 4) R-INFRA Thermal | 12.404 | 281.925 | Include PX | 0.558 | -7.223 |
| D) STATE | | | d) Mumbai Bilateral * | 24.237 | 583.541 |
| 1) Thermal | 264.022 | 6209.328 | Include PX | 1.579 | 14.170 |
| (A1+C1+C4+(B1-B6)) | | | Include Standby | 0.000 | 5.650 |
| 2) Hydro | 17.953 | 691.626 | H) ENERGY CATERED (MUs) | | |
| 3) Gas | 9.336 | 204.824 | 1) MSEDCL | 360.599 | 8571.656 |
| 4) Wind | 18.256 | 253.067 | 2) Mumbai Discoms | 61.438 | 1522.677 |
| 6) SOLAR | 1.505 | 32.547 | TOTAL STATE | 422.037 | 10094.333 |
| TOTAL STATE | 311.072 | 7391.392 | | | |

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

| PARTICULARS | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 5 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal | 5377 | 5178 | 4707 | 5077 |
| MSPGCL Hydro | 1148 | 1073 | 680 | 119 |
| MSPGCL Gas | 275 | 270 | 282 | 289 |
| MSPGCL Total Generation | 6800 | 6521 | 5669 | 5485 |
| Central Sector Receipt | 5418 | 5551 | 4859 | 3976 |
| WIND | 401 | 302 | 1121 | 1002 |
| CPP / IPP | 4922 | 4996 | 4565 | 4462 |
| SOLAR | 178 | 210 | 0 | 0 |
| Exchange with Mumbai | -1311 | -1446 | -1201 | -670 |
| MSEDCL DEMAND MET | 16408 | 16134 | 15013 | 14255 |
| Load Shedding | 46 | 46 | 39 | 43 |
| MSEDCL DEMAND | 16454 | 16180 | 15052 | 14298 |
| TPCL GENERATION | 1061 | 981 | 1057 | 851 |
| R-INFRA GENERATION | 513 | 517 | 517 | 518 |
| MUMBAI DEMAND | 2885 | 2944 | 2775 | 2039 |
| STATE DEMAND MET | 19293 | 19078 | 17788 | 16294 |
| STATE DEMAND | 19339 | 19124 | 17827 | 16337 |
| Frequency (Hz) | 50.01 | 50.02 | 49.95 | 50.10 |

FREQUENCY PARTICULARS

| MAXIMUM FREQ. | MINIMUM FREQ. | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.52 Hz at 11;47 Hrs | 49.74 Hz at 21:04 Hrs | 50.04 | 0 % of Time(min) |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation, Maximum, Minimum for 25/Apr/2015

| Generating unit | Generation | | | |
|--------------------|--------------|---------------|----------|----------|
| | Daily (Mus) | Monthly (Mus) | Max (MW) | Min (MW) |
| Koradi | | | | |
| Unit 5 | 3.03 | 64.17 | 150 | 115 |
| Unit 6 | 0.00 | 0.00 | 0 | 0 |
| Unit 7 | 3.83 | 82.21 | 171 | 145 |
| Total | 6.86 | 146.38 | | |
| Bhusawal | | | | |
| Unit 2 | 0.00 | 0.00 | 0 | 0 |
| Unit 3 | 0.00 | 77.45 | 0 | 0 |
| Unit 4 | 10.12 | 216.64 | 500 | 340 |
| Unit 5 | 8.13 | 216.76 | 360 | 320 |
| Total | 18.24 | 510.85 | | |
| Parli | | | | |
| Unit 3 | 3.10 | 4.81 | 163 | 60 |
| Unit 4 | 0.00 | 25.46 | 0 | 0 |
| Unit 5 | 3.61 | 86.67 | 155 | 137 |
| Unit 6 | 5.31 | 91.52 | 239 | 209 |
| Unit 7 | 5.41 | 121.65 | 250 | 209 |
| Total | 17.42 | 330.11 | | |
| Chandrapur | | | | |
| Unit 1 | 0.00 | 0.00 | 0 | 0 |
| Unit 2 | 3.19 | 79.11 | 136 | 128 |
| Unit 3 | 0.43 | 108.03 | 124 | 0 |
| Unit 4 | 4.35 | 105.79 | 188 | 164 |
| Unit 5 | 10.16 | 224.08 | 435 | 410 |
| Unit 6 | 9.72 | 239.42 | 415 | 376 |
| Unit 7 | 9.79 | 230.71 | 436 | 350 |
| Total | 37.64 | 987.13 | | |
| Paras | | | | |
| Unit 3 | 5.77 | 108.59 | 250 | 221 |
| Unit 4 | 5.14 | 88.56 | 229 | 195 |
| Total | 10.92 | 197.14 | | |
| Khaparkheda | | | | |
| Unit 1 | 4.16 | 105.26 | 185 | 155 |
| Unit 2 | 2.85 | 3.83 | 155 | 75 |
| Unit 3 | 0.00 | 11.38 | 0 | 0 |
| Unit 4 | 4.48 | 90.44 | 198 | 179 |
| Unit 5 | 6.60 | 276.71 | 500 | 0 |
| Total | 18.09 | 487.62 | | |
| Nasik | | | | |
| Unit 3 | 1.96 | 100.20 | 200 | 0 |
| Unit 4 | 4.49 | 112.55 | 196 | 180 |
| Unit 5 | 4.51 | 104.84 | 195 | 181 |
| Total | 10.96 | 317.59 | | |
| Uran | | | | |
| All Units | 6.68 | 140.15 | 291 | 248 |
| Total | 6.68 | 140.15 | | |
| PENCH (MS) | | | | |

| Generating unit | Generation | | | |
|-----------------|---------------|----------------|----------|----------|
| | Daily (Mus) | Monthly (Mus) | Max (MW) | Min (MW) |
| Pench (MS) | 0.05 | 1.61 | 30 | 0 |
| Total | 0.05 | 1.61 | | |
| Koyna | | | | |
| Stage 1-2 | 4.64 | 147.60 | 455 | 40 |
| Stage 4 | 4.44 | 242.60 | 864 | 0 |
| Stage 3 | 2.02 | 84.13 | 240 | 0 |
| Total | 11.09 | 474.32 | | |
| Hydro | | | | |
| KDPH | 0.43 | 13.31 | 18 | 18 |
| VTRNA | 0.87 | 25.69 | 61 | 0 |
| TILLARI | 0.36 | 9.01 | 63 | 0 |
| BHTGR/VEER | 0.04 | 1.28 | 2 | 1 |
| BHIRA T.R. | 0.12 | 5.75 | 63 | 0 |
| RNGR+BHTSA | 0.28 | 5.80 | 12 | 11 |
| BHANDARDRA | 0.46 | 9.20 | 20 | 19 |
| ELDARY | 0.00 | 0.72 | 0 | 0 |
| SMLHY_PTN | 0.73 | 23.42 | 38 | 28 |
| GHATGHAR | 1.15 | 18.14 | 250 | 0 |
| Total | 4.43 | 112.31 | | |
| Wind | | | | |
| Total | 18.26 | 253.07 | 0 | 0 |
| Total | 18.26 | 253.07 | | |
| CPP | | | | |
| APML(Mus) | 58.11 | 1219.78 | 0 | 0 |
| JSWEL(Mus) | 24.56 | 554.14 | 0 | 0 |
| VIPL(Mus) | 11.11 | 288.52 | 0 | 0 |
| RPLAMT(Mus) | 4.36 | 162.09 | 0 | 0 |
| WPCL(Mus) | 9.67 | 98.47 | 0 | 0 |
| Other(Mus) | 6.01 | 194.86 | 0 | 0 |
| Total | 113.82 | 2517.86 | | |
| SOLAR | | | | |
| Total | 1.50 | 32.55 | 0 | 0 |
| Total | 1.50 | 32.55 | | |
| Tata | | | | |
| Trombay 5 | 11.68 | 266.26 | 492 | 443 |
| Trombay 6 | 0.00 | 19.93 | 0 | 0 |
| Trombay 7A | 1.48 | 36.82 | 62 | 61 |
| Trombay 7B | 1.18 | 27.86 | 50 | 48 |
| Trombay 8 | 5.98 | 146.54 | 253 | 247 |
| TATA Hydro | 2.43 | 104.99 | 243 | 0 |
| Total | 22.75 | 602.39 | | |
| R-INFRA | | | | |
| 1-2 | 12.40 | 281.92 | 520 | 512 |
| Total | 12.40 | 281.92 | | |

| Summary | | |
|-----------------|-------------|---------------|
| Particulars | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal | 120.14 | 2976.82 |
| MSPGCL Thml+Gas | 126.81 | 3116.97 |

| Summary | | |
|--------------|-------------|---------------|
| Particulars | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 15.52 | 586.64 |
| MSPGCL Total | 142.34 | 3703.60 |

| Summary | | |
|---------------------|-------------|---------------|
| Particulars | Daily (Mus) | Monthly (Mus) |
| Koyna 1,2 & 4 Total | 9.08 | 390.19 |
| State Total | 311.07 | 7391.39 |

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 25/Apr/2015

Annexure-2

| TIME SR. NO. | MSPGCL GEN. | | | TOTAL | WIND | CPP / IPP | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDCL DEM. MET | LOAD SHEDDING | MSEDCL DEM. WITH LS | MUMBAI DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|-------|-----------|-------|----------|----------|----------------|-----------------|---------------|---------------------|---------------|--------------|------------|
| | THM | HY | GAS | | | | | | | | | | | | | |
| 1 | 5074 | 275 | 291 | 5640 | 1238 | 4797 | 0 | 4567 | 4639 | -1206 | 15108 | 59 | 15167 | 2567 | 17734 | 50.02 |
| 2 | 5034 | 119 | 290 | 5443 | 1210 | 4673 | 0 | 4395 | 4384 | -1031 | 14679 | 43 | 14722 | 2354 | 17076 | 50.05 |
| 3 | 5037 | 124 | 291 | 5452 | 1137 | 4576 | 0 | 4354 | 4433 | -853 | 14745 | 43 | 14788 | 2212 | 17000 | 50.03 |
| 4 | 5064 | 119 | 290 | 5473 | 1122 | 4487 | 0 | 4406 | 4100 | -733 | 14449 | 43 | 14492 | 2100 | 16592 | 50.16 |
| 5 | 5077 | 119 | 289 | 5485 | 1002 | 4462 | 0 | 4534 | 3976 | -670 | 14255 | 43 | 14298 | 2039 | 16337 | 50.10 |
| 6 | 5151 | 129 | 289 | 5569 | 984 | 4493 | 0 | 4681 | 4525 | -692 | 14879 | 46 | 14925 | 2061 | 16986 | 50.03 |
| 7 | 5239 | 303 | 248 | 5790 | 933 | 4515 | 8 | 4587 | 4632 | -695 | 15183 | 48 | 15231 | 2065 | 17296 | 50.20 |
| 8 | 5379 | 263 | 249 | 5891 | 662 | 4722 | 44 | 4618 | 4479 | -762 | 15036 | 48 | 15084 | 2136 | 17220 | 50.14 |
| 9 | 5442 | 189 | 279 | 5910 | 511 | 4905 | 95 | 4784 | 4839 | -894 | 15366 | 48 | 15414 | 2272 | 17686 | 50.14 |
| 10 | 5438 | 519 | 275 | 6232 | 354 | 4937 | 143 | 4975 | 4839 | -1152 | 15353 | 48 | 15401 | 2583 | 17984 | 50.08 |
| 11 | 5377 | 1148 | 275 | 6800 | 401 | 4922 | 178 | 4974 | 5418 | -1311 | 16408 | 46 | 16454 | 2885 | 19339 | 50.01 |
| 12 | 5360 | 1306 | 276 | 6942 | 277 | 5073 | 200 | 5052 | 4790 | -1410 | 15872 | 46 | 15918 | 2948 | 18866 | 50.07 |
| 13 | 5178 | 1073 | 270 | 6521 | 302 | 4996 | 210 | 4973 | 5551 | -1446 | 16134 | 46 | 16180 | 2944 | 19124 | 50.02 |
| 14 | 5078 | 1274 | 270 | 6622 | 319 | 4922 | 195 | 4930 | 4501 | -1339 | 15220 | 40 | 15260 | 2863 | 18123 | 50.04 |
| 15 | 4748 | 1545 | 272 | 6565 | 332 | 4900 | 192 | 4996 | 4952 | -1336 | 15605 | 37 | 15642 | 2910 | 18552 | 49.98 |
| 16 | 4789 | 1830 | 275 | 6894 | 432 | 4941 | 113 | 5044 | 4896 | -1396 | 15880 | 39 | 15919 | 2917 | 18836 | 50.01 |
| 17 | 4748 | 1419 | 276 | 6443 | 575 | 4843 | 91 | 4867 | 4763 | -1336 | 15379 | 39 | 15418 | 2860 | 18278 | 50.01 |
| 18 | 4667 | 718 | 279 | 5664 | 737 | 4647 | 33 | 4289 | 4317 | -1260 | 14138 | 39 | 14177 | 2784 | 16961 | 50.11 |
| 19 | 4636 | 459 | 280 | 5375 | 1040 | 4520 | 3 | 4206 | 3992 | -1164 | 13766 | 39 | 13805 | 2689 | 16494 | 50.02 |
| 20 | 4707 | 680 | 282 | 5669 | 1121 | 4565 | 0 | 4819 | 4859 | -1201 | 15013 | 39 | 15052 | 2775 | 17827 | 49.95 |
| 21 | 4704 | 328 | 280 | 5312 | 955 | 4660 | 0 | 4810 | 5024 | -1189 | 14762 | 39 | 14801 | 2711 | 17512 | 49.95 |
| 22 | 4733 | 323 | 282 | 5338 | 900 | 4768 | 0 | 4420 | 4399 | -996 | 14409 | 39 | 14448 | 2605 | 17053 | 49.96 |
| 23 | 4743 | 353 | 284 | 5380 | 860 | 4754 | 0 | 4285 | 4224 | -1057 | 14161 | 39 | 14200 | 2584 | 16784 | 49.91 |
| 24 | 4735 | 909 | 284 | 5928 | 852 | 4745 | 0 | 4246 | 4434 | -1160 | 14799 | 39 | 14838 | 2575 | 17413 | 49.96 |
| MUs | 120.14 | 15.52 | 6.68 | 142.34 | 18.26 | 113.82 | 1.50 | 111.81 | 110.97 | -26.29 | 360.60 | 1.03 | 361.63 | 61.44 | 423.07 | 50.04 |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Apr/2015

Position as on 6.30 Hrs of 26/Apr/2015

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|--|---------------|
| PLANNED OUTAGE | | | | | | | | |
| CENT.SECTOR | Tarapur 1 | 160 | 12/10/2014 | 22:39 | | Continued. | Refuelling Work. (60 Days) | |
| MSPGCL | Koradi Unit 6 | 210 | 20/03/2015 | 01.02 | | Continued. | Renovation and Modification work | |
| FORCED OUTAGE | | | | | | | | |
| RGPPL | Dabhol 1B | 230 | 28/05/2013 | 22:02 | | Continued. | Gas Shortage. | |
| RGPPL | Dabhol 3A | 230 | 06/06/2013 | 08.28 | | Continued. | Gas Shortage | |
| RGPPL | Dabhol 2A | 230 | 06/06/2013 | 09.10 | | Continued. | Gas Shortage | |
| RGPPL | Dabhol 1X | 290 | 27/06/2013 | 21.46 | | Continued. | Gas Shortage | |
| RGPPL | Dabhol 1A | 230 | 27/06/2013 | 21.47 | | Continued. | Gas Shortage | |
| RGPPL | Dabhol 2X | 290 | 15/07/2013 | 15.09 | | Continued. | Gas Shortage | |
| RGPPL | Dabhol 2B | 230 | 08/08/2013 | 15.03 | | Continued. | Gas Shortage | |
| RGPPL | Dabhol 3X | 290 | 29/12/2013 | 05.47 | | Continued. | Gas Shortage | |
| RGPPL | Dabhol 3B | 230 | 29/12/2013 | 06.14 | | Continued. | Gas Shortage | |
| IPP | Dhariwal | 300 | 28/05/2014 | 02.27 | | Continued. | PA Fan Vibration Problem | |
| MSPGCL | Chandrapur Unit 1 | 210 | 28/08/2014 | 07:15 | | Continued. | Economic Shutdown. | |
| MSPGCL | Bhusawal Unit 2 | 210 | 13/09/2014 | 12.43 | | Continued. | Economic shutdown | |
| IPP | RPL(AMT) U-1 | 270 | 21/03/2015 | 23.28 | | Continued. | Turbine vibration high. | |
| MSPGCL | Chandrapur Unit-8 | 500 | 29/03/2015 | 18.26 | | Continued. | Withdrawn | |
| MSPGCL | Koradi Unit-8 | 660 | 30/03/2015 | 20.22 | | Continued. | BLR Tripped. | |
| MSPGCL | Uran Unit 6 | 108 | 01/04/2015 | 16.35 | | Continued. | Gas shortage | |
| IPP | RPL(AMT) U-4 | 270 | 03/04/2015 | 11.42 | | Continued. | Boiler feed Pump problem. | |
| IPP | RPL(AMT) U-5 | 270 | 03/04/2015 | 14.22 | | Continued. | turbine Shaft Vibration high. | |
| MSPGCL | Khaparkheda Unit 3 | 210 | 04/04/2015 | 22.52 | | Continued. | Gland Steam Temp. High. | |
| IPP | RPL(AMT) U-3 | 270 | 05/04/2015 | 22.01 | | Continued. | Governor AVR Problem. | |
| TPC-G | Trombay 6 | 500 | 06/04/2015 | 16.27 | | Continued. | Economic shut down. | |
| IPP | Adani U-2 | 660 | 09/04/2015 | 15.50 | | Continued. | Boiler feed Pump Problem. | |
| MSPGCL | Parli Unit 4 | 210 | 13/04/2015 | 11.27 | | Continued. | Turbine vibration high. | |
| MSPGCL | Uran Unit 7 | 108 | 17/04/2015 | 00.07 | | Continued. | Gas turbine problem | |
| MSPGCL | Bhusawal Unit 3 | 210 | 20/04/2015 | 00.00 | | Continued. | no buyer as per msdcl reqirment | |
| MSPGCL | Chandrapur Unit 3 | 210 | 24/04/2015 | 12.56 | 25/04/2015 | 18.30 | Low furnace pressure | |
| MSPGCL | Nasik Unit 3 | 210 | 25/04/2015 | 11.40 | | Continued. | GT Bucholz Tripped. | |
| MSPGCL | Khaparkheda Unit 5 | 500 | 25/04/2015 | 13.45 | 26/04/2015 | 18.26 | Main Steam Line Heavy Leakage Due to Earthquake. | |
| IPP | Adani U-5 | 660 | 26/04/2015 | 06.30 | | Continued. | Super Heater Drain Heavy Flange Leakage. | |

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Apr/2015

Statement-VII

Position as on 6.30 Hrs of 26/Apr/2015

| Name of Line | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage |
|---|---------------------------|--------------|--------------|------------|------------|-------------|--|
| 765 KV LINE Outages/Trippings | | | | | | | |
| Wardha(PG)-Aurangabad(PG) I | InterState | 26/04/2015 | 11.36 | 26/04/2015 | 21.05 | HT | Handtripped. |
| Wardha PG -Aurangabad PG III | IntraState | 21/04/2015 | 00.07 | | Continued. | HT | To Control Line Loading of Waluj-A'Bad PG |
| Wardha PG - Aurangabad PG IV | IntraState | 21/04/2015 | 10.33 | | Continued. | HT | Line Rectification work |
| 400 KV LINE Outages/Trippings | | | | | | | |
| Akola II - RPL(Rattanindia) Ckt I | InterState | 07/04/2015 | 00.27 | | Continued. | T | Over Current Protection |
| Dhule Sar'Sarovar II | InterState | 24/04/2015 | 12.41 | 25/04/2015 | 11.35 | PO | Shifted on TBC. |
| Kolhapur Mapusa II | InterState | 24/04/2015 | 17.46 | 25/04/2015 | 07.21 | T | Over Voltage |
| Dhule Sar'Sarovar I | InterState | 24/04/2015 | 18.01 | 25/04/2015 | 07.13 | HT | Over Voltage |
| Kolhapur Mapusa I | InterState | 25/04/2015 | 17.13 | 26/04/2015 | 07.03 | HT | Over Voltage |
| Talegaon PG - Aurangabad - II | InterState | 26/04/2015 | 11.16 | 26/04/2015 | 15.00 | HT | E/O on A'bad-A'bad PG II. |
| Waluj Aurangabad(PG) II | InterState | 26/04/2015 | 12.18 | 26/04/2015 | 14.35 | EO | Hot spot on Y-Ph CT. |
| Kolhapur Mapusa II | InterState | 26/04/2015 | 16.42 | | Continued. | HT | Over Voltage |
| Dhule Sar'Sarovar I | InterState | 26/04/2015 | 17.52 | | Continued. | HT | Over Voltage |
| karad -kolhapur-I | IntraState | 24/04/2015 | 16.17 | 25/04/2015 | 06.45 | HT | Over Voltage |
| Karad-Jaigad - I | IntraState | 24/04/2015 | 17.37 | 25/04/2015 | 06.51 | HT | Over Voltage |
| Bhusawal-Aurangabad | IntraState | 24/04/2015 | 17.47 | 25/04/2015 | 06.42 | HT | Over Voltage |
| karad -kolhapur-II | IntraState | 25/04/2015 | 16.35 | 26/04/2015 | 08.40 | HT | Over Voltage |
| karad -kolhapur-II | IntraState | 26/04/2015 | 16.09 | | Continued. | HT | Over Voltage |
| Karad-Jaigad - I | IntraState | 26/04/2015 | 16.30 | | Continued. | HT | Over Voltage |
| Bhusawal-Aurangabad | IntraState | 26/04/2015 | 17.33 | | Continued. | HT | Over Voltage |
| Babhaleshwar-Taptitanda ckt-I | IntraState | 26/04/2015 | 18.01 | | Continued. | HT | Over Voltage |
| Lonikand I - Koyna stage-IV | IntraState | 26/04/2015 | 18.07 | | Continued. | HT | Over Voltage |
| 400 KV ICT Outages/Trippings | | | | | | | |
| 400/220 Kv 600 MVA ICT-IV @Padghe | IntraState | 25/04/2015 | 01.13 | 25/04/2015 | 03.15 | PO | Emergency Outage for Attending Hot Spot on R-Ph Stub Bus. |
| 400/220 Kv 600 MVA ICT-IV @Padghe | IntraState | 25/04/2015 | 22.19 | 26/04/2015 | 05.59 | PO | For Replacement of R,Y,B 220KV CT'S. |
| 400/220 Kv 600 MVA ICT-II @Kalwa | IntraState | 26/04/2015 | 11.02 | 26/04/2015 | 14.55 | PO | Routine Maintenance Work |
| 400/220kv, 500 MVA ICT-III @Babhleshwar | IntraState | 26/04/2015 | 17.53 | 26/04/2015 | 20.38 | PO | Hot Spot on R-Ph CT. |
| 220 KV LINE Outages/Trippings | | | | | | | |
| Boisar(MS) - Boisar (PG) - I | InterState | 25/04/2015 | 04.16 | 25/04/2015 | 06.45 | PO | Emergency Outage for Attending Hot Spot. |
| Boisar(MS) - Boisar (PG) II | InterState | 25/04/2015 | 06.57 | 25/04/2015 | 08.59 | PO | Emergency Outage for Attending Hot Spot. |
| TBC @ Parli-II | IntraState | 07/01/2015 | 15.48 | | Continued. | PO | Shifting of control panel |
| Sahara-Urse | IntraState | 03/03/2015 | 11.06 | | Continued. | PO | Tower erection work (90Days) |
| Chandrapur Gcr - Warora - I | IntraState | 05/04/2015 | 09.13 | | Continued. | PO | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Chandrapur Gcr - Wani | IntraState | 05/04/2015 | 09.15 | | Continued. | PO | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Apta - Taloja | IntraState | 17/04/2015 | 08.05 | | Continued. | PO | CKT on TBC Breaker O/H Work. |
| Deepnagar Amalner | IntraState | 18/04/2015 | 15.42 | 25/04/2015 | 23.46 | T | Distance Protection Operated Z-I R Ph. |
| Padgha - Temghar I | IntraState | 24/04/2015 | 00.27 | 25/04/2015 | 03.18 | HT | For Availing Outage on Padgha ICT-IV. |
| Padgha-Temghar-II | IntraState | 24/04/2015 | 00.28 | 25/04/2015 | 03.20 | HT | For Availing Outage on Padgha ICT-IV. |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Apr/2015

Statement-VII

Position as on 6.30 Hrs of 26/Apr/2015

| Name of Line | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--|
| Padghe - Wada | IntraState | 24/04/2015 | 06.45 | 26/04/2015 | 19.42 | PO | Making Lilo Appanement for Bhaveghar Wada. |
| Deepnagar Amalner | IntraState | 24/04/2015 | 18.10 | 25/04/2015 | 02.29 | T | Distance Protection Operated Z-I B Ph. |
| Padghe - Jindal | IntraState | 25/04/2015 | 01.00 | 25/04/2015 | 03.25 | HT | For Availing Outage on Padgha ICT-IV. |
| Boisar Versova Line | IntraState | 25/04/2015 | 04.05 | 25/04/2015 | 09.14 | HT | For Outage on 220KV Boiser-Boiser PG. |
| Sonkhar - Trombay | IntraState | 25/04/2015 | 06.04 | 25/04/2015 | 06.45 | T | B-Ph P.T Burst at Sonkhar. |
| Kharghar - Nerul | IntraState | 25/04/2015 | 06.04 | 25/04/2015 | 06.29 | T | Tripped only from kharghar End. |
| Nerul - Sonkhar | IntraState | 25/04/2015 | 06.04 | 25/04/2015 | 10.18 | T | B-Ph P.T Burst at Sonkhar. |
| Boisar II - PGCIL II | IntraState | 25/04/2015 | 06.57 | 25/04/2015 | 08.59 | PO | Attending Hot Spot |
| Peth- Mudshingi -I | IntraState | 25/04/2015 | 08.48 | 25/04/2015 | 17.50 | PO | Insulator Wsshing. |
| Osmanabad - Solapur (Bale) | IntraState | 25/04/2015 | 09.51 | | Continued. | HT | To Control Line Loading. |
| Solapur(Bale) - Tuljapur | IntraState | 25/04/2015 | 09.51 | | Continued. | HT | To Control Line Loading. |
| Eklahara(Ocr)-Raymond (Padagha-I) | IntraState | 25/04/2015 | 09.52 | 25/04/2015 | 18.11 | PO | Cold Washing of Insulator. |
| Chalisingaon -Babhaleshwar | IntraState | 25/04/2015 | 13.30 | 25/04/2015 | 16.50 | HT | Due to Outage on Chalisingaon-khadka - I & II. |
| Khadka-Chalisingaon-1 | IntraState | 25/04/2015 | 13.46 | 25/04/2015 | 16.39 | PO | For Rectification Work of Lossened Earthwire 220KV Chalisingaon-Bhusawal Line. |
| Khadka-Chalisingaon-2 | IntraState | 25/04/2015 | 13.54 | 25/04/2015 | 16.41 | PO | For Rectification Work of Lossened Earthwire 220KV Chalisingaon-Bhusawal Line. |
| Padgha - Temghar I | IntraState | 25/04/2015 | 22.14 | 26/04/2015 | 06.26 | HT | For Availing Outage on ICT-IV @ Padgha. |
| Padgha-Temghar-II | IntraState | 25/04/2015 | 22.14 | 26/04/2015 | 06.27 | HT | For Availing Outage on ICT-IV @ Padgha. |
| Boisar II - PGCIL II | IntraState | 26/04/2015 | 09.05 | 26/04/2015 | 17.40 | PO | Taken on TBC. |
| Nagothane - MSL | IntraState | 26/04/2015 | 09.20 | 26/04/2015 | 17.48 | PO | Testing Work. |
| Dhamangaon New - Badnera | IntraState | 26/04/2015 | 14.17 | 26/04/2015 | 14.31 | T | Distance Protection |
| Dhamangaon New- Tss-II | IntraState | 26/04/2015 | 14.17 | 26/04/2015 | 14.31 | T | Back up prot optd,O/C & E/F. |
| Dhamangaon New- Tss -I | IntraState | 26/04/2015 | 14.17 | 26/04/2015 | 14.31 | T | Back up prot optd,O/C & E/F. |
| Wardha-Dhamangaon | IntraState | 26/04/2015 | 14.17 | 26/04/2015 | 18.44 | T | Distance Protection |
| 220 KV ICT Outages/Trippings | | | | | | | |
| 220/100 Kv 200 MVA ICT III @Borivali | IntraState | 21/09/2014 | 09.16 | | Continued. | T | Monkey Fault |
| 220/132 KV 200MVA Vijai ICT-2 @Theur | IntraState | 25/04/2015 | 09.43 | 25/04/2015 | 15.27 | PO | Half Yearly Maint.Work. |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage