

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 25/Apr/2020 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 61.099         | 1496.086        | 1) Gujrat                      | 8.649          | 252.510         |
| 2) Hydro            | 25.544         | 472.154         | 2) Madhya Pradesh              | 13.668         | 369.848         |
| 3) Gas              | 6.777          | 172.739         | 3) Chattisgarh                 | 7.960          | 190.240         |
| <b>Total MSPGCL</b> | <b>93.420</b>  | <b>2140.979</b> | 4) Maharashtra                 | 137.228        | 3140.210        |
| B) 1) APML          | 56.146         | 1589.114        | 5) Goa (Amona)                 | 0.000          | 0.000           |
| 2) JSWEL            | 19.130         | 400.570         | <b>Total</b>                   | <b>167.505</b> | <b>3952.808</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 21.583         | 461.210         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 23.566         | 420.026         |
| 5) WPCL             | 2.624          | 134.297         | c) MSEDCL Bilateral *          | 63.796         | 1343.318        |
| 6) Other IPP        | 7.222          | 200.490         | Include PX                     | 41.251         | 858.389         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 21.583         | 461.210         |
| C) 1) TPCL Thermal  | 6.510          | 268.316         | Include PX                     | 5.206          | 148.076         |
| 2) TPCL Hydro       | 4.217          | 106.193         | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.405          | 88.002          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.982          | 257.552         | 1) MSEDCL                      | 356.729        | 8507.224        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 47.680         | 1140.086        |
| 1) Thermal          | 161.713        | 4346.425        | <b>TOTAL STATE</b>             | <b>404.409</b> | <b>9647.310</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 29.761         | 578.347         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.182         | 260.741         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 26.105         | 324.805         |                                |                |                 |
| 6) SOLAR            | 8.143          | 184.187         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>236.904</b> | <b>5694.505</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 14 Hrs | C. Evening Peak at 22 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 2485                      | 2209                  | 2822                      | 2734                      |
| MSPGCL Hydro             | 230                       | 258                   | 1325                      | 1700                      |
| MSPGCL Gas               | 280                       | 278                   | 284                       | 289                       |
| MSPGCL Total Generation  | 2995                      | 2745                  | 4431                      | 4723                      |
| Central Sector Receipt   | 7699                      | 8108                  | 5952                      | 5997                      |
| WIND                     | 1092                      | 1282                  | 689                       | 1212                      |
| CPP / IPP Thermal        | 3579                      | 3327                  | 3659                      | 3652                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 1092                      | 1031                  | 0                         | 0                         |
| Exchange with Mumbai     | -1029                     | -1055                 | -961                      | -968                      |
| <b>MSEDCL DEMAND MET</b> | <b>15428</b>              | <b>15438</b>          | <b>13770</b>              | <b>14616</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15428                     | 15438                 | 13770                     | 14616                     |
| TPCL GENERATION          | 498                       | 492                   | 827                       | 743                       |
| AEML GENERATION          | 375                       | 374                   | 376                       | 374                       |
| <b>MUMBAI DEMAND</b>     | <b>1902</b>               | <b>1921</b>           | <b>2164</b>               | <b>2085</b>               |
| STATE DEMAND MET         | 17330                     | 17359                 | 15934                     | 16701                     |
| <b>STATE DEMAND</b>      | <b>17330</b>              | <b>17359</b>          | <b>15934</b>              | <b>16701</b>              |
| Frequency (Hz)           | 50.01                     | 50.04                 | 49.97                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 06:01 Hrs | 49.75 Hz at 12:14 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 25/Apr/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 112.89        | 0        | 0        |
| Unit 9             | 0.00         | 112.84        | 0        | 0        |
| Unit 10            | 0.00         | 108.90        | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>334.63</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 13.91         | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 10.20        | 70.10         | 480      | 370      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 10.46        | 211.09        | 490      | 360      |
| Unit 9             | 10.26        | 238.43        | 482      | 365      |
| <b>Total</b>       | <b>30.92</b> | <b>533.53</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.35         | 134.76        | 250      | 208      |
| Unit 4             | 5.54         | 123.57        | 252      | 200      |
| <b>Total</b>       | <b>10.89</b> | <b>258.33</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 0.00         | 38.21         | 0        | 0        |
| Unit 2             | 0.24         | 44.67         | 70       | 0        |
| Unit 3             | 4.32         | 51.16         | 195      | 158      |
| Unit 4             | 4.21         | 54.86         | 190      | 160      |
| Unit 5             | 10.51        | 180.70        | 500      | 365      |
| <b>Total</b>       | <b>19.29</b> | <b>369.60</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.78         | 172.74        | 300      | 268      |
| <b>Total</b>       | <b>6.78</b>  | <b>172.74</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.00         | 4.15          | 0        | 0        |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>  | <b>4.15</b>    |          |          |
| <b>Koyna</b>    |              |                |          |          |
| Stage 1-2       | 5.84         | 137.12         | 530      | 40       |
| Stage 4         | 13.14        | 189.16         | 1011     | 0        |
| Stage 3         | 4.08         | 68.16          | 280      | 0        |
| <b>Total</b>    | <b>23.06</b> | <b>394.44</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.58         | 21.18          | 36       | 18       |
| VTRNA           | 0.00         | 0.00           | 0        | 0        |
| TILLARI         | 0.38         | 10.39          | 60       | 0        |
| BHTGR/VEER      | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.28         | 5.44           | 80       | 0        |
| RNGR+BHTSA      | 0.29         | 7.14           | 13       | 12       |
| BHANDARDRA      | 0.46         | 12.87          | 33       | 12       |
| ELDARY          | 0.00         | 5.36           | 0        | 0        |
| SMLHY_PTN       | 0.50         | 15.32          | 30       | 18       |
| GHATGHAR        | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>    | <b>2.48</b>  | <b>77.71</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 26.10        | 324.80         | 0        | 0        |
| <b>Total</b>    | <b>26.10</b> | <b>324.80</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 56.15        | 1589.11        | 0        | 0        |
| JSWEL(Mus)      | 19.13        | 400.57         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00           | 0        | 0        |
| WPCL(Mus)       | 2.62         | 134.30         | 0        | 0        |
| Other(Mus)      | 7.22         | 200.49         | 0        | 0        |
| <b>Total</b>    | <b>85.12</b> | <b>2324.47</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 8.14         | 184.19         | 0        | 0        |
| <b>Total</b>    | <b>8.14</b>  | <b>184.19</b>  |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 6.51         | 213.49         | 274      | 270      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 2.81         | 54.40          | 118      | 117      |
| Trombay 7B      | 1.60         | 33.60          | 67       | 66       |
| Trombay 8       | 0.00         | 54.82          | 0        | 0        |
| TATA Hydro      | 4.22         | 106.19         | 373      | 18       |
| <b>Total</b>    | <b>15.13</b> | <b>462.51</b>  |          |          |
| <b>AEML</b>     |              |                |          |          |
| DTPS U-1&2      | 8.98         | 257.55         | 376      | 372      |
| <b>Total</b>    | <b>8.98</b>  | <b>257.55</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 61.10       | 1496.09       | MSPGCL Total        | 93.42       | 2140.98       |
|                |             |         | MSPGCL Thml+Gas | 67.88       | 1668.82       | Koyna 1,2 & 4 Total | 18.98       | 326.28        |
|                |             |         | MSPGCL Hydro    | 25.54       | 472.15        | State Total         | 236.90      | 5694.50       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 25/Apr/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|-------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |       |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 2697        | 1461  | 295  | 4453  | 1171  | 4087      | 0    | 0     | 6533        | 6684        | -1156                | 15239                 | 0                    | 15239                     | 2333             | 17572           | 49.94         |
| 2                  | 2698        | 1736  | 277  | 4711  | 1142  | 3739      | 0    | 0     | 6389        | 6351        | -1050                | 14893                 | 0                    | 14893                     | 2195             | 17088           | 49.98         |
| 3                  | 2734        | 1700  | 289  | 4723  | 1212  | 3652      | 0    | 0     | 6263        | 5997        | -968                 | 14616                 | 0                    | 14616                     | 2085             | 16701           | 49.98         |
| 4                  | 2752        | 1580  | 277  | 4609  | 1181  | 3654      | 0    | 0     | 6194        | 6276        | -905                 | 14815                 | 0                    | 14815                     | 1988             | 16803           | 49.97         |
| 5                  | 2742        | 1555  | 300  | 4597  | 1097  | 3678      | 0    | 0     | 6496        | 6537        | -881                 | 15028                 | 0                    | 15028                     | 1935             | 16963           | 50.01         |
| 6                  | 2722        | 1530  | 290  | 4542  | 1232  | 3648      | 0    | 0     | 7418        | 7437        | -896                 | 15963                 | 0                    | 15963                     | 1950             | 17913           | 50.03         |
| 7                  | 2733        | 1314  | 292  | 4339  | 1069  | 3685      | 0    | 43    | 8183        | 8019        | -811                 | 16344                 | 0                    | 16344                     | 1861             | 18205           | 50.07         |
| 8                  | 2729        | 1145  | 289  | 4163  | 838   | 3644      | 0    | 249   | 7740        | 7871        | -860                 | 15905                 | 0                    | 15905                     | 1821             | 17726           | 50.03         |
| 9                  | 2760        | 1016  | 275  | 4051  | 776   | 3648      | 0    | 541   | 7201        | 7093        | -952                 | 15157                 | 0                    | 15157                     | 1846             | 17003           | 50.06         |
| 10                 | 2550        | 959   | 285  | 3794  | 806   | 3605      | 0    | 816   | 7243        | 7200        | -927                 | 15294                 | 0                    | 15294                     | 1873             | 17167           | 50.04         |
| 11                 | 2460        | 314   | 281  | 3055  | 964   | 3572      | 0    | 990   | 7537        | 7561        | -967                 | 15175                 | 0                    | 15175                     | 1892             | 17067           | 50.08         |
| 12                 | 2485        | 230   | 280  | 2995  | 1092  | 3579      | 0    | 1092  | 7928        | 7699        | -1029                | 15428                 | 0                    | 15428                     | 1902             | 17330           | 50.01         |
| 13                 | 2233        | 288   | 268  | 2789  | 1149  | 3388      | 0    | 1008  | 8009        | 8067        | -1044                | 15357                 | 0                    | 15357                     | 1913             | 17270           | 49.97         |
| 14                 | 2209        | 258   | 278  | 2745  | 1282  | 3327      | 0    | 1031  | 8036        | 8108        | -1055                | 15438                 | 0                    | 15438                     | 1921             | 17359           | 50.04         |
| 15                 | 2210        | 199   | 268  | 2677  | 1383  | 3255      | 0    | 934   | 8087        | 8148        | -1098                | 15299                 | 0                    | 15299                     | 1958             | 17257           | 50.02         |
| 16                 | 2204        | 653   | 288  | 3145  | 1358  | 3231      | 0    | 726   | 7701        | 7563        | -1039                | 14984                 | 0                    | 14984                     | 1956             | 16940           | 50.02         |
| 17                 | 2197        | 716   | 269  | 3182  | 1587  | 3210      | 0    | 470   | 7366        | 7407        | -1020                | 14836                 | 0                    | 14836                     | 1894             | 16730           | 50.00         |
| 18                 | 2198        | 991   | 281  | 3470  | 1567  | 3207      | 0    | 206   | 6639        | 6522        | -988                 | 13984                 | 0                    | 13984                     | 1834             | 15818           | 50.03         |
| 19                 | 2202        | 930   | 272  | 3404  | 1280  | 3242      | 0    | 37    | 5864        | 6035        | -964                 | 13034                 | 0                    | 13034                     | 1808             | 14842           | 49.99         |
| 20                 | 2444        | 1575  | 281  | 4300  | 1011  | 3354      | 0    | 0     | 5667        | 5772        | -920                 | 13517                 | 0                    | 13517                     | 1973             | 15490           | 49.98         |
| 21                 | 2747        | 1369  | 285  | 4401  | 780   | 3553      | 0    | 0     | 5416        | 5500        | -915                 | 13319                 | 0                    | 13319                     | 2052             | 15371           | 49.99         |
| 22                 | 2822        | 1325  | 284  | 4431  | 689   | 3659      | 0    | 0     | 5756        | 5952        | -961                 | 13770                 | 0                    | 13770                     | 2164             | 15934           | 49.97         |
| 23                 | 2792        | 1425  | 287  | 4504  | 676   | 3768      | 0    | 0     | 6444        | 6593        | -1020                | 14521                 | 0                    | 14521                     | 2223             | 16744           | 49.96         |
| 24                 | 2779        | 1275  | 286  | 4340  | 763   | 3737      | 0    | 0     | 7090        | 7113        | -1140                | 14813                 | 0                    | 14813                     | 2303             | 17116           | 49.96         |
| MUs                | 61.10       | 25.54 | 6.78 | 93.42 | 26.10 | 85.12     | 0.00 | 8.14  | 167.20      | 167.51      | -23.57               | 356.73                | 0.00                 | 356.73                    | 47.68            | 404.41          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 25/Apr/2020**

Position as on 6.30 Hrs of 26/Apr/2020

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                            | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |           |            |                                                                                             |               |
| IPP                  | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                     |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                      |               |
| CPP                  | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                               |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                               |               |
| MSPGCL               | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL               | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL               | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |           | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                  | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                  | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |           | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL               | Ghatghar Unit-1         | 125      | 18/02/2020   | 00.25        |           | Continued. | Severe Hunting In Hydro Conduit Across MIV                                                  |               |
| MSPGCL               | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |           | Continued. | Gas shortage                                                                                |               |
| IPP                  | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Ghatghar Unit-2         | 125      | 09/03/2020   | 10:50        |           | Continued. | Expansion joint leakage.                                                                    |               |
| IPP                  | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Parli Unit 6            | 250      | 21/03/2020   | 17.31        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Parli Unit 7            | 250      | 22/03/2020   | 10.45        |           | Continued. | Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)                                             |               |
| MSPGCL               | Bhusawal Unit 4         | 500      | 22/03/2020   | 18.30        |           | Continued. | Zero Schedule.                                                                              |               |
| MSPGCL               | Bhusawal Unit 5         | 500      | 23/03/2020   | 01.13        |           | Continued. | Zero schedule.                                                                              |               |
| MSPGCL               | Parli Unit 8            | 250      | 23/03/2020   | 18.00        |           | Continued. | Zero Schedule.                                                                              |               |
| MSPGCL               | Nasik Unit 4            | 210      | 25/03/2020   | 19.45        |           | Continued. | Reserve Shut Down.                                                                          |               |
| IPP                  | JSW (J) U2              | 300      | 26/03/2020   | 00.13        |           | Continued. | No schedule.                                                                                |               |
| MSPGCL               | Chandrapur Unit 4       | 210      | 26/03/2020   | 16.06        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Chandrapur Unit 5       | 500      | 26/03/2020   | 20.29        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Chandrapur Unit 7       | 500      | 28/03/2020   | 23.56        |           | Continued. | Zero Schedule.                                                                              |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 25/Apr/2020**

**Position as on 6.30 Hrs of 26/Apr/2020**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage               | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------|---------------|
| MSPGCL             | Uran Unit 5             | 108      | 06/04/2020   | 13.23        |            | Continued. | Gas shortage                   |               |
| MSPGCL             | Chandrapur Unit 3       | 210      | 10/04/2020   | 20.30        |            | Continued. | Zero Schedule By MSEDCL        |               |
| TPC_G              | Trombay 8               | 250      | 11/04/2020   | 16.55        |            | Continued. | Zero Schedule.                 |               |
| MSPGCL             | Koradi Unit-8           | 660      | 12/04/2020   | 00.00        |            | Continued. | Zero schedule.                 |               |
| MSPGCL             | Koradi Unit 9           | 660      | 12/04/2020   | 01.10        |            | Continued. | Zero schedule.                 |               |
| MSPGCL             | Koradi Unit 10          | 660      | 12/04/2020   | 02.01        |            | Continued. | Zero schedule.                 |               |
| MSPGCL             | Khaparkheda Unit 1      | 210      | 22/04/2020   | 20.45        |            | Continued. | Zero Schedule By MSEDCL        |               |
| MSPGCL             | Khaparkheda Unit 2      | 210      | 22/04/2020   | 21.06        | 25/04/2020 | 18.59      | Zero Schedule By MSEDCL        |               |
| CPP                | SWPGL U-3               | 135      | 25/04/2020   | 00.08        |            | Continued. | No Schedule                    |               |
| IPP                | Adani U-1               | 660      | 25/04/2020   | 01.12        |            | Continued. | APH 1A Flue Gas Bellow Leakage |               |
| MSPGCL             | Koyana Unit 3           | 70       | 25/04/2020   | 01.29        | 26/04/2020 | 05.55      | Electrical fault               |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 25/Apr/2020**

**Statement-VII**

**Position as on 6.30 Hrs of 26/Apr/2020**

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                         |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                          |
| Karad Solapur (PG)                         | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                 |
| Dhule Sar'Sarovar II                       | InterState                | 21/04/2020   | 17.20        |            | Continued. | HT          | Over Voltage                                                                             |
| Karad - Jaigad - II                        | IntraState                | 23/03/2020   | 18.12        |            | Continued. | HT          | Over Voltage                                                                             |
| Dhule- Bableshtar - I                      | IntraState                | 24/03/2020   | 20.20        |            | Continued. | HT          | Over Voltage                                                                             |
| New Koyana - Dabhol-I                      | IntraState                | 25/03/2020   | 18.01        |            | Continued. | T           | Over Voltage                                                                             |
| Padghe - Nagothane - II                    | IntraState                | 07/04/2020   | 23.58        |            | Continued. | EO          | To attend Hot Spot                                                                       |
| Chandrapur - Parli                         | IntraState                | 19/04/2020   | 02.20        |            | Continued. | T           | Distance Protection(Tower collapsed at Loc.No.59.60.61)                                  |
| Chandrapur-II - Nanded ckt II              | IntraState                | 19/04/2020   | 02.21        |            | Continued. | T           | Distance Protection(Tower collapsed at Loc.No.59.60.61)                                  |
| Babhaleshtar - Padghe-II                   | IntraState                | 20/04/2020   | 09.25        |            | Continued. | PO          | Quarterly Maintenance work & Relay Testing, for CVT replacement work (RFC at 21.22 Hrs). |
| Girwali- Lonikand 2                        | IntraState                | 20/04/2020   | 14.23        |            | Continued. | HT          | Controlling loading of Parli Parli (PG D/C line).                                        |
| Taptitanda Waluj                           | IntraState                | 22/04/2020   | 17.18        |            | Continued. | T           | Distance Protection (RFC at 14.08Hrs DT.24-4-20)                                         |
| karad -kolhapur-II                         | IntraState                | 24/04/2020   | 19.49        |            | Continued. | HT          | Over Voltage                                                                             |
| Khadka-Aurangabad (Waluj)                  | IntraState                | 24/04/2020   | 21.25        | 25/04/2020 | 06.23      | HT          | Over Voltage                                                                             |
| Main Bus A @Kharghar                       | IntraState                | 25/04/2020   | 13.30        |            | Continued. | EO          | Replacement Of A BUS R PH Faulty PG Isolator of ICT-3 & ICT-1.                           |
| Kharghar-Talegaon(PG)                      | IntraState                | 26/04/2020   | 06.43        | 26/04/2020 | 09.00      | EO          | CB air leakage at Kharghar.                                                              |
| <b>400 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                          |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe        | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                                 |
| 400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2 | IntraState                | 09/03/2020   | 12.57        |            | Continued. | EO          | Testing work (Bushing Tan Delta problem hence kept out.)                                 |
| 400/220/33 Kv 315 Mva Ict- 2 @Kharghar     | IntraState                | 25/03/2020   | 13.59        |            | Continued. | EO          | CT Tan Delta High(Kept on Humming at 15.52Hrs DT. 24-4-20)                               |
| 400/220 KV 315 MVA ICT-I @ Nagothane       | IntraState                | 25/03/2020   | 17.57        |            | Continued. | HT          | LV Side CB Hand Tripped For Voltage.                                                     |
| 400/220/33kv 315mva Ict3 @Lonikand         | IntraState                | 25/03/2020   | 22.01        |            | Continued. | HT          | LV Side CB Hand Tripped For Voltage.                                                     |
| 400/220 Kv 500 MVA ICT-III @Kalwa          | IntraState                | 28/03/2020   | 18.07        |            | Continued. | HT          | Over Voltage                                                                             |
| 400/220/33 Kv 500 MVA ICT-I @Lonikand 2    | IntraState                | 17/04/2020   | 13.19        |            | Continued. | PO          | Attending Hot Spot                                                                       |
| 400/220 Kv 500 MVA ICT-IV @Kalwa           | IntraState                | 19/04/2020   | 11.55        |            | Continued. | HT          | Over Voltage                                                                             |
| 400/220/33 Kv 315 MVA ICT-3 @Padghe        | IntraState                | 24/04/2020   | 18.10        |            | Continued. | T           | Y Phase Stub Bus Conductor suspension string broke at Padgha                             |
| 400/220kv 315MVA ICT-III @ Kharghar        | IntraState                | 25/04/2020   | 11.15        | 26/04/2020 | 09.36      | PO          | Routine Maintenance Work                                                                 |
| 400/220/33 Kv 600 MVA ICT 4 @Padghe        | IntraState                | 25/04/2020   | 11.57        | 25/04/2020 | 13.47      | PO          | Routine Maintenance Work                                                                 |
| 400/220/33kv 500MVA ICT 5 @ Padghe         | IntraState                | 25/04/2020   | 13.53        | 25/04/2020 | 13.57      | PO          | Routine Maintenance Work                                                                 |
| <b>220 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                          |
| Mudshingi Chikodi                          | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.                                                                             |
| Talandage - Chikodi                        | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                                                  |
| BOISAR BORIVALI                            | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                                             |
| Borivali - Ghodbunder                      | IntraState                | 30/01/2020   | 12.05        |            | Continued. | PO          | Isolation of 220KV Cables on MSETCL Tower NO.240                                         |
| Lonand-Baramati                            | IntraState                | 16/02/2020   | 09.37        |            | Continued. | PO          | Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand &                                 |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 25/Apr/2020**

**Statement-VII**

Position as on 6.30 Hrs of 26/Apr/2020

| Name of Line                                          | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                             |
|-------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------|
|                                                       |                           |              |              |            |            |             | Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.                  |
| Hinjewadi2 - Hinjewadi 3 ckt II                       | IntraState                | 26/03/2020   | 10.20        |            | Continued. | HT          | Over Voltage                                                                 |
| Hinjewadi2 - Hinjewadi 3 ckt 1                        | IntraState                | 26/03/2020   | 10.20        |            | Continued. | HT          | Over Voltage                                                                 |
| 220 KV VIRODA - AMALNER                               | IntraState                | 25/04/2020   | 07.00        | 25/04/2020 | 20.17      | PO          | For Replacement of suspected insulator strings from loc. no. 117 to 150.     |
| Boisar II - Boisar PG I                               | IntraState                | 25/04/2020   | 07.21        | 25/04/2020 | 13.21      | PO          | Routine Maintenance Work & CT Testing work.                                  |
| Deoli(Pgcil)-Badnera                                  | IntraState                | 25/04/2020   | 07.25        | 25/04/2020 | 18.34      | PO          | For safety Purpose to carry out Construction work of 220KV Badnera-Ner line. |
| Badnera-Akola I                                       | IntraState                | 25/04/2020   | 08.01        | 25/04/2020 | 19.01      | PO          | For Erection of MD+9 Tower at Loc. No.9.of 220KV Badnera-Ner line phase.     |
| Badnera-Akola li                                      | IntraState                | 25/04/2020   | 08.02        | 25/04/2020 | 19.02      | PO          | For Erection of MD+9 Tower at Loc. No.9.of 220KV Badnera-Ner line phase.     |
| Talandage - Sawantwadi I                              | IntraState                | 25/04/2020   | 09.35        | 25/04/2020 | 15.04      | PO          | Outage For 220KV Isolator maintenance work & Relay testing.                  |
| Sawantwadi-Bidri                                      | IntraState                | 25/04/2020   | 18.15        | 26/04/2020 | 08.35      | HT          | Over Voltage                                                                 |
| <b>220 KV ICT Outages/Trippings</b>                   |                           |              |              |            |            |             |                                                                              |
| Carnac : 220 / 110 / 33 315 MVA ICT 5                 | IntraState                | 14/03/2020   | 11.00        |            | Continued. | PO          | Shifting 220KV Side to New GIS                                               |
| 220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-li (Mudshingi) | IntraState                | 21/04/2020   | 17.50        |            | Continued. | HT          | Over Voltage                                                                 |
| 220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon            | IntraState                | 25/04/2020   | 07.33        | 25/04/2020 | 11.58      | PO          | HV & LV CT Tan Delta measurement & bay maintenance work.                     |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage