

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/May/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.513	4163.236	1) Gujrat	-6.209	-143.751
2) Hydro	42.363	550.486	2) Madhya Pradesh	3.329	131.404
3) Gas	3.240	141.398	3) Chattisgarh	3.780	87.420
Total MSPGCL	205.116	4855.120	4) Maharashtra	165.885	4600.119
B) 1) APLM	76.197	1603.555	5) Goa (Amona)	-1.488	-33.523
2) JSWEL	16.504	454.036	Total	165.297	4641.669
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.937	887.879
4) RPL(AMT)	19.290	611.941	b) Mumbai Drawl	40.327	952.817
5) SWPGPL	9.457	209.794	c) MSEDCL Bilateral *	75.865	1896.611
6) Other IPP	16.096	499.088	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.902	887.723
C) 1) TPCL Thermal	15.428	360.841	Include PX	0.000	0.000
2) TPCL Hydro	5.061	103.338	Standby	0.035	0.156
3) TPCL Gas	0.644	56.032	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.651	279.152	1) MSEDCL	496.304	12703.852
D) STATE			2) Mumbai Discoms	73.111	1752.164
1) Thermal	324.136	8181.643	3) Other Discoms	9.662	233.316
(A1+C1+C4+(B1-B6))			TOTAL STATE	579.077	14689.332
2) Hydro	47.424	653.824			
(A2+C2)					
3) Gas	3.884	197.430			
(A3+B7+C3)					
4) Wind	28.075	787.516			
6) SOLAR	10.261	227.266			
TOTAL STATE	413.780	10047.679			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6772	6664	6527	6677
MSPGCL Hydro	1318	1806	2084	1856
MSPGCL Gas	140	120	120	140
MSPGCL Total Generation	8230	8590	8732	8674
Central Sector Receipt	8221	8721	6128	5850
WIND	350	359	1712	1526
CPP / IPP Thermal	5611	5638	5947	5700
CPP / IPP Gas	0	0	0	0
SOLAR	1347	1069	0	0
Exchange with Mumbai	-2132	-2165	-1504	-1278
MSEDCL DEMAND MET	21191	21805	20582	20141
Load Shedding	0	0	0	0
MSEDCL DEMAND	21191	21805	20582	20141
TPCL GENERATION	875	891	1126	715
AEML GENERATION	476	466	500	472
MUMBAI DEMAND	3483	3522	3130	2465
OTHER DISCOM DEMAND	435	408	432	331
STATE DEMAND MET	25110	25734	24144	22936
STATE DEMAND	25110	25734	24144	22936
Frequency (Hz)	49.96	49.97	49.90	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.12 Hz at 18.02 Hrs	49.68 Hz at 23.05 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 25/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.58	97.34	155	135
Unit 7	0.00	0.00	0	0
Unit 8	13.79	333.72	609	538
Unit 9	13.38	308.88	598	498
Unit 10	12.97	318.79	553	510
Total	43.72	1058.73		
Bhusawal				
Unit 3	0.00	74.35	0	0
Unit 4	9.06	198.44	450	285
Unit 5	8.94	221.90	435	275
Total	18.01	494.68		
Parli				
Unit 6	1.49	69.70	235	0
Unit 7	5.17	101.90	227	205
Unit 8	3.10	67.23	136	123
Total	9.76	238.82		
Chandrapur				
Unit 3	3.77	93.84	161	153
Unit 4	3.43	86.75	147	137
Unit 5	0.00	189.08	0	0
Unit 6	9.14	202.37	395	365
Unit 7	8.30	223.94	381	305
Unit 8	10.62	249.76	454	430
Unit 9	10.41	251.45	442	424
Total	45.67	1297.20		
Paras				
Unit 3	4.72	105.35	217	140
Unit 4	4.33	109.67	198	150
Total	9.06	215.03		
Khaparkheda				
Unit 1	2.96	73.86	135	110
Unit 2	3.48	87.84	155	125
Unit 3	4.28	89.33	182	175
Unit 4	3.20	79.39	147	125
Unit 5	11.43	275.02	480	468
Total	25.35	605.43		
Nasik				
Unit 3	0.00	79.46	0	0
Unit 4	3.85	86.12	177	140
Unit 5	4.09	87.77	180	165
Total	7.94	253.35		
Uran				
All Units	3.24	141.40	150	120
Total	3.24	141.40		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	2.84	23	0
Total	0.12	2.84		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	9.39	116.22	525	50
Stage 4	20.60	182.08	1021	406
Stage 3	6.70	66.34	320	160
Total	36.69	364.63		
Hydro				
KDPH	0.59	13.35	25	25
VTRNA	0.00	17.34	0	0
TILLARI	0.00	8.24	0	0
BHIRA T.R.	0.18	4.76	77	0
SMLHY_PTN	4.79	130.06	222	178
GHATGHAR	0.00	9.26	0	0
Total	5.56	183.01		
Wind				
Total	28.08	787.52	0	0
Total	28.08	787.52		
CPP				
APML(Mus)	76.20	1603.56	0	0
JSWEL(Mus)	16.50	454.04	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.29	611.94	0	0
SWPGPL-Mus	9.46	209.79	0	0
Other(Mus)	16.10	499.09	0	0
Total	137.54	3378.41		
SOLAR				
Total	10.26	227.27	0	0
Total	10.26	227.27		
Tata				
Trombay 5	9.99	235.22	453	278
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.64	34.96	114	0
Trombay 7B	0.00	21.07	0	0
TATA Hydro	5.06	103.34	359	52
Trombay 8	5.44	125.63	239	208
Total	21.13	520.21		
AEML				
DTPS U-1&2	11.65	279.15	500	450
Total	11.65	279.15		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	159.51	4163.24
MSPGCL Thml+Gas	162.75	4304.63
MSPGCL Hydro	42.36	550.49

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	205.12	4855.12
Koyna 1,2 & 4 Total	29.98	298.29
State Total	413.78	10047.68

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/May/2022

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6728	2030	130	8888	2171	5981	0	0	5791	5815	-1668	20839	0	20839	3050	348	24238	49.92
2	6695	1934	140	8770	2127	5862	0	0	5742	5921	-1461	20896	0	20896	2842	322	24060	49.92
3	6626	1956	140	8722	1969	5703	0	0	5606	5711	-1316	20483	0	20483	2663	306	23452	49.96
4	6641	1834	140	8614	1679	5683	0	0	5508	5650	-1215	20098	0	20098	2537	313	22948	50.00
5	6677	1856	140	8674	1526	5700	0	0	5569	5850	-1278	20141	0	20141	2465	331	22936	49.98
6	6699	2034	140	8874	1410	5705	0	0	5611	6261	-1271	20621	0	20621	2444	357	23422	49.84
7	6680	2048	140	8868	1039	5656	0	86	5817	6356	-1299	20311	0	20311	2412	395	23118	49.91
8	6721	1864	140	8724	827	5596	0	376	6431	6781	-1472	20403	0	20403	2521	430	23354	50.01
9	6674	1140	130	7944	891	5579	0	740	6933	7139	-1706	20154	0	20154	2817	434	23404	50.04
10	6698	972	150	7820	690	5633	0	1011	7623	7646	-1910	20451	0	20451	3144	438	24033	50.00
11	6763	1116	120	8000	471	5611	0	1252	8017	7800	-2100	20583	0	20583	3378	451	24412	50.00
12	6772	1318	140	8230	350	5611	0	1347	8373	8221	-2132	21191	0	21191	3483	435	25110	49.96
13	6748	1392	130	8270	275	5600	0	1378	8464	8316	-2106	21292	0	21292	3476	441	25210	49.94
14	6715	1390	140	8244	295	5625	0	1274	8461	8368	-2045	21332	0	21332	3413	429	25174	49.91
15	6664	1806	120	8590	359	5638	0	1069	8352	8721	-2165	21805	0	21805	3522	408	25734	49.97
16	6600	1970	130	8700	523	5638	0	853	8347	8552	-2237	21599	0	21599	3592	430	25622	49.94
17	6587	1928	130	8644	830	5636	0	581	8196	7800	-2063	20976	0	20976	3507	453	24936	49.92
18	6578	1806	130	8514	1113	5623	0	257	7539	7345	-1833	20581	0	20581	3366	438	24386	49.97
19	6460	1960	140	8560	1328	5694	0	37	6417	6371	-1583	19969	0	19969	3173	437	23580	50.01
20	6527	2084	120	8732	1712	5947	0	0	5752	6128	-1504	20582	0	20582	3130	432	24144	49.90
21	6598	2062	140	8800	1659	5943	0	0	5887	6077	-1528	20516	0	20516	3060	435	24012	50.00
22	6507	2094	130	8732	1683	5955	0	0	5866	5728	-1464	20211	0	20211	3000	422	23634	49.92
23	6530	1804	140	8474	1619	5959	0	0	6470	6268	-1447	20472	0	20472	3017	401	23890	49.89
24	6625	1962	140	8726	1529	5966	0	0	6729	6472	-1524	20796	0	20796	3099	373	24268	49.85
MUs	159.51	42.36	3.24	205.12	28.07	137.54	0.00	10.26	163.50	165.30	-40.33	496.30	0.00	496.30	73.11	9.66	579.08	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/May/2022

Position as on 6.30 Hrs of 26/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 5	108	16/05/2022	12:59	26/05/2022	09:42	Gas shortage	
TPC-G	Trombay 7B	60	16/05/2022	23:59	26/05/2022	01:25	Non availability of APM gas.	
MSPGCL	Parli Unit 6	250	19/05/2022	20:00	25/05/2022	13:20	Boiler Tube Leakage	23/05/2022
TPC-G	Trombay 7A	120	21/05/2022	01:26	25/05/2022	17:00	Gas shortage	
MSPGCL	Nasik Unit 3	210	21/05/2022	17:14	26/05/2022	09:40	Boiler Tube Leakage	26/05/2022
MSPGCL	Chandrapur Unit 5	500	23/05/2022	07:45	26/05/2022	18:00	Boiler Tube Leakage	26/05/2022
IPP	RPL(AMT) U-3	270	24/05/2022	02:23		Continued.	Flame Failure	28/05/2022
MSPGCL	Bhusawal Unit 3	210	24/05/2022	17:31		Continued.	CVSM Control Valve Problem	30/05/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2022

Statement-VII

Position as on 6.30 Hrs of 26/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TBC @ PADGHE	IntraState	26/05/2022	10:12	26/05/2022	17:15	PO	1) Bay Maint work 2) MTAMC work
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	26/05/2022	08:37	26/05/2022	19:11	PO	For attending oil leakages through PRV by replacing new PRV and replacement of RTD censor with CCU of WTI & OTI and attending problem of motorised 400 kV Reactor isolator problem
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 1	InterState	23/05/2022	09:06	25/05/2022	19:16	PO	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM
400KV NANDED(KUMBHARGAON)-PARLY CKT 2	InterState	25/05/2022	06:22	25/05/2022	16:51	PO	To attend broken conductor strands bet loc no 86_87,116_117
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	25/05/2022	06:20	25/05/2022	14:58	PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	26/05/2022	06:06	26/05/2022	16:47	PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/05/2022	11:07			HT	H/T FOR LOAD MANAGEMENT
PADGHE - NAGOTHANE CKT - 2	IntraState	26/05/2022	12:25	26/05/2022	13:33	PO	For jumper tightning work and emergency tree cutting work
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	25/05/2022	02:33	25/05/2022	10:11	T	Tripped on NDR Stage-1. Heavy Rain with High Speed Winds reported.
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	25/05/2022	08:19	25/05/2022	18:30	PO	For RTV coating to Tertiary 33 kv connection & Pre-Monsoon maintenance
400/220/33KV 500 MVA ICT - 1 @ KUDUS	IntraState	25/05/2022	10:38	25/05/2022	19:16	EO	Outage required for completion of pending work of 400/220/33 kV ICT-2 and 33 kV station T/F -2 Bay
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	26/05/2022	08:54	26/05/2022	18:12	PO	(1) SFRA measurement ICT Units. (2) Bay maintenance work.
400/220/33KV 500 MVA ICT - 1 @ KUDUS	IntraState	26/05/2022	11:50	26/05/2022	17:57	HT	E/O AVAILED BY PG
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	26/05/2022	12:07			PO	Routine Maintenance & testing work
400 KV BR Outages/Trippings							
125MVAr BUS REACTOR @ WARORA	IntraState	25/05/2022	08:21	25/05/2022	15:29	PO	Premonsoon Maintenance work. Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .
220 KV TBC Outages/Trippings							
TBC @ AAREY	IntraState	25/05/2022	09:10	25/05/2022	17:55	PO	For safety purpose while working on 100MVA TR-1
TBC @ AAREY	IntraState	26/05/2022	09:00	26/05/2022	17:50	PO	For Safety Purpose
TBC @ GHODBUNDER	IntraState	26/05/2022	09:22	26/05/2022	11:28	PO	For Safety purpose
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2022

Statement-VII

Position as on 6.30 Hrs of 26/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - TARAPUR	IntraState	18/05/2022	14:36			PO	Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth wire and all insulator strings of the line.
PADGHE - TEMGHAR - 2	IntraState	20/05/2022	00:02	26/05/2022	07:20	PO	Bunching at Loc no.82 and jumper opening at Loc.no. 80.
BUS SECTION-4 @ TEMGHAR	IntraState	20/05/2022	07:23			EO	For closing 220kv Bus section 3 isolator
BUS SECTION-4 @ TEMGHAR	IntraState	20/05/2022	07:23	26/05/2022	07:21	PO	220KV Temghar -Padghe 1 & 220KV Temghar-Colourchem line will be in service. Load of T/F no.4 will be shifted to T/F no. 2. Load of T/F no.5 will be shifted to T/F no. 1 & 3.
JEJURI - KONDHWA	IntraState	24/05/2022	10:41	26/05/2022	11:18	PO	220 kV Jejuri-Kondhwa bay CB mechanism overhauling work and attend of SF6 gas leakage of Y phase pole of CB.
VSNL - STT GIS CKT - 2	IntraState	24/05/2022	10:43			PO	Addition of New 02 Nos of GIS T/F Bay to existing 220kv Bus 2 at 220 KV STT GIS Substation end.
NAGOTHANE - IPCL	IntraState	25/05/2022	02:34	25/05/2022	16:48	T	Tripped HeavyRains with speedy Winds reported.
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	25/05/2022	08:43	25/05/2022	19:49	PO	Hardware Tightening & Fitting work
SADAWAGHAPUR KARAD CKT 1	IntraState	25/05/2022	10:03	25/05/2022	18:18	PO	For taking C & Tan Delta and CB CRM, Timing Measurement.
LAMBOTI - KARKAMB	IntraState	25/05/2022	10:28	25/05/2022	18:34	PO	Outage is required for 1) For changing / replacement of faulty string at loc no. 12, 18, 69, 80 & 89. 2) Disc cleaning work from loc 24 to 75 (Pandharpur - Karkamb section)
NAGOTHANE - POSCO	IntraState	25/05/2022	13:38	25/05/2022	19:57	PO	Outage tree cutting work at various location and other line maintenance work.
PADGHE - TEMGHAR - 1	IntraState	26/05/2022	00:07	26/05/2022	03:27	PO	For removing of bunching arrangement between 220KV Padgha-Temghar 1 & 2 line at Loc no.82 and re-fixing of jumper at Loc. no. 80.
CHAKAN-BHOSARI 1	IntraState	26/05/2022	11:36	26/05/2022	18:56	PO	Double Jumpering Work
PANDHARPUR - MALINAGAR	IntraState	26/05/2022	16:30	26/05/2022	18:56	PO	Outage is required For changing / replacement of faulty string at loc no. Main line - 1CP4, CP 11, CP, 19, 47 LILO Portion - 25, 39, 41.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	25/05/2022	07:48	25/05/2022	13:16	PO	1)Routine Maintenance works Measurement of Neutral Earth Pit Resistance. 3) Premonsoon Maintenance Work
220/33kv 100 MVA TF 3 @ GHODBUNDER	IntraState	25/05/2022	07:54	25/05/2022	17:26	PO	Annual & premonsoon maintenance
220/33kv 100 MVA TF 1 @ AAREY	IntraState	25/05/2022	09:09	25/05/2022	18:33	PO	Annual and Premonsoon maintenance of Transformer, NGT and Bay Equipments

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2022

Statement-VII

Position as on 6.30 Hrs of 26/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 200MVA PTR 1 @ LONAND	IntraState	25/05/2022	09:37	25/05/2022	11:04	PO	Premonsoon maintenance work
220/22 KV 25 MVA PTR 2 @ WASHALA	IntraState	25/05/2022	10:10	25/05/2022	14:50	PO	CB CRM & TIMING, IR Measurement works, Bay Maintenance work
220/100 KV 200 MVA ICT 2 @ PAL-DOMBIVALI	IntraState	25/05/2022	10:12	25/05/2022	15:24	PO	Pre-monsoon RM work. Earth pit resistance measurement work.
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	25/05/2022	10:38	25/05/2022	19:03	PO	Diagnosis of Testing work and pre-monsoon maintenance work.
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/132KV 200MVA PTR 2 @ LONAND	IntraState	25/05/2022	16:34	25/05/2022	17:55	PO	Premonsoon maintenance work
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	25/05/2022	21:29	25/05/2022	23:32	PO	For carrying out Pre-monsoon activities.
220/33kv 100 MVA TF 3 @ AAREY	IntraState	26/05/2022	08:59	26/05/2022	17:50	PO	Annual and Premonsoon maintenance of Transformer, NGT and Bay Equipments
220/33KV 50MVA PTR 1 @ KURKUMBH	IntraState	26/05/2022	09:20	26/05/2022	13:01	PO	PREMONSOON MAINTENANCE WORK
220/33kv 100 MVA TF 1 @ GHODBUNDER	IntraState	26/05/2022	09:22	26/05/2022	11:28	PO	Premonsoon Maintenance
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	26/05/2022	09:36	26/05/2022	18:41	PO	Outage is required for Oil leakage attending work to be carried out by agency.
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	26/05/2022	10:02	26/05/2022	13:44	PO	Premonsoon RM work Earth pit resistance measurement
220/132 KV 100MVA ICT - 1 @ MANMAD	IntraState	26/05/2022	10:05	26/05/2022	11:50	PO	Testing of relays & misc. maintenance work.
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	26/05/2022	10:10	26/05/2022	11:38	PO	Premansoon & Bay maintenance work
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	26/05/2022	10:17	26/05/2022	13:33	PO	Pre monsoon maintenance work .
220/33-33 KV 100 MVA PTR 2 @ BOISAR-II	IntraState	26/05/2022	10:21	26/05/2022	15:26	PO	Pre monsoon maintenance work & diagnostic testing works
220/132KV 100MVA ICT 2 @ KATHAPUR	IntraState	26/05/2022	11:10	26/05/2022	17:40	PO	Pre monsoon Maintenance Work
220/22KV 50MVA PTR 2 @ RANJANGAON	IntraState	26/05/2022	11:16	26/05/2022	17:13	PO	For Pre monsoon work
220/33kv 125 MVA TF 4 @ GHODBUNDER	IntraState	26/05/2022	11:59	26/05/2022	13:44	PO	Premonsoon Maintenance
220/132 KV 100MVA ICT - 2 @ MANMAD	IntraState	26/05/2022	12:26	26/05/2022	13:41	PO	Testing of relays & misc. maintenance work.
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	26/05/2022	13:07	26/05/2022	17:03	PO	PRE MONSOON MAINTENANCE WORK
220/33KV 50MVA PTR -2 @ KURKUMBH	IntraState	26/05/2022	13:15	26/05/2022	17:20	PO	PRE MONSOON MAINTENANCE WORK.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2022

Statement-VII

Position as on 6.30 Hrs of 26/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringing of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage