

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/May/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.079	4111.907	1) Gujrat	-0.467	-79.963
2) Hydro	16.907	527.430	2) Madhya Pradesh	8.108	174.440
3) Gas	5.281	131.343	3) Chattisgarh	4.580	129.220
Total MSPGCL	184.267	4770.680	4) Maharashtra	208.203	5085.015
B) 1) APLM	70.780	1430.631	5) Goa (Amona)	-1.622	-33.534
2) JSWEL	23.200	531.286	Total	218.802	5275.178
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.682	981.939
4) RPL(AMT)	24.927	606.768	b) Mumbai Drawl	47.663	1077.105
5) SWPGPL	10.648	250.453	c) MSEDCL Bilateral *	115.285	2424.449
6) Other IPP	2.768	248.240	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.682	981.851
C) 1) TPCL Thermal	10.705	290.251	Include PX	0.000	0.000
2) TPCL Hydro	5.218	118.774	Standby	0.000	0.089
3) TPCL Gas	2.154	55.920	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.834	251.941	1) MSEDCL	529.355	12640.074
D) STATE			2) Mumbai Discoms	74.574	1793.991
1) Thermal	313.941	7721.477	3) Other Discoms	10.597	257.489
(A1+C1+C4+(B1-B6))			TOTAL STATE	614.526	14691.554
2) Hydro (A2+C2)	22.125	646.204			
3) Gas (A3+B7+C3)	7.435	187.263			
4) Wind	35.246	465.280			
6) SOLAR	16.977	396.152			
TOTAL STATE	395.724	9416.376			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6685	6720	6391	6823
MSPGCL Hydro	182	242	1504	490
MSPGCL Gas	210	205	222	229
MSPGCL Total Generation	7076	7168	8116	7542
Central Sector Receipt	10324	10440	8759	8950
WIND	832	1289	1491	1236
CPP / IPP Thermal	4841	5438	5807	4931
CPP / IPP Gas	0	0	0	0
SOLAR	2201	1429	0	609
Exchange with Mumbai	-2213	-2310	-1975	-1761
MSEDCL DEMAND MET	22585	22982	21709	21065
Load Shedding	0	0	0	0
MSEDCL DEMAND	22585	22982	21709	21065
TPCL GENERATION	817	816	863	559
AEML GENERATION	502	493	353	290
MUMBAI DEMAND	3532	3619	3191	2610
OTHER DISCOM DEMAND	476	471	490	443
STATE DEMAND MET	26594	27072	25390	24118
STATE DEMAND	26594	27072	25390	24118
Frequency (Hz)	50.06	49.97	50.14	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 18:35 Hrs	49.75 Hz at 05:46 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/May/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.92	106.64	180	130
Unit 8	13.33	284.62	601	523
Unit 9	11.03	314.86	585	0
Unit 10	13.13	236.41	577	535
Total	41.41	942.52		
Bhusawal				
Unit 3	3.46	84.98	155	135
Unit 4	10.32	205.94	445	415
Unit 5	0.00	244.74	0	0
Total	13.78	535.66		
Parli				
Unit 6	4.78	90.08	250	151
Unit 7	4.63	97.19	245	115
Unit 8	4.23	114.36	193	148
Total	13.64	301.63		
Chandrapur				
Unit 3	3.73	90.09	165	140
Unit 4	3.63	80.51	160	124
Unit 5	0.00	170.06	0	0
Unit 6	9.51	230.44	415	365
Unit 7	9.68	233.77	430	341
Unit 8	11.45	242.21	489	459
Unit 9	11.73	274.03	500	473
Total	49.73	1321.11		
Paras				
Unit 3	4.66	119.08	228	175
Unit 4	5.19	124.77	235	199
Total	9.85	243.85		
Khaparkheda				
Unit 1	3.14	75.64	135	120
Unit 2	3.04	73.29	139	105
Unit 3	4.10	100.48	184	130
Unit 4	4.41	99.92	190	171
Unit 5	10.91	223.50	465	443
Total	25.60	572.84		
Nasik				
Unit 3	0.00	25.27	0	0
Unit 4	4.12	100.94	180	137
Unit 5	3.95	68.09	174	154
Total	8.07	194.30		
Uran				
All Units	5.28	131.34	232	204
Total	5.28	131.34		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	0.76	20	0
Total	0.03	0.76		
Koyna				
Stage 1-2	3.56	110.26	355	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.93	237.46	999	0
Stage 3	2.07	77.04	320	0
Total	12.56	424.76		
Hydro				
KDPH	0.56	16.62	24	24
VTRNA	1.06	25.93	60	0
TILLARI	0.46	2.13	58	0
BHIRA T.R.	0.26	6.99	77	0
SMLHY_PTN	1.98	50.24	89	79
GHATGHAR	0.00	0.00	0	0
Total	4.32	101.90		
Wind				
Total	35.25	465.28	0	0
Total	35.25	465.28		
CPP				
APML(Mus)	70.78	1430.63	0	0
JSWEL(Mus)	23.20	531.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.93	606.77	0	0
SWPGPL-Mus	10.65	250.45	0	0
Dhariwal	0.00	16.14	0	0
IEPL	0.00	116.69	0	0
Other(Mus)	2.77	115.41	0	0
Total	132.32	3067.38		
SOLAR				
Total	16.98	396.15	0	0
Total	16.98	396.15		
Tata				
Trombay 5	7.20	189.32	363	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.19	32.67	108	38
Trombay 7B	0.96	23.25	64	35
TATA Hydro	5.22	118.77	385	63
Trombay 8	3.50	100.93	174	129
Total	18.08	464.94		
AEML				
DTPS U-1&2	8.83	251.94	502	285
Total	8.83	251.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.08	4111.91	MSPGCL Total	184.27	4770.68
			MSPGCL Thml+Gas	167.36	4243.25	Koyna 1,2 & 4 Total	10.49	347.73
			MSPGCL Hydro	16.91	527.43	State Total	395.72	9416.38

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/May/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6883	1172	228	8284	2063	5977	0	0	8933	8662	-2011	22568	0	0	22568	3113	406	26088	49.98
2	6921	882	231	8034	2081	5977	0	0	8759	8702	-1886	22546	0	0	22546	2889	361	25796	49.98
3	6976	606	230	7812	1969	5977	0	0	8729	8624	-1827	22214	0	0	22214	2706	341	25260	49.98
4	7047	288	232	7568	1830	5956	0	0	8578	8616	-1705	21935	0	0	21935	2569	330	24834	49.98
5	7077	280	231	7588	1662	5942	0	0	8723	8758	-1647	21938	0	0	21938	2509	365	24812	49.99
6	7060	412	232	7704	1494	5927	0	0	8963	8946	-1653	22033	0	0	22033	2490	384	24908	49.98
7	6892	390	230	7512	1391	5732	0	158	8706	8758	-1653	21481	0	0	21481	2474	418	24372	49.90
8	6823	490	229	7542	1236	4931	0	609	8837	8950	-1761	21065	0	0	21065	2610	443	24118	49.96
9	6777	288	219	7284	1217	4893	0	1234	9157	9188	-1992	21356	0	6	21356	2908	468	24732	50.02
10	6714	566	218	7498	1028	4231	0	1724	9736	10034	-2024	22019	0	0	22019	3219	472	25710	50.03
11	6763	440	216	7420	837	4476	0	2052	9923	10171	-2174	22308	0	28	22308	3469	473	26250	49.97
12	6685	182	210	7076	832	4841	0	2201	10131	10324	-2213	22585	0	103	22585	3532	476	26594	50.06
13	6635	144	206	6986	982	5198	0	2250	10157	9869	-2222	22599	0	75	22599	3515	463	26578	50.04
14	6558	148	206	6912	988	5126	0	2134	10128	9819	-2136	22393	0	0	22393	3428	450	26272	49.99
15	6537	218	204	6958	1178	5144	0	1823	10244	10563	-2234	22977	0	0	22977	3534	456	26966	50.03
16	6720	242	205	7168	1289	5438	0	1429	10417	10440	-2310	22982	0	1	22982	3619	471	27072	49.97
17	6810	262	207	7280	1432	5658	0	898	9558	9351	-2237	21889	0	1	21889	3577	493	25958	49.97
18	6517	832	206	7554	1669	5656	0	412	8955	9118	-2370	21544	0	1	21544	3433	495	25472	49.98
19	6295	1248	216	7760	1449	5688	0	53	8383	8634	-2145	20952	0	0	20952	3222	487	24660	50.02
20	6391	1504	222	8116	1491	5807	0	0	8772	8759	-1975	21709	0	0	21709	3191	490	25390	50.14
21	6494	1832	225	8550	1563	5882	0	0	8031	7954	-1861	21616	0	0	21616	3126	473	25214	50.02
22	6765	1434	225	8424	1682	5937	0	0	7793	7795	-1825	21533	0	0	21533	3087	480	25100	50.09
23	6880	1654	226	8760	1906	5969	0	0	8108	8121	-1858	22439	0	0	22439	3132	459	26030	49.99
24	6859	1392	227	8478	1977	5960	0	0	8671	8646	-1944	22673	0	0	22673	3222	443	26338	50.02
MUs	162.08	16.91	5.28	184.27	35.25	132.32	0.00	16.98	218.39	218.80	-47.66	529.35	0.00	0.21	529.35	74.57	10.60	614.53	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) LTS Stage 1 & 2 Operated at 220KV Lonand S/S.Due to overloading of 220 KV Lonand - Jejuri line.2)ELR Carried out at 220kv GCR S/s due to overloading of 220kv GCR BBLR line-1 & 2.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/May/2023

Position as on 6.30 Hrs of 26/May/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Uran Unit 6	108	10/05/2023	02:00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-2	270	16/05/2023	23:00		Continued.	Ash Evacuation Problem.	24/05/2023
MSPGCL	Nasik Unit 3	210	20/05/2023	08:45		Continued.	Boiler Tube Leakage(under tolling from 22.25Hrs DT. 20-5-2023)	
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	25/05/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10		Continued.	Clinker formation in furnace	
MSPGCL	Bhusawal Unit 5	500	24/05/2023	21:15		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	25/05/2023	17:21	25/05/2023	19:08	Water separator Drain Tank Level high	25/05/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2023

Statement-VII

Position as on 6.30 Hrs of 26/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (409) OF BABHALESHWAR CKT - 2 @ EKTUNI	IntraState	26/05/2023	10:46			PO	Diagnostic Testing of CB, CT & Routine Maintenance
400 KV MAINBAY Outages/Trippings							
MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	25/05/2023	10:02			PO	For servicing & overhauling of 400kV AREVA make KDK CKT-2 Main C.B. Mechanism
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
400KV RPL-AKOLA 2 CKT 2	InterState	26/05/2023	06:35			PO	Outage required for routine maintenance and per-monsoon activity of 400kV RPL to Akola II Line II.
DABHOL - NEW KOYNA CKT - 2	IntraState	22/05/2023	13:26			PO	Dismantling of exisging tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	23/05/2023	09:46			HT	For load management
KALWA - KHARGHAR	IntraState	24/05/2023	22:32	25/05/2023	10:40	PO	1) BAY STRENGTHING WORK, 2)OVER VOLTAGE RELAY REPLACEMENT 3)Routine Maintenace Work (AMP)
BUS - C @ KHARGHAR	IntraState	24/05/2023	23:08	25/05/2023	09:48	PO	Bus Extension Connection work along with charging of 2 nos of new 400KV Vikhroli Line Bay's at Kharghar(First time Charging).
DEEPNAGAR - THAPTI TANDA	IntraState	25/05/2023	06:04	25/05/2023	14:27	PO	FOR REPLACEMENT OF BENDED MID SPAN JOINT & DEAD END.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	25/05/2023	09:41	25/05/2023	17:26	PO	line maintenance work & spacer replacement
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	25/05/2023	08:41	25/05/2023	15:17	PO	Pre-monsoon Maintenance activities.
400/220kV SPARE ICT @ JEJURI	IntraState	25/05/2023	10:21	25/05/2023	17:56	PO	For Pre-Monsoon Maintenance & Testing work
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	26/05/2023	10:34			PO	Premonsoon maintenance & testing work.
400 KV BR Outages/Trippings							
400kV BHUSAWAL S/S	IntraState	25/05/2023	10:02			HT	Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
B-BUS @ CHAKAN	IntraState	25/05/2023	06:09	25/05/2023	17:48	PO	220 kV Main Bus-B Y phase and B phase PT are to be replaced due to ratio error and oil leakage.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2023

Statement-VII

Position as on 6.30 Hrs of 26/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WARORA - HINGANGHAT	IntraState	25/05/2023	07:14	25/05/2023	11:42	HT	Diagonstic testing i.e. (tan delta of ct, cc , ir value of ct. cb timing & crm) & line and us isolator maintenance work.
TALANDGE - SAWANTWADI	IntraState	25/05/2023	08:49	25/05/2023	16:35		Insulator cleaning work
NERLE - PEDAMBE	IntraState	25/05/2023	09:00	25/05/2023	19:12	PO	For replacement of damaged conductor at loc no. 42B top ph Pedhambe side, middle Nerle side & Bottom ph loc no. 57B-Yph Nerale side & cold washing of insulator strings.
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	25/05/2023	09:34	25/05/2023	11:45	EO	Emergency outage for checking R phase CT-core-1 of 220kV Kharghar- Khandeshwar-1 Line
CHIKHALI-JALNA I	IntraState	25/05/2023	11:53	25/05/2023	12:06	HT	Ckt tripped without any indication.
KALWA - PANCHANAND	IntraState	25/05/2023	11:54	25/05/2023	12:18	T	A piece of conductor was dropped by crow on Y ph 220 KV bus PT and heavy flash over occurred causing 220 KV bus bar to operate
TEMGHAR - KALWA	IntraState	25/05/2023	11:54	25/05/2023	12:14	T	A piece of conductor was dropped by crow on Y ph 220 KV bus PT and heavy flash over occurred causing 220 KV bus bar to operate
ANANDNAGAR - PALAVA	IntraState	26/05/2023	07:18			PO	R,Y & B Ph CT Replacement work. All three old CTs are aged and rusted .
WADA - BHAVEGHAR	IntraState	26/05/2023	10:16			PO	"1) HV Breaker Overhauling, Dignostic Testing & Maintenance Work. 2) Hot Spot attending Work."
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/33KV 25MVA PTR 1 @ NEW KOYNA	IntraState	23/05/2023	09:20	25/05/2023	17:26	PO	Oil filtration work, Diagnostic testing & Relay testing work & C.T. tand Delta work
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	25/05/2023	06:39	25/05/2023	13:31	PO	DT & HALF YEARLY MAINTENANCE
220/132 KV 200MVA ICT 2	IntraState	25/05/2023	08:07	25/05/2023	14:14	HT	Premonsoon maint. work.
220/100 KV 100 MVA ICT 1 @ TALOJA	IntraState	25/05/2023	08:10	25/05/2023	19:26	PO	EMCO ICT LV CB MAINTANENCE WORK
220/132 KV 100 MVA ICT 2 @ SAWANGI	IntraState	25/05/2023	09:32	25/05/2023	19:20	HT	Pre monsoon maintenance work& diagnostic testing work.
100 MVA 220/132 KV ICT - I	IntraState	25/05/2023	09:36	25/05/2023	14:26	HT	Quarterly maintenance work. also pre 2 monsoon maint. work.
220/132 KV 100 MVA ICT 2 @ GHATODI	IntraState	25/05/2023	10:10	25/05/2023	17:55	HT	For oltc overhauling & premonsoon maintenance work of 220/132kv 100mva ict-ii.
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	25/05/2023	10:26	25/05/2023	17:28	PO	1.CB Overhauling Work 2.Premonsoon Maintenance Work
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	25/05/2023	11:54	25/05/2023	12:16	T	A piece of conductor was dropped by crow on Y ph 220 KV bus PT and heavy flash over occurred causing 220 KV bus bar to operate
220/100 KV 200 MVA ICT 3 @ KALWA	IntraState	25/05/2023	11:54	25/05/2023	12:25	T	A piece of conductor was dropped by crow on Y ph 220 KV bus PT and heavy flash over occurred causing 220 KV bus bar to operate

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2023

Statement-VII

Position as on 6.30 Hrs of 26/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 2 @ KALWA	IntraState	25/05/2023	11:54	25/05/2023	12:22	T	A piece of conductor was dropped by crow on Y ph 220 KV bus PT and heavy flash over occurred causing 220 KV bus bar to operate
220/132kv 200MVA ICT-1 @ KOPARGAON	IntraState	25/05/2023	16:10	25/05/2023	18:15	PO	For Pre Monsoon Maintenance work and Diagnostic testing of ICT and its allied equipments
220/132kv 200MVA ICT-2 @ KOPARGAON	IntraState	25/05/2023	18:45	25/05/2023	20:32	PO	For Pre Monsoon Maintenance work and Diagnostic testing of ICT and its allied equipments
220/132KV 200MVA PTR 2 @ LONAND	IntraState	26/05/2023	10:08			PO	1.CB Overhauling Work 2.Premonsoon Maintenance Work
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
132 KV YAVATMAL - RALEGAON CKT	IntraState	25/05/2023	08:45	25/05/2023	10:57	HT	Pre monsoon maint. diagnostic testing & quarter yearly maintenance. signature analysis testing.
PADEGAON-SILLOD	IntraState	25/05/2023	10:24	25/05/2023	19:32	HT	Flashover disc replacement work at loc 129 and 132.
132 KV CHAKUR JALKOT CKT	IntraState	25/05/2023	13:20	25/05/2023	16:14	HT	C:D/p,z2,36.2 km,1.3 ka,b-ph. jalkot=dist. protn optd.3.98ka,b-e,z1.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	24/05/2023	06:45			EO	Tower erection and conductor shifting work at loc. 36.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage