

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/May/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.511	4273.806	1) Gujrat	-5.980	6.201
2) Hydro	14.212	491.388	2) Madhya Pradesh	-3.346	136.160
3) Gas	6.566	175.757	3) Chattisgarh	1.990	98.560
Total MSPGCL	183.289	4940.951	4) Maharashtra	189.169	4660.410
B) 1) APML	63.104	1611.767	5) Goa (Amona)	-2.317	-50.255
2) JSWEL	25.816	676.346	Total	179.516	4851.076
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.745	1094.905
4) RPL(AMT)	29.113	737.904	b) Mumbai Drawl	47.783	1129.264
5) SWPGPL	12.162	306.351	c) MSEDCL Bilateral *	96.599	2022.188
6) Other IPP	15.736	419.071	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	45.745	1094.905
C) 1) TPCL Thermal	13.870	317.582	Include PX	0.000	0.000
2) TPCL Hydro	3.110	122.808	Standby	0.000	0.000
3) TPCL Gas	3.083	96.463	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.604	250.883	1) MSEDCL	517.265	12936.832
D) STATE			2) Mumbai Discoms	78.450	1916.994
1) Thermal	332.916	8593.710	3) Other Discoms	11.717	289.738
(A1+C1+C4+(B1-B6))			TOTAL STATE	607.432	15143.564
2) Hydro	17.322	614.196			
(A2+C2)					
3) Gas	9.649	272.220			
(A3+B7+C3)					
4) Wind	51.224	395.449			
6) SOLAR	16.805	416.919			
TOTAL STATE	427.916	10292.494			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5836	7158	7031	6694
MSPGCL Hydro	133	297	725	157
MSPGCL Gas	268	281	284	261
MSPGCL Total Generation	6237	7736	8040	7112
Central Sector Receipt	8456	8148	7068	7489
WIND	1873	2278	2615	1762
CPP / IPP Thermal	5194	5760	6414	6222
CPP / IPP Gas	0	0	0	0
SOLAR	2131	820	0	592
Exchange with Mumbai	-2298	-2122	-1886	-1849
MSEDCL DEMAND MET	21070	22096	21719	20845
Load Shedding	0	0	0	0
MSEDCL DEMAND	21070	22096	21719	20845
TPCL GENERATION	660	1013	991	548
AEML GENERATION	486	501	478	320
MUMBAI DEMAND	3444	3636	3355	2717
OTHER DISCOM DEMAND	523	525	532	483
STATE DEMAND MET	25037	26256	25606	24045
STATE DEMAND	25037	26256	25606	24045
Frequency (Hz)	49.96	50.08	49.93	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 16:33 Hrs	49.84 Hz at 14:04 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.38	91.07	188	0
Unit 8	13.56	217.66	588	530
Unit 9	11.97	335.78	525	464
Unit 10	12.03	341.48	530	465
Total	40.94	985.99		
Bhusawal				
Unit 3	0.00	76.13	0	0
Unit 4	9.84	226.96	470	295
Unit 5	8.32	238.10	490	0
Total	18.17	541.18		
Parli				
Unit 6	4.35	112.68	233	148
Unit 7	4.61	107.62	241	144
Unit 8	4.50	105.69	235	145
Total	13.46	325.99		
Chandrapur				
Unit 3	2.68	89.10	165	0
Unit 4	3.65	92.03	162	130
Unit 5	8.77	220.37	425	275
Unit 6	8.82	168.63	430	270
Unit 7	8.03	199.23	380	285
Unit 8	9.80	258.69	455	298
Unit 9	0.00	253.20	0	0
Total	41.75	1281.24		
Paras				
Unit 3	5.07	116.89	241	149
Unit 4	5.33	137.05	250	161
Total	10.39	253.94		
Khaparkheda				
Unit 1	3.78	87.57	175	115
Unit 2	4.56	107.04	205	132
Unit 3	3.98	98.68	178	133
Unit 4	4.12	97.90	191	132
Unit 5	11.70	250.55	500	410
Total	28.14	641.73		
Nasik				
Unit 3	3.64	76.90	166	118
Unit 4	3.28	88.20	143	125
Unit 5	2.74	78.62	153	0
Total	9.66	243.73		
Uran				
All Units	6.57	175.76	290	260
Total	6.57	175.76		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	5.19	0	0
Total	0.00	5.19		
Koyna				
Stage 1-2	3.70	117.00	425	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.65	210.94	976	0
Stage 3	1.87	73.16	240	0
Total	11.22	401.11		
Hydro				
KDPH	0.54	15.71	23	22
VTRNA	0.88	20.75	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.58	47.59	71	62
GHATGHAR	0.00	6.23	0	0
Total	2.99	90.28		
Wind				
Total	51.22	395.45	0	0
Total	51.22	395.45		
CPP				
APML(Mus)	63.10	1611.77	0	0
JSWEL(Mus)	25.82	676.35	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	29.11	737.90	0	0
SWPGPL-Mus	12.16	306.35	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.48	132.99	268	157
Other(Mus)	5.77	169.23	0	0
JPL	4.49	116.85	269	133
Total	145.93	3751.44		
SOLAR				
Total	16.80	416.92	0	0
Total	16.80	416.92		
Tata				
Trombay 5	9.11	216.61	456	269
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.84	59.70	108	40
Trombay 7B	1.24	36.76	65	35
TATA Hydro	3.11	122.81	320	39
Trombay 8	4.76	100.97	229	132
Total	20.06	536.85		
AEML				
DTPS U-1&2	10.60	250.88	504	290
Total	10.60	250.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.51	4273.81	MSPGCL Total	183.29	4940.95
			MSPGCL Thml+Gas	169.08	4449.56	Koyna 1,2 & 4 Total	9.35	327.95
			MSPGCL Hydro	14.21	491.39	State Total	427.92	10292.49

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7356	1703	261	9320	2266	6949	0	0	6916	6641	-2033	22697	0	0	22697	3444	447	26587	50.01
2	7383	1553	261	9197	2078	6847	0	0	6706	6419	-1908	22214	0	0	22214	3219	419	25852	50.01
3	7401	962	261	8624	2363	6871	0	0	7006	6407	-1761	22109	0	0	22109	3039	395	25543	50.03
4	7405	699	263	8367	1999	6872	0	0	7030	6756	-1852	21756	0	0	21756	2891	386	25033	50.03
5	7351	680	263	8294	2016	6848	0	0	7095	6957	-1899	21810	0	0	21810	2790	405	25006	49.99
6	7382	782	263	8427	1736	6846	0	0	7324	7063	-1814	21821	0	0	21821	2765	438	25023	49.95
7	7170	679	261	8110	1744	6677	0	139	7772	7288	-1719	21772	0	10	21772	2706	468	24945	49.99
8	6694	157	261	7112	1762	6222	0	592	7862	7489	-1849	20845	0	11	20845	2717	483	24045	49.96
9	6392	129	262	6783	1922	5287	0	1166	8439	7926	-2033	20536	0	0	20536	2888	515	23939	49.98
10	5808	138	260	6206	2005	5118	0	1692	8712	8381	-2243	20642	0	0	20642	3157	517	24316	50.01
11	5836	133	268	6237	1873	5194	0	2131	8843	8456	-2298	21070	0	0	21070	3444	523	25037	49.96
12	5589	87	278	5954	1785	5056	0	2258	9004	8559	-2278	20806	0	0	20806	3594	528	24928	49.98
13	5678	88	279	6045	1833	5094	0	2302	8856	8284	-2214	20823	0	0	20823	3626	521	24970	49.96
14	5536	87	280	5903	1950	5065	0	2116	8771	8296	-2166	20656	0	0	20656	3582	508	24746	49.91
15	6275	181	283	6739	2177	5065	0	1836	8905	8572	-2233	21651	0	0	21651	3681	505	25837	49.93
16	6792	466	279	7537	2139	5120	0	1312	8885	8471	-2254	21805	0	0	21805	3740	520	26065	50.02
17	7158	297	281	7736	2278	5760	0	820	8358	8148	-2122	22096	0	0	22096	3636	525	26256	50.08
18	7063	195	284	7542	2417	5780	0	378	8399	8066	-2122	21520	0	0	21520	3473	541	25534	50.02
19	7070	325	284	7679	2674	5739	0	63	8050	7934	-2215	21329	0	0	21329	3317	545	25191	50.01
20	7031	725	284	8040	2615	6414	0	0	7538	7068	-1886	21719	0	0	21719	3355	532	25606	49.93
21	6987	882	285	8154	2277	6746	0	0	6913	6762	-1697	21724	0	0	21724	3339	518	25581	49.93
22	6996	983	285	8264	2327	6768	0	0	6567	6407	-1651	21601	0	0	21601	3313	514	25428	49.98
23	7063	1025	290	8378	2528	6792	0	0	6988	6479	-1717	21966	0	0	21966	3333	494	25793	49.97
24	7095	1256	290	8641	2460	6801	0	0	6770	6687	-1819	22299	0	0	22299	3401	471	26171	50.02
MUs	162.51	14.21	6.57	183.29	51.22	145.93	0.00	16.80	187.71	179.52	-47.78	517.26	0.00	0.02	517.26	78.45	11.72	607.43	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to overload of 132KV BBLSR-Rahuri line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/May/2024

Position as on 6.30 Hrs of 26/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Chandrapur Unit 9	500	24/05/2024	01:59		Continued.	Boiler Tube Leakage	27/05/2024
MSPGCL	Bhusawal Unit 3	210	24/05/2024	15:37		Continued.	Boiler Tube Leakage	28/05/2024
MSPGCL	Chandrapur Unit 3	210	25/05/2024	05:58	25/05/2024	11:37	Generator Protection operated	
MSPGCL	Koradi Unit 6	210	25/05/2024	09:34	25/05/2024	13:29	Low Vaccum	
MSPGCL	Nasik Unit 5	210	25/05/2024	13:01	25/05/2024	15:55	reverse power protection	
MSPGCL	Bhusawal Unit 5	500	25/05/2024	19:20	25/05/2024	22:30	Flame Failure	
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	
MSPGCL	Bhusawal Unit 5	500	26/05/2024	19:16	26/05/2024	22:08	Electrical fault	
Total Capacity MSPGCL		2585						
IPP								
IPP	RPL(AMT) U-2	270	25/05/2024	13:52		Continued.	ID Fan Tripped at high Vibration.	27/05/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3175						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	24/05/2024	02:00		Continued.	Due to Zero schedule by MSEDCL.	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/May/2024

Position as on 6.30 Hrs of 26/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2024

Statement-VII

Position as on 6.30 Hrs of 26/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (403) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	25/05/2024	16:14	25/05/2024	18:27	PO	For Work of Chemical Cleaning of Equipment Insulator of TIE Bay.
400 KV MAINBAY Outages/Trippings							
MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	25/05/2024	09:31	25/05/2024	11:57	PO	For Work of Chemical Cleaning of Equipment Insulators of Main Bay.
400 KV LINE Outages/Trippings							
PUNE(GIS) - TALEGAON(PG) CKT - 2	InterState	26/05/2024	01:51	26/05/2024	09:18	HT	HTdue to hotspot on 409 Rph Twin bus dropper to 409 bus isolator.
400KV-PARLI NEW-PARLI-M-1	InterState	26/05/2024	15:45	26/05/2024	17:56	T	Distance protection.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
DABHOL - NEW KOYNA CKT - 2	IntraState	24/05/2024	22:55	25/05/2024	16:56	T	Distance Protection
CHANDRAPUR 2 - CHD SWITCHING CKT - 1	IntraState	25/05/2024	07:01	25/05/2024	10:02	PO	Daignostic testing and allied maintenance work
TBC @ PARLI	IntraState	25/05/2024	10:43	25/05/2024	15:42	PO	Bay maintenance work in view of healthiness.
PARLI - KARJAT CKT - 1	IntraState	25/05/2024	12:10	25/05/2024	12:45	T	Tripped on distance protection
BUS-1 @ TALEGAON (PG	IntraState	25/05/2024	23:24	26/05/2024	09:00	PO	For AMP works
JEJURI - KARAD	IntraState	26/05/2024	10:01	26/05/2024	18:54	PO	PID Faulty disc Insulator replacement work at Different Locations
CHANDRAPUR-PARLI CKT-3	IntraState	26/05/2024	15:50	26/05/2024	22:06	HT	Y-Ph CVT jumper broken.
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	26/05/2024	15:53	26/05/2024	22:51	HT	B-Ph CVT jumper broken.
AKOLA - KHADKA (BHUSAWAL)	IntraState	26/05/2024	17:36	26/05/2024	18:28	T	Distance protection.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	26/05/2024	23:21	26/05/2024	02:24	PO	Y-ph CVT jumper connection work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	25/05/2024	05:00	25/05/2024	07:17	PO	premonsoon maintenance work
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	25/05/2024	10:40	25/05/2024	15:05	PO	For Pre monsoon maintenance work.
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	26/05/2024	11:58	26/05/2024	14:26	PO	Auxiliary isolator found broken and hanging.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220KV SHIVAJINAGAR - MALEGAON	IntraState	25/05/2024	16:47	25/05/2024	20:54	PO	For replacements of flashover disc at loc 96
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2024

Statement-VII

Position as on 6.30 Hrs of 26/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV HARANGUL - PARLY (PG) CKT	InterState	25/05/2024	15:45	25/05/2024	18:29	T	Tripped on dsitance protection.
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	25/05/2024	15:47	25/05/2024	18:38	T	Tripped on dsitance protection.
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	26/05/2024	15:30	26/05/2024	17:02	T	Distance protection.
220 KV HARANGUL - PARLY (PG) CKT	InterState	26/05/2024	15:37	26/05/2024	17:30	T	Distance protection.
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	26/05/2024	15:40	26/05/2024	17:56	T	Distance protection.
PARANDA - OSMANABAD	IntraState	24/05/2024	10:21	25/05/2024	02:20	HT	Dist. protection relay retrofitting work.
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	24/05/2024	12:34			PO	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 2	IntraState	24/05/2024	22:42	25/05/2024	01:44	T	Distance Protection
TROMBAY CARNAC - 6	IntraState	25/05/2024	00:04	25/05/2024	03:49	PO	PROTECTION TESTING
COLOURCHEM - TEMGHAR	IntraState	25/05/2024	04:46	26/05/2024	12:23	PO	For erection of new tower structure, de-stringing of old conductor & stringing of new conductor at new loc no.06.
BOISAR II - VIRAJ	IntraState	25/05/2024	04:51	25/05/2024	09:07	PO	Replacement of Dead end fitting (Y-Phase) and temporary used steel bolts with GI Jumper Bolts (04 Towers)
KHADKI- CENTURY ENKA	IntraState	25/05/2024	06:55	25/05/2024	18:04	PO	Stringing of RYB conductors for river crossing locations- loc 29A-30
ADLABS - PEDAMBE	IntraState	25/05/2024	07:17	25/05/2024	13:29	PO	For dismantaling of old tower at loc no- 94
PEDAMBE-KALAMBANI(TSS)	IntraState	25/05/2024	07:20	25/05/2024	08:55	PO	For dismantaling of old tower at loc no.94.
CHANDRAPUR GCR - SICOM II	IntraState	25/05/2024	09:15	25/05/2024	18:09	PO	Maintenance work
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	25/05/2024	09:22	25/05/2024	18:58	PO	Routine maintenance work, replacement of insulator, cold line cleaning work.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	25/05/2024	11:34	25/05/2024	14:21	PO	1.Attending red hot at loc. No. 142 Y Phase and 172 Y Phase cut point. 2.Replacement Of Faulty PID String at loc. No. 186 R Ph 3Attending low clearance at location no.175-176 (6.16meter)
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	25/05/2024	13:25			HT	For load management
220 KV JALNA - THAPTITANDA CKT - I	IntraState	25/05/2024	15:33	25/05/2024	17:43	EO	Tree trimming work
MALINAGAR - TEMBHURNI	IntraState	25/05/2024	16:32	25/05/2024	19:33	PO	Outage is required for Cold line washing of strings loc no. 51 to 30 & 119 to 149.
SHIVAJINAGAR-MALEGAON	IntraState	25/05/2024	16:47	25/05/2024	20:54	PO	Replacement of Flash over Disc
SONKHAR - TROMBAY	IntraState	25/05/2024	17:57	25/05/2024	21:56	PO	Premonsoon maintainance

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2024

Statement-VII

Position as on 6.30 Hrs of 26/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - NALASOPARA - VASAI (T)	IntraState	26/05/2024	01:27			PO	B) As on dt: 25.05.2024 at 21:00Hrs to 27.05.2024 at 06:00Hrs. outage on 220kV Padghe- Nalasopara for the work of erection of in-line Monopole , cut point formation and conductor de-stringing & stringing work. 1) Jumper at loc.52 of 220kV Padghe-Nalasopra line will be opened to avoid the backfeeding from 220kV Vasai-Nalasopara link line. 2) After opening the jumper at loc.no. 52, 220kV Nalasopara-Vasai link line will be charged at 23:00Hrs. on dt:-25.05.2024 for 02 days. 3) In-line monopole erection work will be carry out at loc.no.48,49 & 49A. 4) Cut point formation over newly erected Monopole work will be carrying out at loc.no. 48,49,&49A of 220kV Padghe-Nalasopara line and also related tower's conductor de-stringing and stringing work will be carry out of above said ckt. 5) After erection of Monopole tower, cut point formation and conductor stringing work, 220kV Padghe-Nalasopara-Vasai tap line will be charged at 06:00 Hrs. on dt: 27.05.2024.
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	IntraState	26/05/2024	08:45	26/05/2024	16:43	PO	MANDALE PROJECT WORK IN VICINITY
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	26/05/2024	09:43	26/05/2024	18:20	PO	Routine maintenance work, replacement of insulator, cold line cleaning work.
TROMBAY - VIKHROLI (GIS) CKT - 3	IntraState	26/05/2024	10:56	26/05/2024	12:42	PO	ATTENDING HOT SPOT
ICL - OLD GCR PARLI	IntraState	26/05/2024	15:19	26/05/2024	18:30	T	Distance protection.
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	26/05/2024	15:30	26/05/2024	22:23	T	Distance protection.
220 PARLI U-8 - NEW GCR PARLI CKT I	IntraState	26/05/2024	15:38	26/05/2024	16:32	T	Tripped from Parli U8 end only.
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 4	IntraState	26/05/2024	15:40		Continued.	T	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 3	IntraState	26/05/2024	15:40		Continued.	T	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.
220 KV GHATODI - HINGOLI	IntraState	26/05/2024	16:07	26/05/2024	16:32	T	Distance protection.
220KV PANDHARKAWDA - WANI CKT II	IntraState	26/05/2024	16:39	26/05/2024	18:28	T	Distance protection.
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25			T	Tripped on distance protection
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25			T	Tripped of distance protection
KHARGHAR - BORIVALI CKT - 2	IntraState	26/05/2024	22:03		Continued.	PO	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 66 sets are to be installed)
MULUND - GIS BHANDUP	IntraState	26/05/2024	22:05		Continued.	PO	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 6 sets are to be installed)
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/May/2024

Statement-VII

Position as on 6.30 Hrs of 26/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 200MVA ICT 2 @ DHULE	IntraState	25/05/2024	08:17	25/05/2024	12:30	PO	Bay maintenance work
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	25/05/2024	09:15	25/05/2024	11:23	PO	Pre monsoon maintenance work
220 / 110 / 33kv 250MVA ICT 2 @ BORIVALI (TATA)	IntraState	25/05/2024	10:01	25/05/2024	14:34	PO	R/M AND TESTING
220/132KV 100 MVA ICT 2@ PETH	IntraState	25/05/2024	10:02	25/05/2024	14:03	PO	Premonsoon Maintenance Work
220/132 KV 200 MVA ICT 1	IntraState	25/05/2024	10:18	25/05/2024	13:10	PO	Maintenance work
220/132 KV 200 MVA ICT 1 @ AHMEDNAGAR	IntraState	25/05/2024	12:53	25/05/2024	16:01	PO	R-ph, HV C.T. oil Leakage Attending work.
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	25/05/2024	13:40	25/05/2024	16:20	PO	Pre monsoon maintenance work
220/33kv 50MVA TF-2 @ KOPARGAON	IntraState	25/05/2024	17:12	25/05/2024	19:00	PO	For Pre Monsoon Maintenance work and Testing works
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	26/05/2024	07:20	26/05/2024	21:19	PO	For safety purpose For tower painting work in 100KV Switchyard, Diagnostic testing & RM work
220 / 110 / 22kv 250MVA ICT 1 @ SAKI	IntraState	26/05/2024	09:45	26/05/2024	20:58	PO	RM, ICT testing and protection testing
220/110/33KV 250 MVA ICT-5 @ MAHALAXMI GIS (T)	IntraState	26/05/2024	09:51	26/05/2024	19:53	PO	RM & testing
220 / 110 / 33kv 250MVA AT 1 @ BACKBAY	IntraState	26/05/2024	10:08	26/05/2024	15:57	PO	R/M Testing & Protection testing &
220/33KV 50MVA PTR 2 @ KATHAPUR	IntraState	26/05/2024	11:24	26/05/2024	15:58	PO	Pre monsoon activities and general maintenance
220/132 KV 100 MVA PTR	IntraState	26/05/2024	15:21	26/05/2024	17:16	T	O/C E/F LV tripped.
220 / 11 KV 200 MVA GT @ BHIRA (T)	IntraState	26/05/2024	23:40		Continued.	PO	REPLACEMENT OF OIL COOLER
110 KV LINE Outages/Trippings							
TATA AMBERNATH MSETCL NERAL	IntraState	25/05/2024	07:16	25/05/2024	13:03	PO	WORK AT MSETCL NERAL END
110 KV BUSBAR Outages/Trippings							
ZONE 2 (BUS SECTION 3+4+5+6) @ BHIVPURI	IntraState	26/05/2024	08:45	26/05/2024	17:54	PO	Main Bus GOD R/M , LA & PT Testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage