

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Jun/2023 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	148.281	4000.891	1) Gujrat	-3.273	-47.513
2) Hydro	5.920	300.105	2) Madhya Pradesh	5.370	152.737
3) Gas	0.000	114.922	3) Chattisgarh	2.340	75.360
Total MSPGCL	154.201	4415.918	4) Maharashtra	180.935	5230.209
B) 1) APML	49.188	1676.051	5) Goa (Amona)	-1.100	-33.835
2) JSWEL	19.518	589.809	Total	184.272	5376.958
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.316	1073.581
4) RPL(AMT)	25.359	666.049	b) Mumbai Drawl	34.489	1174.968
5) SWPGPL	10.604	263.725	c) MSEDCL Bilateral *	111.085	3056.085
6) Other IPP	6.273	143.337	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.316	1073.082
C) 1) TPCL Thermal	11.013	306.458	Include PX	0.000	0.000
2) TPCL Hydro	2.124	129.537	Standby	0.000	0.499
3) TPCL Gas	1.964	45.794	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.364	233.521	1) MSEDCL	445.196	12995.074
D) STATE			2) Mumbai Discoms	57.954	1890.278
1) Thermal	278.600	7879.841	3) Other Discoms	9.690	264.711
(A1+C1+C4+(B1-B6))			TOTAL STATE	512.840	15150.063
2) Hydro	8.044	429.642			
3) Gas	1.964	160.716			
4) Wind	29.800	916.560			
6) SOLAR	10.160	386.346			
TOTAL STATE	328.568	9773.105			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	5803	5937	6817	6363
MSPGCL Hydro	132	129	364	288
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5935	6066	7181	6651
Central Sector Receipt	9345	8418	6933	7800
WIND	933	1269	1425	1003
CPP / IPP Thermal	4174	4176	5323	4408
CPP / IPP Gas	0	0	0	0
SOLAR	1310	1373	0	0
Exchange with Mumbai	-1634	-1604	-1553	-1291
MSEDCL DEMAND MET	19657	19294	18861	18235
Load Shedding	0	0	0	0
MSEDCL DEMAND	19657	19294	18861	18235
TPCL GENERATION	570	585	646	561
AEML GENERATION	336	350	352	311
MUMBAI DEMAND	2540	2539	2551	2163
OTHER DISCOM DEMAND	407	403	448	336
STATE DEMAND MET	22603	22237	21860	20734
STATE DEMAND	22603	22237	21860	20734
Frequency (Hz)	49.98	50.02	50.00	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 13.05 Hrs	49.82 Hz at 19.13 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.87	113.98	175	140
Unit 8	12.52	268.93	569	408
Unit 9	12.12	249.12	527	385
Unit 10	12.14	319.56	542	450
Total	40.66	951.58		
Bhusawal				
Unit 3	2.98	62.84	145	115
Unit 4	10.00	255.64	455	295
Unit 5	10.48	272.56	490	295
Total	23.46	591.02		
Parli				
Unit 6	3.81	111.94	209	146
Unit 7	3.70	115.80	212	144
Unit 8	0.00	71.84	0	0
Total	7.50	299.58		
Chandrapur				
Unit 3	3.14	77.53	157	120
Unit 4	3.07	78.08	150	119
Unit 5	0.00	0.00	0	0
Unit 6	7.55	203.12	388	285
Unit 7	7.52	226.67	413	279
Unit 8	10.12	274.82	493	291
Unit 9	10.00	277.12	488	303
Total	41.39	1137.35		
Paras				
Unit 3	3.87	119.48	190	140
Unit 4	4.16	106.36	201	143
Total	8.03	225.84		
Khaparkheda				
Unit 1	0.00	66.14	0	0
Unit 2	2.88	71.30	137	106
Unit 3	3.54	81.24	168	129
Unit 4	3.68	97.55	182	130
Unit 5	11.07	273.18	470	435
Total	21.17	589.42		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	3.07	99.44	165	120
Unit 5	3.00	96.56	154	115
Total	6.07	206.10		
Uran				
All Units	0.00	114.92	0	0
Total	0.00	114.92		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	2.03	0	0
Total	0.00	2.03		
Koyna				
Stage 1-2	0.98	74.56	155	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.20	36.82	160	0
Total	1.18	192.60		
Hydro				
KDPH	0.00	6.01	0	0
VTRNA	1.13	28.41	61	0
TILLARI	0.46	4.48	58	0
BHIRA T.R.	0.20	7.63	40	0
SMLHY_PTN	2.95	56.18	126	119
GHATGHAR	0.00	2.76	0	0
Total	4.74	105.47		
Wind				
Total	29.80	916.56	0	0
Total	29.80	916.56		
CPP				
APML(Mus)	49.19	1676.05	0	0
JSWEL(Mus)	19.52	589.81	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.36	666.05	0	0
SWPGPL-Mus	10.60	263.72	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.59	91.48	270	152
Other(Mus)	1.68	51.86	0	0
Total	110.94	3338.97		
SOLAR				
Total	10.16	386.35	0	0
Total	10.16	386.35		
Tata				
Trombay 5	7.39	205.64	452	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.07	25.26	61	37
Trombay 7B	0.89	20.54	48	32
TATA Hydro	2.12	129.54	260	5
Trombay 8	3.62	100.82	214	130
Total	15.10	481.79		
AEML				
DTPS U-1&2	8.36	233.52	502	290
Total	8.36	233.52		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	148.28	4000.89	MSPGCL Total	154.20	4415.92
			MSPGCL Thml+Gas	148.28	4115.81	Koyna 1,2 & 4 Total	0.98	155.78
			MSPGCL Hydro	5.92	300.10	State Total	328.57	9773.10

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6598	447	0	7045	847	5714	0	0	7173	6574	-1599	18199	0	0	18199	2593	382	21174	49.99
2	6697	315	0	7012	959	5691	0	0	7202	6690	-1377	18613	0	0	18613	2431	362	21406	50.00
3	6539	283	0	6822	1138	5180	0	0	7396	6973	-1385	18394	0	0	18394	2284	334	21012	50.01
4	6173	287	0	6460	1020	4655	0	0	7658	7715	-1326	18183	0	0	18183	2214	341	20738	50.02
5	6363	288	0	6651	1003	4408	0	0	7976	7800	-1291	18235	0	0	18235	2163	336	20734	50.01
6	6417	281	0	6698	1153	4385	0	1	8396	8165	-1339	18696	0	0	18696	2169	367	21232	50.02
7	6203	223	0	6426	1007	4284	0	118	8178	8396	-1342	18496	0	0	18496	2144	394	21033	49.97
8	6419	258	0	6677	1012	4411	0	361	7755	7567	-1325	18300	0	0	18300	2159	403	20862	50.03
9	6136	229	0	6365	978	4305	0	745	7969	8369	-1432	18892	0	0	18892	2257	438	21587	50.04
10	6302	229	0	6531	898	4330	0	1193	8346	8122	-1504	19155	0	0	19155	2367	416	21937	50.04
11	6040	190	0	6230	887	4210	0	1357	9042	8558	-1571	19260	0	0	19260	2486	411	22157	49.99
12	5803	132	0	5935	933	4174	0	1310	9203	9345	-1634	19657	0	0	19657	2540	407	22603	49.98
13	5937	129	0	6066	1269	4176	0	1373	8958	8418	-1604	19294	0	0	19294	2539	403	22237	50.02
14	5257	124	0	5381	1488	4004	0	1311	8781	8631	-1702	18710	0	0	18710	2491	403	21604	50.06
15	5282	128	0	5410	1511	4234	0	1030	8657	8818	-1677	18921	0	0	18921	2485	405	21811	50.02
16	6177	138	0	6315	1578	4371	0	641	8261	8052	-1671	18864	0	0	18864	2486	423	21772	50.02
17	5874	190	0	6064	1831	4263	0	443	8018	7507	-1528	18156	0	0	18156	2446	424	21026	50.06
18	5571	338	0	5909	1657	4279	0	223	7469	7607	-1551	17685	0	0	17685	2420	438	20544	50.03
19	6310	338	0	6648	1497	4396	0	54	6987	7276	-1574	17868	0	0	17868	2442	429	20739	50.02
20	6817	364	0	7181	1425	5323	0	0	6993	6933	-1553	18861	0	0	18861	2551	448	21860	50.00
21	6555	223	0	6778	1543	5380	0	0	7496	6665	-1387	18545	0	0	18545	2585	434	21564	50.04
22	6153	230	0	6383	1413	4938	0	0	7176	6734	-1063	17967	0	0	17967	2585	438	20990	49.99
23	6352	278	0	6630	1400	4887	0	0	6924	6845	-1033	18292	0	0	18292	2564	437	21293	50.04
24	6306	278	0	6584	1353	4945	0	0	6878	6512	-1021	17954	0	0	17954	2553	418	20926	50.05
MUs	148.28	5.92	0.00	154.20	29.80	110.94	0.00	10.16	188.89	184.27	-34.49	445.20	0.00	0.00	445.20	57.95	9.69	512.84	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Jun/2023

Position as on 6.30 Hrs of 26/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	15/07/2023
MSPGCL	Koyna Unit 8	80	25/06/2023	07:30	25/06/2023	15:45	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 7	80	25/06/2023	07:34	25/06/2023	15:20	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 6	80	25/06/2023	07:39	25/06/2023	15:20	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 5	80	25/06/2023	07:39	25/06/2023	16:05	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 4	70	25/06/2023	07:42	25/06/2023	19:25	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 3	70	25/06/2023	07:44	25/06/2023	15:40	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 2	70	25/06/2023	07:46	25/06/2023	19:05	Koyna dam nawaja intake gate and gate seal inspection work.	
MSPGCL	Koyna Unit 11	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 12	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 10	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 9	80	25/06/2023	09:15	25/06/2023	15:30	Checking of radial gate turn buckle gate equalizer plate and other gate maintenance work.	
MSPGCL	Koyna Unit 1	70	25/06/2023	13:55	25/06/2023	14:45	220KV Bus section 1 tripped.	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Jun/2023

Position as on 6.30 Hrs of 26/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	On boiler protection	
MSPGCL	Khaparkheda Unit 1	210	24/06/2023	22:47	26/06/2023	21:00	Boiler Tube Leakage	27/06/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 26/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kv 1500MVA ICT @ AKOLA 2	IntraState	25/06/2023	10:47	25/06/2023	18:56	PO	TAKING B-PH ICT IN SERVICE IN PLACE OF SPARE PHASE ICT AS PER CEA GUIDELINE.
765/400kv 1500MVA ICT @ AKOLA 2	IntraState	25/06/2023	10:47	25/06/2023	18:56	HT	Planned outage 567 OCC meeting
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	24/06/2023	23:52	25/06/2023	19:43	T	Tripped on differential protection.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	26/06/2023	05:01	26/06/2023	09:00	T	Tripped on R-ph high pressure tap changer
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
MAIN BAY (407) OF KOLHAPUR (TALANDGE) @ ALKUD	IntraState	26/06/2023	14:03	26/06/2023	15:27	PO	Diagnostic testing & Maintenance work
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	24/06/2023	14:42	25/06/2023	01:17	T	Line tripped on distance protection
PUNE(GIS) - TALEGAON(PG) CKT - 3	InterState	25/06/2023	13:43	26/06/2023	04:39	T	Tripped on distance protection
PUNE(GIS) - TALEGAON(PG) CKT - 4	InterState	25/06/2023	21:32	26/06/2023	04:43	HT	Outage availed for safety purpose and to attend broken insulator of 400 kV Pune & Pune Ckt-3
JEJURI - KARAD	IntraState	24/06/2023	18:46	25/06/2023	07:55	T	Tripped on distance protection
DABHOL - NAGOTHANE CKT - 1	IntraState	25/06/2023	06:24	25/06/2023	10:58	EO	Removing of cutted Earthwire between loc no. 68-69
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	25/06/2023	10:40	26/06/2023	10:02	HT	H/T for load management
LONIKAND - JEJURI CKT - 2	IntraState	25/06/2023	16:44	25/06/2023	20:34	HT	HT for Load Management
JEJURI - KARAD	IntraState	25/06/2023	20:28	26/06/2023	11:28	T	Distance Protection
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	26/06/2023	08:51			PO	Diagnostic Testing of 400 kV NTPP I & NTPP II Bay's Outdoor Equipment & Relay.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	26/06/2023	13:05	26/06/2023	15:41	EO	To clean up bird nest and re-fixing of insulation tapes at end terminals of tertiary delta formation to prevent tripping due to NDR fault.
400/220kv 500MVA ICT-2 @ TAPTITANDA	IntraState	26/06/2023	16:11	26/06/2023	17:47	EO	Re fixing of insulation tapes at end terminals of tertiary delta, to prevent tripping due to fault on NDR
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 26/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
GOREGAON - AAREY CKT - 2	IntraState	17/06/2023	18:14			PO	Shifting of existing 220kV AIS Bay no. 2 to New GIS Bay no. 19 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
URAN - KHARGHAR 1	IntraState	23/06/2023	17:36			PO	LILO and commissioning of 220kV Ulwe GIS
URSE - TALEGAON (AMBI) CKT 1	IntraState	24/06/2023	20:33	25/06/2023	03:57	T	Tripped on distance protection
SAHARA-URSE	IntraState	24/06/2023	20:39	25/06/2023	04:02	HT	H/T for load management.
KHARGHAR - SONKHAR	IntraState	25/06/2023	06:05	25/06/2023	11:53	T	Tripped on Distance Protection.
SONKHAR - TROMBAY	IntraState	25/06/2023	06:05	25/06/2023	06:44	T	AR successful at Trombay end only.
KALMESHWAR-PANDHURNA	IntraState	25/06/2023	12:26	25/06/2023	17:39	T	Distance Protection
KALMESHWAR-PANDHURNA	IntraState	25/06/2023	12:26	25/06/2023	17:39	T	D/P OPTED:Y-B,19.99KM,7KA,6.94KA
POPHLI PEDHMBE LINE- 1	IntraState	25/06/2023	13:55	25/06/2023	14:35	T	220KV bus section 1 tripped at pophali.
POPHALI - KDPH	IntraState	25/06/2023	13:55	25/06/2023	14:50	T	220KV bus section 1 tripped at pophali.
KANDALGAON - KOYNA (POPHALI)	IntraState	25/06/2023	13:55	25/06/2023	14:40	T	220KV bus section 1 tripped at pophali.
HINJAWADI I- CHINCHWAD	IntraState	25/06/2023	16:44	26/06/2023	05:28	T	HT for Load Management
WARORA-BHUGAON CKT - 1	IntraState	26/06/2023	08:39	26/06/2023	11:37	PO	Routine Maintenance Work.
MUMEWADI -HALKARNI 2 LINE	IntraState	26/06/2023	11:07	26/06/2023	16:58	PO	For Diagnostic Testing of CT,CB & Premonsoon Maintenance work of bay equipments
AMBAZARI - KARANJA CKT	IntraState	26/06/2023	13:15	26/06/2023	15:29	EO	Distance Relay Testing Work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132-110 KV 100 MVA ICT 2	IntraState	21/06/2023	11:00			EO	Replacement of HV CB
100 MVA 220/132 KV ICT - I @ NARANGWADI	IntraState	26/06/2023	10:34	26/06/2023	16:48	PO	Relay Testing Work By Testing Team.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage