

**State Load Despatch Center,Airoli (MSETCL) Statement I**  
**Daily system Report for 25/Jul/2019 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 122.487        | 2983.756        | 1) Gujrat                      | -2.124         | -74.476          |
| 2) Hydro            | 4.509          | 143.076         | 2) Madhya Pradesh              | 9.415          | 230.109          |
| 3) Gas              | 8.885          | 207.966         | 3) Chattisgarh                 | 1.980          | 94.250           |
| <b>Total MSPGCL</b> | <b>135.881</b> | <b>3334.798</b> | 4) Maharashtra                 | 97.485         | 2526.833         |
| B) 1) APMIL         | 58.531         | 1549.035        | 5) Goa (Amona)                 | -0.594         | -11.484          |
| 2) JSWEL            | 21.745         | 555.534         | <b>Total</b>                   | <b>106.162</b> | <b>2765.232</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 24.190         | 562.783          |
| 4) RPL(AMT)         | 14.689         | 133.149         | b) Mumbai Drawl                | 31.344         | 722.436          |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 11.610         | 212.884          |
| 6) Other IPP        | 2.370          | 61.817          | Include PX                     | -2.603         | -115.651         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 24.190         | 562.783          |
| C) 1) TPCL Thermal  | 12.185         | 332.273         | Include PX                     | 8.445          | 171.873          |
| 2) TPCL Hydro       | 5.101          | 118.460         | Standby                        | 0.000          | 0.000            |
| 3) TPCL Gas         | 4.095          | 97.865          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 9.124          | 243.042         | 1) MSEDCL                      | 362.018        | 8831.429         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 61.849         | 1514.079         |
| 1) Thermal          | 241.131        | 5858.606        | <b>TOTAL STATE</b>             | <b>423.867</b> | <b>10345.508</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro (A2+C2)    | 9.610          | 261.536         |                                |                |                  |
| 3) Gas (A3+B7+C3)   | 12.980         | 305.831         |                                |                |                  |
| 4) Wind             | 50.434         | 1033.809        |                                |                |                  |
| 6) SOLAR            | 3.550          | 120.491         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>317.705</b> | <b>7580.273</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5056                      | 5118                  | 5192                      | 5127                      |
| MSPGCL Hydro             | 171                       | 222                   | 615                       | 156                       |
| MSPGCL Gas               | 378                       | 373                   | 357                       | 375                       |
| MSPGCL Total Generation  | 5605                      | 5713                  | 6164                      | 5658                      |
| Central Sector Receipt   | 5125                      | 4518                  | 4635                      | 3526                      |
| WIND                     | 2394                      | 2325                  | 1891                      | 1979                      |
| CPP / IPP Thermal        | 3938                      | 3830                  | 3922                      | 4060                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 357                       | 469                   | 0                         | 0                         |
| Exchange with Mumbai     | -1709                     | -1695                 | -1361                     | -928                      |
| <b>MSEDCL DEMAND MET</b> | <b>15710</b>              | <b>15160</b>          | <b>15251</b>              | <b>14295</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15710                     | 15160                 | 15251                     | 14295                     |
| TPCL GENERATION          | 1029                      | 1043                  | 1071                      | 599                       |
| AEML GENERATION          | 374                       | 374                   | 375                       | 374                       |
| <b>MUMBAI DEMAND</b>     | <b>3112</b>               | <b>3112</b>           | <b>2807</b>               | <b>1901</b>               |
| STATE DEMAND MET         | 18822                     | 18272                 | 18058                     | 16196                     |
| <b>STATE DEMAND</b>      | <b>18822</b>              | <b>18272</b>          | <b>18058</b>              | <b>16196</b>              |
| Frequency (Hz)           | 50.05                     | 50.06                 | 49.98                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 13.02 Hrs | 49.84 Hz at 18.40 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 25/Jul/2019

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.32         | 55.83          | 155      | 115      |
| Unit 7             | 3.21         | 38.96          | 151      | 112      |
| Unit 8             | 9.93         | 190.83         | 455      | 275      |
| Unit 9             | 0.00         | 154.80         | 0        | 0        |
| Unit 10            | 11.01        | 132.46         | 467      | 450      |
| <b>Total</b>       | <b>27.47</b> | <b>572.88</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 8.64         | 247.02         | 360      | 355      |
| Unit 5             | 8.44         | 231.56         | 370      | 330      |
| <b>Total</b>       | <b>17.08</b> | <b>478.58</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 3.90         | 63.26          | 167      | 140      |
| Unit 4             | 2.99         | 78.85          | 153      | 100      |
| Unit 5             | 0.05         | 180.50         | 49       | 0        |
| Unit 6             | 8.64         | 185.27         | 370      | 355      |
| Unit 7             | 8.72         | 191.68         | 371      | 351      |
| Unit 8             | 8.65         | 208.55         | 365      | 348      |
| Unit 9             | 8.68         | 144.29         | 370      | 360      |
| <b>Total</b>       | <b>41.63</b> | <b>1052.40</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.04         | 114.39         | 39       | 0        |
| Unit 4             | 4.40         | 104.33         | 195      | 160      |
| <b>Total</b>       | <b>4.44</b>  | <b>218.72</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.63         | 82.38          | 165      | 130      |
| Unit 2             | 3.58         | 69.14          | 155      | 130      |
| Unit 3             | 3.78         | 85.69          | 165      | 150      |
| Unit 4             | 0.00         | 60.36          | 0        | 0        |
| Unit 5             | 9.17         | 120.35         | 420      | 365      |
| <b>Total</b>       | <b>20.16</b> | <b>417.92</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 3.89         | 82.74          | 165      | 161      |
| Unit 4             | 3.93         | 93.08          | 172      | 155      |
| Unit 5             | 3.89         | 67.42          | 170      | 158      |
| <b>Total</b>       | <b>11.71</b> | <b>243.25</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 8.88         | 207.97         | 390      | 352      |
| <b>Total</b>       | <b>8.88</b>  | <b>207.97</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.00         | 0.00           | 0        | 0        |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Koyna</b>    |              |                |          |          |
| Stage 1-2       | 1.35         | 51.94          | 145      | 40       |
| Stage 4         | 0.19         | 16.47          | 160      | 0        |
| Stage 3         | 0.95         | 34.03          | 80       | 0        |
| <b>Total</b>    | <b>2.50</b>  | <b>102.44</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.00         | 0.00           | 0        | 0        |
| VTRNA           | 0.00         | 1.16           | 0        | 0        |
| TILLARI         | 0.98         | 6.66           | 62       | 0        |
| BHTGR/VEER      | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.36         | 10.32          | 40       | 0        |
| RNGR+BHTSA      | 0.00         | 0.00           | 0        | 0        |
| BHANDARDRA      | 0.18         | 5.98           | 33       | 0        |
| ELDARY          | 0.00         | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.00         | 2.45           | 0        | 0        |
| GHATGHAR        | 0.50         | 14.06          | 245      | 0        |
| <b>Total</b>    | <b>2.01</b>  | <b>40.64</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 50.43        | 1033.81        | 0        | 0        |
| <b>Total</b>    | <b>50.43</b> | <b>1033.81</b> |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 58.53        | 1549.04        | 0        | 0        |
| JSWEL(Mus)      | 21.74        | 555.53         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 14.69        | 133.15         | 0        | 0        |
| WPCL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| Other(Mus)      | 2.37         | 61.82          | 0        | 0        |
| <b>Total</b>    | <b>97.34</b> | <b>2299.54</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 3.55         | 120.49         | 0        | 0        |
| <b>Total</b>    | <b>3.55</b>  | <b>120.49</b>  |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 7.43         | 209.88         | 318      | 283      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 2.57         | 60.94          | 116      | 65       |
| Trombay 7B      | 1.52         | 36.92          | 67       | 50       |
| Trombay 8       | 4.76         | 122.39         | 203      | 195      |
| TATA Hydro      | 5.10         | 118.46         | 374      | 0        |
| <b>Total</b>    | <b>21.38</b> | <b>548.60</b>  |          |          |
| <b>AEML</b>     |              |                |          |          |
| DTPS U-1&2      | 9.12         | 243.04         | 484      | 373      |
| <b>Total</b>    | <b>9.12</b>  | <b>243.04</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 122.49      | 2983.76       | MSPGCL Total        | 135.88      | 3334.80       |
|                |             |         | MSPGCL Thml+Gas | 131.37      | 3191.72       | Koyna 1,2 & 4 Total | 1.54        | 68.41         |
|                |             |         | MSPGCL Hydro    | 4.51        | 143.08        | State Total         | 317.70      | 7580.27       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 25/Jul/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5121        | 185  | 376  | 5682   | 1696  | 4669      | 0    | 0     | 4006        | 4109        | -1130                | 15026                 | 0                    | 15026                     | 2248             | 17274           | 50.07         |
| 2                  | 5094        | 172  | 364  | 5630   | 1865  | 4648      | 0    | 0     | 4227        | 3873        | -1010                | 15006                 | 0                    | 15006                     | 2070             | 17076           | 50.04         |
| 3                  | 5098        | 172  | 369  | 5639   | 1972  | 4107      | 0    | 0     | 3835        | 3617        | -962                 | 14373                 | 0                    | 14373                     | 1965             | 16338           | 49.96         |
| 4                  | 5127        | 156  | 375  | 5658   | 1979  | 4060      | 0    | 0     | 3524        | 3526        | -928                 | 14295                 | 0                    | 14295                     | 1901             | 16196           | 50.01         |
| 5                  | 5070        | 88   | 365  | 5523   | 2313  | 4052      | 0    | 0     | 3583        | 3754        | -909                 | 14733                 | 0                    | 14733                     | 1882             | 16615           | 50.01         |
| 6                  | 5062        | 90   | 388  | 5540   | 2026  | 4088      | 0    | 0     | 4579        | 4599        | -1006                | 15247                 | 0                    | 15247                     | 1977             | 17224           | 50.00         |
| 7                  | 5115        | 223  | 379  | 5717   | 2149  | 4535      | 0    | 41    | 5022        | 5037        | -1069                | 16410                 | 0                    | 16410                     | 2093             | 18503           | 49.99         |
| 8                  | 5133        | 146  | 370  | 5649   | 2058  | 4662      | 0    | 140   | 5148        | 5179        | -1198                | 16490                 | 0                    | 16490                     | 2284             | 18774           | 50.04         |
| 9                  | 5095        | 98   | 390  | 5583   | 2154  | 4221      | 0    | 280   | 5255        | 5161        | -1328                | 16071                 | 0                    | 16071                     | 2602             | 18673           | 50.05         |
| 10                 | 5061        | 136  | 364  | 5561   | 2182  | 4160      | 0    | 331   | 5293        | 5065        | -1532                | 15767                 | 0                    | 15767                     | 2918             | 18685           | 49.99         |
| 11                 | 5056        | 171  | 378  | 5605   | 2394  | 3938      | 0    | 357   | 5126        | 5125        | -1709                | 15710                 | 0                    | 15710                     | 3112             | 18822           | 50.05         |
| 12                 | 5081        | 169  | 373  | 5623   | 2207  | 3863      | 0    | 426   | 5050        | 5087        | -1754                | 15452                 | 0                    | 15452                     | 3174             | 18626           | 50.06         |
| 13                 | 5118        | 222  | 373  | 5713   | 2325  | 3830      | 0    | 469   | 4736        | 4518        | -1695                | 15160                 | 0                    | 15160                     | 3112             | 18272           | 50.06         |
| 14                 | 5106        | 222  | 360  | 5688   | 2170  | 3838      | 0    | 417   | 4316        | 4458        | -1550                | 15021                 | 0                    | 15021                     | 2966             | 17987           | 50.03         |
| 15                 | 5137        | 225  | 372  | 5734   | 2378  | 3829      | 0    | 452   | 4483        | 4273        | -1543                | 15123                 | 0                    | 15123                     | 2961             | 18084           | 49.99         |
| 16                 | 5124        | 230  | 359  | 5713   | 2439  | 3832      | 0    | 335   | 4313        | 4198        | -1492                | 15025                 | 0                    | 15025                     | 2946             | 17971           | 49.92         |
| 17                 | 5149        | 220  | 370  | 5739   | 2537  | 3831      | 0    | 198   | 3956        | 4027        | -1494                | 14838                 | 0                    | 14838                     | 2934             | 17772           | 50.00         |
| 18                 | 5190        | 190  | 370  | 5750   | 2337  | 3846      | 0    | 86    | 4001        | 4060        | -1398                | 14681                 | 0                    | 14681                     | 2909             | 17590           | 50.04         |
| 19                 | 5159        | 368  | 352  | 5879   | 2098  | 3643      | 0    | 18    | 4146        | 4250        | -1399                | 14489                 | 0                    | 14489                     | 2841             | 17330           | 49.97         |
| 20                 | 5192        | 615  | 357  | 6164   | 1891  | 3922      | 0    | 0     | 4674        | 4635        | -1361                | 15251                 | 0                    | 15251                     | 2807             | 18058           | 49.98         |
| 21                 | 5110        | 211  | 370  | 5691   | 1818  | 3994      | 0    | 0     | 4884        | 4776        | -1279                | 15000                 | 0                    | 15000                     | 2710             | 17710           | 50.01         |
| 22                 | 5033        | 115  | 371  | 5519   | 1867  | 3977      | 0    | 0     | 4587        | 4522        | -1196                | 14689                 | 0                    | 14689                     | 2584             | 17273           | 50.00         |
| 23                 | 5000        | 45   | 362  | 5407   | 1792  | 3960      | 0    | 0     | 4451        | 4233        | -1168                | 14224                 | 0                    | 14224                     | 2479             | 16703           | 50.03         |
| 24                 | 5056        | 40   | 378  | 5474   | 1787  | 3830      | 0    | 0     | 4291        | 4080        | -1234                | 13937                 | 0                    | 13937                     | 2374             | 16311           | 50.04         |
| MUs                | 122.49      | 4.51 | 8.88 | 135.88 | 50.43 | 97.33     | 0.00 | 3.55  | 107.49      | 106.16      | -31.34               | 362.02                | 0.00                 | 362.02                    | 61.85            | 423.87          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 25/Jul/2019**

**Position as on 6.30 Hrs of 26/Jul/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                  |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                  |               |
| MSPGCL                | Parli Unit 8            | 250      | 04/06/2019   | 00.00        |            | Continued. | Zero Schedule (converted to AOH from 25/06/2019) |               |
| MSPGCL                | Koyna Unit 12           | 80       | 16/07/2019   | 09.00        |            | Continued. | Annual Overhaul                                  |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 17/07/2019   | 21.44        |            | Continued. | Annual Overhaul                                  |               |
| MSPGCL                | Koradi Unit 9           | 660      | 19/07/2019   | 17.35        |            | Continued. | Annual Overhaul                                  |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                          |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                      |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                      |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.              |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                                |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                     |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.(water shortage from 25/06/2019)   |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                    |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                    |               |
| MSPGCL                | Parli Unit 7            | 250      | 25/06/2019   | 09.45        |            | Continued. | Water Shortage                                   |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 28/06/2019   | 18.35        |            | Continued. | Zero schedule.                                   |               |
| IPP                   | Dhariwal                | 300      | 01/07/2019   | 00.01        |            | Continued. | NO SCHEDULE                                      |               |
| MSPGCL                | Koyna STG- IV Unit - 1  | 250      | 18/07/2019   | 14.30        |            | Continued. | Breaker Air Pressure Problem                     |               |
| MSPGCL                | Koyna STG-IV Unit-2     | 250      | 18/07/2019   | 15.00        |            | Continued. | Checking of Generator Protection System          |               |
| MSPGCL                | Paras Unit 3            | 250      | 23/07/2019   | 12.05        | 25/07/2019 | 23.25      | Boiler Tube Leakage                              |               |
| MSPGCL                | Chandrapur Unit 5       | 500      | 24/07/2019   | 23.57        | 25/07/2019 | 23.30      | Feed water Line Leakage                          |               |
| IPP                   | RPL(AMT) U-2            | 270      | 25/07/2019   | 02.00        |            | Continued. | Zero Schedule                                    |               |
| IPP                   | RPL(AMT) U-1            | 270      | 25/07/2019   | 08.00        |            | Continued. | Zero schedule.                                   |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/07/2019   | 18.00        |            | Continued. | Zero Schedule                                    |               |
| MSPGCL                | Koradi Unit-8           | 660      | 26/07/2019   | 00.15        |            | Continued. | Air heater problem                               |               |
| IPP                   | RPL(AMT) U-4            | 270      | 26/07/2019   | 01.09        |            | Continued. | Zero Schedule                                    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 25/Jul/2019**

**Statement-VII**

**Position as on 6.30 Hrs of 26/Jul/2019**

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                            |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                             |
| Karad Solapur (PG)                         | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403    |
| Dhule Sar'Sarovar I                        | InterState                | 23/07/2019   | 14.32        |            | Continued. | EO          | Replacement of Flashover Disc Insulator String              |
| Padghe - Kalwa- I                          | IntraState                | 13/07/2019   | 10.48        |            | Continued. | PO          | MMRDA Work Tower Height Raising Work At Location 1142/1142. |
| Khadka-Aurangabad (Waluj)                  | IntraState                | 22/07/2019   | 18.20        |            | Continued. | T           | Over Voltage                                                |
| Babhleshwar - RIPL(Nashik)                 | IntraState                | 23/07/2019   | 10.10        |            | Continued. | PO          | Testing Work                                                |
| New Koyna - Dabhol - II                    | IntraState                | 24/07/2019   | 10.28        |            | Continued. | PO          | Routine Maintenance Work                                    |
| Lonikand I - Koyna stage-IV                | IntraState                | 25/07/2019   | 10.02        | 25/07/2019 | 17.11      | PO          | Line Maintenance work                                       |
| Dhule - Bableswhar - II                    | IntraState                | 25/07/2019   | 21.47        |            | Continued. | HT          | Over Voltage                                                |
| Lonikand I - Koyna stage-IV                | IntraState                | 26/07/2019   | 02.40        |            | Continued. | T           | Y-Phase LA Burst                                            |
| Chandrapur-II - Nanded ckt II              | IntraState                | 26/07/2019   | 06.12        |            | Continued. | T           | Distance Protection                                         |
| <b>400 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                             |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe        | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                   |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2 | IntraState                | 12/04/2019   | 17.10        |            | Continued. | HT          | Due To CVT Porcelain Collars Of The ICT-1 are Damaged.      |
| 400/220kv 315MVA ICT-III @ Kharghar        | IntraState                | 25/07/2019   | 03.48        | 25/07/2019 | 04.45      | T           | 220KV Bus-I Protection Operated at Kharghar                 |
| 400/220/33 Kv 315 MVA ICT -I @Kharghar     | IntraState                | 25/07/2019   | 03.48        |            | Continued. | T           | 220KV Bus-I Protection Operated at Kharghar                 |
| 400/220/33kv, 500 MVA ICT-I @Khaparkhedra  | IntraState                | 25/07/2019   | 10.12        | 25/07/2019 | 14.47      | PO          | Attending Oil Leakage                                       |
| 400/220KV 500MVA ICT-I @Nanded             | IntraState                | 25/07/2019   | 10.34        | 25/07/2019 | 15.46      | PO          | Attend 89B Y-Phase Isolator Sparking                        |
| <b>220 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                             |
| Talandage - Chikodi                        | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                 |
| Mudshingi - Chikodi                        | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                |
| Boisar(MS) - Boisar (PG) - I               | InterState                | 25/07/2019   | 17.28        | 25/07/2019 | 17.39      | EO          | Remove Earthwire                                            |
| BOISAR BORIVALI                            | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                |
| UTECH SUGAR BABHALESHWAR                   | IntraState                | 24/07/2019   | 08.09        |            | Continued. | PO          | Testing Work                                                |
| Ambazari-Amravati                          | IntraState                | 24/07/2019   | 10.47        |            | Continued. | PO          | To Carry out Ambazari-Amravati LLO activities               |
| Balapur-Malegaon                           | IntraState                | 24/07/2019   | 14.06        | 25/07/2019 | 00.41      | EO          | PID Faulty Disc Replacement work                            |
| Uran - Kharghar I                          | IntraState                | 25/07/2019   | 03.48        | 25/07/2019 | 05.21      | T           | Bus Bar Protection Operated at Kharghar                     |
| BUS A @Kharghar                            | IntraState                | 25/07/2019   | 03.48        | 25/07/2019 | 23.20      | T           | Bus-I B phase PT Burst                                      |
| Kharghar-Panvel TSS                        | IntraState                | 25/07/2019   | 03.48        | 25/07/2019 | 07.32      | T           | Bus Bar Protection Operated at Kharghar                     |
| Kharghar-Borivali ckt I                    | IntraState                | 25/07/2019   | 03.48        | 26/07/2019 | 00.05      | T           | Bus Bar Protection Operated at Kharghar                     |
| Kharghar - Nerul                           | IntraState                | 25/07/2019   | 03.48        | 25/07/2019 | 05.36      | T           | Bus Bar Protection Operated at Kharghar                     |
| WALCHANDNAGAR - PHALTAN MIDC               | IntraState                | 25/07/2019   | 10.35        | 25/07/2019 | 19.15      | PO          | Alignment of Bus Isolator work                              |
| Bombay Dyeing - Sahara                     | IntraState                | 25/07/2019   | 16.25        | 25/07/2019 | 19.57      | EO          | Remove Earthwire                                            |
| Lamboti(solapur)-Karkamb                   | IntraState                | 25/07/2019   | 20.20        | 25/07/2019 | 20.40      | T           | Tripped at Lamboti End only                                 |
| TPC Borivali Aarey Line 1                  | IntraState                | 25/07/2019   | 23.11        | 26/07/2019 | 06.41      | PO          | Metro Work                                                  |
| Kharghar-Sonkhar                           | IntraState                | 26/07/2019   | 01.50        | 26/07/2019 | 02.22      | T           | Distance Protection                                         |
| <b>220 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                             |
| 220/132 Kv 200 Mva Cgl Ptr No 5 @Parvati   | IntraState                | 25/07/2019   | 09.36        |            | Continued. | PO          | Half yearly maintenance work                                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 25/Jul/2019**

**Statement-VII**

Position as on 6.30 Hrs of 26/Jul/2019

| Name of Line                               | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                             |
|--------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|--------------------------------------------------------------|
| 220/132 KV 100MVA ICT-I @<br>Walchandnagar | IntraState                   | 25/07/2019      | 10.35           | 25/07/2019 | 19.03         | PO             | Alignment of Bus Isolator ICT-1 &<br>Tightning of Bus jumper |
| 220/33 Kv 50mva Bhel Ptr No 1<br>@Alephata | IntraState                   | 25/07/2019      | 11.40           | 25/07/2019 | 15.54         | PO             | Routine Maintenance Work                                     |
| Ptr No 2 50mva, 220/33 Kv<br>@Alephata     | IntraState                   | 25/07/2019      | 15.56           | 25/07/2019 | 20.01         | PO             | Routine Maintenance Work                                     |