

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Aug/2016 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	121.768	1920.755	1) Gujrat	12.063	157.436
2) Hydro	5.608	325.277	2) Madhya Pradesh	13.799	333.735
3) Gas	5.002	179.959	3) Chattisgarh	4.930	160.680
Total MSPGCL	132.378	2425.991	4) Maharashtra Net	71.756	1621.042
B) 1) APML	52.209	916.151	5) Goa (Amona)	-0.504	-16.307
2) JSWEL	21.649	525.937	6) TAPS 1&2 Injection	7.508	188.049
3) VIPL	11.439	250.712	7) RGPPL Injection	11.619	296.440
4) RPL(AMT)	0.000	0.000	8) Pench (MS)	0.509	7.201
5) WPCL	4.934	111.336	9) Pench (Excess)	-0.509	-7.201
6) PGPL	6.874	50.518	Total	120.662	2733.874
7) Other IPP	2.159	56.669	a) Mumbai Schedule	19.073	472.936
C) 1) TPCL Thermal	13.550	356.210	b) Mumbai Drawl	23.028	564.312
2) TPCL Hydro	5.925	140.472	c) MSEDCL Bilateral *	27.512	673.178
3) TPCL Gas	4.183	95.193	Include PX	-0.944	-31.282
4) R-INFRA Thermal	10.198	261.209	d) Mumbai Bilateral *	19.073	472.936
D) STATE			Include PX	0.270	42.136
1) Thermal	237.906	4398.979	Include Standby	0.000	0.000
(A1+C1+C4+(B1-B6))			H) ENERGY CATERED (MUs)		
2) Hydro (A2+C2)	11.533	465.749	1) MSEDCL	349.364	7559.567
3) Gas (A3+B6+C3)	16.059	325.670	2) Mumbai Discoms	56.885	1417.392
4) Wind	19.019	1031.247	TOTAL STATE	406.249	8976.959
6) SOLAR	1.069	21.444			
TOTAL STATE	285.586	6243.089			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5715	5626	5105	4687
MSPGCL Hydro	596	257	321	77
MSPGCL Gas	148	163	294	148
MSPGCL Total Generation	6459	6046	5720	4912
Central Sector Receipt	5241	5430	5036	4583
WIND	802	710	989	628
CPP / IPP Thermal	4054	3982	3751	3848
CPP / IPP Gas	0	0	0	0
SOLAR	120	123	0	0
Exchange with Mumbai	-974	-1123	-1042	-739
MSEDCL DEMAND MET	15988	15454	14741	13519
Load Shedding	0	0	0	0
MSEDCL DEMAND	15988	15454	14741	13519
TPCL GENERATION	1239	1262	1106	631
R-INFRA GENERATION	488	488	403	403
MUMBAI DEMAND	2701	2873	2551	1773
STATE DEMAND MET	18689	18327	17292	15292
STATE DEMAND	18689	18327	17292	15292
Frequency (Hz)	49.94	49.95	50.00	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.21 Hz at 18.01 Hrs	49.81 Hz at 00.11 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 25/Aug/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	2.05	2.13	115	40
Unit 6	0.00	0.00	0	0
Unit 7	3.49	8.29	155	134
Unit 8	12.78	217.54	580	491
Total	18.32	227.96		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	9.82	26.21	500	365
Unit 5	9.74	22.28	500	360
Total	19.56	48.50		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.21	66.80	198	159
Unit 4	0.00	73.15	0	0
Unit 5	9.29	214.48	425	360
Unit 6	9.44	209.44	450	360
Unit 7	9.31	220.50	425	349
Unit 8	9.47	145.66	467	270
Total	41.72	930.05		
Paras				
Unit 3	5.54	77.81	256	210
Unit 4	5.23	125.17	248	192
Total	10.77	202.97		
Khaparkheda				
Unit 1	3.78	9.53	180	135
Unit 2	3.90	10.11	170	140
Unit 3	2.09	2.09	138	0
Unit 4	2.45	8.84	197	0
Unit 5	10.65	260.68	500	390
Total	22.87	291.25		
Nasik				
Unit 3	3.97	101.15	185	160
Unit 4	3.09	90.22	188	0
Unit 5	1.46	11.50	166	17
Total	8.52	202.87		
Uran				
All Units	5.00	179.96	301	147
Total	5.00	179.96		
PGPL				
Unit 1	4.34	31.61	184	179

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Unit 2	2.53	18.91	108	103
Total	6.87	50.52		
PENCH (MS)				
Pench (MS)	0.51	7.20	27	0
Total	0.51	7.20		
Koyna				
Stage 1-2	2.44	99.42	395	40
Stage 4	0.00	87.80	0	0
Stage 3	0.76	55.94	160	0
Total	3.20	243.16		
Hydro				
KDPH	0.00	5.89	0	0
VTRNA	0.45	16.02	59	0
TILLARI	0.43	7.11	62	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.47	11.43	80	0
RNGR+BHTSA	0.06	4.39	3	2
BHANDARDRA	0.34	10.38	15	14
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.53	9.24	29	19
GHATGHAR	0.14	17.65	90	0
Total	2.41	82.12		
Wind				
Total	19.02	1031.25	0	0
Total	19.02	1031.25		
CPP				
APML(Mus)	52.21	916.15	0	0
JSWEL(Mus)	21.65	525.94	0	0
VIPL(Mus)	11.44	250.71	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	4.93	111.34	0	0
Other(Mus)	2.16	56.67	0	0
Total	92.39	1860.80		
SOLAR				
Total	1.07	21.44	0	0
Total	1.07	21.44		
Tata				
Trombay 5	8.43	225.52	467	315
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.64	58.88	121	63
Trombay 7B	1.55	36.31	68	50
Trombay 8	5.12	130.69	247	199
TATA Hydro	5.92	140.47	387	0
Total	23.66	591.88		
R-INFRA				
1-2	10.20	261.21	503	402
Total	10.20	261.21		

* Infirm Power		
Particulars	Daily (Mus)	Monthly
Chandrapur 9	0.00	17.16
Koradi 9	0.00	0.00
Koradi 10	0.00	0.00
Parli 8	0.00	0.00

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	121.77	1920.76
MSPGCL Thml+Gas	126.77	2100.71
MSPGCL Hydro	5.61	325.28

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	132.38	2425.99
Koyna 1,2 & 4 Total	2.44	187.22
State Total	285.59	6243.09

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 25/Aug/2016

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4709	167	147	5023	572	3825	0	0	4448	4886	-858	13735	0	13735	2145	15880	49.95
2	4646	97	148	4891	646	3838	0	0	4474	4498	-771	13389	0	13389	1936	15325	49.98
3	4685	87	148	4920	666	3852	0	0	4352	4554	-778	13501	0	13501	1841	15342	49.68
4	4687	77	148	4912	628	3848	0	0	4349	4583	-739	13519	0	13519	1773	15292	50.00
5	4713	82	149	4944	555	3831	0	0	4560	4880	-691	13807	0	13807	1752	15559	49.97
6	4794	209	150	5153	533	3823	0	0	4899	5138	-690	14244	0	14244	1835	16079	49.97
7	5036	354	150	5540	555	3813	0	0	5127	5466	-747	14915	0	14915	1911	16826	50.02
8	5339	592	150	6081	603	3872	0	27	5175	5533	-807	15595	0	15595	2078	17673	49.99
9	5522	374	147	6043	798	3965	0	84	5366	5794	-941	16028	0	16028	2386	18414	49.97
10	5715	596	148	6459	802	4054	0	120	5236	5241	-974	15988	0	15988	2701	18689	49.94
11	5677	313	151	6141	719	4023	0	110	5303	5332	-1093	15517	0	15517	2874	18391	49.97
12	5628	276	158	6062	712	4019	0	151	5373	5497	-1098	15630	0	15630	2877	18507	49.97
13	5626	257	163	6046	710	3982	0	123	5371	5430	-1123	15454	0	15454	2873	18327	49.95
14	5557	132	200	5889	667	4012	0	149	5252	5583	-1205	15380	0	15380	2726	18106	49.98
15	5407	271	244	5922	691	4009	0	119	5163	5588	-1191	15424	0	15424	2724	18148	49.97
16	5358	146	282	5786	933	4070	0	80	5060	5268	-957	15466	0	15466	2723	18189	49.99
17	5254	86	280	5620	1181	4120	0	70	4798	4460	-971	14765	0	14765	2641	17406	50.02
18	4729	95	279	5103	1317	3671	0	35	4503	4418	-1138	13692	5	13697	2562	16259	50.03
19	4705	243	294	5242	1054	3447	0	1	4644	4378	-1147	13262	0	13262	2466	15728	50.00
20	5105	321	294	5720	989	3751	0	0	4821	5036	-1042	14741	0	14741	2551	17292	50.00
21	4777	245	295	5317	878	3834	0	0	4881	5013	-1052	14276	0	14276	2489	16765	50.02
22	4745	155	301	5201	983	3619	0	0	4471	4828	-993	13926	0	13926	2396	16322	49.99
23	4702	152	280	5134	943	3550	0	0	4177	4572	-1044	13441	0	13441	2378	15819	49.99
24	4652	281	296	5229	884	3560	0	0	4206	4682	-978	13663	0	13663	2246	15909	49.98
MUs	121.77	5.61	5.00	132.38	19.02	92.39	0.00	1.07	116.01	120.66	-23.03	349.36	0.01	349.37	56.88	406.25	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 25/Aug/2016

Position as on 6.30 Hrs of 26/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkhedda Unit 3	210	05/07/2016	23.52	25/08/2016	04.48	Zero Shedule By MSEDCL, converted for AOH from 00 Hrs Dt.25-7-16	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
MSPGCL	Koradi Unit 9	660	04/06/2016	14.45		Continued.	No concent to operate	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
IPP	RPL(AMT) U-2	270	18/06/2016	06.54		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-3	270	29/06/2016	03.01		Continued.	Zero Shedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	30/06/2016	10.11		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-1	270	01/07/2016	18.40		Continued.	Zero Shedule By MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	08/07/2016	23.57		Continued.	ID Fan Problem (Converted to Zero schedule by MSEDCL from 11-07-2016)	
IPP	Adani U-4	660	13/07/2016	02.22		Continued.	Zero Shedule By MSEDCL,Shedule Glven On 21/08/2016	
MSPGCL	Nasik Unit 5	210	03/08/2016	17.30	25/08/2016	12.37	Zero shedule	
MSPGCL	Chandrapur Unit 9	500	11/08/2016	22.11		Continued.	Oil Shortage.	
MSPGCL	Uran Unit B0	120	14/08/2016	07.56		Continued.	Maintenance work	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 3A	230	16/08/2016	17.24		Continued.	Change Over	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Aug/2016

Position as on 6.30 Hrs of 26/Aug/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koyana Unit 8	80	19/08/2016	11.00		Continued.	High Vibration On LGB & UGB.	
MSPGCL	Uran Unit 5	108	19/08/2016	22.03	25/08/2016	11.57	Boiler trip.	
MSPGCL	Chandrapur Unit 4	210	21/08/2016	22.02	26/08/2016	10.10	ID Fan Problem	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Khaparkheda Unit 4	210	25/08/2016	13.50	26/08/2016	13.58	Boiler Tube Leakage	
MSPGCL	Nasik Unit 4	210	25/08/2016	18.40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	26/08/2016	18.33	26/08/2016	21.53	Bearing Temp.High	
MSPGCL	Uran Unit 5	108	26/08/2016	18.33	26/08/2016	20.30	Bearing Temp.High	
MSPGCL	Uran Unit A0	120	26/08/2016	18.33		Continued.	Bearing Temp.High	
MSPGCL	Khaparkheda Unit 1	210	26/08/2016	19.49	26/08/2016	23.00	Stator water pump pressure zero	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 26/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	22/08/2016	19.53		Continued.	T	Buchholz Trip 330 MVA Converter Pole-2 Y-Phase T/F At Chandrapur End.
Chandrapur - Padghe Hvdc Pole 1	IntraState	24/08/2016	23.00	25/08/2016	00.40	EO	Inspection of Y Phase Converter T/F
400 KV LINE Outages/Trippings							
Padgha Tarapur II	InterState	25/08/2016	13.11	25/08/2016	21.53	PO	Testing Work
Akola Aurangabad(PG) I	InterState	25/08/2016	18.40	25/08/2016	19.20	T	Tripped @ Akola,D.T.Received.
Akola Aurangabad(PG) II	InterState	26/08/2016	10.42	26/08/2016	15.00	PO	Quarterly Maintanance Work
Kolhapur(M)-Kolhapur(GIS) cktII	InterState	26/08/2016	11.17	26/08/2016	18.24	PO	Replacment of male and female assembly of isolator.
Ektuni-Bableshwar ckt II	IntraState	01/08/2016	09.53		Continued.	HT	To control Padgha-BBLSR L/L
Chandrapur II - Chandrapur ckt 2	IntraState	24/08/2016	11.27		Continued.	PO	Routine Maintenance Work
karad -kolhapur-I	IntraState	24/08/2016	17.59	25/08/2016	09.30	HT	Over Voltage
Karad - Jaigad - II	IntraState	24/08/2016	18.03	25/08/2016	09.52	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	24/08/2016	18.04	25/08/2016	09.27	HT	Over Voltage
Padghe - Nagothane - II	IntraState	25/08/2016	06.05	25/08/2016	20.13	T	LA Burst at Padgha end
karad -kolhapur-II	IntraState	25/08/2016	16.31	26/08/2016	09.23	HT	Over Voltage
Karad-Jaigad - I	IntraState	25/08/2016	16.33	26/08/2016	10.41	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	25/08/2016	17.16	26/08/2016	07.49	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	25/08/2016	18.14	26/08/2016	06.28	HT	Over Voltage
karad -kolhapur-I	IntraState	26/08/2016	16.39		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	26/08/2016	16.41		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	26/08/2016	17.14		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	20/08/2016	11.06		Continued.	PO	Shifted on TBC, by hot line jumper open for construction of kudus bay ektuni CKT-2 will remain off during this outage period.
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	24/08/2016	10.45	25/08/2016	18.55	PO	Isolator maint.work
400/220/33 Kv 315 Mva Ict 2 @Girwali	IntraState	25/08/2016	19.21	25/08/2016	19.37	T	Tripped During TBC Transfer.
400/132 Kv 200 Mva Ict 1 @Khadka	IntraState	26/08/2016	05.44	26/08/2016	07.55	HT	Emergency hand tripped core CT open as per testing
400/132 Kv 200 Mva Ict 2 @Khadka	IntraState	26/08/2016	10.33	26/08/2016	17.25	PO	Routine Maintenance Work
220 KV LINE Outages/Trippings							
Talandge Chikodi	InterState	25/08/2016	14.44	25/08/2016	16.12	T	Distance Protection
Vasai Boiser(PG)	InterState	26/08/2016	07.00	26/08/2016	09.22	PO	Breaker off at vasai end.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Kalwa-Salsette-IV	IntraState	28/06/2016	18.17		Continued.	T	Distance Protection
Bableshwar- Alephata	IntraState	24/07/2016	07.57	26/08/2016	17.15	HT	Load Diversion.
Bhugaon-Pusad	IntraState	25/08/2016	07.21	25/08/2016	18.36	PO	LILO Work @ Excisting Loc no.42 of Bhugaon Pusad Line for PGCIL Deoli S/S & Charging of Line as 220KV PGCIL Deoli-Bhugaon

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Aug/2016

Statement-VII

Position as on 6.30 Hrs of 26/Aug/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Line & PGCIL Deoli-Pusad Line.
Chandrapur GCR - Sicom II	IntraState	25/08/2016	11.00	25/08/2016	14.45	PO	Relay Instalation & Testing Work.
Khaparkheda-Kalmeshwar	IntraState	25/08/2016	11.21	25/08/2016	14.08	T	Distance Protection
Parli 2-(Girwali) -Murud	IntraState	25/08/2016	12.42	25/08/2016	17.03	PO	Attending Hot Spot
Chitegaon-Shendra Ckt-Ii	IntraState	25/08/2016	23.54	26/08/2016	00.41	T	Bus Bar Protection Operated
Gadchandur - Virur-Ii	IntraState	26/08/2016	02.19	26/08/2016	02.42	T	Distance Protection
Padghe - Nalasopara	IntraState	26/08/2016	07.00	26/08/2016	09.07	PO	Replacement of CT jumper.
Gadchandur - Grace	IntraState	26/08/2016	10.21	26/08/2016	15.43	PO	Replacement of faulty string.
IPCL - SPCL	IntraState	26/08/2016	13.05	26/08/2016	16.15	PO	Annual Maintenance Work
Bhugaon- Wardha	IntraState	26/08/2016	13.32	26/08/2016	19.00	PO	Routine Maintenance Work
Bableshwar- Alephata	IntraState	26/08/2016	20.54		Continued.	HT	Hand tripped.
Chitegaon-Shendra Ckt-I	IntraState	26/08/2016	23.54	26/08/2016	00.38	T	Bus Bar Protection Operated
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 KV ICT II @ Kopergaon	IntraState	25/08/2016	15.25	25/08/2016	18.00	PO	Testing Work
220/132 Kv 80 Mva Cgl Ict 1 @Hinganghat	IntraState	26/08/2016	13.55	26/08/2016	14.55	PO	OLTC healthiness checking.
132 KV LINE Outages/Trippings							
Khadka-Deepnagar Ckt-2	IntraState	26/08/2016	04.47	26/08/2016	09.38	T	Burst and caught fire.
Deepnagar- Muktainagar	IntraState	26/08/2016	04.47	26/08/2016	05.39	T	Distance Protection
Khadka-Deepnagar Ckt-2	IntraState	26/08/2016	07.08	26/08/2016	07.10	T	Tripped During Operation.
100 KV LINE Outages/Trippings							
Vasai-Ii - Vasai 2 Line	IntraState	13/08/2016	08.53		Continued.	HT	ICT Problem.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage