

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Aug/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	105.612	2563.353	1) Gujrat	10.618	227.496
2) Hydro	24.206	348.661	2) Madhya Pradesh	8.055	144.215
3) Gas	5.866	127.558	3) Chattisgarh	4.370	74.410
Total MSPGCL	135.684	3039.572	4) Maharashtra	161.930	3573.479
B) 1) APLM	75.565	1302.372	5) Goa (Amona)	-1.976	-41.276
2) JSWEL	14.942	351.208	Total	182.997	3978.324
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.882	758.384
4) RPL(AMT)	19.002	496.798	b) Mumbai Drawl	29.521	826.682
5) SWPGPL	5.584	152.168	c) MSEDCL Bilateral *	72.784	1889.350
6) Other IPP	4.903	143.615	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.838	758.116
C) 1) TPCL Thermal	12.041	256.919	Include PX	0.000	0.000
2) TPCL Hydro	8.880	153.564	Standby	0.043	0.268
3) TPCL Gas	1.765	47.758	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.129	215.137	1) MSEDCL	430.222	9631.843
D) STATE			2) Mumbai Discoms	62.337	1500.061
1) Thermal	247.778	5481.570	3) Other Discoms	9.084	217.592
(A1+C1+C4+(B1-B6))			TOTAL STATE	501.643	11349.496
2) Hydro	33.086	502.225			
3) Gas	7.631	175.316			
4) Wind	19.935	1011.599			
6) SOLAR	10.215	200.461			
TOTAL STATE	318.645	7371.171			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4328	4370	4432	4370
MSPGCL Hydro	902	776	1992	357
MSPGCL Gas	238	245	241	251
MSPGCL Total Generation	5468	5391	6665	4978
Central Sector Receipt	9204	8967	7638	5945
WIND	377	406	871	1154
CPP / IPP Thermal	5020	4995	5059	4996
CPP / IPP Gas	0	0	0	0
SOLAR	1196	1243	0	0
Exchange with Mumbai	-1937	-1954	-1272	-746
MSEDCL DEMAND MET	18920	18615	18557	16037
Load Shedding	0	0	0	0
MSEDCL DEMAND	18920	18615	18557	16037
TPCL GENERATION	878	844	1155	752
AEML GENERATION	350	321	437	407
MUMBAI DEMAND	3165	3119	2864	1905
OTHER DISCOM DEMAND	408	433	404	290
STATE DEMAND MET	22493	22167	21825	18232
STATE DEMAND	22493	22167	21825	18232
Frequency (Hz)	49.97	50.02	49.75	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.11 Hz at 12.33 Hrs	49.47 Hz at 19.24 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.38	64.20	175	110
Unit 7	0.00	0.00	0	0
Unit 8	0.00	102.62	0	0
Unit 9	0.00	46.51	0	0
Unit 10	10.32	258.24	481	330
Total	13.71	471.58		
Bhusawal				
Unit 3	0.00	7.23	0	0
Unit 4	8.62	202.94	400	310
Unit 5	0.00	55.81	0	0
Total	8.62	265.98		
Parli				
Unit 6	4.62	103.19	202	175
Unit 7	4.51	92.76	202	169
Unit 8	3.78	88.60	170	143
Total	12.92	284.56		
Chandrapur				
Unit 3	0.00	32.41	0	0
Unit 4	0.00	12.42	0	0
Unit 5	4.67	127.24	320	125
Unit 6	8.05	130.76	360	310
Unit 7	5.70	49.34	257	228
Unit 8	9.54	221.76	442	355
Unit 9	9.88	231.61	439	384
Total	37.84	805.54		
Paras				
Unit 3	4.71	89.40	215	163
Unit 4	4.57	93.71	203	182
Total	9.28	183.11		
Khaparkheda				
Unit 1	0.44	37.85	90	0
Unit 2	0.00	44.16	0	0
Unit 3	3.26	84.42	150	120
Unit 4	3.92	60.15	186	139
Unit 5	9.78	182.08	435	357
Total	17.40	408.66		
Nasik				
Unit 3	3.03	72.54	137	117
Unit 4	0.00	0.00	0	0
Unit 5	2.81	71.38	130	100
Total	5.85	143.92		
Uran				
All Units	5.87	127.56	252	233
Total	5.87	127.56		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	14.90	27	23
Total	0.60	14.90		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.52	62.14	515	35
Stage 4	6.71	54.79	824	0
Stage 3	2.75	36.80	240	0
Total	14.98	153.73		
Hydro				
KDPH	0.36	11.91	36	0
VTRNA	0.71	15.26	61	0
TILLARI	0.58	13.29	58	0
BHIRA T.R.	0.50	11.73	80	0
SMLHY_PTN	6.36	123.02	276	254
GHATGHAR	0.13	4.83	65	0
Total	8.63	180.03		
Wind				
Total	19.94	1011.60	0	0
Total	19.94	1011.60		
CPP				
APML(Mus)	75.56	1302.37	0	0
JSWEL(Mus)	14.94	351.21	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.00	496.80	0	0
SWPGPL-Mus	5.58	152.17	0	0
Other(Mus)	4.90	143.62	0	0
Total	120.00	2446.16		
SOLAR				
Total	10.22	200.46	0	0
Total	10.22	200.46		
Tata				
Trombay 5	7.86	171.31	432	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.94	27.42	39	39
Trombay 7B	0.83	20.34	37	34
TATA Hydro	8.88	153.56	448	221
Trombay 8	4.18	85.61	226	131
Total	22.69	458.24		
AEMIL				
DTPS U-1&2	10.13	215.14	498	321
Total	10.13	215.14		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	105.61	2563.35	MSPGCL Total	135.68	3039.57
			MSPGCL Thml+Gas	111.48	2690.91	Koyna 1,2 & 4 Total	12.23	116.93
			MSPGCL Hydro	24.21	348.66	State Total	318.64	7371.17

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 25/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4391	659	252	5302	1206	4994	0	0	6174	5894	-794	16262	0	16262	2194	340	18796	50.05
2	4391	408	242	5041	1198	5012	0	0	6420	6192	-861	16274	0	16274	2022	308	18604	49.99
3	4370	357	251	4978	1154	4996	0	0	6326	5945	-746	16037	0	16037	1905	290	18232	50.02
4	4375	359	242	4976	1061	4866	0	0	6538	6116	-486	16224	0	16224	1875	309	18408	50.02
5	4410	360	252	5022	992	4962	0	0	6690	6604	-457	16829	0	16829	1858	294	18981	50.00
6	4376	494	251	5121	781	5054	0	0	7351	7531	-487	17670	0	17670	1978	330	19978	50.01
7	4408	1403	251	6062	553	5033	0	41	7959	8334	-626	19031	0	19031	2157	366	21554	50.00
8	4322	1607	252	6181	466	5033	0	273	8658	8737	-1021	19285	0	19285	2352	384	22021	49.98
9	4293	1165	252	5710	516	5034	0	636	8988	9053	-1369	19167	0	19167	2673	413	22253	49.93
10	4329	788	242	5359	501	5025	0	962	8810	9024	-1725	18733	0	18733	2960	413	22106	50.00
11	4339	788	251	5378	483	5020	0	1176	9057	9210	-1916	18937	0	18937	3133	414	22484	50.00
12	4328	902	238	5468	377	5020	0	1196	9110	9204	-1937	18920	0	18920	3165	408	22493	49.97
13	4370	776	245	5391	406	4995	0	1243	9010	8967	-1954	18615	0	18615	3119	433	22167	50.02
14	4390	645	237	5272	512	5008	0	1266	8337	8527	-1784	18400	0	18400	2981	401	21782	50.02
15	4397	599	245	5241	585	4909	0	1341	8864	8618	-1782	18509	0	18509	3015	403	21927	49.99
16	4501	600	236	5337	766	5031	0	1031	8550	8660	-1826	18585	0	18585	3032	414	22031	49.89
17	4401	599	238	5238	1266	4980	0	707	8793	8314	-1754	18359	0	18359	2994	392	21745	49.93
18	4364	752	242	5358	1473	5042	0	307	8106	7900	-1644	18027	0	18027	2948	409	21384	49.92
19	4425	1548	245	6218	1082	5062	0	36	7273	7465	-1453	17977	0	17977	2882	433	21292	49.82
20	4432	1992	241	6665	871	5059	0	0	7143	7638	-1272	18557	0	18557	2864	404	21825	49.75
21	4510	1895	233	6638	858	5053	0	0	6510	7046	-1071	18120	0	18120	2743	404	21267	49.87
22	4496	1824	243	6563	877	5060	0	0	6059	6534	-966	17680	0	17680	2599	388	20667	49.99
23	4521	1819	248	6588	936	4983	0	0	5826	6021	-851	17295	0	17295	2495	382	20172	49.98
24	4473	1867	237	6577	1015	4765	0	0	5645	5463	-739	16730	0	16730	2392	351	19473	50.00
MUs	105.61	24.21	5.87	135.68	19.93	120.00	0.00	10.21	182.20	183.00	-29.52	430.22	0.00	430.22	62.34	9.08	501.64	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 25/Aug/2022

Position as on 6.30 Hrs of 26/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	24/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 4	210	09/08/2022	20:25	26/08/2022	01:05	FURNACE DRAFT VERY HIGH/ poor coal receipt & wet coal.	
MSPGCL	Chandrapur Unit 3	210	15/08/2022	12:50		Continued.	Poor Coal Receipt	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	16/08/2022	03:44		Continued.	Wet coal problem.	
MSPGCL	Khaparkheda Unit 1	210	16/08/2022	04:28	25/08/2022	17:06	DUE TO WET STEAM PROTECTION/ poor coal receipt & wet coal.	
MSPGCL	Khaparkheda Unit 2	210	19/08/2022	02:18		Continued.	Furnace Pressure High/poor coal receipt &	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Aug/2022

Position as on 6.30 Hrs of 26/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							wet coal.	
IPP	RPL(AMT) U-5	270	19/08/2022	11:00		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 8	660	21/08/2022	14:10		Continued.	SUSPECTED BOILER TUBE LEAKAGE	27/08/2022
MSPGCL	Uran Unit 5	108	24/08/2022	02:29		Continued.	Gas shortage	
MSPGCL	Koyana STG-IV Unit-2	250	25/08/2022	18:40	25/08/2022	23:25	Spherical Oil Pump Pressure Issue.	
IPP	Adani U-5	660	26/08/2022	00:06		Continued.	HOT PA-5A bellow leakage	
MSPGCL	Koyana STG-IV Unit-2	250	26/08/2022	05:18		Continued.	SPERICAL VALVE OIL SYSTEM PROBLEM	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 26/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Trippings							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/08/2022	15:11			HT	This breaker put in lock out at 15:06hrs dt.15.08.2022 and this filter is under breakdown and expert service are required for
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (407) OF ICT - 2 @ NANDED	IntraState	25/08/2022	11:57	25/08/2022	16:09	PO	CB DCRM and Bay maintenance works.
400 KV LINE Outages/Trippings							
400 KV AKOLA - AURANGABAD(PG) CKT -2	InterState	25/08/2022	09:50	25/08/2022	21:01	PO	For Line Bays, L/R & Line AMP works at both ends, Dia to be kept in open condition at both ends.
KALWA - TALEGAON (PG)	InterState	25/08/2022	23:32	26/08/2022	07:00	HT	EMERGENCY OUTAGE AVALIED FOR CVT REPLACEMENT AT TALEGAON PG END
JAIGAD - KARAD CKT - 2	IntraState	22/08/2022	00:24	25/08/2022	13:56	HT	To control OV
KHADKA-AURANGABAD (WALUJ)	IntraState	24/08/2022	20:08	25/08/2022	09:10	HT	H/T DUE TO O/V
KALWA - KHARGHAR	IntraState	25/08/2022	02:05	25/08/2022	07:25	EO	Red Hot spot attending emergency work 1) Y-Ph wave trap jumper bottom pad red hot
B - BUS @ KHARGHAR	IntraState	25/08/2022	02:05	25/08/2022	04:52	T	Grading Capacitor of Y Phase Circuit Breaker of Kalwa line Burst
KHADKA-AURANGABAD (WALUJ)	IntraState	25/08/2022	22:30	26/08/2022	06:32	HT	H/T DUE TO O/V
NEW KOYNA - DABHOL CKT - 1	IntraState	26/08/2022	02:48			T	TRIPPED DUE TO OVER VOLTAGE
400 KV ICT Outages/Trippings							
95 MVA STN TF - II @KORADI 2	IntraState	23/08/2022	12:26			PO	1)Transformer testing and oil filtration 2)Transformer bus duct inspection 3) Station switch gear checking , breaker and relay testing
500 MVA 400/220 KV ICT - I @ CHANDRAPUR 2	IntraState	24/08/2022	16:01			T	Y-Ph Buchholz trip.
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	25/08/2022	02:05	25/08/2022	07:53	T	400KV Bus-2 Fault
400/220kv SPARE ICT @ JEJURI	IntraState	25/08/2022	09:12	25/08/2022	19:26	PO	Annual bay Maintenance and Testing Work
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	25/08/2022	09:21	25/08/2022	18:31	PO	Demonstration of SFRA kits
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	25/08/2022	10:32	25/08/2022	19:13	PO	For replacement of 1 No insulator string at 220 KV Gantry as directed by PID team vide mail Dt. 02.08.2022, after conducting PID scan.
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	25/08/2022	10:40	25/08/2022	16:36	PO	Quartely Maint. of bays & CT Tan Delta & capacitance , CB timing & CRM,Reactor winding & bushing Tan Delta & capacitance
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	26/08/2022	05:56			HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	19/08/2022	06:26			HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
INFOSYS - HINJAWADI 1	IntraState	25/08/2022	07:19	25/08/2022	18:04	PO	To complete the balance work of MCTT nut bolt tightening.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 26/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAHAPE - RELIANCE GIS	IntraState	25/08/2022	08:52	25/08/2022	13:02	EO	Replacement of B-Phase Twin Jumper from GIS Bushing to Gantry in Reliance yard. B phase jumper is having hotspot needs replacement to be done.
HALKARNI-OLAM AGRO (HEMRUS) LINE	IntraState	25/08/2022	10:15	25/08/2022	17:34	PO	Quarterly Maintenance and Diagnostic Testing Work.
BHOSARI- BHOSARI 2	IntraState	25/08/2022	10:36	25/08/2022	10:48	T	Tripped at Bhosari 1 end only
KHARGHAR - TOPWORTH	IntraState	25/08/2022	10:39	25/08/2022	16:50	EO	Replacement of broken disc insulator at Loc No. 650 And emergency tree cutting work
BHOSARI- BHOSARI 2	IntraState	25/08/2022	16:37	25/08/2022	18:06	EO	Bhosari II Bay CB testing work , PDR optd on 25.08.2022 at (10:36)hrs
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 1	IntraState	25/08/2022	19:04	25/08/2022	23:51	HT	To control Overdrawal
WARDHA (PG) - BADNERA	IntraState	25/08/2022	19:24	25/08/2022	23:46	HT	To control Overdrawal
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 2	IntraState	25/08/2022	19:24	25/08/2022	23:54	HT	To control Overdrawal
BHUGAON - WARDHA (PG)	IntraState	25/08/2022	19:25	25/08/2022	23:46	HT	To control Overdrawal
OSMANABAD - PARLY (PG)	IntraState	25/08/2022	19:35	25/08/2022	23:37	HT	To control Overdrawal
WARDHA - WARDHA (PG)	IntraState	26/08/2022	06:44			HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	25/08/2022	09:26			PO	Commissioning of new HV & LV Relay & Control panel.
220/132 KV 200MVA ICT NO 2 @ THEUR	IntraState	25/08/2022	09:35	25/08/2022	13:41	PO	ICT-II CTR Fire detector cable replacement work
220/33 KV 25MVA PTR 3 @ BARAMATI	IntraState	25/08/2022	13:12	25/08/2022	17:38	PO	OLTC OVERHAULING & RELAY TESTING WORK.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
KHOPOLI - KARANJADE	IntraState	25/08/2022	09:02	25/08/2022	14:41	EO	Attending Line GOD stuck defect at Khopoli end

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage