

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Sep/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	120.680	2831.827	1) Gujrat	13.469	245.281
2) Hydro	8.800	288.687	2) Madhya Pradesh	11.925	105.582
3) Gas	2.092	65.742	3) Chattisgarh	4.090	90.400
Total MSPGCL	131.572	3186.256	4) Maharashtra	143.530	3735.692
B) 1) APLM	60.426	1567.406	5) Goa (Amona)	-1.090	-30.015
2) JSWEL	17.348	448.838	Total	171.924	4146.940
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.363	811.004
4) RPL(AMT)	18.802	412.297	b) Mumbai Drawl	30.138	894.188
5) SWPGPL	7.249	116.027	c) MSEDCL Bilateral *	70.863	1446.156
6) Other IPP	4.828	138.943	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.363	810.789
C) 1) TPCL Thermal	10.191	279.490	Include PX	0.000	0.000
2) TPCL Hydro	2.425	128.408	Standby	0.000	0.215
3) TPCL Gas	0.447	13.880	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.398	222.334	1) MSEDCL	394.911	9671.294
D) STATE			2) Mumbai Discoms	51.599	1538.301
1) Thermal	247.922	6017.162	3) Other Discoms	8.718	224.428
(A1+C1+C4+(B1-B6))			TOTAL STATE	455.228	11434.023
2) Hydro	11.225	417.095			
3) Gas	2.539	79.622			
4) Wind	10.653	552.834			
6) SOLAR	10.965	220.369			
TOTAL STATE	283.304	7287.082			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	4956	4921	5163	5063
MSPGCL Hydro	408	283	1679	156
MSPGCL Gas	86	85	85	88
MSPGCL Total Generation	5450	5289	6927	5307
Central Sector Receipt	8176	8096	6755	5846
WIND	150	150	514	701
CPP / IPP Thermal	4272	4090	5176	4302
CPP / IPP Gas	0	0	0	0
SOLAR	1387	1358	0	0
Exchange with Mumbai	-1462	-1376	-1148	-1140
MSEDCL DEMAND MET	17593	17242	17815	14687
Load Shedding	0	0	0	0
MSEDCL DEMAND	17593	17242	17815	14687
TPCL GENERATION	616	608	814	512
AEML GENERATION	462	443	443	303
MUMBAI DEMAND	2540	2427	2405	1955
OTHER DISCOM DEMAND	380	365	409	329
STATE DEMAND MET	20513	20034	20629	16971
STATE DEMAND	20513	20034	20629	16971
Frequency (Hz)	50.03	50.00	49.95	49.90

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 16.06 Hrs	49.74 Hz at 20.47 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	7.44	244.44	364	268
Unit 9	7.64	39.08	380	279
Unit 10	7.73	249.35	352	274
Total	22.81	572.22		
Bhusawal				
Unit 3	2.68	55.89	155	85
Unit 4	8.15	206.18	405	260
Unit 5	8.45	56.00	410	295
Total	19.28	318.08		
Parli				
Unit 6	5.04	107.31	229	163
Unit 7	4.58	88.44	234	151
Unit 8	3.92	92.10	180	144
Total	13.54	287.85		
Chandrapur				
Unit 3	3.41	72.84	163	125
Unit 4	3.19	74.89	147	122
Unit 5	6.56	134.36	315	235
Unit 6	7.11	141.08	380	245
Unit 7	7.30	144.49	340	279
Unit 8	0.00	49.00	0	0
Unit 9	9.18	231.19	438	299
Total	36.75	847.85		
Paras				
Unit 3	4.96	110.01	230	162
Unit 4	0.00	86.15	0	0
Total	4.96	196.15		
Khaparkheda				
Unit 1	2.98	65.82	140	110
Unit 2	0.00	38.82	0	0
Unit 3	1.92	78.27	164	0
Unit 4	3.41	74.48	163	126
Unit 5	9.08	201.23	450	270
Total	17.39	458.61		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	3.00	48.24	138	112
Unit 5	2.96	70.25	135	112
Total	5.96	151.06		
Uran				
All Units	2.09	65.74	90	83
Total	2.09	65.74		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	12.70	27	23
Total	0.59	12.70		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.78	54.85	335	35
Stage 4	1.42	45.43	689	0
Stage 3	0.75	26.51	240	0
Total	3.95	126.79		
Hydro				
KDPH	0.43	6.12	18	18
VTRNA	0.75	18.98	61	0
TILLARI	0.70	11.88	58	0
BHIRA T.R.	0.30	10.04	60	0
SMLHY_PTN	1.89	96.83	88	74
GHATGHAR	0.19	5.35	125	0
Total	4.26	149.20		
Wind				
Total	10.65	552.83	0	0
Total	10.65	552.83		
CPP				
APML(Mus)	60.43	1567.41	0	0
JSWEL(Mus)	17.35	448.84	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.80	412.30	0	0
SWPGPL-Mus	7.25	116.03	0	0
Other(Mus)	4.83	138.94	0	0
Total	108.65	2683.51		
SOLAR				
Total	10.96	220.37	0	0
Total	10.96	220.37		
Tata				
Trombay 5	6.82	188.00	366	256
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.45	9.12	101	0
Trombay 7B	0.00	4.76	0	0
TATA Hydro	2.42	128.41	302	24
Trombay 8	3.37	91.50	168	132
Total	13.06	421.78		
AEMIL				
DTPS U-1&2	8.40	222.33	489	286
Total	8.40	222.33		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	120.68	2831.83	MSPGCL Total	131.57	3186.26
			MSPGCL Thml+Gas	122.77	2897.57	Koyna 1,2 & 4 Total	3.20	100.28
			MSPGCL Hydro	8.80	288.69	State Total	283.30	7287.08

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 25/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5085	166	89	5340	776	4303	0	0	6307	6316	-1252	15136	0	15136	2091	347	17574	50.03
2	5063	156	88	5307	701	4302	0	0	6100	5846	-1140	14687	0	14687	1955	329	16971	49.90
3	5055	155	89	5299	660	4310	0	0	5983	6039	-1096	14923	0	14923	1850	289	17062	50.00
4	5107	154	89	5350	610	4344	0	0	6162	6210	-1062	15166	0	15166	1781	286	17233	49.98
5	5113	159	90	5362	501	4497	0	0	6471	6686	-1028	15715	0	15715	1763	302	17781	49.98
6	5192	154	90	5436	472	5086	0	0	6833	6633	-1066	16233	0	16233	1823	329	18384	49.96
7	5245	194	90	5529	428	5196	0	62	7580	7405	-1084	17183	0	17183	1856	353	19392	50.00
8	5215	199	90	5504	376	5150	0	411	7588	7332	-1187	17217	0	17217	1925	369	19511	50.02
9	5157	257	89	5503	355	4848	0	897	7530	7691	-1284	17624	0	17624	2070	387	20080	49.92
10	5048	404	88	5540	227	4547	0	1213	7404	7449	-1305	17281	0	17281	2271	390	19942	50.03
11	4953	294	87	5334	184	4225	0	1350	7956	8235	-1273	17664	0	17664	2372	391	20427	50.05
12	4956	408	86	5450	150	4272	0	1387	7821	8176	-1462	17593	0	17593	2540	380	20513	50.03
13	4921	283	85	5289	150	4090	0	1358	8197	8096	-1376	17242	0	17242	2427	365	20034	50.00
14	4600	275	84	4959	219	4101	0	1364	8287	8116	-1558	16851	0	16851	2335	350	19536	50.03
15	4563	436	83	5082	317	4100	0	1201	8211	8094	-1451	16969	0	16969	2192	374	19535	50.02
16	4739	333	83	5155	477	4155	0	923	8162	7691	-1386	16650	0	16650	2125	365	19140	50.04
17	4863	275	85	5223	553	3922	0	604	8391	7854	-1357	16413	0	16413	2111	386	18910	50.06
18	5037	274	85	5396	497	4292	0	188	8094	7771	-1360	16390	0	16390	2125	394	18909	50.03
19	5193	852	85	6130	517	4730	0	7	7494	7139	-1312	16796	0	16796	2299	415	19510	49.99
20	5163	1679	85	6927	514	5176	0	0	6667	6755	-1148	17815	0	17815	2405	409	20629	49.95
21	5126	753	86	5965	576	4966	0	0	6732	6628	-1178	16561	0	16561	2390	396	19347	49.92
22	5144	516	88	5748	507	4958	0	0	6757	6430	-1193	16050	0	16050	2342	399	18792	50.02
23	5094	254	89	5437	454	4644	0	0	6710	6724	-1279	15612	0	15612	2322	368	18302	50.01
24	5048	169	89	5306	432	4438	0	0	6606	6609	-1301	15136	0	15136	2229	348	17713	50.01
MUs	120.68	8.80	2.09	131.57	10.65	108.65	0.00	10.97	174.04	171.92	-30.14	394.91	0.00	394.91	51.60	8.72	455.23	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 25/Sep/2022

Position as on 6.30 Hrs of 26/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58	26/09/2022	16:59	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	14/09/2022	05:36	25/09/2022	19:00	Gas shortage	
TPC-G	Trombay 7B	60	14/09/2022	05:50	26/09/2022	00:33	Gas shortage	
MSPGCL	Khaparkheda Unit 2	210	17/09/2022	13:00	26/09/2022	22:30	wet coal	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	29/09/2022
MSPGCL	Khaparkheda Unit 3	210	23/09/2022	22:04	25/09/2022	09:47	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Sep/2022

Position as on 6.30 Hrs of 26/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	26/09/2022	05:33	26/09/2022	07:08	Gas shortage	26/09/2022
MSPGCL	Bhusawal Unit 3	210	26/09/2022	16:08		Continued.	Boiler Tube Leakage	30/09/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 26/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	26/09/2022	00:39	26/09/2022	03:41	EO	A] HVDC TL O&M Sub-Division, Babhaleshwar:- 1. Cold line washing of bird shit insulator string at Loc No. 1441.
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	13/09/2022	21:00	25/09/2022	17:54	T	Reason awaited
400 KV TBC Outages/Trippings							
BUS COUPLER @ AURANGABAD (WALUJ)	IntraState	25/09/2022	16:06	25/09/2022	16:38	EO	To attend hot spot by operation of 89A Yph PG Isolator for proper fixing with hanger.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KORADI 2-WARDHA (PG)	InterState	21/09/2022	08:55	26/09/2022	18:31	PO	Diversion of 400 kV Koradi-Wardha Line through 6 nos of Newly constructed tower of POWERGRID. Configuration of 400 kV Koradi Bays at Wardha shall remain the same. MSETCL 400 kV IEPL-Warora Line shall be in non- A/R Mode for safety precautions
KALWA - TALEGAON (PG)	InterState	25/09/2022	09:50	25/09/2022	20:22	PO	Replacement of discs type insulator string with AF long rod type insulator string at cut point tower location for D/C portion
KORADI - SATPUR	InterState	26/09/2022	08:53	26/09/2022	18:35	HT	OUTAGE AVAILED FOR JUMPER REPLACEMENT WORK
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	24/09/2022	19:52	25/09/2022	09:19	T	TRIPPED ON DISTANCE PROTECTION
CHANDRAPUR-PARLI CKT-3	IntraState	25/09/2022	14:22	25/09/2022	19:38	PO	for replacement of of polymer insulator with long rod porcelain insulator strings.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	25/09/2022	16:48	25/09/2022	20:04	PO	Cold Line Washing work to be carried out in view of frequent tripping of line.
JEJURI- KOYNA STAGE-IV	IntraState	25/09/2022	17:23	25/09/2022	20:20	PO	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
KHADKA-AURANGABAD (WALUJ)	IntraState	25/09/2022	20:58	26/09/2022	06:53	HT	H/T for Over Voltage.
KHADKA-AURANGABAD (WALUJ)	IntraState	26/09/2022	22:39		Continued.	HT	H/T FOR O/V
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	26/09/2022	10:45	26/09/2022	19:31	PO	1) HV breaker and IV CTs Testing work.(2) Bay maintenance work.
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	26/09/2022	11:32				Oil filtration, Oil leakage attending, Electrical Testing and painting of Station Transformer -8A Station Transformer -8A Bus duct servicing, maintenance and below replacement
105 MVA SPARE ICT @ CHAKAN	IntraState	26/09/2022	11:46	26/09/2022	17:29	PO	Diagnostic Testing and maintenance
220 KV TBC Outages/Trippings							
BUS SECTION BAY @ VSNL	IntraState	25/09/2022	10:37	25/09/2022	13:18	EO	Replacement of damaged jumps from Bus to Bus Isolator of 220kV Bus Section

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 26/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV MAINBAY Outages/Trippings							
TBC @ BHOSARI-1	IntraState	26/09/2022	11:05		Continued.	PO	CT erection work at 220kV TBC Bay
220 KV LINE Outages/Trippings							
CHINCHWAD-2 - TELCO	IntraState	24/09/2022	23:45	25/09/2022	06:57	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to theconstruction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
CHAKAN - CHINCHWAD 2	IntraState	25/09/2022	00:02	25/09/2022	06:47	PO	For erection of monopole tower at location 17 for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to theconstruction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
VSNL- KHADKI	IntraState	25/09/2022	10:07	25/09/2022	13:19	EO	Replacement of damaged jumps from Bus to Bus Isolator of 220kV Bus Section
VSNL - STT GIS CKT - 1	IntraState	25/09/2022	10:13	25/09/2022	13:20	EO	Replacement of damaged jumps from Bus to Bus Isolator of 220kV Bus Section
KANDALGAON - PIRANGUT	IntraState	25/09/2022	14:25	25/09/2022	16:45	PO	1)Replacement of polymer insulators by longrod porcelain, loc no-32,33,34 2) Replacement of all nut bolt at loc no -33
KHARGHAR - BORIVALI CKT - 2	IntraState	25/09/2022	20:36	26/09/2022	09:18	PO	Outage required for safety purpose To carry out the work of making LILO arrangement at Loc no. 40 of 220KV Kalwa-TFIPL Line as both lines are on same M/C tower.
KALWA - TFIPL	IntraState	25/09/2022	20:54	26/09/2022	10:31	PO	For removing of bunching arrangement at Loc no.45 and connecting jumpers at Loc no.45 to newly proposed 220/22KV GIS S/stn at Pawane Mahape.
KHARGHAR - NET MAGIC GIS	IntraState	26/09/2022	04:03	26/09/2022	09:20	PO	Outage required for safety purpose To carry out the work of making LILO arrangement at Loc no. 40 of 220KV Kalwa-TFIPL Line as both lines are on same M/C tower.
EKLAHARE (OCR) - PADGHE	IntraState	26/09/2022	07:44			HT	for load management on Nashik BBLR
KARAD - VITA CKT- 1	IntraState	26/09/2022	09:10	26/09/2022	16:11	PO	Insulator string replacement work at STN LILO Loc No. 27 R, 65 R, 76 B. SSN LILO Loc No.44 Y, 62 B, 64 B LILO Loc No.01 T replacement
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	26/09/2022	09:59	26/09/2022	21:04	HT	For Load management
PEDAMBE-KALAMBANI(TSS)	IntraState	26/09/2022	10:50	26/09/2022	12:40	PO	Bypassed Y phase LA replacement of 220KV Pedhambe line Bay at Kalambani TSS end & Maintenance work.
PARGAON(KATHAPUR)- LONIKAND	IntraState	26/09/2022	11:55	26/09/2022	16:55	PO	Sf6 gas leakage attending work in CB
KANDALGAON - PIRANGUT	IntraState	26/09/2022	13:13	26/09/2022	19:39	EO	Dismantling of hanging conductor piece from double conductor by restringing new conductor at Loc.No.01 to gantry near kgaon SS.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 26/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - CARNAC - 7	IntraState	26/09/2022	20:30	26/09/2022	21:45	EO	For Test Charging of 220 KV NEW SIEMENS make breaker of Trombay Carnac-7 line after replacement at Trombay generating station.
BUS SECTION-6 @ TROMBAY	IntraState	26/09/2022	23:10		Continued.	EO	for connecting Trombay Carnac -7 Main bus isolator jumper after breaker replacement work.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	26/09/2022	23:15		Continued.	T	TRIPPED ON DISTANCE PROTECTION.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/33KV 50MVA PTR 1 @ VITA	IntraState	25/09/2022	10:35	25/09/2022	14:35	PO	OLTC Overhauling Work
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	25/09/2022	14:19	25/09/2022	15:17	T	Tripped from both HV & LV Side with WTI flag.
220/132KV 100MVA PTR 2 @ KHAREPATAN	IntraState	26/09/2022	08:10	26/09/2022	09:26	T	Tripped on PRV. Charged with PRV disconnected.
220/33 KV 50 MVA PTR NO 1 @ BHIGWAN	IntraState	26/09/2022	10:05	26/09/2022	19:15	PO	Oil leakage attending work.
220/33 KV 50 MVA CGL PTR 1 @ MUDSHINGI	IntraState	26/09/2022	10:34	26/09/2022	16:42	PO	HV Breaker Overhauling work in presence of M/S Siemens engineer,
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage