

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Oct/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	72.162	2772.783	1) Gujrat	0.079	268.436
2) Hydro	6.548	182.622	2) Madhya Pradesh	1.716	204.660
3) Gas	6.337	237.887	3) Chattisgarh	6.740	98.110
Total MSPGCL	85.047	3193.292	4) Maharashtra	114.375	3197.042
B) 1) APML	56.830	1011.754	5) Goa (Amona)	-0.418	-12.386
2) JSWEL	21.634	498.783	Total	122.492	3755.862
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.864	781.171
4) RPL(AMT)	15.084	520.078	b) Mumbai Drawl	33.067	866.541
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	19.384	558.429
6) Other IPP	9.607	215.786	Include PX	0.032	82.917
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.864	781.171
C) 1) TPCL Thermal	12.772	326.327	Include PX	5.442	272.365
2) TPCL Hydro	4.335	98.462	Standby	0.000	0.000
3) TPCL Gas	4.364	94.282	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.819	159.972	1) MSEDCL	306.675	8677.256
D) STATE			2) Mumbai Discoms	59.358	1545.581
1) Thermal	192.908	5505.483	TOTAL STATE	366.033	10222.837
(A1+C1+C4+(B1-B6))					
2) Hydro	10.883	281.084			
(A2+C2)					
3) Gas	10.701	332.169			
(A3+B7+C3)					
4) Wind	26.192	218.072			
6) SOLAR	2.856	130.170			
TOTAL STATE	243.540	6466.978			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	3151	3063	3539	2727
MSPGCL Hydro	361	222	406	151
MSPGCL Gas	9	341	391	430
MSPGCL Total Generation	3521	3626	4336	3308
Central Sector Receipt	5817	5693	5462	4241
WIND	1118	1030	1177	871
CPP / IPP Thermal	4825	4395	5103	3790
CPP / IPP Gas	0	0	0	0
SOLAR	348	32	9	0
Exchange with Mumbai	-1404	-1541	-1560	-876
MSEDCL DEMAND MET	14225	13235	14527	11334
Load Shedding	0	0	0	0
MSEDCL DEMAND	14225	13235	14527	11334
TPCL GENERATION	1130	1077	1121	689
AEML GENERATION	251	191	191	191
MUMBAI DEMAND	2785	2809	2872	1756
STATE DEMAND MET	17010	16044	17399	13090
STATE DEMAND	17010	16044	17399	13090
Frequency (Hz)	50.01	50.05	50.06	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 17.03 Hrs	49.78 Hz at 06.41 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 25/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	69.41	0	0
Unit 9	10.28	225.06	520	260
Unit 10	8.84	250.42	411	330
Total	19.12	544.88		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.20	208.95	460	355
Unit 5	9.28	133.95	465	350
Total	18.48	342.90		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	41.35	0	0
Unit 7	0.00	109.68	0	0
Unit 8	0.00	71.04	0	0
Total	0.00	222.07		
Chandrapur				
Unit 3	0.19	78.77	187	0
Unit 4	3.91	90.86	170	159
Unit 5	0.41	196.93	370	0
Unit 6	0.40	204.59	359	0
Unit 7	0.00	0.00	0	0
Unit 8	8.11	222.89	460	250
Unit 9	8.07	217.04	455	245
Total	21.08	1011.07		
Paras				
Unit 3	0.00	88.52	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	88.52		
Khaparkheda				
Unit 1	0.00	30.23	0	0
Unit 2	0.00	35.13	0	0
Unit 3	0.00	44.89	0	0
Unit 4	0.00	63.23	0	0
Unit 5	9.64	241.37	500	360
Total	9.64	414.85		
Nasik				
Unit 3	0.00	24.52	0	0
Unit 4	0.00	31.55	0	0
Unit 5	3.85	92.41	183	142
Total	3.85	148.48		
Uran				
All Units	6.34	237.89	457	0
Total	6.34	237.89		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.91	16.76	53	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.91	16.76		
Koyna				
Stage 1-2	2.25	74.76	355	40
Stage 4	0.00	43.69	0	0
Stage 3	0.60	29.09	132	0
Total	2.85	147.54		
Hydro				
KDPH	0.89	8.90	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.94	5.66	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.38	7.34	80	0
RNGR+BHTSA	0.35	0.39	15	14
BHANDARDRA	0.22	1.93	15	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.92	7.09	39	37
GHATGHAR	0.00	3.77	0	0
Total	3.70	35.08		
Wind				
Total	26.19	218.07	0	0
Total	26.19	218.07		
CPP				
APML(Mus)	56.83	1011.75	0	0
JSWEL(Mus)	21.63	498.78	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	15.08	520.08	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	9.61	215.79	0	0
Total	103.16	2246.40		
SOLAR				
Total	2.86	130.17	0	0
Total	2.86	130.17		
Tata				
Trombay 5	8.00	206.64	464	298
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	58.72	117	115
Trombay 7B	1.58	35.56	67	65
Trombay 8	4.78	119.69	203	195
TATA Hydro	4.34	98.46	426	0
Total	21.47	519.07		
AEML				
DTPS U-1&2	4.82	159.97	251	190
Total	4.82	159.97		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	72.16	2772.78	MSPGCL Total	85.05	3193.29
			MSPGCL Thml+Gas	78.50	3010.67	Koyna 1,2 & 4 Total	2.25	118.45
			MSPGCL Hydro	6.55	182.62	State Total	243.54	6466.98

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3633	146	429	4208	577	4019	0	0	4392	4148	-1154	11798	0	11798	2080	13878	49.99
2	2769	376	427	3572	622	4038	0	0	4196	4265	-999	11498	0	11498	1925	13424	49.98
3	2708	166	429	3303	798	3838	0	0	4715	4397	-943	11393	0	11393	1825	13218	50.01
4	2727	151	430	3308	871	3790	0	0	4400	4241	-876	11334	0	11334	1756	13090	50.01
5	2810	146	457	3413	882	3777	0	0	4253	4387	-868	11591	0	11591	1747	13338	50.00
6	2880	461	242	3583	983	4008	0	0	4657	4951	-938	12587	0	12587	1831	14418	50.00
7	3198	415	0	3613	966	4601	0	12	5093	4886	-985	13093	0	13093	1934	15027	49.93
8	3259	459	0	3718	1039	4734	0	108	5214	5307	-985	13921	0	13921	2159	16080	49.94
9	3159	364	0	3523	1098	4848	0	210	5460	5622	-1214	14087	0	14087	2481	16568	50.03
10	3151	361	9	3521	1118	4825	0	348	5805	5817	-1404	14225	0	14225	2785	17010	50.01
11	3086	335	24	3445	1136	4714	0	379	6101	5764	-1788	13650	0	13650	3157	16807	50.01
12	2766	309	66	3141	1013	4377	0	372	6135	6180	-1876	13207	0	13207	3051	16258	49.94
13	2646	301	132	3079	1041	4284	0	363	6090	5981	-1894	12854	0	12854	3030	15884	50.02
14	2778	209	193	3180	1036	3936	0	361	5824	5722	-1744	12491	0	12491	2880	15371	50.04
15	2908	203	221	3332	1177	3843	0	266	5677	5539	-1727	12430	0	12430	2865	15295	49.99
16	2952	199	277	3428	967	3842	0	253	5528	5660	-1684	12466	0	12466	2865	15331	50.00
17	2974	193	333	3500	970	3960	0	143	5397	5504	-1587	12490	0	12490	2846	15336	50.03
18	3063	222	341	3626	1030	4395	0	32	5424	5693	-1541	13235	0	13235	2809	16044	50.05
19	3539	406	391	4336	1177	5103	0	9	5517	5462	-1560	14527	0	14527	2872	17399	50.06
20	3189	325	386	3900	1406	5078	0	0	5550	5413	-1564	14233	0	14233	2753	16986	50.02
21	3004	194	385	3583	1640	4745	0	0	5295	4905	-1496	13377	0	13377	2612	15989	50.01
22	2979	189	394	3562	1543	4454	0	0	4520	4517	-1474	12602	0	12602	2536	15138	50.04
23	2977	219	386	3582	1529	4029	0	0	4173	4483	-1419	12204	0	12204	2344	14548	50.04
24	3007	199	385	3591	1573	3917	0	0	4284	3648	-1347	11382	0	11382	2214	13596	50.07
MUs	72.16	6.55	6.34	85.05	26.19	103.16	0.00	2.86	123.70	122.49	-33.07	306.68	0.00	306.68	59.36	366.03	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 25/Oct/2019

Position as on 6.30 Hrs of 26/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn on shaft seal water leakage. Converted to AOH from 1 Nov 2019.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyna Unit 10	80	05/08/2019	20.05	26/10/2019	10.10	Stator Earth Fault	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL.	
AEML	AEML Unit 2	250	07/10/2019	21.18		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)	
IPP	Adani U-2	660	21/10/2019	22.58	25/10/2019	16.05	APH Hot PA Bellow Leakage	
MSPGCL	Khaparkheda Unit 4	210	22/10/2019	23.52		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Parli Unit 6	250	23/10/2019	03.30		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Oct/2019

Position as on 6.30 Hrs of 26/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	23/10/2019	12.46	25/10/2019	04.14	Compress Bearing vibration high.	
MSPGCL	Parli Unit 7	250	23/10/2019	17.00		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit-8	660	24/10/2019	05.27		Continued.	Rotary Air Preheater Trip.	
MSPGCL	Chandrapur Unit 5	500	25/10/2019	01.03		Continued.	Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).	
MSPGCL	Chandrapur Unit 3	210	25/10/2019	01.03		Continued.	Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).	
MSPGCL	Chandrapur Unit 6	500	25/10/2019	01.03	25/10/2019	23.00	Bus-1 LBB Operation.	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 5	108	25/10/2019	05.30		Continued.	Gas Skid Failure	
MSPGCL	Uran Unit 6	108	25/10/2019	05.30	25/10/2019	09.53	Gas Skid Failure	
MSPGCL	Uran Unit 8	108	25/10/2019	05.30	25/10/2019	15.43	Gas Skid Failure	
MSPGCL	Uran Unit B0	120	25/10/2019	05.30	25/10/2019	14.38	Gas Skid Failure.	
MSPGCL	Uran Unit 7	108	25/10/2019	05.30	25/10/2019	11.34	Gas Skid Failure.	
MSPGCL	Uran Unit A0	120	25/10/2019	05.30	25/10/2019	12.15	Gas Skid Failure.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Chandrapur Unit 6	500	25/10/2019	23.11	26/10/2019	01.15	Turbine Tripped	
IPP	RPL(AMT) U-5	270	26/10/2019	00.30		Continued.	Zero Schedule	
IPP	RPL(AMT) U-4	270	26/10/2019	08.00		Continued.	Zero Schedule	
MSPGCL	Chandrapur Unit 6	500	26/10/2019	21.52		Continued.	Zero Schedule	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 26/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 1	IntraState	25/10/2019	01.03	25/10/2019	4.12	T	LBB operated
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	19/10/2019	23.13		Continued.	HT	Over Voltage
Dhule Khandwa I	InterState	21/10/2019	22.06		Continued.	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	24/10/2019	23.54	26/10/2019	13.02	T	Over Voltage
Chandrapur Bhadravati II	InterState	25/10/2019	01.03	25/10/2019	08.36	T	Bus-1 LBB Operated.
Chandrapur Bhadravati III	InterState	25/10/2019	01.03	25/10/2019	08.43	T	Bus-1 LBB Operated.
Jaigad-Karad Ckt-I	IntraState	19/10/2019	03.20		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	19/10/2019	19.15	26/10/2019	10.02	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	24/10/2019	23.34	25/10/2019	12.16	HT	Over Voltage
Chandrapur - Khaperkheda	IntraState	25/10/2019	01.03	25/10/2019	07.13	T	Bus-1 LBB Operated.
Bus Coupler @ Chandrapur	IntraState	25/10/2019	01.03	25/10/2019	02.55	T	Bus-1 LBB Operated.
Chandrapur II - Chandrapur ckt 2	IntraState	25/10/2019	01.03	25/10/2019	07.24	T	Tripped With Bus -1 LBB Operated.
Main Bus I @ Chandrapur Sw	IntraState	25/10/2019	01.03	25/10/2019	2.55	T	On LBB Operated.
Chandrapur-II - Nanded ckt II	IntraState	25/10/2019	03.15		Continued.	T	Over Voltage
TBC @ Babhaleshwar	IntraState	25/10/2019	12.40	25/10/2019	13.47	EO	Attending Hot Spot On Line Work By Hot Line.
Lonikand I - Koyna stage-IV	IntraState	25/10/2019	23.04	26/10/2019	09.39	HT	Over Voltage
Chandrapur - Parli	IntraState	26/10/2019	05.58		Continued.	T	Distance Protection (RFC from 26.10.2019 23:14Hrs).
Khadka- Deepnagar Ckt 2	IntraState	26/10/2019	10.10	26/10/2019	14.38	EO	Testing of Y Phase CVT
Khadka-Aurangabad (Waluj)	IntraState	26/10/2019	14.55		Continued.	HT	Over Voltage
karad -kolhapur-II	IntraState	26/10/2019	22.52		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	26/10/2019	23.01		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220/33 kv 315 MVA ICT-I @Chandrapur GCR	IntraState	25/10/2019	01.03	25/10/2019	03.05	T	Bus-1 LBB Operated.
400/11.5 kv 90MVA STN T/F-IV @ Chandrapur	IntraState	25/10/2019	01.03	25/10/2019	09.48	T	Tripped With Bus-1 LBB Operated.Taken In Service.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	25/10/2019	06.44	25/10/2019	09.52	PO	Investigation Of Bucolz tripping/maloperation.
400/11.5 kv 90MVA STN T/F-IV @ Chandrapur	IntraState	25/10/2019	10.04	25/10/2019	18.55	PO	Generation End Breaker Tripped Due To Relay Problem.Charged Trough TBC.
400/220 kv 500 MVA ICT III @ Jejuri	IntraState	26/10/2019	09.53	26/10/2019	14.31	PO	Annual Maintenance Work
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Borivali - Tarapur	InterState	25/10/2019	04.19	25/10/2019	13.46	T	Distance Protection
Tillari Amona	InterState	25/10/2019	09.01	25/10/2019	09.28	T	Tripped At Amona End Only.
Mahalakshmi Amona	InterState	25/10/2019	09.01	25/10/2019	09.27	T	Tripped At Amona End Only.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 26/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Lonand-Baramati	IntraState	17/09/2019	11.13		Continued.	HT	To Control Overloading of Lonand-Jejuri Line.
Trombay Dharavi 9	IntraState	23/10/2019	08.50		Continued.	PO	Erection Of Tower LoC.I No.23
Chandrapur GCR - Sicom I	IntraState	25/10/2019	01.03	25/10/2019	01.33	T	Due To LTS Operation.
Chandrapur GCR - Sicom II	IntraState	25/10/2019	01.03	25/10/2019	01.44	T	Due To LTS Operation.
Bus section @ Kalwa	IntraState	25/10/2019	06.44	25/10/2019	10.08	PO	Due To Outage On ICT.
Butibori - Purti	IntraState	25/10/2019	09.20	25/10/2019	14.54	PO	STN To DTN Conversion At Loc 198 & SSN To DSN Conversion at 200
Dahanu Versova	IntraState	25/10/2019	09.33	25/10/2019	16.20	T	Distance Protection
Trombay - Mulund	IntraState	25/10/2019	10.04	25/10/2019	18.55	PO	Line Isolator Alignment Work.
Butibori - VIPL Ckt I	IntraState	25/10/2019	12.01	25/10/2019	18.09	PO	Testing Work
Bableshwar Ahamadnagar-Ii	IntraState	25/10/2019	14.12	25/10/2019	18.40	PO	Flash Over Disc Replacement.
Trombay - Kalwa	IntraState	25/10/2019	20.18		Continued.	PO	Piling work at Loc.No.22A
Parli(U-VIII) GCR CKT	IntraState	26/10/2019	02.25	26/10/2019	15.45	T	Distance Protection
Satana-Gangapur	IntraState	26/10/2019	06.55		Continued.	T	Distance Protection
Nanded - Parli Ext. Ckt II	IntraState	26/10/2019	07.02	26/10/2019	07.20	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 kV 200 MVA ICT II @Padghe	IntraState	25/10/2019	08.26	25/10/2019	17.33	PO	U Bolt Replacement Work.
220/22 Kv 50 Mva Areva Ptr 2 @Anandnagar	IntraState	25/10/2019	10.45	25/10/2019	11.50	EO	Hot Spot LV CT.
220/100 Kv 200 MVA ICT I @Pal-Dombivali	IntraState	25/10/2019	11.24	25/10/2019	18.25	PO	Relay Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage