

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 25/Oct/2020 SUNDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	123.947	3310.395	1) Gujrat	1.152	42.181
2) Hydro	2.647	152.527	2) Madhya Pradesh	6.643	143.203
3) Gas	6.446	141.448	3) Chattisgarh	6.400	141.580
<b>Total MSPGCL</b>	<b>133.040</b>	<b>3604.370</b>	4) Maharashtra	99.369	2856.210
B) 1) APLM	57.465	1535.069	5) Goa (Amona)	-1.407	-34.590
2) JSWEL	21.123	585.518	<b>Total</b>	<b>112.157</b>	<b>3148.584</b>
3) VIPL	0.000	0.000	a) Mumbai Schedule	16.863	513.284
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	21.171	562.909
5) WPCL	6.585	153.893	c) MSEDCL Bilateral *	26.224	781.912
6) Other IPP	7.627	213.714	Include PX	0.163	60.064
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	16.863	511.706
C) 1) TPCL Thermal	12.476	294.698	Include PX	6.276	188.573
2) TPCL Hydro	3.185	115.689	Standby	0.000	1.578
3) TPCL Gas	4.378	107.430	<b>H) ENERGY CATERED (MUs)</b>		
4) AEML Thermal	8.777	248.829	1) MSEDCL	326.263	9044.369
D) STATE			2) Mumbai Discoms	49.987	1329.552
1) Thermal	238.000	6342.116	<b>TOTAL STATE</b>	<b>376.250</b>	<b>10373.921</b>
(A1+C1+C4+(B1-B6))					
2) Hydro	5.832	268.216			
(A2+C2)					
3) Gas	10.824	248.878			
(A3+B7+C3)					
4) Wind	4.276	236.448			
6) SOLAR	5.161	129.682			
<b>TOTAL STATE</b>	<b>264.093</b>	<b>7225.340</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6071	4480	5351	4561
MSPGCL Hydro	127	87	71	56
MSPGCL Gas	270	267	270	281
MSPGCL Total Generation	6468	4834	5692	4898
Central Sector Receipt	4584	5063	4776	4456
WIND	169	158	149	130
CPP / IPP Thermal	4385	3683	3936	3664
CPP / IPP Gas	0	0	0	0
SOLAR	325	785	0	0
Exchange with Mumbai	-1002	-1222	-859	-910
<b>MSEDCL DEMAND MET</b>	<b>14929</b>	<b>13301</b>	<b>13694</b>	<b>12238</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	14929	13301	13694	12238
TPCL GENERATION	619	619	1013	890
AEML GENERATION	283	282	393	492
<b>MUMBAI DEMAND</b>	<b>1904</b>	<b>2123</b>	<b>2265</b>	<b>2292</b>
STATE DEMAND MET	16833	15424	15959	14530
<b>STATE DEMAND</b>	<b>16833</b>	<b>15424</b>	<b>15959</b>	<b>14530</b>
Frequency (Hz)	50.03	50.02	50.01	50.01

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 22.00 Hrs	49.85 Hz at 20.19 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation, Maximum, Minimum for 25/Oct/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.84	231.60	527	370
Unit 9	9.78	194.17	540	360
Unit 10	8.83	206.60	381	360
<b>Total</b>	<b>28.45</b>	<b>632.37</b>		
<b>Bhusawal</b>				
Unit 3	0.00	0.00	0	0
Unit 4	7.90	241.64	500	280
Unit 5	7.82	240.78	490	280
<b>Total</b>	<b>15.72</b>	<b>482.42</b>		
<b>Parli</b>				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.35	90.07	190	173
Unit 7	0.00	77.44	0	0
Unit 8	4.76	100.59	250	177
<b>Total</b>	<b>9.12</b>	<b>268.10</b>		
<b>Chandrapur</b>				
Unit 3	3.27	31.64	163	115
Unit 4	3.15	75.99	150	117
Unit 5	8.35	234.86	425	275
Unit 6	8.28	217.24	421	278
Unit 7	0.00	0.00	0	0
Unit 8	9.71	258.02	465	280
Unit 9	9.80	255.59	468	280
<b>Total</b>	<b>42.57</b>	<b>1073.34</b>		
<b>Paras</b>				
Unit 3	5.11	117.25	245	170
Unit 4	5.62	127.62	251	188
<b>Total</b>	<b>10.72</b>	<b>244.87</b>		
<b>Khaparkheda</b>				
Unit 1	3.39	84.05	155	130
Unit 2	3.54	96.86	180	140
Unit 3	3.58	90.68	180	140
Unit 4	3.55	97.86	180	140
Unit 5	0.12	204.85	86	0
<b>Total</b>	<b>14.17</b>	<b>574.31</b>		
<b>Nasik</b>				
Unit 3	0.00	0.00	0	0
Unit 4	3.20	34.98	151	127
Unit 5	0.00	0.00	0	0
<b>Total</b>	<b>3.20</b>	<b>34.98</b>		
<b>Uran</b>				
All Units	6.45	141.45	281	251
<b>Total</b>	<b>6.45</b>	<b>141.45</b>		
<b>PGPL</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.08	15.53	40	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Total</b>	<b>0.08</b>	<b>15.53</b>		
<b>Koyna</b>				
Stage 1-2	1.86	60.97	270	45
Stage 4	0.00	24.78	0	0
Stage 3	0.43	21.27	160	0
<b>Total</b>	<b>2.30</b>	<b>107.02</b>		
<b>Hydro</b>				
KDPH	0.00	5.06	0	0
VTRNA	0.00	0.49	0	0
TILLARI	0.00	4.42	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.31	8.22	40	0
RNGR+BHTSA	0.00	4.24	0	0
BHANDARDRA	0.00	1.30	0	0
ELDARY	0.00	11.22	0	0
SMLHY_PTN	0.04	4.76	2	1
GHATGHAR	0.00	5.79	0	0
<b>Total</b>	<b>0.35</b>	<b>45.50</b>		
<b>Wind</b>				
Total	4.28	236.45	0	0
<b>Total</b>	<b>4.28</b>	<b>236.45</b>		
<b>CPP</b>				
APML(Mus)	57.46	1535.07	0	0
JSWEL(Mus)	21.12	585.52	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	6.58	153.89	0	0
Other(Mus)	7.63	213.71	0	0
<b>Total</b>	<b>92.80</b>	<b>2488.19</b>		
<b>SOLAR</b>				
Total	5.16	129.68	0	0
<b>Total</b>	<b>5.16</b>	<b>129.68</b>		
<b>Tata</b>				
Trombay 5	8.30	229.56	444	284
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	69.62	118	116
Trombay 7B	1.57	37.82	66	64
Trombay 8	4.18	65.14	225	138
TATA Hydro	3.18	115.69	357	3
<b>Total</b>	<b>20.04</b>	<b>517.82</b>		
<b>AEML</b>				
DTPS U-1&2	8.78	248.83	500	281
<b>Total</b>	<b>8.78</b>	<b>248.83</b>		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	123.95	3310.40	MSPGCL Total	133.04	3604.37
			MSPGCL Thml+Gas	130.39	3451.84	Koyna 1,2 & 4 Total	1.86	85.75
			MSPGCL Hydro	2.65	152.53	State Total	264.09	7225.34

# State Load Despatch Center, Airoli (MSETCL)

# Annexure-2

## Hourly Load Data As on 25/Oct/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5813	57	251	6121	172	4018	0	0	4627	4195	-636	13870	0	13870	2279	16149	50.02
2	5191	47	280	5518	213	3759	0	0	4541	4545	-426	13609	0	13609	2101	15710	50.00
3	5058	57	271	5386	192	3713	0	0	4468	4274	-286	13279	0	13279	1988	15267	50.00
4	4858	47	280	5185	146	3737	0	0	4399	4510	-219	13359	0	13359	1903	15262	49.99
5	5193	47	270	5510	185	3785	0	0	4384	4325	-163	13642	0	13642	1852	15494	49.97
6	5737	299	271	6307	169	3953	0	0	4334	4612	-258	14783	0	14783	1869	16652	50.00
7	6109	212	271	6592	161	4494	0	8	4459	4441	-458	15238	0	15238	1865	17103	50.00
8	6089	168	281	6538	202	4561	0	131	4835	4944	-793	15583	0	15583	1849	17432	49.98
9	6071	127	270	6468	169	4385	0	325	4897	4584	-1002	14929	0	14929	1904	16833	50.03
10	5771	91	279	6141	189	4016	0	543	5025	4820	-1114	14595	0	14595	2021	16616	50.02
11	5024	52	259	5335	209	3813	0	697	5373	5116	-1189	13981	0	13981	2091	16072	49.99
12	4537	54	258	4849	211	3805	0	756	5282	5213	-1210	13624	0	13624	2113	15737	50.02
13	4480	87	267	4834	158	3683	0	785	5238	5063	-1222	13301	0	13301	2123	15424	50.02
14	4506	97	257	4860	140	3394	0	716	5135	5083	-1207	12986	0	12986	2102	15088	50.00
15	4551	312	267	5130	134	3245	0	583	4870	5265	-1223	13134	0	13134	2116	15250	49.99
16	4847	217	257	5321	147	3527	0	384	4683	4744	-1219	12904	0	12904	2109	15013	50.00
17	4936	92	258	5286	266	3813	0	187	4700	4574	-1173	12953	0	12953	2073	15026	49.96
18	5118	87	268	5473	259	3916	0	46	4481	4178	-1043	12829	0	12829	2054	14883	49.95
19	5308	92	269	5669	213	3922	0	0	4727	4456	-920	13340	0	13340	2209	15549	50.04
20	5351	71	270	5692	149	3936	0	0	4642	4776	-859	13694	0	13694	2265	15959	50.01
21	4962	171	259	5392	112	3946	0	0	4608	4628	-1155	12923	0	12923	2274	15197	49.93
22	5099	61	280	5440	172	3918	0	0	4720	4653	-1219	12964	0	12964	2268	15232	50.02
23	4777	46	272	5095	178	3797	0	0	4742	4702	-1267	12505	0	12505	2267	14772	50.03
24	4561	56	281	4898	130	3664	0	0	4813	4456	-910	12238	0	12238	2292	14530	50.01
<b>MUs</b>	<b>123.95</b>	<b>2.65</b>	<b>6.45</b>	<b>133.04</b>	<b>4.28</b>	<b>92.80</b>	<b>0.00</b>	<b>5.16</b>	<b>113.98</b>	<b>112.16</b>	<b>-21.17</b>	<b>326.26</b>	<b>0.00</b>	<b>326.26</b>	<b>49.99</b>	<b>376.25</b>	<b>50.00</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 25/Oct/2020**

Position as on 6.30 Hrs of 26/Oct/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>FORCED OUTAGE</b>								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Ghatghar Unit-1	125	30/09/2020	18.05		Continued.	Turbine Guide Bearing problem	
MSPGCL	Khaparkheda Unit 5	500	21/10/2020	13.52	25/10/2020	22.36	Boiler Tube Leakage	
MSPGCL	Parli Unit 7	250	22/10/2020	20.00		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Paras Unit 4	250	26/10/2020	06.27		Continued.	Electrical protection.	
MSPGCL	Khaparkheda Unit 5	500	26/10/2020	07.52		Continued.	Boiler Tube Leakage	

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 25/Oct/2020**

**Statement-VII**

Position as on 6.30 Hrs of 26/Oct/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>500 KV LINE Outages/Trippings</b>							
Chandrapur - Padghe Hvdc Pole 2	IntraState	19/10/2020	23.01		Continued.	PO	Abnormal sound from main tank of smoothing reactor.
<b>400 KV LINE Outages/Trippings</b>							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	23/10/2020	12.05	26/10/2020	10.00	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	26/10/2020	10.53		Continued.	PO	Replacement of Damage Earth wire.26/Oct/2020 (RFC 17.22)
Kudus-Padgha (PG) Ckt II	InterState	26/10/2020	14.58	26/10/2020	19.18	EO	Attending Hot Spot
Kolhapur(M)-Kolhapur(GIS) cktII	InterState	26/10/2020	20.45		Continued.	EO	Y Phase Isolator Replacement
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Akola II - RPL(Rattanindia) Ckt I	IntraState	23/10/2020	01.52	26/10/2020	09.17	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	24/10/2020	21.01	26/10/2020	07.26	HT	Over Voltage
Dhule - Bableshtar - II	IntraState	24/10/2020	21.05	26/10/2020	08.51	HT	Over Voltage
Kharghar-Talegaon(PG)	IntraState	25/10/2020	00.37	25/10/2020	06.36	PO	For replacement of 3 Nos of Twin 400kV CT Jumper's which were damaged in occurrence on dtd 12.10.2020.
Lonikand I - Koyna stage-IV	IntraState	25/10/2020	01.20	25/10/2020	09.12	HT	Over Voltage
Chandrapur-II - Nanded ckt I	IntraState	25/10/2020	11.03	25/10/2020	Continued.	PO	Replacement of faulty insulator string at loc no.305.
karad -kolhapur-II	IntraState	25/10/2020	21.56	26/10/2020	07.57	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	25/10/2020	23.11	26/10/2020	09.28	HT	Over Voltage
Kalwa - Kharghar	IntraState	25/10/2020	23.15	26/10/2020	06.31	HT	Jumper Replacement Work.
Padghe - Kalwa - I	IntraState	26/10/2020	03.53	26/10/2020	06.41	T	Over Voltage
N.Koyna-Karad -Ckt I	IntraState	26/10/2020	08.44	26/10/2020	16.31	PO	Relay testing work & PID Faulty Insulator replacement work.
Chandrapur-II - Nanded ckt I	IntraState	26/10/2020	08.55	26/10/2020	15.06	EO	CB Maintenance Work at Chandrapur End.
Bhusawal-Aurangabad	IntraState	26/10/2020	20.16		Continued.	HT	Over Voltage
Dhule - Bableshtar - II	IntraState	26/10/2020	22.26		Continued.	HT	Over Voltage
<b>400 KV ICT Outages/Trippings</b>							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33kv, 500 MVA ICT-I @Khaparkheda	IntraState	26/10/2020	01.29	26/10/2020	05.30	T	Differential protection due to bursting of R-phase CT Tie-bay 403.
<b>220 KV LINE Outages/Trippings</b>							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Tillari Amona	InterState	26/10/2020	06.45	26/10/2020	10.30	EO	Emergency Outage at Goa end.
Mahalakshmi Amona	InterState	26/10/2020	06.55	26/10/2020	10.11	EO	Emergency Outage at Goa end.
Mahalakshmi Amona	InterState	26/10/2020	22.37	26/10/2020	23.24	T	Distance Protection
Kharghar-Borivali ckt II	IntraState	11/08/2020	01.45		Continued.	T	Special Repair Cable work.
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 25/Oct/2020**

**Statement-VII**

Position as on 6.30 Hrs of 26/Oct/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Lonikand1 (400 Kv)-Theur II	IntraState	06/10/2020	08.54		Continued.	PO	HTLS Stringing work
Jejuri (400 Kv)- Baramati li	IntraState	25/10/2020	05.45	25/10/2020	07.06	T	PDR operated at Jejuri end.
Lamboti(solapur)-Karkamb	IntraState	25/10/2020	10.08	26/10/2020	09.19	T	Distance Protection
Vankuswadi- Ajinkyatara	IntraState	25/10/2020	11.05	25/10/2020	16.05	EO	CB Maintenance Work.
Kandalgaon - Bhira	IntraState	25/10/2020	20.50	26/10/2020	05.20	T	Distance Protection
Alkud Miraj	IntraState	26/10/2020	10.10	26/10/2020	14.25	PO	Quarterly Maintenance Work and to Attending Hot Spot at B PH CT.
Karad(400kv) - Ogalewadi Ckt 1	IntraState	26/10/2020	10.11	26/10/2020	16.11	PO	CB Timing, CRM & Quarterly Bay Maintenance Work.
Eklahara(Gcr)(Nasik)- Bableshwar-I	IntraState	26/10/2020	15.17	26/10/2020	16.02	T	Distance Protection
Eklahare (Gcr)(Nashik) - Airoli Know Park	IntraState	26/10/2020	15.26	26/10/2020	16.21	HT	For Load Management.
<b>220 KV ICT Outages/Trippings</b>							
220/100 Kv 100 MVA ICT I @Vasai-II	IntraState	26/10/2020	08.50	26/10/2020	22.50	PO	Attending Oil Leakage
220/66 Kv 150 Mva Emco Ict 2 @Gadchandur	IntraState	26/10/2020	10.15		Continued.	PO	Overhauling of OLTC. Diagnostic Testing & TNC Replacement Switch Work.
220/132 Kv 100 Mva Gec Ict 1 @Pusad	IntraState	26/10/2020	13.50	26/10/2020	20.35	PO	Attending Oil Leakage
220/132 Kv 200 Mva Cgl Ptr No 5 @Parvati	IntraState	26/10/2020	14.35	26/10/2020	16.22	PO	LV Breaker CRM, Timing Test.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage