

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Nov/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.278	3544.727	1) Gujrat	-8.174	-209.391
2) Hydro	7.271	212.192	2) Madhya Pradesh	0.206	-36.651
3) Gas	5.610	63.693	3) Chattisgarh	6.260	155.420
Total MSPGCL	164.159	3820.612	4) Maharashtra	165.059	4219.925
B) 1) APLM	73.776	1662.172	5) Goa (Amona)	-1.198	-34.417
2) JSWEL	11.584	306.464	Total	162.153	4094.886
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.875	772.298
4) RPL(AMT)	31.141	675.004	b) Mumbai Drawl	35.887	887.800
5) SWPGPL	7.910	185.917	c) MSEDCL Bilateral *	61.741	1722.125
6) Other IPP	43.394	874.770	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.875	772.295
C) 1) TPCL Thermal	10.667	269.459	Include PX	0.000	0.000
2) TPCL Hydro	3.890	87.712	Standby	0.000	0.002
3) TPCL Gas	0.000	13.475	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.951	222.065	1) MSEDCL	467.371	11117.760
D) STATE			2) Mumbai Discoms	60.395	1480.511
1) Thermal	339.701	7740.578	3) Other Discoms	9.661	233.831
(A1+C1+C4+(B1-B6))			TOTAL STATE	537.427	12832.102
2) Hydro	11.161	299.904			
(A2+C2)					
3) Gas	5.610	77.168			
(A3+B7+C3)					
4) Wind	8.108	322.633			
6) SOLAR	10.694	296.933			
TOTAL STATE	375.274	8737.216			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6546	6262	7122	5505
MSPGCL Hydro	407	230	611	138
MSPGCL Gas	236	225	232	238
MSPGCL Total Generation	7189	6717	7965	5881
Central Sector Receipt	8353	8210	6512	5525
WIND	295	165	238	401
CPP / IPP Thermal	7100	7064	7268	6905
CPP / IPP Gas	0	0	0	0
SOLAR	1493	1654	0	0
Exchange with Mumbai	-1858	-1880	-1696	-1220
MSEDCL DEMAND MET	22129	21497	19847	17123
Load Shedding	0	0	0	0
MSEDCL DEMAND	22129	21497	19847	17123
TPCL GENERATION	683	689	771	478
AEML GENERATION	497	502	479	346
MUMBAI DEMAND	3038	3071	2946	2044
OTHER DISCOM DEMAND	443	433	440	369
STATE DEMAND MET	25610	25001	23233	19536
STATE DEMAND	25610	25001	23233	19536
Frequency (Hz)	50.00	49.98	50.03	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 06:02 Hrs	49.81 Hz at 06:44 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.84	112.66	215	150
Unit 7	0.00	0.00	0	0
Unit 8	13.61	320.50	605	502
Unit 9	12.95	318.82	619	418
Unit 10	12.95	176.07	569	415
Total	44.35	928.04		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.41	204.83	480	280
Unit 5	9.12	232.32	470	275
Total	18.53	437.14		
Parli				
Unit 6	4.03	100.00	232	143
Unit 7	4.14	94.36	230	143
Unit 8	3.54	85.44	156	129
Total	11.71	279.80		
Chandrapur				
Unit 3	3.54	79.38	174	125
Unit 4	3.04	72.53	138	117
Unit 5	6.93	161.52	310	260
Unit 6	6.77	134.45	295	265
Unit 7	7.53	180.56	325	289
Unit 8	9.70	238.69	487	280
Unit 9	9.38	186.25	482	277
Total	46.89	1053.37		
Paras				
Unit 3	5.39	123.72	244	211
Unit 4	5.12	68.82	230	197
Total	10.51	192.53		
Khaparkheda				
Unit 1	2.75	67.16	130	100
Unit 2	2.77	67.34	130	100
Unit 3	3.72	81.42	180	128
Unit 4	0.29	77.54	72	0
Unit 5	3.48	214.32	465	0
Total	13.02	507.79		
Nasik				
Unit 3	3.25	16.98	162	114
Unit 4	3.01	70.07	141	115
Unit 5	0.00	58.99	0	0
Total	6.26	146.04		
Uran				
All Units	5.61	63.69	240	224
Total	5.61	63.69		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	11.95	41	0
Total	0.12	11.95		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.06	59.21	460	40
Stage 4	1.79	50.34	745	0
Stage 3	0.67	24.14	160	0
Total	4.52	133.69		
Hydro				
KDPH	0.43	8.95	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	6.42	0	0
BHIRA T.R.	0.14	4.43	40	0
SMLHY_PTN	1.84	40.24	80	71
GHATGHAR	0.22	6.52	125	0
Total	2.63	66.55		
Wind				
Total	8.11	322.63	0	0
Total	8.11	322.63		
CPP				
APML(Mus)	73.78	1662.17	0	0
JSWEL(Mus)	11.58	306.46	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.14	675.00	0	0
SWPGPL-Mus	7.91	185.92	0	0
Other(Mus)	43.39	874.77	0	0
Total	167.80	3704.33		
SOLAR				
Total	10.69	296.93	0	0
Total	10.69	296.93		
Tata				
Trombay 5	7.21	182.75	382	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	7.77	0	0
Trombay 7B	0.00	5.71	0	0
TATA Hydro	3.89	87.71	360	30
Trombay 8	3.46	86.71	173	129
Total	14.56	370.65		
AEML				
DTPS U-1&2	9.95	222.06	502	305
Total	9.95	222.06		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	151.28	3544.73	MSPGCL Total	164.16	3820.61
			MSPGCL Thml+Gas	156.89	3608.42	Koyna 1,2 & 4 Total	3.85	109.55
			MSPGCL Hydro	7.27	212.19	State Total	375.27	8737.22

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 25/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5505	138	238	5881	401	6905	0	0	5501	5525	-1220	17123	0	17123	2044	369	19536	49.98
2	5602	137	240	5979	479	7045	0	0	5460	5481	-1118	17521	0	17521	1904	345	19770	50.01
3	5553	137	238	5928	506	6941	0	0	5617	5516	-1044	17535	0	17535	1807	312	19654	50.00
4	5510	137	238	5885	517	6900	0	0	5665	5571	-994	17555	0	17555	1752	324	19631	49.99
5	5657	272	240	6169	579	7046	0	0	5473	5992	-1004	18452	0	18452	1753	330	20535	50.04
6	6314	151	238	6703	536	7095	0	0	6234	6402	-1098	19281	0	19281	1873	357	21511	50.02
7	6530	366	240	7136	550	7095	0	15	6769	6658	-1198	19877	0	19877	2054	379	22310	49.94
8	6583	1341	239	8163	498	7107	0	247	6360	6541	-1357	20801	0	20801	2235	398	23434	49.97
9	6604	554	236	7394	411	7098	0	770	7238	7374	-1590	21028	0	21028	2538	429	23995	50.01
10	6457	503	237	7197	322	7089	0	1238	7460	7856	-1647	21645	0	21645	2832	410	24887	49.97
11	6546	407	236	7189	295	7100	0	1493	8094	8353	-1858	22129	0	22129	3038	443	25610	50.00
12	6392	228	232	6852	226	7100	0	1580	8342	8371	-1907	21800	0	21800	3095	422	25317	49.99
13	6262	230	225	6717	165	7064	0	1654	8086	8210	-1880	21497	0	21497	3071	433	25001	49.98
14	6657	157	224	7038	121	6980	0	1409	7643	7856	-1768	21225	0	21225	2954	411	24590	50.06
15	6773	137	226	7136	91	7026	0	1120	7984	8049	-1769	21226	0	21226	2990	427	24643	50.04
16	6757	140	225	7122	86	7001	0	812	8277	7803	-1716	20689	0	20689	3009	419	24117	50.00
17	6853	175	227	7255	99	7102	0	321	7833	7515	-1763	20110	0	20110	2926	419	23455	50.01
18	7033	358	230	7621	159	7201	0	35	6633	6669	-1769	19468	0	19468	2878	448	22794	50.01
19	7122	611	232	7965	238	7268	0	0	6358	6512	-1696	19847	0	19847	2946	440	23233	50.03
20	6805	236	233	7274	327	7047	0	0	6552	6232	-1621	18811	0	18811	2823	448	22082	50.04
21	6412	223	229	6864	399	6937	0	0	5824	5651	-1514	17898	0	17898	2679	439	21016	50.00
22	5881	149	235	6265	370	6586	0	0	5769	6080	-1462	17407	0	17407	2532	432	20371	50.00
23	5700	284	235	6219	378	6522	0	0	5785	5909	-1462	17133	0	17133	2392	433	19958	50.00
24	5770	200	237	6207	355	6550	0	0	5753	6027	-1432	17314	0	17314	2270	393	19977	49.99
MUs	151.28	7.27	5.61	164.16	8.11	167.81	0.00	10.69	160.71	162.15	-35.89	467.37	0.00	467.37	60.39	9.66	537.43	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Nov/2022

Position as on 6.30 Hrs of 26/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.	29/11/2022
MSPGCL	Koyana STG-IV Unit-3	250	19/11/2022	09:25	25/11/2022	17:20	Trunnion Seal repair work.	25/11/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20		Continued.	Boiler Tube Leakage	29/11/2022
MSPGCL	Khaparkheda Unit 5	500	23/11/2022	12:45	25/11/2022	12:42	WITHDRAWN DUE TO CLINKER FORMATION	29/11/2022
MSPGCL	Khaparkheda Unit 4	210	24/11/2022	00:01	25/11/2022	19:33	Boiler Tube Leakage	25/11/2022
TPC-G	Trombay 7B	60	24/11/2022	04:52		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	24/11/2022	05:13		Continued.	Gas shortage	
MSPGCL	Parli Unit 7	250	26/11/2022	14:52		Continued.	Boiler Tube Leakage	
IPP	IEPL Unit 1	270	26/11/2022	18:42		Continued.	EXCITATION PROBLEM.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	18/11/2022	00:36		Continued.	PO	For Pole 1 Scheduled Annual Outage and Pole1 Y Phase Converter Transformer replacement work.
CHANDRAPUR - PADGHE POLE 1 & 2	IntraState	25/11/2022	23:24		Continued.	PO	annual outage
CHANDRAPUR - PADGHE POLE 1 & 2	IntraState	26/11/2022	10:38		Continued.		to execute overhead stringing of 400kV Babhaleshwar Kudus (under construction) line between locn no G315 & G316.
400 KV TIEBAY Outages/Trippings							
TIE BAY (414) OF PADGHE PG CKT - 1 @ KUDUS	InterState	25/11/2022	11:24	25/11/2022	16:48	PO	AMP of 414 Bay
400 KV FUTURE BAY II @ WARORA	IntraState	25/11/2022	09:59	25/11/2022	13:22	PO	Routine maintenance, Relay Testing works and isolater maintenance work .
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
PADGHE - PADGHE HVDC CKT- 1	IntraState	18/11/2022	00:36		Continued.	PO	1) Bay Maint work 2) Diagnostic Testing work 3)A Bus :- PG Isolator replacement of 400kV HVDC-I Y&B-ph 4) Bhel CB Pole Overhauling work. If pole overhauling not completed within outage period line will be charge on TBC.
LONIKAND I - KOYNA STAGE-IV	IntraState	19/11/2022	18:23			EO	For shifting 400kV Lonikand-Stage IV line on 400kV TBC due to hotspot on 29 B Isolator B phase on hanger rod assembly
BUS - 2 @ NEW KOYNA	IntraState	21/11/2022	12:51			PO	1) 21/11/2022 to 22/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 23/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 3) 24/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 25/11/2022 Bus Insulator replacement work at section Koyna -I & II and damage conductor replacement work 5) 26/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 27/11/2022 to 28/11/2022 Bus Insulator replacement work at section Jaigad - I & II
KORADI - KHADKA	IntraState	24/11/2022	10:34	26/11/2022	20:40	PO	For CB Mechanism Overahuling work by agency
BABHALESHWAR - PADGHE CKT - 2	IntraState	24/11/2022	15:10		Continued.	EO	During Yard Inspection a leakage is observed on Bph Grading capacitor of 400 KV Padghe-II and it is requested to give permission for shifting of 400 KV BBLR-Padghe-II on 400 KV TBC to attend the same.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	25/11/2022	06:12	25/11/2022	18:24	PO	1) String Disc Replacement Work 2) Maintenance Work
JAIGAD - NEW KOYNA CKT - 2	IntraState	25/11/2022	08:57	25/11/2022	19:51	PO	Bus Insulator replacement work at section Jaigad - I & II
JAIGAD - NEW KOYNA CKT - 1	IntraState	25/11/2022	09:14	25/11/2022	17:55	PO	Bus Insulator replacement work at section Jaigad - I & II
BUS - 2 @ AKOLA 2	IntraState	25/11/2022	09:29	25/11/2022	18:18	PO	Annual Maintenance of Bus Equipment
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	26/11/2022	06:36	26/11/2022	18:36	PO	1) String Disc Replacement Work 2) Maintenance Work
NEW KOYNA-KARAD CKT - 1	IntraState	26/11/2022	09:28	26/11/2022	17:50	PO	Bus Insulator replacement work at section Karad - I & II
KHADKA-AURANGABAD (WALUJ)	IntraState	26/11/2022	21:29		Continued.	HT	H/T FOR O/V
400 KV ICT Outages/Trippings							
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	25/11/2022	08:00	25/11/2022	17:54	PO	Erection of 400 kV bushing & testing of ICT-I unit after internal inspection is required for internal inspection of ICT-I R ph unit & taking R ph unit in service & spare ICT-I unit is to be taken out from RRS & kept on humming.
220 KV MAINBAY Outages/Trippings							
TBC @ RANJANGAON	IntraState	25/11/2022	11:55	25/11/2022	18:20	PO	Isolator alignment work of A & B Isolator.
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KHARGHAR - NERUL	IntraState	22/11/2022	06:38			EO	A bus to B bus shift Via TBC for prevent to further avoid damage of A bus B phase conductor near Nerul bay.
KHARGHAR - SONKHAR	IntraState	22/11/2022	10:45			EO	B bus to A bus shift Via TBC for balancing of Bus loading & Nerul ,Sonkhar line connected to MMR region for saftety purpose both are charged throuh different Bus.
EKLAHARE (OCR) - PADGHE	IntraState	23/11/2022	08:22	26/11/2022	18:59	HT	H/T TO CONTROL 220KV NASIK-BBLR LINEL OADING

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ONGC PANVEL - TSS PANVEL	IntraState	23/11/2022	09:05	25/11/2022	22:33	PO	1. Outage on 220kV ONGC Panvel TSS line for Retrofitting the Differential Relay at 220kV ONGC S/s for New 220kV Panvel TSS on dt. 23.11.2022 2. Outage on 220kV ONGC Panvel TSS line and 220kV Kharghar-Panvel TSS line for connecting the second circuit and making the LILO to 220kV New Panvel TSS on dt. 24.11.2022 from Loc No. 3 Lattice Tower to Monopole No.1
AAREY - MSETCL BORIVALI CKT - 1	IntraState	24/11/2022	17:39			T	Tripped on Differential protection
PEDHAMBE ONI LINE	IntraState	25/11/2022	09:00	25/11/2022	15:30	PO	C & Tan delta test of Line CT and bay equipment maintenance
JAMBHUL - ANANDNAGAR	IntraState	25/11/2022	09:13	25/11/2022	14:56	PO	1) Jaw Replacement and Servicing, Overhauling, alignment of 220 kV Bus Isolators of Jambhul-Anandnagar Line. 2) Bus Isolators Maintenance Work of ICT-2 & Section-2 Isolators.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	25/11/2022	09:38	25/11/2022	21:35	HT	H/T TO CONTROL LOAD MANAGEMENT
ACCIL - APTA	IntraState	25/11/2022	10:25	25/11/2022	15:09	PO	Bay Mantance R/M work and Diagnostic test CT Tan delta work.
OSMANABAD - SOLAPUR (BALE)	IntraState	25/11/2022	10:30	25/11/2022	19:22	PO	for Conversion of SSN to DSN at loc no.61,62,81,82,102,103,139,140,141,142
MAIN BUS SECTION - 3 @ EKLAHARE (GCR)	IntraState	25/11/2022	10:35	25/11/2022	17:02	PO	For overhauling of 220kV CB
TROMBAY MSETCL TIE - 2	IntraState	25/11/2022	12:10	25/11/2022	13:23	PO	TO BE OPEN AT BOTH ENDS FOR CHECKING FOR HOT SPOT ON TIE-1 LINE
PADGHE - NALASOPARA - VASAI (T)	IntraState	26/11/2022	17:05		Continued.	PO	A) Work by Project Dn, Kalyan: Outage on Padghe-Nalasopara tap to vasa line will be taken out on 26.11.2022 16:00 to 18:00 Hrs to remove jumper at loc no.54 and 2nd source to Vasai-Padgha will be established till the start of AEMLs work at 23:00 Hrs 2) At Loc No.54, Jumpers will be removed and then from Loc No.54 to Nalasopara line will be in outage from Dtd 26.11.2022 at 16:00 Hrs to 27.11.2022 at 19:00Hrs. In this case 2nd source to Nalasopara will not be available. B) Outage for safety purpose for DFCCIL during which AEML will carry out stringing of 6 conductors & 1 OPGW for height raising work of AEML's existing 220KV D/C SS-Line section betwn loc no. SS-225 & SS-228 in Vasai for DFCCIL. C) During above outage, PT diagnostic & Bus Section Isolator maintenance including bay maint.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	25/11/2022	09:10	25/11/2022	14:41	PO	1) Jaw Replacement and Servicing, Overhauling, alignment of 220 kV Bus Isolators of Jambhul-Anandnagar Line. 2) Bus Isolators Maintenance Work of ICT-2 & Section-2 Isolators.
220/132KV 200MVA PTR 1 @ LONAND	IntraState	25/11/2022	09:25	26/11/2022	23:40	PO	Oil leakage attending work
220/33kV 100 MVA TF 2 @ GHODBUNDER	IntraState	25/11/2022	10:05	25/11/2022	15:17	PO	ANNUAL MAINTENANCE OF CB
220/110 KV 250 MVA ICT - 1 @ VERSOVA (TATA)	IntraState	25/11/2022	10:20	26/11/2022	19:06	PO	FOR R/M AND TESTING
220/100 KV 200 MVA ICT 2 @ PAL- DOMBIVALI	IntraState	25/11/2022	10:38	25/11/2022	18:51	PO	Bus Isolator maintence work
220/132 KV 200 MVA ICT 2 @ BOISAR-II	IntraState	25/11/2022	12:38	25/11/2022	19:27	PO	Hot spot attending work: 1) HV Bph Bushing jumper. 95.8OC. Image 1412. 2) LV Rph Bushing jumper clamp nut/bolts. 54.5OC.
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	26/11/2022	23:50		Continued.		For Diagnostic testing work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage