

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Nov/2024 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	141.727	3710.322	1) Gujrat	-5.830	96.584
2) Hydro	5.440	175.766	2) Madhya Pradesh	3.524	79.096
3) Gas	7.098	167.138	3) Chattisgarh	6.150	167.020
Total MSPGCL	154.265	4053.226	4) Maharashtra	198.651	5232.612
B) 1) APLM	57.380	1389.115	5) Goa (Amona)	-2.276	-57.426
2) JSWEL	23.522	611.639	Total	200.219	5517.886
3) VIPL	0.000	0.000	a) Mumbai Schedule	39.941	1054.517
4) RPL(AMT)	24.090	591.149	b) Mumbai Drawl	43.118	1170.737
5) SWPGPL	9.090	228.358	c) MSEDCL Bilateral *	97.509	2461.018
6) Other IPP	29.635	367.170	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	39.857	1054.064
C) 1) TPCL Thermal	3.852	100.940	Include PX	0.000	0.000
2) TPCL Hydro	3.205	84.604	Standby	0.084	0.453
3) TPCL Gas	4.158	100.346	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.603	182.677	1) MSEDCL	477.650	11997.276
D) STATE			2) Mumbai Discoms	61.936	1639.292
1) Thermal	296.899	7181.370	3) Other Discoms	11.998	306.729
(A1+C1+C4+(B1-B6))			TOTAL STATE	551.584	13943.297
2) Hydro	8.645	260.370			
(A2+C2)					
3) Gas	11.256	267.484			
(A3+B7+C3)					
4) Wind	15.033	239.333			
6) SOLAR	19.532	476.866			
TOTAL STATE	351.365	8425.423			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6165	5726	7181	5149
MSPGCL Hydro	176	184	493	161
MSPGCL Gas	290	288	289	305
MSPGCL Total Generation	6631	6198	7963	5615
Central Sector Receipt	9664	9580	8207	7246
WIND	570	419	499	732
CPP / IPP Thermal	6140	5308	7095	5306
CPP / IPP Gas	0	0	0	0
SOLAR	2633	2943	1	0
Exchange with Mumbai	-2318	-2375	-1718	-1197
MSEDCL DEMAND MET	22756	21519	21494	17325
Load Shedding	0	0	0	0
MSEDCL DEMAND	22756	21519	21494	17325
TPCL GENERATION	432	401	825	378
AEML GENERATION	298	290	502	296
MUMBAI DEMAND	3048	3066	3045	1871
OTHER DISCOM DEMAND	564	554	553	377
STATE DEMAND MET	26368	25139	25092	19573
STATE DEMAND	26368	25139	25092	19573
Frequency (Hz)	50.02	50.01	49.97	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 06.01 Hrs	49.64 Hz at 17.42 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Nov/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.67	98.70	177	116
Unit 8	12.87	255.63	610	382
Unit 9	12.20	293.48	580	372
Unit 10	12.12	314.04	570	380
Total	40.86	961.84		
Bhusawal				
Unit 3	3.21	64.41	180	125
Unit 4	7.38	206.13	485	275
Unit 5	7.42	161.99	485	275
Total	18.01	432.53		
Parli				
Unit 6	3.72	75.52	249	135
Unit 7	3.60	72.68	245	133
Unit 8	3.70	94.45	210	144
Total	11.03	242.65		
Chandrapur				
Unit 3	3.29	84.04	185	120
Unit 4	3.19	81.12	158	122
Unit 5	7.16	197.71	370	283
Unit 6	7.08	168.69	385	275
Unit 7	0.00	142.45	0	0
Unit 8	6.85	177.33	303	275
Unit 9	8.70	210.20	450	273
Total	36.28	1061.54		
Paras				
Unit 3	3.84	104.82	204	113
Unit 4	4.11	110.64	219	149
Total	7.95	215.46		
Khaparkheda				
Unit 1	3.30	97.89	160	120
Unit 2	3.50	103.16	171	120
Unit 3	0.00	50.81	0	0
Unit 4	3.66	103.58	173	126
Unit 5	10.15	257.76	450	330
Total	20.62	613.19		
Nasik				
Unit 3	0.00	62.06	0	0
Unit 4	3.50	80.84	180	120
Unit 5	3.48	40.21	181	121
Total	6.98	183.11		
Uran				
All Units	7.10	167.14	307	282
Total	7.10	167.14		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.30	8.20	48	0
Total	0.30	8.20		
Koyna				
Stage 1-2	1.50	46.12	215	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.04	21.60	36	0
Stage 3	0.33	15.49	80	0
Total	1.86	83.21		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.28	7.04	62	0
BHIRA T.R.	0.12	4.62	40	0
SMLHY_PTN	3.08	76.19	138	118
GHATGHAR	0.10	4.71	80	0
Total	3.58	92.56		
Wind				
Total	15.03	239.33	0	0
Total	15.03	239.33		
CPP				
APML(Mus)	57.38	1389.12	0	0
JSWEL(Mus)	23.52	611.64	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.09	591.15	0	0
SWPGPL-Mus	9.09	228.36	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.87	141.79	269	215
Other(Mus)	21.76	177.08	0	0
JPL	2.00	48.30	134	73
Total	143.72	3187.43		
SOLAR				
Total	19.53	476.87	0	0
Total	19.53	476.87		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.61	63.27	112	107
Trombay 7B	1.55	37.08	66	64
TATA Hydro	3.20	84.60	435	38
Trombay 8	3.85	100.94	222	135
Total	11.22	285.89		
AEML				
DTPS U-1&2	7.60	182.68	502	284
Total	7.60	182.68		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	141.73	3710.32	MSPGCL Total	154.26	4053.23
			MSPGCL Thml+Gas	148.82	3877.46	Koyna 1,2 & 4 Total	1.53	67.72
			MSPGCL Hydro	5.44	175.77	State Total	351.36	8425.42

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 25/Nov/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5038	172	304	5514	860	5095	0	0	7501	7456	-1508	16964	0	0	16964	2215	454	19632	50.01
2	5120	162	305	5587	851	5267	0	0	7512	7264	-1389	17169	0	0	17169	2057	411	19637	49.99
3	5075	171	305	5551	814	5294	0	0	7332	7274	-1272	17276	0	0	17276	1941	384	19602	49.99
4	5149	161	305	5615	732	5306	0	0	7213	7246	-1197	17325	0	0	17325	1871	377	19573	49.99
5	5699	178	304	6181	711	5393	0	0	7101	7306	-1179	18012	0	0	18012	1865	400	20277	49.96
6	5990	174	305	6469	749	6027	0	0	7482	7549	-1258	19109	0	0	19109	1969	428	21505	49.97
7	5966	245	304	6515	742	6559	0	29	8261	8346	-1418	20308	0	0	20308	2144	465	22917	49.97
8	6122	440	307	6869	661	6881	0	417	8645	8526	-1565	21297	0	0	21297	2333	492	24122	49.91
9	6192	317	303	6812	532	6702	0	1217	8825	8976	-1872	21846	0	0	21846	2623	521	24990	49.95
10	6178	263	295	6736	484	6523	0	2026	9532	9378	-2137	22475	0	0	22475	2871	534	25881	50.03
11	6165	176	290	6631	570	6140	0	2633	10038	9664	-2318	22756	0	0	22756	3048	564	26368	50.02
12	6028	174	289	6491	487	5642	0	2966	9846	9530	-2417	22147	0	0	22147	3104	552	25803	50.01
13	5726	184	288	6198	419	5308	0	2943	9635	9580	-2375	21519	0	0	21519	3066	554	25139	50.01
14	5522	184	283	5989	350	5210	0	2781	9703	9479	-2227	21050	0	0	21050	2947	532	24529	50.02
15	5901	196	282	6379	310	5603	0	2269	9537	9674	-2237	21447	0	0	21447	2977	551	24975	49.99
16	6170	177	283	6630	249	6359	0	1519	9857	9562	-2259	21501	0	0	21501	2993	558	25053	49.98
17	6551	212	282	7045	274	6705	0	643	9215	9049	-1993	21170	0	0	21170	2974	553	24697	49.89
18	7180	182	288	7650	343	7102	0	88	8469	8126	-1724	21029	0	0	21029	2993	556	24578	49.83
19	7181	493	289	7963	499	7095	0	1	8264	8207	-1718	21494	0	0	21494	3045	553	25092	49.97
20	6580	313	291	7184	672	6942	0	0	8604	8108	-1914	20464	0	0	20464	2883	528	23875	50.01
21	5993	265	295	6553	807	6247	0	0	8330	7568	-1974	18689	0	0	18689	2715	512	21916	49.99
22	5637	242	296	6175	896	5498	0	0	7960	7570	-1860	17768	0	0	17768	2584	512	20863	50.02
23	5327	190	302	5819	929	5379	0	0	7657	7536	-1710	17451	0	0	17451	2412	503	20365	49.99
24	5237	169	303	5709	1092	5439	0	0	7467	7245	-1597	17383	0	0	17383	2306	506	20194	50.01
MUs	141.73	5.44	7.10	154.26	15.03	143.72	0.00	19.53	203.99	200.22	-43.12	477.65	0.00	0.00	477.65	61.94	12.00	551.58	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Maximum Demand scenario for the date 25/Nov/2024		
State Demand	MSEDC Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
26368 MW	22756 MW	3104 MW
11 Hrs	11 Hrs	12 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Nov/2024

Position as on 6.30 Hrs of 26/Nov/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Khaparkheda Unit 3	210	21/11/2024	00:32		Continued.	Annual Overhaul	16/12/2024
Total Capacity MSPGCL		210						
Total Capacity PLANNED OUTAGE		210						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/11/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	31/03/2025
MSPGCL	Nasik Unit 3	210	23/11/2024	01:08		Continued.	Boiler Tube Leakage	26/11/2024
MSPGCL	Chandrapur Unit 7	500	23/11/2024	09:15		Continued.	Boiler Tube Leakage	26/11/2024
Total Capacity MSPGCL		955						
TPC-G								
TPC-G	Trombay 5	500	22/09/2024	16:14		Continued.	Emergency withdrwan due to fire in cable vault.	
Total Capacity TPC-G		500						
IPP								
IPP	RPL(AMT) U-3	270	23/07/2024	00:47		Continued.	Turbine Vibration High	30/11/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2045						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2024	19:10		Continued.	Due to no schedule from MSEDCL.	
MSPGCL	Uran Unit 6	108	12/11/2024	19:20		Continued.	Due to no schedule from MSEDCL.	
Total Capacity MSPGCL		216						
IPP								
IPP	SWPGPL U-1	135	30/10/2024	00:00		Continued.	Unit Out due to Non-avaialbility of Schedule	
IPP	JPL Unit 2	150	21/11/2024	01:30		Continued.	Unit Out due to Non-avaialbility of Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Nov/2024

Position as on 6.30 Hrs of 26/Nov/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity IPP		285						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		501						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV TBC Outages/Trippings							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	24/11/2024	12:43	25/11/2024	00:59	EO	Unbalance protection level 2 alarm
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	19/11/2024	23:23			PO	HVDC POLE-2 annual outage work such as O-ring replacement,P-2 B-ph converter transformer repalcement work,AC/DC yard maintenace, valve hall, valve cooling system,smoothing reactor,converter transformer,33kv GIS,Dry type transformer,filter areas,400KV C.B & isolator maintenace work,testing of
400 KV TIEBAY Outages/Trippings							
400KV TIE BAY 414 GT 3 - REACTOR @ NANDGAONPETH	InterState	25/11/2024	09:44				414 Bay Isolator maintenance and alignment work Opportunity outage is required for 414 Bay Isolator maintenance and alignment work as Dia-4 related GT-3 is already shutdown from dated 22.07.2024 and reactor transformer is already out from dated 16.11.2024 as per information from LDC Ambazari.
400 KV MAINBAY Outages/Trippings							
MAIN BAY 415 REACTOR @ NANDGAONPETH	InterState	25/11/2024	09:43				415 CB maintenance and testing work. Bay CT tan delta testing work Opportunity outage is required for 415 CB testing and maintenance work as Dia-4 related GT-3 is already shutdown from dated 22.07.2024 and reactor transformer is already out from dated 16.11.2024 as per information from LDC Ambazari.
400KV MAIN BAY 413 GT -3 @ NANDGAONPETH	InterState	25/11/2024	09:44				413 Bay Isolator maintenance and alignment work. Opportunity outage is required for 413 Bay Isolator maintenance and alignment work as Dia-4 related GT-3 is already shutdown from dated 22.07.2024 and reactor transformer is already out from dated 16.11.2024 as per information from LDC Ambazari.
MAIN BAY (412) LINE - 1 OF KORADI-2 @ KORADI 3	IntraState	25/11/2024	09:37	25/11/2024	18:34	PO	Bay Outage
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/10/2024	08:31	25/11/2024	09:15	HT	H/T for load management.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2024	16:09	25/11/2024	09:26	HT	For load management
PADGHE - PADGHE HVDC CKT- 2	IntraState	20/11/2024	00:36			PO	1. Bay Maintenance work. 2.Diagnostic Testing Work. 3.MTAMC Work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KHADKA-AURANGABAD (WALUJ)	IntraState	24/11/2024	20:46	25/11/2024	08:54	HT	Overvoltage Control
JAIGAD - KARAD CKT - 1	IntraState	24/11/2024	22:11	25/11/2024	11:14	HT	H/T For voltage management.
220kV Koradi-2 - Uppalwadi ckt 1	IntraState	25/11/2024	10:07	25/11/2024	17:15	PO	Reorientation of panel earthing of bay 211
KARAD - TALANDGE CKT - 2	IntraState	25/11/2024	11:30			PO	For Distance relay retrofitting and quaterly maintainance work at Karad end
KARAD - TALANDGE CKT - 2	IntraState	25/11/2024	11:30	25/11/2024	18:34		CB overhauling work & Quarterly maintenance work at Talandge end.
KHADKA-AURANGABAD (WALUJ)	IntraState	25/11/2024	22:00			HT	H/T For voltage management.
JAIGAD - KARAD CKT - 2	IntraState	25/11/2024	22:12			HT	H/T For voltage management.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400 KV BR Outages/Trippings							
BUS REACTOR (80 MVA) - 1 @ BABHALESHWAR	IntraState	07/10/2024	09:40			PO	The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
JEUR - SOLAPUR PG	InterState	21/11/2024	08:24			PO	For Restoration of 400 KV PGCIL Karad Original Line after removing temporary bunching arrangement of 400 KV PGCIL-Karad Line with 220 KV Jeur-VSSK line and 220 KV Bale PGCIL ckt-2
APTA - NAVI MUMBAI (PG) CKT - 2	InterState	25/11/2024	20:45	25/11/2024	23:59	T	Due to Y Ph CT burst of 220 kV Bus section
APTA - NAVI MUMBAI (PG) CKT - 1	InterState	25/11/2024	20:45	25/11/2024	23:59	T	Due to Y Ph CT burst of 220 kV Bus section

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
220kV Koradi-2 - Uppalwadi ckt 2	IntraState	28/08/2024	00:14			T	Distance Protection
EKLAHARE (OCR) - PADGHE	IntraState	24/09/2024	07:48			HT	For load mgmt
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
KALWA - PRINT HOUSE LINE	IntraState	15/10/2024	16:31			HT	Hand tripped at Kalwa end for load management.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	16/10/2024	16:01			HT	Line Hand tripped for load management on 220kV Ulve - Waghivali ckt no 1.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	17/10/2024	06:26			HT	H/T for controlling load of 220kV Ulve-Waghivali ckt-1
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
KALWA - PRINT HOUSE LINE	IntraState	17/10/2024	12:23			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	05/11/2024	17:03			HT	Line hand trip for load management on 220kv Nashik Babhaleshawr ckt 1,2.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	18/11/2024	08:50			HT	Load management.
HINJAWADI I- CHINCHWAD	IntraState	25/11/2024	07:16	25/11/2024	20:47	HT	load management
ALEPHATA-PARGAON(KATHAPUR)	IntraState	25/11/2024	09:16	25/11/2024	19:37	HT	load management
TALANDAGE - FIVE STAR MIDC 2	IntraState	25/11/2024	09:42	25/11/2024	18:59	PO	For disc insulator string cleaning by chemical method.
TROMBAY CARNAC - 5	IntraState	25/11/2024	09:49	25/11/2024	18:59	PO	For De-mucking of seal well at U5 aeration basin as a part of U5 outage work at Trombay
TALANDGE - SAWANTWADI	IntraState	25/11/2024	10:03	25/11/2024	17:50	PO	Replacement of faulty string found in PID
WARORA-BHUGAON CKT - 2	IntraState	25/11/2024	10:22	25/11/2024	16:32	PO	Confirmation of IR value of R ph LA
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	25/11/2024	10:26	25/11/2024	23:43	PO	Distance relay A/R function configuration & testing work
KADEGAON-MIRAJ	IntraState	25/11/2024	10:37	25/11/2024	14:03	PO	CT tan delta & B Ph wave trap string replacement work
132 KV PARTUR - BAGESHWARI CKT	IntraState	25/11/2024	10:40	25/11/2024	12:18	T	Distance protection
220 KV SICOM - CFP CKT - 1	IntraState	25/11/2024	11:24	25/11/2024	17:49	PO	Attending of oil leakages from secondary terminal box of B ph line PT at M/S. CFAP End.
BHUGAON - WARDHA (PG)	IntraState	25/11/2024	11:30	25/11/2024	17:04	PO	For Replacement of Old BHEL Insulators on gantries of element.
PUSAD - WARDHA (PG)	IntraState	25/11/2024	11:46	25/11/2024	16:52	PO	For Replacement of Old BHEL Insulators on gantries of element.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARA(OCR)-RAYMOND	IntraState	25/11/2024	15:36	25/11/2024	19:34	PO	1. Attending the red-hot at loc.no.4 of LILO Raymond side 88.2ꜰC and loc.no.1 of LILO Nashik side 71.1ꜰC. 2. Conversion of STN into DTN of B-phase due National Highway crossing at loc.no. 318. 3. Replacement of rusted tension bolt at loc.no.309 R, Y & B-phase both side
APTA - TAMBATI	IntraState	25/11/2024	20:45	25/11/2024	21:32	T	Due to Y Ph CT burst of 220 kV Bus section
URAN - APTA 2	IntraState	25/11/2024	20:45	25/11/2024	21:29	T	Due to Y Ph CT burst of 220 kV Bus section
ACCIL - APTA	IntraState	25/11/2024	20:45	25/11/2024	21:36	T	Due to Y Ph CT burst of 220 kV Bus section
APTA - BOMBAY DYEING	IntraState	25/11/2024	20:45	25/11/2024	21:35	T	Due to Y Ph CT burst of 220 kV Bus section
URAN - APTA 4	IntraState	25/11/2024	20:45	25/11/2024	21:31	T	Due to Y Ph CT burst of 220 kV Bus section
URAN - APTA 3	IntraState	25/11/2024	20:45	25/11/2024	21:30	T	Due to Y Ph CT burst of 220 kV Bus section
URAN - APTA CKT - 1	IntraState	25/11/2024	20:45	25/11/2024	21:28	T	Due to Y Ph CT burst of 220 kV Bus section
KALWA - SALESETTE CKT - 5	IntraState	26/11/2024	00:11	26/11/2024	01:56	PO	220kV Kalwa-Salsette#5 line QL#3 isolator mechanism defect attending
220 KV ICT Outages/Trippings							
220/22KV 50MVA PTR 3 @ BHOSARI 2	IntraState	24/07/2024	23:02			T	Tripped due to caught fire.
220/132 KV 100 MVA ICT I @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/132 KV 100 MVA ICT II @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/132 KV 150 MVA PTR NO 7 @ CHINCHWAD	IntraState	11/11/2024	03:05			T	Bucholz Protection
220/22KV 50MVA PTR - 2 @ PALAVA	IntraState	25/11/2024	08:52	25/11/2024	15:30	PO	OLTC overhauling work.
220/33-33KV 100MVA TF- 2 @ ICHALKARANJI - II	IntraState	25/11/2024	10:18	25/11/2024	14:07	PO	1) For replacement of HV Side Panel Energy Meter & Isolator MB Box.
220/132 KV 200 MVA ICT 1@AKOLA	IntraState	25/11/2024	10:21	25/11/2024	16:09	PO	For HV B Ph LA Jumper replacement work and routine maintenance work at 220kV Akola s/s
220/132 KV 100 MVA ICT 2 @ BHOKAR	IntraState	25/11/2024	11:18	25/11/2024	19:15	PO	replace R ph HV side bushing work.
220 MVA 220/132 KV ICT 3 @ JALNA	IntraState	25/11/2024	11:35	25/11/2024	18:16	PO	Diagnostic testing and CTR work
220/22KV 50MVA PTR - 1 @ PALAVA	IntraState	25/11/2024	15:30	25/11/2024	18:28	PO	OLTC overhauling work.
220/100 KV 200 MVA ICT 3 @ APTA	IntraState	25/11/2024	20:45	25/11/2024	21:40	T	Due to Y Ph CT burst of 220 kV Bus section
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	25/11/2024	20:45	25/11/2024	21:41	T	Due to Y Ph CT burst of 220 kV Bus section
220/100 KV 200 MVA ICT 1 @ APTA	IntraState	25/11/2024	20:45	25/11/2024	21:38	T	Due to Y Ph CT burst of 220 kV Bus section
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	25/11/2024	20:45	25/11/2024	21:39	T	Due to Y Ph CT burst of 220 kV Bus section
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	26/09/2024	14:40			HT	H/T at 132KV Pench end
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management
132 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Nov/2024

Statement-VII

Position as on 6.30 Hrs of 26/Nov/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
132/33 KV 50 MVA PTR 2 @ DONDAICHA	IntraState	15/11/2024	11:40			T	Tripped on Buchholz alarm
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	25/11/2024	08:16	25/11/2024	19:35	PO	Installation of PICA insulator from loc. 53 to 56

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage