

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 25/Dec/2021 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	144.101	3441.654	1) Gujrat	-11.910	-189.140
2) Hydro	11.254	188.168	2) Madhya Pradesh	1.604	35.522
3) Gas	5.346	121.039	3) Chattisgarh	5.960	145.500
Total MSPGCL	160.701	3750.861	4) Maharashtra	138.653	3377.243
B) 1) APML	71.640	1529.625	5) Goa (Amona)	-1.003	-40.359
2) JSWEL	12.503	346.712	Total	133.304	3328.766
3) VIPL	0.000	0.000	a) Mumbai Schedule	17.430	621.861
4) RPL(AMT)	27.648	651.656	b) Mumbai Drawl	22.436	662.615
5) SWPGPL	5.952	191.978	c) MSEDCL Bilateral *	51.016	1229.308
6) Other IPP	40.065	941.233	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	17.430	621.861
C) 1) TPCL Thermal	7.077	198.545	Include PX	0.000	3.902
2) TPCL Hydro	4.458	109.242	Standby	0.000	0.000
3) TPCL Gas	2.462	72.914	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.741	242.223	1) MSEDCL	429.866	10183.222
D) STATE			2) Mumbai Discoms	46.174	1285.532
1) Thermal	318.727	7543.626	3) Other Discoms	9.859	244.830
(A1+C1+C4+(B1-B6))			TOTAL STATE	485.899	11713.584
2) Hydro	15.712	297.410			
(A2+C2)					
3) Gas	7.808	193.953			
(A3+B7+C3)					
4) Wind	3.327	199.811			
6) SOLAR	7.021	150.025			
TOTAL STATE	352.595	8384.825			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6169	6252	6371	5568
MSPGCL Hydro	1616	963	309	210
MSPGCL Gas	248	231	214	217
MSPGCL Total Generation	8033	7446	6894	5995
Central Sector Receipt	7213	6714	5601	4261
WIND	79	70	110	243
CPP / IPP Thermal	6978	7008	6917	5719
CPP / IPP Gas	0	0	0	0
SOLAR	939	1048	0	0
Exchange with Mumbai	-1131	-1203	-978	-765
MSEDCL DEMAND MET	17254	16205	13378	11481
Load Shedding	0	0	0	0
MSEDCL DEMAND	17254	16205	13378	11481
TPCL GENERATION	629	571	886	415
AEML GENERATION	500	500	410	319
MUMBAI DEMAND	2260	2274	2274	1499
OTHER DISCOM DEMAND	347	348	369	284
STATE DEMAND MET	24370	23357	20818	16952
STATE DEMAND	24370	23357	20818	16952
Frequency (Hz)	49.99	49.99	50.00	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 06.02 Hrs	49.73 Hz at 09.10 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 25/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.48	89.48	185	115
Unit 7	0.00	0.00	0	0
Unit 8	5.90	336.83	653	0
Unit 9	14.66	210.27	656	500
Unit 10	13.74	326.68	610	515
Total	37.79	963.26		
Bhusawal				
Unit 3	3.42	53.00	170	120
Unit 4	9.20	216.70	455	280
Unit 5	9.46	217.94	470	280
Total	22.08	487.64		
Parli				
Unit 6	5.05	48.39	250	150
Unit 7	4.87	31.16	250	148
Unit 8	4.26	82.52	215	154
Total	14.18	162.07		
Chandrapur				
Unit 3	3.88	58.08	181	117
Unit 4	3.65	79.63	170	120
Unit 5	7.90	139.62	380	260
Unit 6	9.07	192.89	435	274
Unit 7	7.19	191.46	328	275
Unit 8	0.00	218.66	0	0
Unit 9	9.90	230.70	440	374
Total	41.59	1111.04		
Paras				
Unit 3	4.62	107.58	250	141
Unit 4	4.59	109.23	232	139
Total	9.20	216.81		
Khaparkheda				
Unit 1	0.00	24.87	0	0
Unit 2	0.00	25.46	0	0
Unit 3	1.32	28.37	138	0
Unit 4	1.35	21.82	143	0
Unit 5	9.89	237.75	460	299
Total	12.56	338.28		
Nasik				
Unit 3	3.20	47.70	160	118
Unit 4	0.00	33.17	0	0
Unit 5	3.49	81.68	185	115
Total	6.70	162.55		
Uran				
All Units	5.35	121.04	252	196
Total	5.35	121.04		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.62	5.45	31	20
Total	0.62	5.45		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.74	55.64	465	35
Stage 4	2.19	20.50	708	0
Stage 3	1.15	17.68	274	0
Total	6.08	93.82		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.46	7.92	58	0
BHIRA T.R.	0.28	6.35	40	0
SMLHY_PTN	4.43	80.02	202	166
GHATGHAR	0.00	0.00	0	0
Total	5.17	94.35		
Wind				
Total	3.33	199.81	0	0
Total	3.33	199.81		
CPP				
APML(Mus)	71.64	1529.62	0	0
JSWEL(Mus)	12.50	346.71	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	27.65	651.66	0	0
SWPGPL-Mus	5.95	191.98	0	0
Other(Mus)	40.06	941.23	0	0
Total	157.81	3661.20		
SOLAR				
Total	7.02	150.02	0	0
Total	7.02	150.02		
Tata				
Trombay 5	7.08	176.74	406	257
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.42	43.18	116	45
Trombay 7B	1.04	29.74	66	37
Trombay 8	0.00	21.80	0	0
TATA Hydro	4.46	109.24	429	42
Total	14.00	380.70		
AEMIL				
DTPS U-1&2	9.74	242.22	500	315
Total	9.74	242.22		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	144.10	3441.65	MSPGCL Total	160.70	3750.86
			MSPGCL Thml+Gas	149.45	3562.69	Koyna 1,2 & 4 Total	4.93	76.14
			MSPGCL Hydro	11.25	188.17	State Total	352.60	8384.82

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 25/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5552	226	217	5995	195	5717	0	0	5028	4436	-918	15113	0	15113	1665	311	17090	50.01
2	5507	211	206	5924	229	5560	0	0	4931	4691	-817	15301	0	15301	1559	287	17146	49.95
3	5568	210	217	5995	243	5719	0	0	4856	4261	-765	15169	0	15169	1499	284	16952	49.94
4	5565	207	209	5981	268	5953	0	0	4800	4402	-713	15602	0	15602	1443	289	17334	49.95
5	5620	210	218	6048	258	6113	0	0	4923	4763	-719	16153	0	16153	1450	310	17913	50.02
6	6074	220	208	6502	217	6751	0	0	5059	4890	-785	17242	0	17242	1521	333	19096	50.01
7	6494	222	218	6934	162	6859	0	2	5121	4888	-694	17823	0	17823	1599	328	19750	50.02
8	6779	310	209	7298	128	6958	0	83	5647	5601	-776	18958	0	18958	1698	334	20990	49.98
9	6765	571	219	7555	77	7054	0	375	5892	6082	-860	19939	0	19939	1880	344	22163	49.92
10	6472	1198	243	7913	88	7056	0	678	6335	6416	-988	20830	0	20830	2099	333	23262	49.86
11	6169	1616	248	8033	79	6978	0	939	6702	7213	-1131	21764	0	21764	2260	347	24370	49.99
12	6225	1481	234	7940	74	6954	0	1068	7125	6781	-1201	21272	0	21272	2306	344	23922	49.99
13	6252	963	231	7446	70	7008	0	1048	7056	6714	-1203	20735	0	20735	2274	348	23357	49.99
14	6229	365	237	6831	94	6934	0	1029	7050	6681	-1118	20103	0	20103	2140	348	22591	50.00
15	6035	371	196	6602	95	6948	0	900	7131	6902	-1128	19966	0	19966	2122	353	22441	49.98
16	6291	528	206	7025	77	6979	0	578	6476	6473	-1050	19709	0	19709	2110	373	22192	49.96
17	6353	398	205	6956	89	6998	0	263	5985	5758	-940	18747	0	18747	2116	377	21240	49.97
18	6332	343	203	6878	126	6900	0	58	5759	5295	-874	18003	0	18003	2155	380	20538	50.00
19	6371	309	214	6894	110	6917	0	0	5763	5601	-978	18175	0	18175	2274	369	20818	50.00
20	6432	247	226	6905	177	6953	0	0	5357	5418	-964	18111	0	18111	2248	378	20737	50.00
21	5852	234	246	6332	164	6867	0	0	5126	4436	-942	16484	0	16484	2139	373	18996	50.01
22	5116	221	240	5577	126	6364	0	0	5342	5378	-1018	16066	0	16066	2013	361	18440	49.97
23	5144	259	252	5655	113	5654	0	0	5357	5116	-974	15227	0	15227	1864	337	17428	49.96
24	4904	334	244	5482	68	5614	0	0	5212	5108	-880	15067	0	15067	1740	325	17132	49.96
MUs	144.10	11.25	5.35	160.70	3.33	157.81	0.00	7.02	138.03	133.30	-22.44	431.56	0.00	431.56	46.17	8.17	485.90	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 25/Dec/2021

Position as on 6.30 Hrs of 26/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 8	500	25/12/2021	00:01		Continued.	CW DEBRIS FILTER INSPECTION AND MAINTENENCE WORK	
IPP	SWPGL U-2	135	25/12/2021	00:09		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 4	210	08/12/2021	21:00	25/12/2021	11:45	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 3	210	09/12/2021	00:01	25/12/2021	11:20	CHP coal feeding problem	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56		Continued.	CHP coal feeding problem	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22		Continued.	withdrawn against case 4 to dhariwal	
MSPGCL	Koradi Unit 8	660	25/12/2021	09:56		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 26/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	24/12/2021	23:54	25/12/2021	01:20	EO	Red hot observed at connecting jumper of capacitor bushing
400 KV LINE Outages/Trippings							
PARLI(MS) - PARLI (PG) CKT -2	InterState	24/12/2021	17:07	25/12/2021	00:25	HT	Emergency outage at Parli PG end to attend hotspot
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadruple CB. 3) Measurement of Timing, DCRM and CRM of CB.
KHADKA-AURANGABAD	IntraState	23/12/2021	07:17	25/12/2021	08:59	PO	For Reconnection of Live 400 KV Main Bus-1&2 section jumpers of 400 KV Akola & Aurangabad section after replacement of damaged bus section
KARAD - LONIKAND I	IntraState	23/12/2021	09:19	25/12/2021	09:43	PO	Distance Protection relay (M-1) replacement under MTAMC Project. Existing relay ABB REL521 & new relay Siemens 7SA52
KARAD - LONIKAND I	IntraState	23/12/2021	09:19	25/12/2021	09:43	PO	Half yearly bay maintenance and DT work. Diagnostic testing and maintenance work.
KARAD - LONIKAND I	IntraState	23/12/2021	09:19	25/12/2021	09:43	PO	PID faulty disc insulator replacement work and cold line washing work
TBC @ KORADI-1	IntraState	24/12/2021	13:40			EO	"Heavy air leakage in ABB make 400 kV CB R pole observed and CB got lockout due to 0 bar air pressure in CB. To attend the heavy air leakage of ABB make 400 kV CB R pole emergency outage is required on 400 kV TBC Bay ."
JAIGAD - KARAD CKT - 1	IntraState	24/12/2021	22:21	25/12/2021	09:59	HT	over voltage
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	IntraState	25/12/2021	09:16	25/12/2021	18:16	PO	1) Measurement of tan delta & capacitance of CTs and CVTs. 2) Maintenance & alignment of Isolators. 3) MTAMC project work
JAIGAD - KARAD CKT - 2	IntraState	25/12/2021	19:56	26/12/2021	09:13	HT	over voltage
LONIKAND I -JEJURI	IntraState	26/12/2021	08:11	26/12/2021	20:38	PO	Insulator string replacement work (LILO part)
JAIGAD - KARAD CKT - 1	IntraState	26/12/2021	22:03		Continued.	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	26/12/2021	22:56		Continued.	HT	HT FOR OVERVOLTAGE
PADGHE - NAGOTHANE CKT - 1	IntraState	26/12/2021	23:30		Continued.	HT	HT FOR OVERVOLTAGE
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	25/12/2021	10:12	25/12/2021	23:34	PO	1) Bay maintenance work 2) Diagnostic testing work 3) MTAMC work 4) attending Hot Spot on R & Y Ph IV Bushing 120,102deg resp., B-Ph CT 102deg
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	25/12/2021	18:00	25/12/2021	19:30	EO	For attending of red hot on HV Side 2 Y 2 Ph bushing of ICT 1
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 25/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 26/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BAY(208) OF 220KV-SOLAPUR-FUTURE 1 @SOLAPUR (PG)-220 KV	InterState	20/12/2021	17:22		Continued.	PO	reorientation work along with the disconnection of 220KV Bale-Tuljapur line at Loc.NO. 37 and establishment of link between Solapur PG to 220KV Bale substation will be carried out by utilizing D/C portion of Solapur PG -Bale line and jumpering work at substation end.
TBC @ BABHLESHWAR	IntraState	25/12/2021	15:00	25/12/2021	16:40		R phase CT oil top up
220 KV LINE Outages/Trippings							
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51	26/12/2021	21:43	HT	line work
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01		Continued.	HT	air leakage in CB
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
SOLAPUR(BALE) - TULJAPUR	IntraState	20/12/2021	10:54		Continued.	PO	Outage is required 1. Testing & communication work of line and bay at both substation (Bale & PGCIL) 2. Jumpering work at loc 37 on 220kV PGCIL Bale Line 3. Shifting of WT, CC & LMU (in existing Tuljapur bay) at 220kV Bale Substaion.
TROMBAY SALSETTE LINE-2	IntraState	24/12/2021	23:27	25/12/2021	05:25		Metro -4 project work
KALWA SALSETTE - 4	IntraState	25/12/2021	06:50	25/12/2021	08:06	PO	BREAKER TESTING
BOISAR II - BOISAR (PG) CKT - 2	IntraState	25/12/2021	09:42	25/12/2021	21:55	PO	FIXING OF MISSING SPACERS
DASTURI-KANDALGAON LINE	IntraState	25/12/2021	12:09	25/12/2021	16:02	PO	For C & tan delta testing of Line CTs at 220kV Dasturi S/s.
BUS - 1 @ TROMBAY	IntraState	26/12/2021	00:36	26/12/2021	05:30	PO	GT-8 MBS GOD R/M
KHARGHAR - BORIVALI CKT - 1	IntraState	26/12/2021	06:09	26/12/2021	08:52	T	tripped on DP Protection , R- E , IA 8900 Amp
BOISAR II - BOISAR (PG) CKT - 2	IntraState	26/12/2021	06:17		Continued.	PO	Replacement of conductor between loc no.3 & 4(Railway Crossing) and 220KV Boisar-II S/stn Gantry to Loc no.4
BABLESHWAR- ALEPHATA CKT - 1	IntraState	26/12/2021	11:40	26/12/2021	14:40	HT	For Load Managenent at 400 kV Babbhleshwar ICT loadings, Facilitating Emergency Outage on 220 kV Waluj - Bhenda.
AURANGABAD (WALUJ)-BHENDA	IntraState	26/12/2021	11:53	26/12/2021	14:37	HT	Squirrel dead on the CT of Bhenda at Waluj. Possibility of 220 kV Bus Fault, Emergency outage proposed for half hour.
KARAD - NERLE	IntraState	26/12/2021	12:31	26/12/2021	12:57	T	Tripped on Distance Protection.
JEJURI-PHURSUNGI 2	IntraState	26/12/2021	14:07	26/12/2021	18:02	T	Reverse Power Flow
JEJURI-PHURSUNGI 1	IntraState	26/12/2021	14:07	26/12/2021	18:02	T	Reverse Power Flow

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 25/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 26/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BABHALESHWAR - UTECH SUGAR	IntraState	26/12/2021	22:30		Continued.	PO	29A, 29B isolator servicing and alignment and mechanism box replacement . Jump opening and reconnection for Main bus I and Main bus II by Hot line Unit,Nasik
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 3 @ PADGHE	IntraState	24/12/2021	09:47	26/12/2021	19:07	PO	1. Retrofitting of REF relay & 86 Master trip relay for MTAMC work 2. Diagnostic Testing Work 3. For Attending Hotspot
220/132 KV 200 MVA ICT 2 @ SATANA	IntraState	25/12/2021	10:46	25/12/2021	19:27	PO	Outage proposal for LV CB Overhauling Work
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	25/12/2021	12:55	25/12/2021	16:04	EO	For topping of oil
220/132 KV 150 MVA ICT 1 @ SATANA	IntraState	26/12/2021	09:13	26/12/2021	17:05	PO	Outage proposal for LV CB Overhauling Work
220/22-22 KV 100 MVA PTR 1 @ NALASOPARA	IntraState	26/12/2021	09:45	26/12/2021	20:25	PO	1) 80MVA 220/22-22 kV PTR-1 for attending PTR LV Bushing oil leakage (minor) attending work. 2) SFRA, Cap & Tan delta of winding, bushing and CT, 10kV Excitation, DFR winding, winding resistance measurement, Tap Changer Continuity and PI of PTR. 3)PTR LV 2 ph Stub bus to line isolator drop jumper replacement due to deterioration. 4) Auxiliary protection Trials of PTR. 5) HV and LV side Isolator maintenance, LA Meggering 6) HT tapping of LV side jumper. 7) LV side CB timings and CRM. 8) Cooling fan maintenance work.
220/33KV 50MVA T/F-I @ BRIDGESTONE	IntraState	26/12/2021	10:32	26/12/2021	12:30	PO	For commisioning of LTS scheme to avoid tripping/overloading of Transformer/Feeders
220/22 KV 50 MVA PTR 2 @ VASAI	IntraState	26/12/2021	13:38	26/12/2021	17:57	PO	For hotspot attending from LV Bph bushing by agency.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage