

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/Feb/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	147.280	3958.337	1) Gujrat	-6.960	-201.306
2) Hydro	13.476	443.956	2) Madhya Pradesh	8.925	158.824
3) Gas	3.582	187.193	3) Chattisgarh	6.460	169.080
Total MSPGCL	164.338	4589.486	4) Maharashtra	173.556	3934.048
B) 1) APLM	74.477	1638.918	5) Goa (Amona)	-1.336	-37.215
2) JSWEL	20.101	385.989	Total	180.645	4023.431
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.731	551.808
4) RPL(AMT)	25.479	699.689	b) Mumbai Drawl	29.390	622.953
5) SWPGPL	6.284	219.759	c) MSEDCL Bilateral *	89.084	1973.369
6) Other IPP	40.657	1053.885	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.731	551.166
C) 1) TPCL Thermal	9.798	245.472	Include PX	0.000	0.000
2) TPCL Hydro	3.634	99.636	Standby	0.000	0.642
3) TPCL Gas	0.000	78.820	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.684	210.551	1) MSEDCL	489.055	12220.760
D) STATE			2) Mumbai Discoms	50.506	1257.431
1) Thermal	331.760	8412.600	3) Other Discoms	8.646	217.264
(A1+C1+C4+(B1-B6))			TOTAL STATE	548.207	13695.455
2) Hydro (A2+C2)	17.110	543.592			
3) Gas (A3+B7+C3)	3.582	266.013			
4) Wind	6.873	228.044			
6) SOLAR	8.237	221.776			
TOTAL STATE	367.562	9672.025			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6508	6441	6109	5878
MSPGCL Hydro	931	509	1111	398
MSPGCL Gas	144	142	155	159
MSPGCL Total Generation	7583	7092	7375	6435
Central Sector Receipt	9130	8803	6924	5913
WIND	160	189	284	659
CPP / IPP Thermal	7036	7029	7018	6938
CPP / IPP Gas	0	0	0	0
SOLAR	1134	1195	0	0
Exchange with Mumbai	-1542	-1638	-1296	-1197
MSEDCL DEMAND MET	23115	22265	19905	18413
Load Shedding	0	0	0	0
MSEDCL DEMAND	23115	22265	19905	18413
TPCL GENERATION	703	594	707	402
AEML GENERATION	288	285	429	284
MUMBAI DEMAND	2533	2517	2432	1883
OTHER DISCOM DEMAND	386	405	400	335
STATE DEMAND MET	26034	25187	22737	20631
STATE DEMAND	26034	25187	22737	20631
Frequency (Hz)	49.99	50.00	50.03	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 06:02 Hrs	49.82 Hz at 14:55 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/Feb/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.82	98.45	175	140
Unit 7	0.00	0.00	0	0
Unit 8	13.94	357.89	602	535
Unit 9	0.00	268.33	0	0
Unit 10	11.93	324.58	515	480
Total	29.68	1049.24		
Bhusawal				
Unit 3	0.00	64.29	0	0
Unit 4	9.73	99.59	485	285
Unit 5	9.46	258.72	470	285
Total	19.19	422.60		
Parli				
Unit 6	3.67	101.35	178	147
Unit 7	3.58	101.88	187	144
Unit 8	0.00	87.09	0	0
Total	7.24	290.32		
Chandrapur				
Unit 3	4.26	76.42	188	155
Unit 4	4.06	66.05	175	163
Unit 5	7.51	192.43	320	300
Unit 6	9.28	150.96	410	358
Unit 7	9.37	219.50	420	327
Unit 8	10.96	241.28	465	450
Unit 9	7.68	253.00	416	0
Total	53.12	1199.63		
Paras				
Unit 3	5.60	111.32	246	174
Unit 4	3.64	108.79	246	0
Total	9.24	220.12		
Khaparkheda				
Unit 1	3.47	84.27	150	135
Unit 2	3.65	57.12	160	140
Unit 3	0.00	93.56	0	0
Unit 4	3.76	90.26	175	133
Unit 5	10.77	276.08	475	410
Total	21.65	601.29		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.69	92.87	192	121
Unit 5	3.46	82.27	173	117
Total	7.15	175.14		
Uran				
All Units	3.58	187.19	162	141
Total	3.58	187.19		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	5.37	27	0
Total	0.04	5.37		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.89	78.57	420	35
Stage 4	1.55	110.72	631	0
Stage 3	1.09	40.76	160	0
Total	5.52	230.05		
Hydro				
KDPH	0.43	14.93	18	18
VTRNA	0.00	14.56	0	0
TILLARI	0.52	12.15	58	0
BHIRA T.R.	0.24	5.40	80	0
SMLHY_PTN	6.71	151.71	302	260
GHATGHAR	0.00	9.79	0	0
Total	7.91	208.54		
Wind				
Total	6.87	228.04	0	0
Total	6.87	228.04		
CPP				
APML(Mus)	74.48	1638.92	0	0
JSWEL(Mus)	20.10	385.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.48	699.69	0	0
SWPGPL-Mus	6.28	219.76	0	0
Other(Mus)	40.66	1053.88	0	0
Total	167.00	3998.24		
SOLAR				
Total	8.24	221.78	0	0
Total	8.24	221.78		
Tata				
Trombay 5	6.55	149.98	333	260
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	47.96	0	0
Trombay 7B	0.00	30.86	0	0
TATA Hydro	3.63	99.64	383	0
Trombay 8	3.25	95.50	183	131
Total	13.43	423.93		
AEMIL				
DTPS U-1&2	7.68	210.55	499	281
Total	7.68	210.55		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	147.28	3958.34	MSPGCL Total	164.34	4589.49
			MSPGCL Thml+Gas	150.86	4145.53	Koyna 1,2 & 4 Total	4.44	189.29
			MSPGCL Hydro	13.48	443.96	State Total	367.56	9672.02

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 26/Feb/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5728	358	149	6235	348	6912	0	0	6671	6588	-1138	18628	0	18628	1821	317	20766	50.02
2	5789	360	160	6309	349	6963	0	0	6756	6588	-1010	18909	0	18909	1695	290	20894	50.02
3	5780	354	149	6283	314	6898	0	0	6950	6738	-925	19040	0	19040	1605	268	20913	50.03
4	5769	355	149	6273	285	6800	0	0	7091	6988	-882	19193	0	19193	1556	271	21020	50.03
5	5794	386	160	6340	219	6705	0	0	7384	7473	-887	19559	0	19559	1561	291	21411	50.01
6	5919	357	152	6428	265	6956	0	0	7728	7404	-936	19795	0	19795	1654	322	21771	50.00
7	5971	694	150	6815	248	7018	0	16	7471	7367	-708	20421	0	20421	1758	335	22514	50.01
8	6114	1324	162	7600	205	7047	0	128	7169	7305	-665	21248	0	21248	1883	372	23503	50.03
9	6215	809	150	7174	177	7044	0	459	7923	8114	-956	21619	0	21619	2070	393	24082	50.04
10	6412	580	157	7149	166	7065	0	788	8987	8698	-1407	22082	0	22082	2325	377	24784	50.02
11	6565	781	146	7492	186	7083	0	1045	9237	9131	-1514	23048	0	23048	2481	375	25904	50.00
12	6508	931	144	7583	160	7036	0	1134	9296	9130	-1542	23115	0	23115	2533	386	26034	49.99
13	6441	509	142	7092	189	7029	0	1195	9287	8803	-1638	22265	0	22265	2517	405	25187	50.00
14	6360	389	141	6890	156	6757	0	1150	9119	8821	-1557	21827	0	21827	2395	390	24612	50.03
15	6378	432	151	6961	167	6763	0	1059	9117	8989	-1551	22025	0	22025	2384	363	24772	49.90
16	6446	644	142	7232	129	7001	0	693	8895	8752	-1550	21857	0	21857	2384	400	24641	49.95
17	6460	550	141	7151	181	7091	0	426	8399	8078	-1536	20983	0	20983	2361	408	23752	49.94
18	6399	419	142	6960	264	7100	0	140	7417	7196	-1298	19956	0	19956	2348	406	22710	49.99
19	6220	421	143	6784	286	7048	0	4	6608	6592	-1113	19197	0	19197	2390	404	21991	50.01
20	6109	1111	155	7375	284	7018	0	0	6679	6924	-1296	19905	0	19905	2432	400	22737	50.03
21	6173	482	145	6800	431	7012	0	0	6748	6479	-1423	18898	0	18898	2303	401	21602	50.01
22	5973	422	146	6541	552	6794	0	0	6483	6351	-1388	18471	0	18471	2166	379	21016	50.00
23	5879	410	147	6436	653	6920	0	0	6302	6223	-1273	18599	0	18599	2001	360	20960	50.01
24	5878	398	159	6435	659	6938	0	0	6283	5913	-1197	18413	0	18413	1883	335	20631	49.96
MUs	147.28	13.48	3.58	164.34	6.87	167.00	0.00	8.24	184.00	180.65	-29.39	489.05	0.00	489.05	50.51	8.65	548.21	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Feb/2022

Position as on 6.30 Hrs of 27/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U4	300	14/02/2022	16:08		Continued.	No Schedule	
IPP	RPL(AMT) U-3	270	16/02/2022	00:00		Continued.	Coal Shortage	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Ghatghar Unit-2	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Bhusawal Unit 3	210	20/02/2022	22:03		Continued.	Coal Shortage	
MSPGCL	Uran Unit 6	108	21/02/2022	00:37		Continued.	Gas shortage	
MSPGCL	Koradi Unit 9	660	21/02/2022	12:42	27/02/2022	21:05	Boiler Tube Leakage	
MSPGCL	Uran Unit A0	120	21/02/2022	21:57		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	21/02/2022	21:57		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	23/02/2022	02:12		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	23/02/2022	02:22	27/02/2022	10:56	Gas shortage	
MSPGCL	Paras Unit 4	250	23/02/2022	13:45	26/02/2022	06:30	Boiler Tube Leakage	26/02/2022
MSPGCL	Parli Unit 8	250	24/02/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 3	210	25/02/2022	01:17		Continued.	Boiler Tube Leakage	
IPP	SWPGPL U-4	135	25/02/2022	16:47		Continued.	Turbine Vibration	
MSPGCL	Chandrapur Unit 9	500	26/02/2022	21:29		Continued.	Boiler Tube Leakage	
TPC_G	Trombay 8	250	27/02/2022	09:49	27/02/2022	16:22	UNIT TRIPPED REASON AWAITED	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Feb/2022

Position as on 6.30 Hrs of 27/Feb/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 5	500	27/02/2022	09:49	27/02/2022	13:02	UNIT TRIPPED REASON AWAITED	
TPC_G	Trombay 8	250	27/02/2022	16:51	27/02/2022	17:41	Drum level low	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 27/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	26/02/2022	22:28	27/02/2022	03:54	EO	cooling fans replacement..and Tan Delta measurement of Pole-1 R-phase Converter CT for tran analysis as the values on verge of permissible limits
400 KV TBC Outages/Trippings							
TBC @ LONIKAND	IntraState	22/02/2022	12:30			EO	400 kv B ph CT replacement due to oil leakage.
400 KV LINE Outages/Trippings							
KARAD - SOLAPUR (PG)	InterState	22/02/2022	08:50				Commissioning of 400 kv 80 MVar Kanohar make line shunt reactor with allied equipments under LE scheme
THAPTI TANDA - WALUJ	IntraState	01/02/2022	13:01	27/02/2022	19:49	PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
DEEPNAGAR - THAPTI TANDA	IntraState	01/02/2022	13:11	27/02/2022	19:37	PO	TOWER HEIGHT RAISING FOR MUMBAI -NAGPUR SAMRUDDHI HIGHWAY CROSSING . DISMANTLING OF LOC 155(DA+0) AND 156(DA+0) .ERECTION OF NEW TOWERS AT LOC 155(DD+9) AND LOC 156(DD+9) RESTRINGING FROM LOC 155 TO 156.
KHADKA- DEEPNAGAR CKT 1	IntraState	26/02/2022	10:06	26/02/2022	15:07	PO	For Main CB DCRM testing work
MAIN BUS - 2 @ KUMBHARGAON (NANDED)	IntraState	26/02/2022	11:30	26/02/2022	16:02	PO	Bus CVT Testing, Bus Isolator Maintenance & Relay Routine Testing
PADGHE - NAGOTHANE CKT - 2	IntraState	26/02/2022	11:49	26/02/2022	22:32	PO	STRING REPLACEMENT WORK NEEDS TO BE DONE
DEEPNAGAR - THAPTI TANDA	IntraState	27/02/2022	19:42			T	Distance protection
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	24/02/2022	03:29			T	Differential Relay Optd, R-ph HV CT Burst
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	25/02/2022	11:41			PO	1) ICT Painting Work 2)Diagnostic Testing Work 3) Routine Maintenance Work
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	26/02/2022	10:26	27/02/2022	20:46	PO	1) Construction of concrete masonry up to 8.5 mte height (width uo to 5 mtr) 2) Construction of concrete masonry up to 8.5 mte height (width uo to 10 mtr)
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	26/02/2022	07:39	26/02/2022	19:18		Safety Purpose for carrying out Annual maintenance of 220kv Ghodbunder-Gorai line
220 KV MAINBAY Outages/Trippings							
INTERCONNECTOR @ KALWA	IntraState	26/02/2022	06:05	26/02/2022	08:16	EO	220 KV Interconnector 52 C breaker B ph CT attending oil leakage.
BUS SECTION @ BHOSARI II	IntraState	26/02/2022	12:45	26/02/2022	18:11	PO	Replacement of EHV R phase CT due to higher tan delta under LE Scheme 2. EHV CB CRM
220 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 27/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	CABLE FAULT
SONKHAR - TROMBAY	IntraState	04/02/2022	10:39	27/02/2022	11:49	PO	To carry out the erection of 4 nos. of new Towers between Loc no. 721 to 724 and stringing of HTLS conductor from Loc no. 721 to 724 (in BSNL & BARC premises) for shifting height raising of 2 nos. of existing D/C Transmission Line of MSETCL, infringing MMRDA Metro 2-B Line Project.
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	05/02/2022	13:58			PO	To carry out the erection of newly proposed 4 nos. of M/C Tower and stringing with HTLS conductor in between Loc no. 721 to 724 (In BSNL & BARC Premises).
BORIVALI - TARAPUR	IntraState	18/02/2022	09:16			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2. Railway crossing stringing between loc.no.36 & 37a-38a-38
BOISAR II - TARAPUR	IntraState	18/02/2022	09:33			PO	1. Dismantling of existing loc.no. 37, erection proposed on loc.37a & 38a. 2. Railway crossing stringing between loc.no.36 & 37a-38a-38
GHODBUNDER - GORAI	IntraState	20/02/2022	03:56			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable
VERSOVA - GHODBUNDER	IntraState	20/02/2022	04:00			PO	Project activity 1) Modification / relocation of existing tower no LS 275 to 277 at Mira Road for Metro 09 Project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Monopoles. 4. Re-stringing of conductors & OPGW cable
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	22/02/2022	10:16			PO	GETCO WORK. SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C) CROSSING AT NHRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	22/02/2022	10:17			PO	GETCO WORK. SHIFTING OF EXI. 220KV NAVSARI - NASIK LINE NO 1 & 2 (D/C) CROSSING AT NHRCL PRO.CH:- 233/720 (EXI. CROSSING CH:- 233/895)
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	25/02/2022	09:18			PO	Project work for Shifting of line on new GIS bay and HV test of new GIS
DASTURI-KANDALGAON LINE	IntraState	26/02/2022	10:07	26/02/2022	19:30	PO	Insulator string replacement work at Loc.No.169 R,Y,B Ph & Emergency tree cutting work and other line maintenance work.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 27/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KHARGHAR - TOPWORTH	IntraState	26/02/2022	10:33			PO	Erection of inline tower at Proposed Khandeshwar GIS, Erection of inline tower and Preparation of Cable End Termination at Proposed Panvel Timber Market
TEMBHURNI - JEUR	IntraState	26/02/2022	10:40	26/02/2022	16:54	PO	Outage is required for Replacement of CT jumps & bus to CB jump
KHARGHAR - TSS PANVEL	IntraState	26/02/2022	11:31			PO	Erection of inline tower at Proposed Khandeshwar GIS, Erection of inline tower and Preparation of Cable End Termination at Proposed Panvel Timber Market
NAGOTHANE - SPCL	IntraState	26/02/2022	12:45	26/02/2022	16:20	EO	for attending oil pump problem
TROMBAY - SALSETTE CKT - 1	IntraState	26/02/2022	23:17	27/02/2022	10:15	PO	METRO-4 WORK
TROMBAY SALSETTE LINE-2	IntraState	26/02/2022	23:22	27/02/2022	06:39	PO	METRO-4 WORK
CHEMBUR (AEML) - NERUL (M)	IntraState	27/02/2022	07:00	27/02/2022	10:16	EO	For removal of Bunching work at Loc no.689 to restore 220KV Sonkhar-Trombay Line.
TROMBAY - MULUND	IntraState	27/02/2022	08:44	27/02/2022	17:34	T	TRIPPED ON DIST.PROTN
PADGHE - JAMBHUL 1	IntraState	27/02/2022	08:46	27/02/2022	19:31	PO	1) Fixing of new cross arm on newly erected 220kV D/C tower of type 60+ 6 (at new loc no. 44) near existing Loc No. 45 and related stringing work for cut point formation. 2) Tapping of new 220kV cable to 220kV Padghe- Jambhul line for soak tet purpose only at loc. No. 44 after cut-point formation and it will be open at other end i.e. new loc no. 43.
TROMBAY - KALWA	IntraState	27/02/2022	09:49	27/02/2022	10:08	T	TRIPPED ON DIST.PROTN, A/R SUCCESSFUL
TROMBAY (M) - CHEMBUR CKT-1	IntraState	27/02/2022	09:49	27/02/2022	10:55	HT	TRIPPED
TROMBAY (M) - CHEMBUR CKT-2	IntraState	27/02/2022	09:49	27/02/2022	10:57	T	TRIPPED
TROMBAY SALSETTE LINE-2	IntraState	27/02/2022	09:49	27/02/2022	10:05	T	Tripped
KARAD - OGALEWADI CKT 1	IntraState	27/02/2022	12:25	27/02/2022	14:44	T	Distance Protection
TALEGAON (AMBI)-TALEGAON (PG) CKT 2	IntraState	27/02/2022	16:03	27/02/2022	20:13	EO	Cu Palm Replacement of Main Bus Iso. Jumps for attending Hot-spot by shifting 220kV PGCIL-2 Bay on 220kV TBC Bay.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/33kV 100 MVA TF 1 @ GHODBUNDER	IntraState	26/02/2022	07:37	26/02/2022	17:47	PO	"Testing of 33kV Auto restoration scheme for Boards under 33kV AIS to GIS project work."
220/33 KV 50 MVA PTR 3 @ SONKAR	IntraState	26/02/2022	09:03	26/02/2022	11:42	PO	Attending hotspot on Incomer CT by replacement of Damaged Jumper

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Feb/2022

Statement-VII

Position as on 6.30 Hrs of 27/Feb/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100 MVA ICT 2@ PETH	IntraState	26/02/2022	10:13	26/02/2022	14:13	PO	Quarterly maintenance & oil leakage attending work
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	27/02/2022	09:49	27/02/2022	10:12	T	TRIPPED
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	27/02/2022	09:49	27/02/2022	10:24	T	TRIPPED
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	24/02/2022	08:18			PO	FOR DFCC PROJECT WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage