

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 26/Mar/2018 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 150.565        | 3701.298        | 1) Gujrat                      | -2.517         | -23.318          |
| 2) Hydro            | 28.491         | 374.778         | 2) Madhya Pradesh              | 19.507         | 508.013          |
| 3) Gas              | 6.679          | 198.618         | 3) Chattisgarh                 | 6.880          | 162.940          |
| <b>Total MSPGCL</b> | <b>185.735</b> | <b>4274.694</b> | 4) Maharashtra Net             | 110.386        | 2940.500         |
| B) 1) APML          | 39.902         | 1131.212        | 5) Goa (Amona)                 | -0.396         | -17.204          |
| 2) JSWEL            | 18.958         | 486.238         | <b>Total</b>                   | <b>133.860</b> | <b>3570.931</b>  |
| 3) VIPL             | 14.211         | 268.045         | a) Mumbai Schedule             | 22.453         | 566.171          |
| 4) RPL(AMT)         | 19.095         | 436.256         | b) Mumbai Drawl                | 27.018         | 621.632          |
| 5) WPCL             | 2.983          | 102.031         | c) MSEDCL Bilateral *          | 30.587         | 935.801          |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | 1.239          | 189.805          |
| 7) Other IPP        | 13.634         | 321.643         | d) Mumbai Bilateral *          | 22.453         | 566.171          |
| C) 1) TPCL Thermal  | 16.380         | 405.112         | Include PX                     | 2.495          | 120.819          |
| 2) TPCL Hydro       | 5.257          | 104.242         | Include Standby                | 0.000          | 0.000            |
| 3) TPCL Gas         | 4.436          | 100.513         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) R-INFRA Thermal  | 11.465         | 287.444         | 1) MSEDCL                      | 411.781        | 10244.606        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 64.556         | 1518.960         |
| 1) Thermal          | 287.193        | 7139.279        | <b>TOTAL STATE</b>             | <b>476.337</b> | <b>11763.566</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 33.748         | 479.020         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 11.115         | 299.131         |                                |                |                  |
| (A3+B6+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 6.642          | 185.382         |                                |                |                  |
| 6) SOLAR            | 3.779          | 89.806          |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>342.477</b> | <b>8192.618</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6286                      | 6443                  | 6312                      | 6040                      |
| MSPGCL Hydro             | 1950                      | 2002                  | 1037                      | 193                       |
| MSPGCL Gas               | 258                       | 252                   | 283                       | 279                       |
| MSPGCL Total Generation  | 8494                      | 8697                  | 7632                      | 6512                      |
| Central Sector Receipt   | 6256                      | 6655                  | 5235                      | 5221                      |
| WIND                     | 272                       | 112                   | 206                       | 484                       |
| CPP / IPP Thermal        | 4558                      | 4695                  | 4701                      | 3938                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 525                       | 340                   | 0                         | 0                         |
| Exchange with Mumbai     | -1408                     | -1373                 | -1144                     | -832                      |
| <b>MSEDCL DEMAND MET</b> | <b>18697</b>              | <b>19126</b>          | <b>16630</b>              | <b>15323</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 18697                     | 19126                 | 16630                     | 15323                     |
| TPCL GENERATION          | 1322                      | 1324                  | 1305                      | 709                       |
| R-INFRA GENERATION       | 500                       | 502                   | 502                       | 375                       |
| <b>MUMBAI DEMAND</b>     | <b>3230</b>               | <b>3199</b>           | <b>2951</b>               | <b>1916</b>               |
| STATE DEMAND MET         | 21927                     | 22325                 | 19581                     | 17239                     |
| <b>STATE DEMAND</b>      | <b>21927</b>              | <b>22325</b>          | <b>19581</b>              | <b>17239</b>              |
| Frequency (Hz)           | 49.91                     | 49.87                 | 49.91                     | 49.96                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.19 Hz at 18.01 Hrs | 49.74 Hz at 15.23 Hrs | 49.96         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 26/Mar/2018

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 9.98         | 242.26        | 456      | 385      |
| Unit 9             | 9.72         | 259.57        | 495      | 347      |
| Unit 10            | 9.88         | 309.63        | 500      | 350      |
| <b>Total</b>       | <b>29.58</b> | <b>811.46</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 4.55         | 52.96         | 200      | 160      |
| Unit 4             | 11.49        | 293.90        | 495      | 460      |
| Unit 5             | 11.86        | 297.82        | 500      | 490      |
| <b>Total</b>       | <b>27.90</b> | <b>644.68</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 5.68         | 132.96        | 250      | 190      |
| Unit 7             | 5.48         | 122.70        | 256      | 176      |
| Unit 8             | 5.12         | 140.36        | 240      | 186      |
| <b>Total</b>       | <b>16.28</b> | <b>396.02</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 9.19         | 273.27        | 460      | 345      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 50.03         | 0        | 0        |
| Unit 8             | 10.49        | 228.94        | 475      | 385      |
| Unit 9             | 10.26        | 289.71        | 452      | 390      |
| <b>Total</b>       | <b>29.94</b> | <b>841.95</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 6.05         | 130.69        | 257      | 250      |
| Unit 4             | 6.01         | 152.19        | 254      | 250      |
| <b>Total</b>       | <b>12.06</b> | <b>282.88</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 4.70         | 54.88         | 205      | 185      |
| Unit 3             | 4.65         | 82.27         | 210      | 180      |
| Unit 4             | 4.96         | 108.07        | 210      | 199      |
| Unit 5             | 12.03        | 271.39        | 505      | 500      |
| <b>Total</b>       | <b>26.34</b> | <b>516.61</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 3.83          | 0        | 0        |
| Unit 4             | 4.09         | 106.76        | 177      | 160      |
| Unit 5             | 4.38         | 97.11         | 195      | 160      |
| <b>Total</b>       | <b>8.47</b>  | <b>207.69</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.68         | 198.62        | 301      | 252      |
| <b>Total</b>       | <b>6.68</b>  | <b>198.62</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.03         | 0.86          | 20       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.03</b>   | <b>0.86</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 6.18          | 92.87          | 485      | 40       |
| Stage 4         | 14.04         | 133.67         | 1002     | 0        |
| Stage 3         | 3.75          | 48.31          | 320      | 0        |
| <b>Total</b>    | <b>23.97</b>  | <b>274.85</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 13.35          | 36       | 36       |
| VTRNA           | 1.40          | 30.42          | 61       | 14       |
| TILLARI         | 0.00          | 5.87           | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.14          | 5.00           | 80       | 0        |
| RNGR+BHTSA      | 0.33          | 7.98           | 14       | 13       |
| BHANDARDRA      | 0.47          | 10.13          | 20       | 19       |
| ELDARY          | 0.00          | 1.40           | 0        | 0        |
| SMLHY_PTN       | 0.55          | 17.66          | 23       | 23       |
| GHATGHAR        | 0.76          | 8.12           | 125      | 0        |
| <b>Total</b>    | <b>4.52</b>   | <b>99.93</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 6.64          | 185.38         | 0        | 0        |
| <b>Total</b>    | <b>6.64</b>   | <b>185.38</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 39.90         | 1131.21        | 0        | 0        |
| JSWEL(Mus)      | 18.96         | 486.24         | 0        | 0        |
| VIPL(Mus)       | 14.21         | 268.04         | 0        | 0        |
| RPLAMT(Mus)     | 19.10         | 436.26         | 0        | 0        |
| WPCL(Mus)       | 2.98          | 102.03         | 0        | 0        |
| Other(Mus)      | 13.63         | 321.64         | 0        | 0        |
| <b>Total</b>    | <b>108.78</b> | <b>2745.42</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 3.78          | 89.81          | 0        | 0        |
| <b>Total</b>    | <b>3.78</b>   | <b>89.81</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 10.74         | 262.72         | 486      | 314      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.80          | 62.20          | 118      | 114      |
| Trombay 7B      | 1.63          | 38.32          | 69       | 67       |
| Trombay 8       | 5.64          | 142.40         | 244      | 200      |
| TATA Hydro      | 5.26          | 104.24         | 422      | 8        |
| <b>Total</b>    | <b>26.07</b>  | <b>609.87</b>  |          |          |
| <b>R-INFRA</b>  |               |                |          |          |
| DTPS U-1&2      | 11.46         | 287.44         | 503      | 375      |
| <b>Total</b>    | <b>11.46</b>  | <b>287.44</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 150.56      | 3701.30       | MSPGCL Total        | 185.74      | 4274.69       |
|                |             |         | MSPGCL Thml+Gas | 157.24      | 3899.92       | Koyna 1,2 & 4 Total | 20.22       | 226.54        |
|                |             |         | MSPGCL Hydro    | 28.49       | 374.78        | State Total         | 342.48      | 8192.62       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 26/Mar/2018

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 6265        | 213   | 286  | 6764   | 668  | 4456      | 0    | 0     | 5193        | 4894        | -918                 | 15864                 | 0                    | 15864                     | 2354             | 18218           | 49.97         |
| 2                  | 6076        | 282   | 287  | 6645   | 592  | 4179      | 0    | 0     | 5242        | 5279        | -980                 | 15715                 | 0                    | 15715                     | 2151             | 17866           | 49.97         |
| 3                  | 6032        | 208   | 289  | 6529   | 525  | 3995      | 0    | 0     | 5235        | 5233        | -880                 | 15402                 | 0                    | 15402                     | 2010             | 17412           | 49.96         |
| 4                  | 6040        | 193   | 279  | 6512   | 484  | 3938      | 0    | 0     | 5227        | 5221        | -832                 | 15323                 | 0                    | 15323                     | 1916             | 17239           | 49.96         |
| 5                  | 6177        | 197   | 290  | 6664   | 475  | 4136      | 0    | 0     | 5252        | 5260        | -789                 | 15746                 | 0                    | 15746                     | 1887             | 17633           | 49.97         |
| 6                  | 6257        | 485   | 291  | 7033   | 322  | 4482      | 0    | 0     | 5376        | 5285        | -731                 | 16391                 | 0                    | 16391                     | 1979             | 18370           | 49.96         |
| 7                  | 6255        | 1469  | 301  | 8025   | 302  | 4599      | 0    | 10    | 5282        | 5542        | -684                 | 17794                 | 0                    | 17794                     | 2077             | 19871           | 50.01         |
| 8                  | 6267        | 1603  | 292  | 8162   | 237  | 4521      | 0    | 91    | 5392        | 5334        | -802                 | 17543                 | 0                    | 17543                     | 2216             | 19759           | 50.03         |
| 9                  | 6292        | 870   | 275  | 7437   | 236  | 4573      | 0    | 243   | 5486        | 5505        | -1035                | 16959                 | 0                    | 16959                     | 2529             | 19488           | 49.99         |
| 10                 | 6223        | 1206  | 276  | 7705   | 255  | 4578      | 0    | 368   | 5597        | 5716        | -1218                | 17404                 | 0                    | 17404                     | 2888             | 20292           | 49.94         |
| 11                 | 6279        | 1492  | 262  | 8033   | 294  | 4573      | 0    | 457   | 5740        | 6150        | -1387                | 18120                 | 0                    | 18120                     | 3107             | 21227           | 49.94         |
| 12                 | 6286        | 1950  | 258  | 8494   | 272  | 4558      | 0    | 525   | 6102        | 6256        | -1408                | 18697                 | 0                    | 18697                     | 3230             | 21927           | 49.91         |
| 13                 | 6275        | 1866  | 256  | 8397   | 261  | 4562      | 0    | 509   | 6296        | 6496        | -1409                | 18816                 | 0                    | 18816                     | 3211             | 22027           | 49.94         |
| 14                 | 6320        | 1923  | 266  | 8509   | 173  | 4543      | 0    | 489   | 6001        | 6332        | -1356                | 18690                 | 0                    | 18690                     | 3106             | 21796           | 49.97         |
| 15                 | 6433        | 1967  | 270  | 8670   | 117  | 4569      | 0    | 431   | 6005        | 6249        | -1389                | 18647                 | 0                    | 18647                     | 3169             | 21816           | 49.93         |
| 16                 | 6443        | 2002  | 252  | 8697   | 112  | 4695      | 0    | 340   | 6256        | 6655        | -1373                | 19126                 | 0                    | 19126                     | 3199             | 22325           | 49.87         |
| 17                 | 6528        | 2045  | 276  | 8849   | 172  | 4811      | 0    | 217   | 6099        | 6078        | -1361                | 18766                 | 0                    | 18766                     | 3168             | 21934           | 49.94         |
| 18                 | 6484        | 1643  | 268  | 8395   | 153  | 4835      | 0    | 97    | 5498        | 5117        | -1407                | 17190                 | 0                    | 17190                     | 3068             | 20258           | 49.96         |
| 19                 | 6315        | 946   | 280  | 7541   | 234  | 4695      | 0    | 2     | 5027        | 4958        | -1265                | 16165                 | 0                    | 16165                     | 2951             | 19116           | 49.97         |
| 20                 | 6312        | 1037  | 283  | 7632   | 206  | 4701      | 0    | 0     | 5089        | 5235        | -1144                | 16630                 | 0                    | 16630                     | 2951             | 19581           | 49.91         |
| 21                 | 6294        | 976   | 284  | 7554   | 105  | 4679      | 0    | 0     | 4887        | 4972        | -1023                | 16287                 | 0                    | 16287                     | 2861             | 19148           | 49.93         |
| 22                 | 6243        | 1077  | 285  | 7605   | 82   | 4706      | 0    | 0     | 4839        | 5015        | -1030                | 16378                 | 0                    | 16378                     | 2835             | 19213           | 49.97         |
| 23                 | 6221        | 1382  | 286  | 7889   | 142  | 4706      | 0    | 0     | 5034        | 5554        | -1270                | 17021                 | 0                    | 17021                     | 2848             | 19869           | 49.95         |
| 24                 | 6248        | 1459  | 287  | 7994   | 223  | 4691      | 0    | 0     | 5221        | 5524        | -1327                | 17105                 | 0                    | 17105                     | 2845             | 19950           | 49.98         |
| MUs                | 150.56      | 28.49 | 6.68 | 185.74 | 6.64 | 108.78    | 0.00 | 3.78  | 131.38      | 133.86      | -27.02               | 411.78                | 0.00                 | 411.78                    | 64.56            | 476.34          | 49.96         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Mar/2018**

**Position as on 6.30 Hrs of 27/Mar/2018**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                    | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                     |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown.                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 04/06/2017   | 19.09        |            | Continued. | 3 months outage for refuelling.                                                     |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 26/12/2017   | 10.51        |            | Continued. | AOH                                                                                 |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 04/01/2018   | 13.30        |            | Continued. | Water Shortage, converted to AOH w.e.f 01.02.2018, 00:00Hrs                         |               |
| MSPGCL                | Uran Unit 6             | 108      | 11/02/2018   | 23.43        |            | Continued. | Annual Overhaul                                                                     |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                     |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |            | Continued. | EE R&M LE Work                                                                      |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                             |               |
| IPP                   | SWPGL U-2               | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                                                              |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                   |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                   |               |
| RGPL                  | Dabhol 2A               | 230      | 24/08/2016   | 13.31        |            | Continued. | Change Over.                                                                        |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                         |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                         |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 28/07/2017   | 00.00        |            | Continued. | due to common pressure shaft with unit 1.                                           |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 03/12/2017   | 01.35        |            | Continued. | Water Shortage                                                                      |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 03/12/2017   | 14.17        |            | Continued. | Water Shortage                                                                      |               |
| CPP                   | IEPL Unit 1             | 270      | 30/12/2017   | 23.58        |            | Continued. | No Schedule                                                                         |               |
| IPP                   | Adani U-2               | 660      | 02/01/2018   | 15.26        |            | Continued. | HPBP Bonnet leakage                                                                 |               |
| MSPGCL                | Koradi Unit 7           | 210      | 07/01/2018   | 17.00        |            | Continued. | Poor Coal Receipt.                                                                  |               |
| IPP                   | Adani U-4               | 660      | 12/02/2018   | 07.24        |            | Continued. | Governing valve abnormal sound(Out due to coal shortage w.e.f 20.02.2018, 18:00hrs) |               |
| IPP                   | JSW (J) U1              | 300      | 20/02/2018   | 12.06        |            | Continued. | Turbine Vibration high.                                                             |               |
| IPP                   | RPL(AMT) U-3            | 270      | 27/02/2018   | 00.01        |            | Continued. | Coal Shortage                                                                       |               |
| MSPGCL                | Khaparkheda Unit 1      | 210      | 27/02/2018   | 18.00        |            | Continued. | Poor Coal Receipt                                                                   |               |
| MSPGCL                | Nasik Unit 3            | 210      | 01/03/2018   | 20.40        |            | Continued. | Poor coal Receipt From 06.03.2018                                                   |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 10/03/2018   | 23.06        | 27/03/2018 | 01.55      | Water Shortage From 12/03/2018                                                      |               |
| IPP                   | RPL(AMT) U-5            | 270      | 24/03/2018   | 07.36        |            | Continued. | ID Fan Problem                                                                      |               |
| CPP                   | SWPGL U-4               | 135      | 24/03/2018   | 21.09        |            | Continued. | ID Fan Problem                                                                      |               |
| MSPGCL                | Uran Unit 8             | 108      | 25/03/2018   | 06.25        |            | Continued. | Thrust Bearing Tripped                                                              |               |
| MSPGCL                | Koyna Unit 12           | 80       | 26/03/2018   | 20.40        | 26/03/2018 | 23.35      | LBB Operated while withdrawing Unit No.11(Breaker Pole Stuck                        |               |
| MSPGCL                | Koyna Unit 11           | 80       | 26/03/2018   | 20.40        | 27/03/2018 | 06.10      | LBB Operated while withdrawing Unit No.11(Breaker Pole Stuck                        |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Mar/2018**

Position as on 6.30 Hrs of 27/Mar/2018

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage   | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|--------------------|---------------|
| MSPGCL             | Koradi Unit-8           | 660      | 27/03/2018   | 02.04        |           | Continued. | Air heater problem |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Mar/2018**

**Statement-VII**

Position as on 6.30 Hrs of 27/Mar/2018

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                     |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                      |
| Karad Solapur (PG)                        | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                             |
| Dhule Sar'Sarovar II                      | InterState                | 23/03/2018   | 20.59        | 26/03/2018 | 08.55      | HT          | Over Voltage                                                                                                         |
| Dhule Sar'Sarovar II                      | InterState                | 26/03/2018   | 14.33        | 26/03/2018 | 15.19      | T           | Distance Protection                                                                                                  |
| Dhule Sar'Sarovar I                       | InterState                | 26/03/2018   | 18.06        | 27/03/2018 | 06.30      | HT          | Over Voltage                                                                                                         |
| Khadka-Aurangabad (Waluj)                 | IntraState                | 25/03/2018   | 18.21        | 26/03/2018 | 08.52      | HT          | Over Voltage                                                                                                         |
| Padghe - Nagothane - I                    | IntraState                | 26/03/2018   | 10.08        | 26/03/2018 | 20.30      | PO          | Faulty String Replacement work                                                                                       |
| Babhaleshwar - Padghe-I                   | IntraState                | 26/03/2018   | 15.22        | 26/03/2018 | 17.45      | T           | Distance Protection                                                                                                  |
| Bhusawal-Aurangabad                       | IntraState                | 26/03/2018   | 20.13        | 27/03/2018 | 06.20      | HT          | Over Voltage                                                                                                         |
| <b>400 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                      |
| 400/220 KV 315MVA ICT II @ Parli          | IntraState                | 26/03/2018   | 10.16        | 26/03/2018 | 20.23      | PO          | Painting work                                                                                                        |
| 400/220/33 Kv 315 MVA ICT II @Babhleshwar | IntraState                | 26/03/2018   | 18.45        | 26/03/2018 | 22.56      | EO          | CT Oil Leakage                                                                                                       |
| <b>220 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                      |
| Talandage - Chikodi                       | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | NO SCHEDULE.                                                                                                         |
| Mudshingi - Chikodi                       | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                         |
| Chandrapur GCR - Warora - I               | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                     | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Kharghar-Borivali ckt II                  | IntraState                | 07/06/2017   | 12:23        |            | Continued. | T           | Distance Protection                                                                                                  |
| Pedambe-Nerle                             | IntraState                | 23/09/2017   | 00.50        |            | Continued. | T           | 'B'Phase CT Burst                                                                                                    |
| Mumewadi -Halkarni II                     | IntraState                | 17/11/2017   | 10.00        |            | Continued. | PO          | Tower erection work (temporarily line would be Mumewadi-Tillari)                                                     |
| Halkarni - Tillari II                     | IntraState                | 17/11/2017   | 12.25        |            | Continued. | PO          | Tower erection work. (temporarily line would be Mumewadi-Tillari)                                                    |
| Kharghar-Borivali ckt I                   | IntraState                | 12/03/2018   | 10.00        |            | Continued. | PO          | Cable Termination work & Line Diverted To Siemenc.                                                                   |
| Arey - TPC Borivali                       | IntraState                | 26/03/2018   | 01.42        | 26/03/2018 | 05.51      | PO          | Safety purpose for Metro work                                                                                        |
| Sawantwadi-Bidri                          | IntraState                | 26/03/2018   | 03.15        | 26/03/2018 | 20.08      | T           | Distance Protection                                                                                                  |
| Kadegaon-Miraj                            | IntraState                | 26/03/2018   | 08.54        | 26/03/2018 | 12.13      | T           | LBB operated                                                                                                         |
| Vita - Miraj                              | IntraState                | 26/03/2018   | 08.54        | 26/03/2018 | 09.08      | T           | LBB operated                                                                                                         |
| Miraj - Mhaishal                          | IntraState                | 26/03/2018   | 08.54        | 26/03/2018 | 09.08      | T           | LBB operated                                                                                                         |
| Miraj - Ichalkaranji II                   | IntraState                | 26/03/2018   | 08.54        | 26/03/2018 | 09.08      | T           | LBB operated                                                                                                         |
| Ghodbunder - Gorai                        | IntraState                | 26/03/2018   | 09.03        | 26/03/2018 | 15.05      | PO          | Insulator Replacement Work                                                                                           |
| Virur - Virur Rly Tss 2                   | IntraState                | 26/03/2018   | 11.15        | 26/03/2018 | 14.44      | PO          | Testing Work                                                                                                         |
| Chikhli-Jalna-I                           | IntraState                | 26/03/2018   | 11.44        | 26/03/2018 | 15.31      | PO          | Testing Work                                                                                                         |
| Uran - Apta III                           | IntraState                | 26/03/2018   | 12.35        | 26/03/2018 | 13.25      | T           | Distance Protection                                                                                                  |
| Vilebagad-Kandalgaon( Inox tap)           | IntraState                | 26/03/2018   | 14.29        | 26/03/2018 | 15.00      | T           | Distance Protection                                                                                                  |
| Pophali - Nerale                          | IntraState                | 26/03/2018   | 14.45        | 26/03/2018 | 16.00      | T           | Distance Protection                                                                                                  |
| Main bus section-II @ Pedambe             | IntraState                | 26/03/2018   | 20.40        | 26/03/2018 | 21.25      | T           | LBB Operated while withdrawing Unit No.11(Breaker Pole Stuck Up)                                                     |
| Pedhambe - Oni                            | IntraState                | 26/03/2018   | 20.40        | 26/03/2018 | 21.43      | T           | LBB Operated while withdrawing Unit No.11(Breaker Pole Stuck Up)                                                     |
| Adlabs - Pedambe                          | IntraState                | 26/03/2018   | 20.40        | 26/03/2018 | 21.58      | T           | LBB Operated while withdrawing Unit No.11(Breaker Pole Stuck Up)                                                     |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Mar/2018**

**Statement-VII**

Position as on 6.30 Hrs of 27/Mar/2018

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                 |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------|
| Pophali - Pedambe II                       | IntraState                | 26/03/2018   | 20.40        | 26/03/2018 | 22.02      | T           | LBB Operated while withdrawing Unit No.11(Breaker Pole Stuck Up) |
| Talandage - Sawantwadi I                   | IntraState                | 27/03/2018   | 02.23        | 27/03/2018 | 03.12      | T           | Distance Protection                                              |
| Niwali - Pawas Line                        | IntraState                | 27/03/2018   | 04.14        |            | Continued. | T           | Distance Protection                                              |
| Mahad - Pedambe                            | IntraState                | 27/03/2018   | 04.40        | 27/03/2018 | 05.05      | T           | Distance Protection                                              |
| Kandalgaon - Koyna                         | IntraState                | 27/03/2018   | 05.54        |            | Continued. | T           | Distance Protection                                              |
| <b>220 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                  |
| 220/100 Kv 200 MVA ICT III @Borivali       | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(repaired and ready for commissioning)   |
| 220/100 Kv 200 MVA ICT-IV@Kalwa            | IntraState                | 24/11/2017   | 01.58        |            | Continued. | T           | Buchholz PRV Operated(Failed on Internal Fault)                  |
| 220/66 Kv 150 Mva Ngef Ict 1 @Gadchandur   | IntraState                | 04/03/2018   | 02.55        |            | Continued. | T           | Differential protection                                          |
| 220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.19      | T           | Bus Bar Protection Operated                                      |
| 220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.18      | T           | Bus Bar Protection Operated                                      |
| 100MVA ICT - I @ Boisar-II                 | IntraState                | 26/03/2018   | 13.54        |            | Continued. | T           | Buccholz Protection Optd                                         |
| <b>132 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                  |
| Mansar Pench                               | InterState                | 25/03/2018   | 21.25        |            | Continued. | T           | Y-PHASE BUS P T BURST.                                           |
| Kanhan-Mansar                              | IntraState                | 25/03/2018   | 21.25        |            | Continued. | T           | Y-PHASE BUS PT BRUST. 16 MW LOAD AFFECTED.                       |
| Pachora-Chalisgaon-1                       | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.24      | T           | Bus Bar Protection Operated                                      |
| Chalisgaon- Dhule                          | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.25      | T           | Bus Bar Protection Operated                                      |
| Chalisgaon-Chalisgaon- 1                   | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.23      | T           | Bus Bar Protection Operated                                      |
| Chalisgaon-Chalisgaon-2                    | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.23      | T           | Bus Bar Protection Operated                                      |
| Chalisgaon-Pimparkhed                      | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.25      | T           | Bus Bar Protection Operated                                      |
| Chalisgaon - Manmad                        | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.25      | T           | Bus Bar Protection Operated                                      |
| Pachora-Chalisgaon-2                       | IntraState                | 26/03/2018   | 10.55        | 26/03/2018 | 11.24      | T           | Bus Bar Protection Operated                                      |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage