

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 26/Mar/2023 SUNDAY**

| I GENERATION (MUs)  |                |                  | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|------------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly          | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 169.384        | 4144.738         | 1) Gujrat                      | -4.136         | 49.638           |
| 2) Hydro            | 8.991          | 276.882          | 2) Madhya Pradesh              | 10.237         | 156.794          |
| 3) Gas              | 2.676          | 97.231           | 3) Chattisgarh                 | 5.120          | 115.830          |
| <b>Total MSPGCL</b> | <b>181.051</b> | <b>4518.851</b>  | 4) Maharashtra                 | 164.532        | 4283.542         |
| B) 1) APLM          | 67.868         | 1769.555         | 5) Goa (Amona)                 | -1.282         | -39.845          |
| 2) JSWEL            | 19.810         | 618.831          | <b>Total</b>                   | <b>174.471</b> | <b>4565.959</b>  |
| 3) VIPL             | 0.000          | 0.000            | a) Mumbai Schedule             | 29.228         | 809.881          |
| 4) RPL(AMT)         | 27.923         | 788.355          | b) Mumbai Drawl                | 28.683         | 935.857          |
| 5) SWPGPL           | 9.284          | 255.825          | c) MSEDCL Bilateral *          | 95.628         | 2234.921         |
| 6) Other IPP        | 27.192         | 976.184          | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000            | d) Mumbai Bilateral *          | 29.228         | 809.881          |
| C) 1) TPCL Thermal  | 9.596          | 275.230          | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 3.075          | 86.187           | Standby                        | 0.000          | 0.000            |
| 3) TPCL Gas         | 1.883          | 68.232           | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 9.245          | 271.130          | 1) MSEDCL                      | 501.849        | 12971.782        |
| <b>D) STATE</b>     |                |                  | 2) Mumbai Discoms              | 52.482         | 1636.636         |
| 1) Thermal          | 340.302        | 9099.848         | 3) Other Discoms               | 9.922          | 263.285          |
| (A1+C1+C4+(B1-B6))  |                |                  | <b>TOTAL STATE</b>             | <b>564.253</b> | <b>14871.703</b> |
| 2) Hydro            | 12.066         | 363.069          |                                |                |                  |
| (A2+C2)             |                |                  |                                |                |                  |
| 3) Gas              | 4.559          | 165.463          |                                |                |                  |
| (A3+B7+C3)          |                |                  |                                |                |                  |
| 4) Wind             | 15.591         | 314.217          |                                |                |                  |
| 6) SOLAR            | 17.264         | 363.147          |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>389.782</b> | <b>10305.744</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 23 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal             | 6911                      | 6583                  | 7652                      | 7257                       |
| MSPGCL Hydro               | 328                       | 186                   | 617                       | 246                        |
| MSPGCL Gas                 | 113                       | 112                   | 111                       | 110                        |
| MSPGCL Total Generation    | 7352                      | 6881                  | 8380                      | 7613                       |
| Central Sector Receipt     | 8696                      | 8659                  | 6731                      | 6406                       |
| WIND                       | 197                       | 328                   | 789                       | 775                        |
| CPP / IPP Thermal          | 6508                      | 6481                  | 5973                      | 5868                       |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                          |
| SOLAR                      | 2268                      | 2305                  | 0                         | 0                          |
| Exchange with Mumbai       | -1515                     | -1497                 | -1136                     | -1151                      |
| <b>MSEDCL DEMAND MET</b>   | <b>23071</b>              | <b>22731</b>          | <b>20318</b>              | <b>19084</b>               |
| Load Shedding              | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND              | 23071                     | 22731                 | 20318                     | 19084                      |
| TPCL GENERATION            | 549                       | 558                   | 792                       | 734                        |
| AEML GENERATION            | 320                       | 319                   | 439                       | 408                        |
| <b>MUMBAI DEMAND</b>       | <b>2384</b>               | <b>2374</b>           | <b>2367</b>               | <b>2293</b>                |
| <b>OTHER DISCOM DEMAND</b> | <b>435</b>                | <b>426</b>            | <b>419</b>                | <b>427</b>                 |
| STATE DEMAND MET           | 25890                     | 25531                 | 23104                     | 21804                      |
| <b>STATE DEMAND</b>        | <b>25890</b>              | <b>25531</b>          | <b>23104</b>              | <b>21804</b>               |
| Frequency (Hz)             | 49.91                     | 49.95                 | 49.96                     | 49.95                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.27 Hz at 18:03 Hrs | 49.74 Hz at 11:48 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 26/Mar/2023

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 4.75         | 118.18         | 210      | 180      |
| Unit 8             | 13.09        | 244.86         | 553      | 485      |
| Unit 9             | 13.77        | 351.37         | 604      | 505      |
| Unit 10            | 13.29        | 229.14         | 592      | 525      |
| <b>Total</b>       | <b>44.90</b> | <b>943.56</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 2.96         | 83.76          | 150      | 115      |
| Unit 4             | 9.79         | 245.79         | 490      | 280      |
| Unit 5             | 9.36         | 256.74         | 490      | 280      |
| <b>Total</b>       | <b>22.12</b> | <b>586.28</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 6             | 3.90         | 116.33         | 241      | 142      |
| Unit 7             | 3.70         | 114.08         | 223      | 133      |
| Unit 8             | 3.29         | 89.56          | 161      | 109      |
| <b>Total</b>       | <b>10.90</b> | <b>319.97</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 3.00         | 89.39          | 152      | 101      |
| Unit 4             | 3.16         | 82.87          | 147      | 120      |
| Unit 5             | 7.60         | 119.34         | 420      | 260      |
| Unit 6             | 8.37         | 223.25         | 395      | 325      |
| Unit 7             | 8.24         | 215.12         | 425      | 280      |
| Unit 8             | 10.07        | 276.12         | 490      | 274      |
| Unit 9             | 10.35        | 244.62         | 500      | 310      |
| <b>Total</b>       | <b>50.79</b> | <b>1250.69</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 5.36         | 120.77         | 233      | 211      |
| Unit 4             | 5.61         | 135.63         | 247      | 183      |
| <b>Total</b>       | <b>10.96</b> | <b>256.40</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 2.50         | 68.84          | 115      | 95       |
| Unit 2             | 2.43         | 76.81          | 116      | 82       |
| Unit 3             | 3.66         | 93.19          | 181      | 126      |
| Unit 4             | 3.90         | 99.40          | 191      | 129      |
| Unit 5             | 9.54         | 271.68         | 450      | 285      |
| <b>Total</b>       | <b>22.04</b> | <b>609.92</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 3.89         | 15.90          | 184      | 107      |
| Unit 4             | 3.79         | 84.85          | 175      | 130      |
| Unit 5             | 0.00         | 77.17          | 0        | 0        |
| <b>Total</b>       | <b>7.68</b>  | <b>177.91</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 2.68         | 97.23          | 115      | 109      |
| <b>Total</b>       | <b>2.68</b>  | <b>97.23</b>   |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.15         | 3.32           | 47       | 0        |
| <b>Total</b>       | <b>0.15</b>  | <b>3.32</b>    |          |          |
| <b>Koyna</b>       |              |                |          |          |
| Stage 1-2          | 2.27         | 64.42          | 270      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 0.65          | 58.81          | 250      | 0        |
| Stage 3         | 0.55          | 26.67          | 160      | 0        |
| <b>Total</b>    | <b>3.47</b>   | <b>149.91</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 22.02          | 36       | 36       |
| VTRNA           | 1.18          | 28.52          | 61       | 0        |
| TILLARI         | 0.46          | 8.23           | 58       | 0        |
| BHIRA T.R.      | 0.24          | 3.77           | 77       | 0        |
| SMLHY_PTN       | 2.62          | 61.11          | 110      | 108      |
| GHATGHAR        | 0.00          | 0.00           | 0        | 0        |
| <b>Total</b>    | <b>5.37</b>   | <b>123.65</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 15.59         | 314.22         | 0        | 0        |
| <b>Total</b>    | <b>15.59</b>  | <b>314.22</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 67.87         | 1769.56        | 0        | 0        |
| JSWEL(Mus)      | 19.81         | 618.83         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 27.92         | 788.36         | 0        | 0        |
| SWPGPL-Mus      | 9.28          | 255.82         | 0        | 0        |
| Dhariwal        | 5.06          | 154.44         | 273      | 177      |
| IEPL            | 4.78          | 129.15         | 225      | 193      |
| Other(Mus)      | 17.35         | 692.59         | 0        | 0        |
| <b>Total</b>    | <b>152.08</b> | <b>4408.75</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 17.26         | 363.15         | 0        | 0        |
| <b>Total</b>    | <b>17.26</b>  | <b>363.15</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 6.43          | 182.79         | 270      | 263      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.00          | 39.62          | 63       | 35       |
| Trombay 7B      | 0.88          | 28.61          | 49       | 33       |
| TATA Hydro      | 3.08          | 86.19          | 306      | 18       |
| Trombay 8       | 3.17          | 92.44          | 138      | 130      |
| <b>Total</b>    | <b>14.55</b>  | <b>429.65</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.24          | 271.13         | 460      | 312      |
| <b>Total</b>    | <b>9.24</b>   | <b>271.13</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 169.38      | 4144.74       | MSPGCL Total        | 181.05      | 4518.85       |
|                |             |         | MSPGCL Thml+Gas | 172.06      | 4241.97       | Koyna 1,2 & 4 Total | 2.92        | 123.24        |
|                |             |         | MSPGCL Hydro    | 8.99        | 276.88        | State Total         | 389.78      | 10305.74      |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 26/Mar/2023

### Annexure-2

| TIME SR. NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | LOAD SHED DING | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|------|------|--------|-------|-----------|------|-------|----------|----------|----------------|------------------|----------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY   | GAS  |        |       | THM       | GAS  |       |          |          |                |                  |                |                      |               |                     |              |            |
| 1            | 7468        | 279  | 111  | 7858   | 693   | 6624      | 0    | 0     | 6771     | 6695     | -1197          | 20283            | 0              | 20283                | 2195          | 390                 | 22868        | 49.96      |
| 2            | 7506        | 294  | 112  | 7912   | 788   | 6591      | 0    | 0     | 6748     | 6341     | -1061          | 20206            | 0              | 20206                | 2065          | 365                 | 22636        | 49.93      |
| 3            | 7527        | 244  | 110  | 7881   | 867   | 6624      | 0    | 0     | 6898     | 6597     | -997           | 20630            | 0              | 20630                | 1949          | 342                 | 22921        | 50.01      |
| 4            | 7529        | 280  | 109  | 7918   | 767   | 6630      | 0    | 0     | 6852     | 6660     | -1013          | 20612            | 0              | 20612                | 1868          | 350                 | 22830        | 49.98      |
| 5            | 7637        | 634  | 113  | 8384   | 617   | 6679      | 0    | 0     | 6773     | 6783     | -945           | 21159            | 0              | 21159                | 1860          | 359                 | 23378        | 49.97      |
| 6            | 7742        | 731  | 111  | 8584   | 586   | 6725      | 0    | 0     | 6500     | 6624     | -851           | 21288            | 0              | 21288                | 1925          | 380                 | 23593        | 50.02      |
| 7            | 7727        | 816  | 110  | 8653   | 353   | 6687      | 0    | 42    | 6684     | 6894     | -831           | 21400            | 0              | 21400                | 1948          | 398                 | 23746        | 50.02      |
| 8            | 7628        | 583  | 110  | 8321   | 444   | 6702      | 0    | 461   | 7195     | 6997     | -932           | 21567            | 0              | 21567                | 1994          | 426                 | 23987        | 50.05      |
| 9            | 6975        | 335  | 113  | 7423   | 388   | 6702      | 0    | 1076  | 7913     | 7656     | -1283          | 21527            | 0              | 21527                | 2109          | 435                 | 24071        | 50.02      |
| 10           | 6433        | 287  | 115  | 6835   | 225   | 6719      | 0    | 1686  | 8525     | 8300     | -1395          | 21936            | 0              | 21936                | 2248          | 434                 | 24618        | 50.02      |
| 11           | 6508        | 478  | 112  | 7098   | 172   | 6506      | 0    | 2128  | 8948     | 8991     | -1473          | 22971            | 0              | 22971                | 2356          | 450                 | 25778        | 50.00      |
| 12           | 6911        | 328  | 113  | 7352   | 197   | 6508      | 0    | 2268  | 9122     | 8696     | -1515          | 23071            | 0              | 23071                | 2384          | 435                 | 25890        | 49.91      |
| 13           | 6583        | 186  | 112  | 6881   | 328   | 6481      | 0    | 2305  | 9167     | 8659     | -1497          | 22731            | 0              | 22731                | 2374          | 426                 | 25531        | 49.95      |
| 14           | 6303        | 196  | 112  | 6611   | 588   | 6424      | 0    | 2146  | 8721     | 7974     | -1441          | 21892            | 0              | 21892                | 2306          | 410                 | 24608        | 49.99      |
| 15           | 6003        | 184  | 111  | 6298   | 758   | 6237      | 0    | 1953  | 8679     | 8396     | -1366          | 21858            | 0              | 21858                | 2275          | 418                 | 24551        | 50.00      |
| 16           | 6089        | 184  | 115  | 6388   | 979   | 6032      | 0    | 1668  | 8363     | 8103     | -1348          | 21375            | 0              | 21375                | 2257          | 447                 | 24079        | 50.02      |
| 17           | 6219        | 378  | 112  | 6709   | 979   | 5892      | 0    | 1099  | 7860     | 7689     | -1294          | 20633            | 0              | 20633                | 2239          | 441                 | 23313        | 49.94      |
| 18           | 6612        | 341  | 110  | 7063   | 1019  | 5876      | 0    | 416   | 7175     | 7380     | -1228          | 20072            | 0              | 20072                | 2228          | 454                 | 22754        | 50.01      |
| 19           | 6898        | 490  | 111  | 7499   | 820   | 5962      | 0    | 16    | 6771     | 6516     | -1117          | 19255            | 0              | 19255                | 2256          | 441                 | 21952        | 50.03      |
| 20           | 7652        | 617  | 111  | 8380   | 789   | 5973      | 0    | 0     | 6654     | 6731     | -1136          | 20318            | 0              | 20318                | 2367          | 419                 | 23104        | 49.96      |
| 21           | 7603        | 375  | 111  | 8089   | 868   | 5891      | 0    | 0     | 6527     | 6198     | -1163          | 19463            | 0              | 19463                | 2384          | 420                 | 22267        | 49.96      |
| 22           | 7309        | 254  | 111  | 7674   | 841   | 5889      | 0    | 0     | 6564     | 6494     | -1142          | 19318            | 0              | 19318                | 2348          | 438                 | 22104        | 49.98      |
| 23           | 7257        | 246  | 110  | 7613   | 775   | 5868      | 0    | 0     | 6562     | 6406     | -1151          | 19084            | 0              | 19084                | 2293          | 427                 | 21804        | 49.95      |
| 24           | 7265        | 251  | 111  | 7627   | 750   | 5855      | 0    | 0     | 6803     | 6691     | -1307          | 19200            | 0              | 19200                | 2254          | 416                 | 21870        | 49.98      |
| MUs          | 169.38      | 8.99 | 2.68 | 181.05 | 15.59 | 152.08    | 0.00 | 17.26 | 178.78   | 174.47   | -28.68         | 501.85           | 0.00           | 501.85               | 52.48         | 9.92                | 564.25       | 49.99      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Mar/2023**

**Position as on 6.30 Hrs of 27/Mar/2023**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                         |               |
| IPP                   | JSW (J) U1              | 300      | 19/03/2023   | 17:29        |           | Continued. | Zero Schedule                                                                                                                                           |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                                                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |           | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 01/04/2024    |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                                                                                   | 07/04/2023    |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |           | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 01/05/2024    |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |           | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |           | Continued. | Stator Earth Fault                                                                                                                                      | 31/07/2023    |
| MSPGCL                | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |           | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 30/05/2023    |
| MSPGCL                | Uran Unit 5             | 108      | 12/11/2022   | 13:23        |           | Continued. | Gas shortage                                                                                                                                            |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 08/02/2023   | 07:02        |           | Continued. | Stator Earth Fault                                                                                                                                      | 30/04/2023    |
| MSPGCL                | Uran Unit 6             | 108      | 18/03/2023   | 12:44        |           | Continued. | ZERO SCHEDULE.                                                                                                                                          |               |
| MSPGCL                | Nasik Unit 5            | 210      | 23/03/2023   | 03:10        |           | Continued. | Withdrawn due to changer from Unit3 to 5                                                                                                                | 27/03/2023    |
| IPP                   | RPL(AMT) U-2            | 270      | 26/03/2023   | 10:34        |           | Continued. | bottom ash evacuation problem                                                                                                                           | 28/03/2023    |
| IPP                   | Adani U-4               | 660      | 26/03/2023   | 15:59        |           | Continued. | Due to turbine left hand side MS drain bonnet leakage.                                                                                                  | 29/03/2023    |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Mar/2023**

**Statement-VII**

Position as on 6.30 Hrs of 27/Mar/2023

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                            |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                             |
| TALANDGE - KOLHAPUR (PG) CKT - 2       | InterState                | 20/03/2023   | 07:49        |            |            | PO          | For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1                                                                                                                                                                       |
| CHANDRAPUR - BHADRAVATI CKT - 2        | InterState                | 26/03/2023   | 15:13        |            |            | T           | Tripped on Distance Protection.                                                                                                                                                                                                                                                                                             |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2    | IntraState                | 24/03/2023   | 10:17        |            |            | HT          | System loading                                                                                                                                                                                                                                                                                                              |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                             |
| STATION TF No 3 @ CHANDRAPUR GCR       | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                                                              |
| 400/220/20 KV 500MVA ICT - 1 @ KALWA   | IntraState                | 26/03/2023   | 06:09        | 26/03/2023 | 10:38      | PO          | LV R-ph LA replacement work due to high LCM value.                                                                                                                                                                                                                                                                          |
| 400/220/33 KV 315MVA ICT - 1 @ AKOLA   | IntraState                | 26/03/2023   | 08:14        | 26/03/2023 | 21:06      | PO          | 1. Dismantling of existing ICT-1 LV bay and reorientation to old existing 220KV ICT-02 LV bay 2. Removing of control cables from existing breaker, CT, Isolator and shifting to old existing 220KV ICT-02 bay MB 3. 220KV bus bar out, CT injection , stability and trials by testing tea                                   |
| <b>400 KV BUSBAR Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                             |
| MAIN BUS - 1 @ DHARIWAL                | IntraState                | 18/03/2023   | 10:28        |            |            | PO          | STU CTU bus connection as per CERC order                                                                                                                                                                                                                                                                                    |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                             |
| NALASOPARA - BOISAR PG                 | InterState                | 26/03/2023   | 00:10        |            |            | PO          | for retrofitting of line differential 1. For retrofitting of Line Differential relay ABB make main-I at PGCIL S/stn. end.<br><br>2. For retrofitting of Line Differential relay GE make main-II at PGCIL S/stn. end.<br><br>3. Tapping on PGCIL_Nalasopara line at CTT tower for SOAK test of EHV cable (1000 sq.mm cable). |
| EKLAHARE (OCR) - NAVASARI CKT - 1      | IntraState                | 10/02/2023   | 09:45        |            |            | PO          | Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)                                                                                                                                                                                                                              |
| EKLAHARE (OCR) - PADGHE                | IntraState                | 05/03/2023   | 08:55        |            |            | HT          | For load management                                                                                                                                                                                                                                                                                                         |
| TROMBAY DHARAVI - 5                    | IntraState                | 24/03/2023   | 22:56        |            |            | PO          | Third Party Work - Diversion of Line at Sejal Shakti Project site                                                                                                                                                                                                                                                           |
| PHURSUNGI-PARVATI                      | IntraState                | 25/03/2023   | 23:49        | 26/03/2023 | 02:58      | PO          | Half Yearly Maint. attending oil leakage from collar of R Ph CT                                                                                                                                                                                                                                                             |
| NEW KOYNA - NIWALI                     | IntraState                | 26/03/2023   | 08:54        | 26/03/2023 | 16:12      | PO          | For cold washing of insulator strings.                                                                                                                                                                                                                                                                                      |
| TATA BORIVLI MSETCL BORIVLI - 5        | IntraState                | 26/03/2023   | 10:59        | 26/03/2023 | 13:43      | PO          | For closer inspection of line                                                                                                                                                                                                                                                                                               |
| SALSETTE BORIVLI - 2                   | IntraState                | 26/03/2023   | 11:13        | 26/03/2023 | 13:40      | PO          | For Closer inspection of line                                                                                                                                                                                                                                                                                               |
| MAHAD - KANDALGAON                     | IntraState                | 26/03/2023   | 14:34        | 26/03/2023 | 17:18      | T           | Tripped on Distance Protection.                                                                                                                                                                                                                                                                                             |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Mar/2023**

**Statement-VII**

Position as on 6.30 Hrs of 27/Mar/2023

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                            |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| DAHANU - VERSOVA                          | IntraState                | 27/03/2023   | 00:42        | 27/03/2023 | 05:15      | PO          | (Metro Line 9 : Dahisar to MiraBhayander MMRDA Project work in view of erection of Pier cap and 200 Girders at pier location P 229 to P232 ( Bhayander ROB location) on SS line 220 KV (Dahanu to Versova). |
| BOISAR - VERSOVA                          | IntraState                | 27/03/2023   | 01:11        | 27/03/2023 | 06:26      | PO          | (Metro Line 9 : Dahisar to MiraBhayander MMRDA Project work in view of erection of Pier cap and 200 Girders at pier location P 229 to P232 ( Bhayander ROB location) on SS line 220 KV (Dahanu to Versova). |
| MUDSHINGI- BELEWADI LINE                  | IntraState                | 27/03/2023   | 03:41        | 27/03/2023 | 09:23      | T           | Phase to Phase fault                                                                                                                                                                                        |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                             |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                            |
| 220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE | IntraState                | 10/11/2022   | 10:35        |            |            | EO          | For attending to abnormal Nosie from ICT                                                                                                                                                                    |
| 220/110 KV ICT - 1 @ BHIRA                | IntraState                | 26/03/2023   | 09:34        | 26/03/2023 | 15:26      | PO          | Attending run & pad Hot spot (110 kV Switchyard) at Bhira generating station                                                                                                                                |
| 220/100 KV 200 MVA ICT 2 @ KALWA          | IntraState                | 26/03/2023   | 10:12        | 26/03/2023 | 11:00      | T           | Tripped Due to Winding Temperature High.                                                                                                                                                                    |
| 220/110 KV ICT - 2 @ BHIRA                | IntraState                | 26/03/2023   | 15:50        | 26/03/2023 | 17:28      | PO          | Attending run & pad Hot spot (110 kV Switchyard) at Bhira generating station                                                                                                                                |
| 220/33 KV 50 MVA PTR 3 @ KHARGHAR         | IntraState                | 27/03/2023   | 06:30        |            |            | PO          | For SFRA & DFR testing work                                                                                                                                                                                 |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                             |
| WAGHIVALI - MANKHURD                      | IntraState                | 26/03/2023   | 09:38        | 26/03/2023 | 11:56      | PO          | For Tree trimming work                                                                                                                                                                                      |
| <b>110 KV BUSBAR Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                             |
| ZONE 2 (BUS SECTION 2 & 3) @ BHIRA (T)    | IntraState                | 27/03/2023   | 00:50        | 27/03/2023 | 04:25      | PO          | Tree removal from 110KV Switchyard and Main B.S#3 R/M work                                                                                                                                                  |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage